

CORRIGENDUM 1

Page 3

Foreword

Replace the existing text of the 6th dash with the following:

- Restrictions on available short-circuit current level for level of protection “ta”

Page 8

5.2.2 Threaded entries

Replace the existing text of this subclause by the following:

Threaded entries with tapered threads are considered to meet the requirements for “ta”, “tb” and “tc” equipment. Threaded entries with parallel threads shall be provided with not less than five threads, with a minimum tolerance of medium or fine according to ISO 965-1 and ISO 965-3.