

INTERNATIONAL STANDARD



**Fixed capacitors for use in electronic equipment –
Part 25: Sectional specification – Fixed aluminium electrolytic surface mount
capacitors with conductive polymer solid electrolyte**



THIS PUBLICATION IS COPYRIGHT PROTECTED

Copyright © 2021 IEC, Geneva, Switzerland

All rights reserved. Unless otherwise specified, no part of this publication may be reproduced or utilized in any form or by any means, electronic or mechanical, including photocopying and microfilm, without permission in writing from either IEC or IEC's member National Committee in the country of the requester. If you have any questions about IEC copyright or have an enquiry about obtaining additional rights to this publication, please contact the address below or your local IEC member National Committee for further information.

IEC Central Office
3, rue de Varembe
CH-1211 Geneva 20
Switzerland

Tel.: +41 22 919 02 11
info@iec.ch
www.iec.ch

About the IEC

The International Electrotechnical Commission (IEC) is the leading global organization that prepares and publishes International Standards for all electrical, electronic and related technologies.

About IEC publications

The technical content of IEC publications is kept under constant review by the IEC. Please make sure that you have the latest edition, a corrigendum or an amendment might have been published.

IEC publications search - webstore.iec.ch/advsearchform

The advanced search enables to find IEC publications by a variety of criteria (reference number, text, technical committee, ...). It also gives information on projects, replaced and withdrawn publications.

IEC Just Published - webstore.iec.ch/justpublished

Stay up to date on all new IEC publications. Just Published details all new publications released. Available online and once a month by email.

IEC Customer Service Centre - webstore.iec.ch/csc

If you wish to give us your feedback on this publication or need further assistance, please contact the Customer Service Centre: sales@iec.ch.

IEC online collection - oc.iec.ch

Discover our powerful search engine and read freely all the publications previews. With a subscription you will always have access to up to date content tailored to your needs.

Electropedia - www.electropedia.org

The world's leading online dictionary on electrotechnology, containing more than 22 000 terminological entries in English and French, with equivalent terms in 18 additional languages. Also known as the International Electrotechnical Vocabulary (IEV) online.

IECNORM.COM : Click to view the full PDF of IEC 60364-25:2021 PLV

INTERNATIONAL STANDARD



**Fixed capacitors for use in electronic equipment –
Part 25: Sectional specification – Fixed aluminium electrolytic surface mount
capacitors with conductive polymer solid electrolyte**

INTERNATIONAL
ELECTROTECHNICAL
COMMISSION

ICS 31.060.40; 31.060.50

ISBN 978-2-8322-1005-0

Warning! Make sure that you obtained this publication from an authorized distributor.

CONTENTS

FOREWORD.....	5
1 Scope.....	7
2 Normative references	7
3 Terms and definitions	8
4 Preferred ratings and characteristics	8
4.1 Preferred characteristics	8
4.2 Preferred values of ratings	8
4.2.1 Nominal capacitance (C_N)	8
4.2.2 Tolerance on nominal capacitance.....	8
4.2.3 Rated voltage (U_R).....	9
4.2.4 Category voltage (U_C).....	9
4.2.5 Surge voltage (U_{RS}).....	9
4.2.6 Rated temperature	9
5 Test and measurement procedures	9
5.1 General.....	9
5.2 Preliminary drying	9
5.3 Measuring conditions	9
5.4 Mounting.....	9
5.4.1 General	9
5.4.2 Initial inspections	10
5.4.3 Test conditions	10
5.4.4 Final inspections and requirements	10
5.5 Visual examination and check of dimensions	10
5.5.1 General	10
5.5.2 Visual examination and check of dimensions	10
5.5.3 Requirements.....	10
5.6 Electrical tests	10
5.6.1 Leakage current.....	10
5.6.2 Capacitance.....	11
5.6.3 Tangent of loss angle ($\tan \delta$).....	11
5.6.4 Equivalent series resistance (ESR) (if required).....	11
5.6.5 Impedance (if required)	12
5.7 Resistance to soldering heat	12
5.7.1 General	12
5.7.2 Initial inspections	12
5.7.3 Test conditions	12
5.7.4 Recovery	12
5.7.5 Final inspections and requirements	12
5.8 Solderability.....	13
5.8.1 General	13
5.8.2 Final inspections and requirements	13
5.9 Shear test (if required)	13
5.10 Substrate bending test (if required).....	13
5.10.1 General	13
5.10.2 Initial inspections	13
5.10.3 Test conditions	13

5.10.4	Final inspections and requirements	13
5.11	Rapid change of temperature	13
5.11.1	General	13
5.11.2	Initial inspections	13
5.11.3	Test conditions	13
5.11.4	Recovery	13
5.11.5	Final inspections and requirements	14
5.12	Climatic sequence	14
5.12.1	General	14
5.12.2	Initial inspections	14
5.12.3	Dry heat	14
5.12.4	Damp heat, cyclic, Test Db, first cycle	14
5.12.5	Cold	14
5.12.6	Damp heat, cyclic, Test Db, remaining cycles	14
5.12.7	Recovery	14
5.12.8	Final inspections and requirements	14
5.13	Damp heat, steady state	14
5.13.1	General	14
5.13.2	Initial inspections	14
5.13.3	Test conditions	14
5.13.4	Recovery	15
5.13.5	Final inspections and requirements	15
5.14	Characteristics at high and low temperature	15
5.14.1	General	15
5.14.2	Inspections and requirements	15
5.15	Surge voltage	15
5.15.1	General	15
5.15.2	Initial inspections	15
5.15.3	Test conditions	15
5.15.4	Recovery	16
5.15.5	Final inspections and requirements	16
5.16	Endurance	16
5.16.1	General	16
5.16.2	Initial inspections	16
5.16.3	Test conditions	16
5.16.4	Recovery	16
5.16.5	Final inspections and requirements	16
5.17	Storage at high temperature	16
5.17.1	General	16
5.17.2	Initial inspections	16
5.17.3	Test conditions	17
5.17.4	Recovery	17
5.17.5	Final inspections and requirements	17
5.18	Charge and discharge (if required)	17
5.18.1	General	17
5.18.2	Initial inspections	17
5.18.3	Test conditions	17
5.18.4	Final inspections and requirements	17
5.19	Component solvent resistance (if required)	17

5.20	Solvent resistance of marking (if required)	17
5.21	High surge current (if required)	18
5.21.1	General	18
5.21.2	Final inspections and requirements	18
6	Marking	18
6.1	General	18
6.2	Information for marking	18
6.3	Marking on capacitors	18
6.4	Marking on packaging	18
7	Information to be given in a detail specification	18
7.1	General	18
7.2	Outline drawing and dimensions	19
7.3	Mounting	19
7.4	Ratings and characteristics	19
7.4.1	General	19
7.4.2	Nominal capacitance range	19
7.4.3	Particular characteristics	19
7.4.4	Soldering	19
7.5	Marking	20
8	Quality assessment procedures	20
8.1	Primary stage of manufacture	20
8.2	Structurally similar components	20
8.3	Certified test records of released lots	20
8.4	Qualification approval (QA) procedures	20
8.4.1	General	20
8.4.2	Qualification approval on the basis of the fixed sample size procedure	20
8.4.3	Tests	21
8.5	Quality conformance inspections	28
8.5.1	Formation of inspection lots	28
8.5.2	Test schedule	29
8.5.3	Delayed delivery	29
8.5.4	Assessment levels	29
Annex X (informative)	Cross-references to the prior edition of this document	31
Bibliography		32
Table 1	Surge voltages	9
Table 2	Sampling plan for qualification approval, assessment level EZ	22
Table 3	Test schedule for qualification approval	23
Table 4	Lot-by-lot inspection	29
Table 5	Periodic inspection	30
Table X.1	Reference to IEC 60384-25 for clauses/subclauses and tables	31

INTERNATIONAL ELECTROTECHNICAL COMMISSION

FIXED CAPACITORS FOR USE IN ELECTRONIC EQUIPMENT –

Part 25: Sectional specification – Fixed aluminium electrolytic surface mount capacitors with conductive polymer solid electrolyte

FOREWORD

- 1) The International Electrotechnical Commission (IEC) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, IEC publishes International Standards, Technical Specifications, Technical Reports, Publicly Available Specifications (PAS) and Guides (hereafter referred to as "IEC Publication(s)"). Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations liaising with the IEC also participate in this preparation. IEC collaborates closely with the International Organization for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.
- 2) The formal decisions or agreements of IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC National Committees.
- 3) IEC Publications have the form of recommendations for international use and are accepted by IEC National Committees in that sense. While all reasonable efforts are made to ensure that the technical content of IEC Publications is accurate, IEC cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.
- 4) In order to promote international uniformity, IEC National Committees undertake to apply IEC Publications transparently to the maximum extent possible in their national and regional publications. Any divergence between any IEC Publication and the corresponding national or regional publication shall be clearly indicated in the latter.
- 5) IEC itself does not provide any attestation of conformity. Independent certification bodies provide conformity assessment services and, in some areas, access to IEC marks of conformity. IEC is not responsible for any services carried out by independent certification bodies.
- 6) All users should ensure that they have the latest edition of this publication.
- 7) No liability shall attach to IEC or its directors, employees, servants or agents including individual experts and members of its technical committees and IEC National Committees for any personal injury, property damage or other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication, use of, or reliance upon, this IEC Publication or any other IEC Publications.
- 8) Attention is drawn to the Normative references cited in this publication. Use of the referenced publications is indispensable for the correct application of this publication.
- 9) Attention is drawn to the possibility that some of the elements of this IEC Publication may be the subject of patent rights. IEC shall not be held responsible for identifying any or all such patent rights.

This redline version of the official IEC Standard allows the user to identify the changes made to the previous edition IEC 60384-25:2015. A vertical bar appears in the margin wherever a change has been made. Additions are in green text, deletions are in strikethrough red text.

International Standard IEC 60384-25 has been prepared by IEC technical committee 40: Capacitors and resistors for electronic equipment.

This third edition cancels and replaces the second edition published in 2015. This edition constitutes a technical revision.

This edition includes the following significant technical changes with respect to the previous edition:

- a) Revision of the structure in accordance with ISO/IEC Directives, Part 2:2018, to the extent practicable, and harmonization between other similar kinds of documents.
- b) In addition, Clause 5 and all the tables have been reviewed in order to prevent duplications and contradictions.

The text of this standard is based on the following documents:

FDIS	Report on voting
40/2850/FDIS	40/2861/RVD

Full information on the voting for its approval can be found in the report on voting indicated in the above table.

The language used for the development of this International Standard is English.

A list of all parts in the IEC 60384 series, published under the general title *Fixed capacitors for use in electronic equipment*, can be found on the IEC website.

This document was drafted in accordance with ISO/IEC Directives, Part 2, and developed in accordance with ISO/IEC Directives, Part 1 and ISO/IEC Directives, IEC Supplement, available at www.iec.ch/members_experts/refdocs. The main document types developed by IEC are described in greater detail at <http://www.iec.ch/standardsdev/publications>.

The committee has decided that the contents of this document will remain unchanged until the stability date indicated on the IEC website under webstore.iec.ch in the data related to the specific document. At this date, the document will be

- reconfirmed,
- withdrawn,
- replaced by a revised edition, or
- amended.

IMPORTANT – The 'colour inside' logo on the cover page of this publication indicates that it contains colours which are considered to be useful for the correct understanding of its contents. Users should therefore print this document using a colour printer.

FIXED CAPACITORS FOR USE IN ELECTRONIC EQUIPMENT –

Part 25: Sectional specification – Fixed aluminium electrolytic surface mount capacitors with conductive polymer solid electrolyte

~~1~~ **General**

1 Scope

This part of IEC 60384 applies to fixed aluminium electrolytic surface mount capacitors with conductive polymer solid electrolyte, primarily intended for DC applications for use in electronic equipment.

Fixed aluminium electrolytic surface mount capacitors with solid (MnO_2) are not included but are covered by IEC 60384-18.

These capacitors are primarily intended for use in electronic equipment to be mounted directly on substrates for hybrid circuits or to printed boards.

Capacitors for special-purpose applications ~~may~~ can need additional requirements.

~~1.2~~ **Object**

The object of this document is to prescribe preferred ratings and characteristics and to select from IEC 60384-1:2016, the appropriate quality assessment procedures, tests and measuring methods and to give general performance requirements for this type of capacitor. ~~Test severities and requirements prescribed in detail specifications referring to this sectional specification shall be of equal or higher performance level, because lower performance levels are not permitted.~~

2 Normative references

The following documents are referred to in the text in such a way that some or all of their content constitutes requirements of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

IEC 60063, *Preferred number series for resistors and capacitors*

IEC 60068-1:2013, *Environmental testing – Part 1: General and guidance*

IEC 60384-1:20082016, *Fixed capacitors for use in electronic equipment – Part 1: Generic specification*

IEC 61193-2:2007, *Quality assessment systems – Part 2: Selection and use of sampling plans for inspection of electronic components and packages*

~~ISO 3, Preferred numbers Series of preferred numbers~~

3 Terms and definitions

For the purposes of this document, the terms and definitions given in IEC 60384-1:2008 and the following apply.

ISO and IEC maintain terminological databases for use in standardization at the following addresses:

- IEC Electropedia: available at <http://www.electropedia.org/>
- ISO Online browsing platform: available at <http://www.iso.org/obp>

3.1

capacitance

<electrolytic capacitor> capacitance of an equivalent circuit whose capacitance and resistance in series is measured with an alternating current having an approximately sinusoidal waveform at a specified frequency

4 Preferred ratings and characteristics

4.1 Preferred characteristics

Preferred climatic categories only shall be given in the preferred characteristics.

The capacitors covered by this sectional specification are classified into ~~climatic~~ categories in accordance with the general rules given in IEC 60068-1:2013, Annex A.

The lower and upper category temperatures shall be taken from the following:

- lower category temperature: -55°C ;
- upper category temperature: $+105^{\circ}\text{C}$ and $+125^{\circ}\text{C}$.

The severities for the cold and dry heat tests are the lower and upper category temperatures respectively.

4.2 Preferred values of ratings

4.2.1 Nominal capacitance (C_N)

Preferred values of nominal capacitance are indicated in microfarad (μF).

Preferred values of nominal capacitance shall be taken from the E 12 series of IEC 60063 as follows:

1,0 – 1,2 – 1,5 – 1,8 – 2,2 – 2,7 – 3,3 – 3,9 – 4,7 – 5,6 – 6,8 – 8,2;

and their decimal multiples ($\times 10^n$, n : integer).

4.2.2 Tolerance on nominal capacitance

Preferred value of tolerance on nominal capacitance is:

$\pm 20\%$.

4.2.3 Rated voltage (U_R)

The preferred values of rated ~~direct~~ DC voltages taken from the R10 and R20 series of ISO 3 are:

- from R 10: 1,0 – 1,25 – 1,6 – 2,0 – 2,5 – 3,15 – 4,0 – 5,0 – 6,3 – 8,0;
- from R 20: 3,5¹ – 4,5;
- and their decimal multiples ($\times 10^n$, n : integer).

4.2.4 Category voltage (U_C)

The category voltage is equal to the rated voltage.

4.2.5 Surge voltage (U_{RS})

The surge voltage shall be 1,15 times the rated or category voltage rounded off to the nearest volt (two significant digits) (see Table 1 and Table 2).

Table 1 – Surge voltages

	Values in volts												
Rated voltage	2,0	2,5	4,0	5,0	6,3	8,0	10	12,5	16	20	25	35	50
Surge voltage	2,3	2,9	4,6	5,8	7,2	9,2	12	14	18	23	29	40	58

4.2.6 Rated temperature

The value of the rated temperature is +105 °C and +125 °C.

5 Test and measurement procedures

5.1 General

Test severities and requirements prescribed in detail specifications referring to this sectional specification are of equal or higher performance level, because lower performance levels are not permitted.

This clause supplements the information given in IEC 60384-1:20082016, Clause 4.

5.2 Preliminary drying

See IEC 60384-1:20082016, 4.3.

5.3 Measuring conditions

See IEC 60384-1:20082016, 4.2.1.

5.4 Mounting

5.4.1 General

See IEC 60384-1:20082016, 4.33, with 5.4.2 to 5.4.4 of this document.

¹ ISO 3 indicates the value 3,55 for R20.

5.4.2 Initial inspections

See Table 3.

5.4.3 Test conditions

The test method shall be the reflow method and reflow temperature profile specified in the detail specification.

5.4.4 Final inspections and requirements

See Table 3.

5.5 Visual examination and check of dimensions

5.5.1 General

See IEC 60384-1:2008/2016, 4.4, with 5.5.2 and 5.5.3 of this document.

5.5.2 Visual examination and check of dimensions

Visual examination shall be carried out with suitable equipment with approximately 10× magnification and lighting appropriate to the specimen under test and the quality level required. The operator should have available facilities for incident or transmitted illumination, as well as an appropriate measuring facility. The capacitors shall be examined to verify that the materials, design, construction, and physical dimensions are appropriate.

5.5.3 Requirements

The workmanship shall be in accordance with the applicable requirements given in the detail specification.

5.6 Electrical tests

5.6.1 Leakage current

5.6.1.1 General

See IEC 60384-1:2008/2016, 4.9, with 5.6.1.2 to 5.6.1.4 of this document.

5.6.1.2 Pre-conditioning

If the leakage current of the capacitor increases, the following processing can be performed as pre-conditioning.

The capacitor should be serially attached to a protective resistor ranging from 10 Ω to 1 000 Ω and DC voltage equivalent to the rated voltage should be applied for 2 h at 105 °C $\pm$ 2 °C. Applied voltage to the capacitors shall be maintained within $\pm$ 3 % of the rated voltage.

Next, after letting the capacitor cool to room temperature, it should be discharged through a resistor of approximately 1 Ω /V and then stored at standard atmospheric conditions for 12 h to 24 h.

5.6.1.3 Measuring conditions

The rated voltage shall be applied across the capacitor and its protective resistor placed in series with the capacitor to limit the charging current.

The protective resistor shall have a value of 1 000 Ω .

The measurement of each test should be carried out after pre-conditioning.

5.6.1.4 Requirements

See Table 3.

5.6.2 Capacitance

5.6.2.1 General

See IEC 60384-1:20082016, 4.7, with 5.6.2.2 and 5.6.2.3 of this document.

5.6.2.2 Measuring conditions

Unless otherwise specified in the detail specifications, the capacitance shall be measured at a frequency of 120 Hz.

The peak alternating voltage actually applied across the capacitor terminations shall not exceed 0,5 V (RMS).

A DC bias voltage of 0,7 V to 1,0 V may be applied during the measurement to avoid negative voltage application to the capacitor by the applied AC voltage.

The inaccuracy of the measuring instruments shall not exceed ± 2 % of the limit specified in the detail specification, whether this is given as an absolute value or as a change of capacitance.

5.6.2.3 Requirements

See Table 3.

5.6.3 Tangent of loss angle ($\tan \delta$)

5.6.3.1 General

See IEC 60384-1:20082016, 4.8.1, with 5.6.3.2 and 5.6.3.3 of this document.

5.6.3.2 Measuring conditions

The measurement shall be made under the conditions as specified in 5.6.2.

The inaccuracy of the measuring equipment shall not exceed 0,01 absolute value.

5.6.3.3 Requirements

See Table 3.

5.6.4 Equivalent series resistance (ESR) (if required)

5.6.4.1 General

See IEC 60384-1:20082016, 4.8.2, with 5.6.4.2 and 5.6.4.3 of this document.

5.6.4.2 Measuring conditions

Unless otherwise specified in the detail specifications, test conditions are as follows:

- temperature: 20 °C $\pm$ 2 °C;
- applied voltage: peak AC value $\leq$ 0,5 V (RMS);

- voltage frequency: 100 kHz $\pm$ 10 kHz;

The error of measurement shall not exceed 5 % of the requirement, or 0,02 Ω , whichever is greater.

5.6.4.3 Requirements

See Table 3.

5.6.5 Impedance (if required)

5.6.5.1 General

See IEC 60384-1:20082016, 4.10, with 5.6.5.2 and 5.6.5.3 of this document.

5.6.5.2 Measuring conditions

The frequency of measurement: 120 Hz, with a tolerance of ± 10 %.

Measurement voltage should be set sufficiently low, and the change of impedance value should be in the range of measurement error when the voltage is applied to capacitors for 1 min.

The error of measurement shall not exceed ± 5 % of the requirement, or 0,02 Ω , whichever is greater.

5.6.5.3 Requirements

See Table 3.

5.7 Resistance to soldering heat

5.7.1 General

See IEC 60384-1:20082016, 4.14, with 5.7.2 to 5.7.5 of this document, unless otherwise specified in the detail specification.

5.7.2 Initial inspections

See Table 3.

5.7.3 Test conditions

The test method shall be the reflow method, and the reflow temperature profile shall be specified in the detail specification.

5.7.4 Recovery

The recovery period shall be 24 h $\pm$ 2 h.

5.7.5 Final inspections and requirements

After recovery, the surface mount capacitors shall be visually examined under normal lighting and approximately 10 $\times$ magnification and the measured electrical characteristics given in ~~Table 4~~ Table 3.

5.8 Solderability

5.8.1 General

See IEC 60384-1:20082016, 4.15, with 5.8.2 of this document.

5.8.2 Final inspections and requirements

See ~~Table 4~~ Table 3.

5.9 Shear test (if required)

See IEC 60384-1:20082016, 4.34.

5.10 Substrate bending test (if required)

5.10.1 General

See IEC 60384-1:20082016, 4.35, with 5.10.2 to 5.10.4 of this document.

5.10.2 Initial inspections

See Table 3.

5.10.3 Test conditions

Deflection D and the number of bends shall be specified in the detail specification.

5.10.4 Final inspections and requirements

See Table 3.

5.11 Rapid change of temperature

5.11.1 General

See IEC 60384-1:20082016, 4.16, with 5.11.2 to 5.11.5 of this document:

The capacitors shall be mounted in accordance with 5.4.

5.11.2 Initial inspections

See Table 3.

5.11.3 Test conditions

Test conditions are as follows:

- T_A = lower category temperature;
- T_B = upper category temperature;
- the capacitors shall be tested for 5 cycles;
- the duration of the exposure at each temperature limit shall be 30 min.

5.11.4 Recovery

The recovery period shall be 1 h to 2 h.

5.11.5 Final inspections and requirements

See Table 3.

5.12 Climatic sequence

5.12.1 General

See IEC 60384-1:20082016, 4.21, with 5.12.2 to 5.12.8 of this document.

5.12.2 Initial inspections

See Table 3.

5.12.3 Dry heat

See IEC 60384-1:20082016, 4.21.3, with the following details:

- temperature: upper category temperature;
- duration: 16 h.

5.12.4 Damp heat, cyclic, Test Db, first cycle

See IEC 60384-1:20082016, 4.21.4.

5.12.5 Cold

See IEC 60384-1:20082016, 4.21.5, with the following details:

- temperature: lower category temperature;
- duration: 2 h.

5.12.6 Damp heat, cyclic, Test Db, remaining cycles

See IEC 60384-1:20082016, 4.21.7.

5.12.7 Recovery

The recovery period shall be 1 h to 2 h.

5.12.8 Final inspections and requirements

See Table 3.

5.13 Damp heat, steady state

5.13.1 General

See IEC 60384-1:20082016, 4.22, with 5.13.2 to 5.13.5 of this document:

The capacitors shall be mounted in accordance with 5.4.

5.13.2 Initial inspections

See Table 3.

5.13.3 Test conditions

Test conditions are as follows:

- temperature: $40\text{ °C} \pm 2\text{ °C}$;
- relative humidity: $(93 \pm 3)\%$;
- applied voltage: No voltage shall be applied;
- duration: 21 days.

5.13.4 Recovery

The recovery period shall be 1 h to 2 h.

5.13.5 Final inspections and requirements

See Table 3.

5.14 Characteristics at high and low temperature

5.14.1 General

See IEC 60384-1:2008/2016, 4.29, with 5.14.2 of this document:

The capacitors shall be mounted in accordance with 5.4.

5.14.2 Inspections and requirements

The capacitors shall be measured at each temperature step and shall meet the requirements given in Table 3.

5.15 Surge voltage

5.15.1 General

See IEC 60384-1:2008/2016, 4.26, with 5.15.2 to 5.15.5 of this document.

5.15.2 Initial inspections

See Table 3.

5.15.3 Test conditions

Test conditions are as follows:

- number of cycles: 1 000;
- temperature: 15 °C to upper category temperature with the applicable requirements given in the detail specification;
- voltage: $1,15\ U_R$ or $1,15\ U_C$;
- ~~Protective~~ charge resistor: $1\ 000\ \Omega \pm 100\ \Omega$ or a value calculated by Formula (1);

$$RC = 0,1 \pm 0,05\ (\text{s}) \quad (1)$$

Where

If the internal resistance of the power supply is negligibly smaller than $1\ 000\ \Omega$, R is equal to the resistance of the charging circuit. If the internal resistance of the power supply affects the charging resistance of the circuit, the current value possibly gets too small to measure correctly. On the other hand, if the time constant is $0,1\ \text{s}$ and the capacitance is $1\ 000\ \mu\text{F}$, the R value is $100\ \Omega$. Since an excessive inrush current then flows depending on the applied voltage, it is not possible to distinguish whether a defect, even if it occurs, is caused by the

inrush current or the surge. Therefore, either of the two conditions above should be selectable depending on the situation at measurement.

R is the ~~value of charge resistor~~ sum of the internal resistance of the power supply and resistance of the charge circuit (Ω)

C is the value of nominal capacitance (F)

$R(\Omega)$ is the sum of the internal resistance of the power supply and resistance of the charge circuit

$C(F)$ is the value of nominal capacitance;

- duration of charge: 30 s;
- duration of no-load: 5 min 30 s.

5.15.4 Recovery

The recovery period shall be 1 h to 2 h.

5.15.5 Final inspections and requirements

See Table 3.

5.16 Endurance

5.16.1 General

See IEC 60384-1:20082016, 4.23, with 5.16.2 to 5.16.5 of this document:

The capacitors shall be mounted in accordance with 5.4.

5.16.2 Initial inspections

See Table 3.

5.16.3 Test conditions

Test conditions are as follows:

- applied voltage: rated voltage, unless otherwise specified in the detail specification;
- temperature: upper category temperature;
- duration: 1 000 h.

5.16.4 Recovery

The recovery period shall be 1 h to 2 h.

5.16.5 Final inspections and requirements

See Table 3.

5.17 Storage at high temperature

5.17.1 General

See IEC 60384-1:20082016, 4.25.1, with 5.17.2 to 5.17.5 of this document.

5.17.2 Initial inspections

See Table 3.

5.17.3 Test conditions

Test conditions are as follows:

- temperature: upper category temperature;
- duration: 96 h ± 4 h.

5.17.4 Recovery

The minimum recovery period shall be 16 h.

5.17.5 Final inspections and requirements

See Table 3.

5.18 Charge and discharge (if required)

5.18.1 General

See IEC 60384-1:20082016, 4.27, with 5.18.2 to 5.18.4 of this document.

5.18.2 Initial inspections

See Table 3.

5.18.3 Test conditions

Charge and discharge shall be performed up to the specified cycles at the temperature (within the ambient temperature range of 15 °C to the upper category temperature) specified in the detail specification.

The capacitors shall be subjected to the specified number of cycles, each cycle consisting of a charge in accordance with a), followed by a discharge in accordance with b).

a) Charge:

- applied voltage: rated direct voltage;
- internal resistance of the voltage source plus external series resistor: as required for $RC = 0,1$ s;
- duration: 0,5 s;
- number of cycles: 10^6 .

b) Discharge:

- no voltage applied;
- discharge resistor: as required for $RC = 0,1$ s;
- duration: 0,5 s;
- number of cycles: 10^6 .

5.18.4 Final inspections and requirements

See Table 3.

5.19 Component solvent resistance (if required)

See IEC 60384-1:20082016, 4.31.

5.20 Solvent resistance of marking (if required)

See IEC 60384-1:20082016, 4.32.

5.21 High surge current (if required)

5.21.1 General

See IEC 60384-1:20082016, 4.39, with 5.21.2 of this document.

5.21.2 Final inspections and requirements

See ~~Table 4~~ Table 3.

6 Marking

6.1 General

See IEC 60384-1:20082016, 2.4, with 6.2 to 6.4 of this document.

6.2 Information for marking

Information given in the marking is normally selected from the following list; the relative importance of each item is indicated by its position in the list:

- a) polarity of the terminations (unless identified by the construction);
- b) nominal capacitance;
- c) rated voltage (DC voltage may be indicated by the symbol: $\equiv$ (IEC 60417-5031-2002-10) or —);
- d) category temperature;
- e) tolerance on nominal capacitance;
- f) year and month (or, year and week) of manufacture;
- g) manufacturer's name and/or trademark;
- h) manufacturer's type designation;
- i) reference to the detail specification.

6.3 Marking on capacitors

Polarity of the terminations shall be marked. Other elements are marked, as necessary.

Any marking shall be legible and not easily smeared or removed by rubbing with fingers.

6.4 Marking on packaging

The packaging containing the capacitors should be clearly marked with the information listed in 6.2 as necessary.

7 Information to be given in a detail specification

7.1 General

Detail specifications shall be derived from the blank detail specification.

Detail specifications shall not specify requirements inferior to those of the generic, sectional or blank detail specification. When more severe requirements are included, they shall be listed in 1.9 of the detail specification and indicated in the test schedules, for example, by an asterisk.

The information given in 7.2 may, for convenience, be presented in tabular form.

The following information shall be given in each detail specification and the values quoted shall preferably be selected from those given in the appropriate clause of this sectional specification.

7.2 Outline drawing and dimensions

There shall be an illustration of the capacitors as an aid to easy recognition and for comparison of the capacitors with others.

Dimensions and their associated tolerances, which affect interchangeability and mounting, shall be given in the detail specification. All dimensions shall ~~preferably~~ be stated in millimetres; ~~however~~, when the original dimensions are given in inches, the converted metric dimensions in millimetres shall be added.

The numerical values of the body shall be given as follows:

- for general: width, length and height.
- for cylindrical body: diameter and length.

The numerical values of the terminals shall be given as follows:

- for terminals: width, length and spacing.

When the configuration is other than described above, the detail specification shall state such dimensional information as will adequately describe the capacitor.

7.3 Mounting

The method of mounting for tests and measurements are given in 5.4. The detail specification shall specify the methods of mounting for normal use.

7.4 Ratings and characteristics

7.4.1 General

The ratings and characteristics shall be given in accordance with the relevant subclauses of this sectional specification, including the items specified in 7.4.2 to 7.4.4.

7.4.2 Nominal capacitance range

See 4.2.1.

When products approved to the detail specification have different nominal capacitance ranges, the following statement should be added:

“The nominal capacitance range available in each voltage range is given in the register of approvals, available for example on the IECQ on-line certificate system website www.iecq.org”.

7.4.3 Particular characteristics

Additional characteristics may be listed when they are considered necessary to specify adequately the component for design and application purposes.

7.4.4 Soldering

The detail specification shall specify the test methods, severities and requirements applicable for the solderability and the resistance to soldering heat tests.

7.5 Marking

The detail specification shall specify the content of the marking on the capacitor and on the packaging.

When there are deviations from Clause 6, these shall be given in the detail specification.

8 Quality assessment procedures

8.1 Primary stage of manufacture

The primary stage of manufacture is the capacitor manufacturer's evaluation of the formed anode foil.

8.2 Structurally similar components

Capacitors, considered as being structurally similar, produced with similar are capacitors produced with similar processes and materials, though they may be of different case sizes and values.

8.3 Certified test records of released lots

The information required in IEC 60384-1:20082016, Q.1.5, shall be made available when prescribed in the detail specification and when requested by a purchaser. After the endurance test, the required parameters are the capacitance change, tangent of loss angle, equivalent series resistance, and leakage current.

8.4 Qualification approval (QA) procedures

8.4.1 General

The procedures for qualification approval testing are given in IEC 60384-1:20082016, Q.2.

The schedule to be used for qualification approval testing on the basis of lot-by-lot and periodic tests is given in 8.5. The procedure using a fixed sample size schedule is given in 8.4.2 and 8.4.3.

8.4.2 Qualification approval on the basis of the fixed sample size procedure

The fixed sample size procedure is described in IEC 60384-1:20082016, Q.2.4. The sample shall be representative of the range of capacitors for which approval is sought. The ~~sample~~ range of approval may be the whole or the part of the range given in the detail specification.

The sample shall consist of four specimens having the maximum and minimum rated voltages and, for these voltages, the maximum and minimum case size. When there are more than four case sizes, an intermediate case size shall also be tested. In each of these case size/voltage combinations (values), the maximum capacitance shall be chosen. Thus, for the approval of a range, testing is required for either four or six values. When the range consists of fewer than four values, the number of specimens to be tested shall be that required for four values.

Two (for 6 values) or three (for 4 values) specimens per value may be used as replacements for specimens, that are non-conforming because of incidents not attributable to the manufacturer.

The numbers given in Group 0 assume that all groups are applicable. If this is not so, the numbers may be reduced accordingly.

When additional groups are introduced into the qualification approval test schedule, the number of specimens required for Group 0 shall be increased by the same number as that required for the additional groups.

Table 2 gives the number of samples to be tested in each group or subgroup together with the number of permissible ~~non-conforming items~~ non-conformances for qualification approval test.

8.4.3 Tests

The complete series of tests specified in Table 2 and Table 3 are required for the approval of capacitors covered by a detail specification. The tests of each group shall be carried out in the order given.

The whole sample shall be subjected to the tests of Group 0 and then divided for the other groups.

Specimens found to be non-conforming in the tests of Group 0 shall not be used for the other groups.

Approval is granted when the number of non-conforming items is zero.

Table 2 and Table 3 together form the fixed sample size test schedule for the qualification approval on the basis of the fixed sample size procedure.

Table 2 gives the number of the samples and permissible non-conforming items for each test or test group.

Table 3 gives a summary of the test conditions ~~or performance requirements, and choices of the test conditions~~ and performance requirements, and when a choice shall be made in the detail specification.

The test conditions and performance requirements for the qualification approval on the basis of the fixed sample size procedure should be identical to those for quality conformance inspection given in the detail specification.

Table 2 – Sampling plan for qualification approval, assessment level EZ

Group no.	Test	Subclause	Number of specimens n^d	Permissible number of non-conforming items c^g
0	High surge current ^c	5.21	120+12 ^f	0
	Visual examination	5.5		
	Dimensions	5.5		
	Leakage current	5.6.1		
	Capacitance	5.6.2		
	Tangent of loss angle	5.6.3		
	Equivalent series resistance ^c	5.6.4		
	Spare specimens			
	1A Resistance to soldering heat	5.7	12	0
	Component solvent resistance ^c	5.19		
	1B Solderability	5.8	12	0
	Solvent resistance of the marking ^c	5.20		
	2 Substrate bending test ^e	5.10	12	0
	3 ^a Mounting	5.4	84	0 ^b
	Visual examination	5.5		
	Leakage current	5.6.1		
	Capacitance	5.6.2		
	Tangent of loss angle	5.6.3		
	Equivalent series resistance ^c	5.6.4		
	3.1 Shear test ^c	5.9		
	Rapid change of temperature	5.11		
	Climatic sequence	5.12		
	3.2 Damp heat, steady state	5.13	12	0
	3.3 Characteristics at high and low temperature	5.14	12	0
	Charge and discharge ^c	5.18		
	3.4 Endurance	5.16	36	0
	3.5 Storage at high temperature	5.17	12	0
	Surge voltage	5.15		

^a The values of these measurements serve as initial measurements for the tests of Group 3.

^b The capacitors found non-conforming after mounting shall not be taken into account when calculating the non-conforming items for the following tests. They shall be replaced by spare capacitors.

^c If required.

^d For case size/voltage combinations, see 8.4.2.

^e Not applicable to capacitors, which shall be mounted on alumina substrates only, according to their detail specification.

^f Spare specimens.

^g This is the acceptance number, which is not to be exceeded for acceptance.

Table 3 – Test schedule for qualification approval (1 of 6)

Subclause number and test ^a , inspection items	D or ND ^b	Conditions of test ^a , and measurements	Number of specimens (<i>n</i>) and permissible number of non-conforming items (<i>c</i>)	Performance requirements ^a
GROUP 0	ND		See Table 2	
5.21 High surge current ^e		See IEC 60384-1:20082016, 4.39		See detail specification
5.5 Dimension (detail)		See 5.5.2		See detail specification
5.5.2 Visual examination		See 5.5.2		Legible marking and as specified in detail specification
5.6.1 Leakage current		See 5.6.1.2 and 5.6.1.3		$\leq 0,2 C_N U_R$ or 500 μ A, whichever is greater (at 20 °C $\pm$ 2 °C) ^d
5.6.2 Capacitance		See 5.6.2.2		See detail specification
5.6.3 Tangent of loss angle (tan δ)		See 5.6.3.2		See detail specification
5.6.4 Equivalent series resistance ^e		See 5.6.4.2		See detail specification
GROUP 1A	D		See Table 2	
5.7 Resistance to soldering heat		See 5.7.3		
5.7.2 Initial inspections				
Capacitance		See 5.6.2.2		
5.7.4 Recovery		See 5.7.4		
5.7.5 Final inspections				
Visual examination		See 5.5.2		There shall be no signs of damage
Leakage current		See 5.6.1.2 and 5.6.1.3		See detail specification
Capacitance		See 5.6.2.2		See detail specification
Tangent of loss angle		See 5.6.3.2		See detail specification
Equivalent series resistance ^e		See 5.6.4.2		See detail specification
5.19 Component solvent resistance ^e		See IEC 60384-1:20082016, 4.31		See IEC 60384-1:20082016, 4.31

Table 3 (2 of 6)

Subclause number and test ^a , inspection items	D or ND ^b	Conditions of test ^a , and measurements	Number of specimens (<i>n</i>) and permissible number of non-conforming items (<i>c</i>)	Performance requirements ^a
GROUP 1B 5.8 Solderability 5.8.2 Final inspections Visual examination 5.20 Solvent resistance of the marking ^{c,e}	D	See IEC 60384-1:20082016, 4.15 See 5.5.2 See IEC 60384-1:20082016, 4.32	See Table 2	There shall be No signs of damage. Areas to be soldered shall be covered with a new solder coating with no more than a small number of scattered imperfections such as pinholes or un-wetted or de-wetted areas. These imperfections shall not be concentrated in one area. Areas in which plating does not exist, such as tip of the terminal, shall not be evaluated. See IEC 60384-1:20082016, 4.32
GROUP 2 5.10 Substrate bending test ^e 5.10.2 Initial inspections Capacitance 5.10.4 Final inspections Visual examination Change of capacitance	D	See 5.10.3 See 5.6.2.2 See 5.5.2 See 5.6.2.2	See Table 2	No visible damage See detail specification
GROUP 3 5.4 Mounting 5.4.2 Initial inspections Capacitance 5.4.4 Final inspections Visual examination Leakage current Capacitance Tangent of loss angle Equivalent series resistance ^e	D	See 5.4.3 See 5.6.2.2 See 5.5.2 See 5.6.1.2 and 5.6.1.3 See 5.6.2.2 See 5.6.3.2 See 5.6.4.2	See Table 2	No visible damage $\leq 0,2 C_N U_R$ or 500 μA, whichever is greater (at 20 °C $\pm$ 2 °C) ^d See detail specification See detail specification See detail specification

Table 3 (3 of 6)

Subclause number and test ^a , inspection items	D or ND ^b	Conditions of test ^a , and measurements	Number of specimens (<i>n</i>) and permissible number of non-conforming items (<i>c</i>)	Performance requirements ^a
GROUP 3.1	D		See Table 2	
5.9 Shear test ^e		See IEC 60384-1:20082016, 4.34		
5.11 Rapid change of temperature		See 5.11.3		
5.11.2 Initial inspections				
Capacitance		See 5.6.2.2		
5.11.4 Recovery		See 5.11.4		
5.11.5 Final inspections				
Leakage current		See 5.6.1.2 and 5.6.1.3		≤ initial limit
Capacitance		See 5.6.2.2		$ \Delta C/C \leq 10\%$ of the value measured in 5.11.2
Tangent of loss angle		See 5.6.3.2		≤ initial limit
5.12 Climatic sequence		See IEC 60384-1:2016, 4.21		
5.12.2 Initial inspections				
Capacitance		See 5.6.2.2		
5.12.3 Dry heat		See 5.12.3		
5.12.4 Damp heat, cyclic, test Db, first cycle		See IEC 60384-1:20082016, 4.21.4		
5.12.5 Cold		See 5.12.5		
5.12.6 Damp heat, cyclic, test Db, remaining cycles		See IEC 60384-1:20082016, 4.21.7		
5.12.7 Recovery		See 5.12.7		
5.12.8 Final inspections				
Visual examination		See 5.5.2		No visible damage
Capacitance		See 5.6.2.2		Legible marking
Leakage current		See 5.6.1.2 and 5.6.1.3		$ \Delta C/C \leq 20\%$ of the value measured in 5.12.2
Tangent of loss angle		See 5.6.3.2		≤ initial limit
				≤ 1,5 times the initial limit

Table 3 (4 of 6)

Subclause number and test ^a , inspection items	D or ND ^b	Conditions of test ^a , and measurements	Number of specimens (<i>n</i>) and permissible number of non-conforming items (<i>c</i>)	Performance requirements ^a
GROUP 3.2 5.13 Damp heat, steady state 5.13.2 Initial inspections Capacitance 5.13.4 Recovery 5.13.5 Final inspections Visual examination Leakage current Capacitance Tangent of loss angle	D	See 5.13.3 See 5.6.2.2 See 5.13.4 See 5.5.2 See 5.6.1.2 and 5.6.1.3 See 5.6.2.2 See 5.6.3.2	See Table 2	No visible damage Legible marking ≤ 5 times initial limit See detail specification $\leq 1,5$ times the initial limit
GROUP 3.3 5.14 Characteristics at high and low temperature Step 1: 20 °C Capacitance Impedance ^e Step 2: lower category temperature Capacitance Impedance ^e Tangent of loss angle (if applicable required) Step 3: upper category temperature Leakage current Capacitance Tangent of loss angle (if applicable required)	D	See IEC 60384-1:2008/2016, 4.29 See 5.6.2.2 See 5.6.5.2 See 5.6.2.2 See 5.6.5.2 See 5.6.3.2 See 5.6.1.2 and 5.6.1.3 See 5.6.2.2 See 5.6.3.2	See Table 2	 $ \Delta C/C \leq 20$ % of the value measured in step 1 Ratio with respect to value in step 1: $\leq 1,5$ times ≤ 2 times the initial limit At 105 °C (with U_R): $\leq 12,5$ times the limit of 5.6.1 $ \Delta C/C \leq 20$ % of the value measured in step 1 At $U_R \leq 4$: ≤ 3 times the initial limit At $U_R > 4$: ≤ 2 times the initial limit

Table 3 (5 of 6)

Subclause number and test ^a , inspection items	D or ND ^b	Conditions of test ^a , and measurements	Number of specimens (<i>n</i>) and permissible number of non-conforming items (<i>c</i>)	Performance requirements ^a
5.18 Charge and discharge ^e 5.18.2 Initial inspections Capacitance 5.18.4 Final inspections Visual examination Leakage current Capacitance Tangent of loss angle Equivalent series resistance ^e	D	See 5.18.3 See 5.6.2.2 See 5.5.2 See 5.6.1.2 and 5.6.1.3 See 5.6.2.2 See 5.6.3.2 See 5.6.4.2	See Table 2	No visible damage Legible marking $\leq$ initial limit $ \Delta C/C \leq 20$ % of the value measured in 5.18.2 $\leq 1,5$ times the initial limit ≤ 2 times the initial limit
GROUP 3.4 5.16 Endurance 5.16.2 Initial inspections Capacitance 5.16.4 Recovery 5.16.5 Final inspections Visual examination Leakage current Capacitance Tangent of loss angle Equivalent series resistance ^e	D	See 5.16.3 See 5.6.2.2 See 5.16.4 See 5.5.2 See 5.6.1.2 and 5.6.1.3 See 5.6.2.2 See 5.6.3.2 See 5.6.4.2	See Table 2	No visible damage Legible marking ≤ 2 times the initial limit $ \Delta C/C \leq 20$ % of the value measured in 5.16.2 $\leq 1,5$ times the initial limit ≤ 2 times the initial limit

Table 3 (6 of 6)

Subclause number and test ^a , inspection items	D or ND ^b	Conditions of test ^a , and measurements	Number of specimens (<i>n</i>) and permissible number of non-conforming items (<i>c</i>)	Performance requirements ^a
GROUP 3.5	D		See Table 2	
5.17 Storage at high temperature		See 5.17.3		
5.17.2 Initial inspections				
Capacitance		See 5.6.2.2		
5.17.4 Recovery		See 5.17.4		
5.17.5 Final inspections				
Visual examination		See 5.5.2		No visible damage
Leakage current		See 5.6.1.2 and 5.6.1.3		Legible marking
Capacitance		See 5.6.2.2		≤ 2 times the initial limit
Tangent of loss angle		See 5.6.3.2		$ \Delta C/C \leq 10\%$ of the value measured in 5.17.2
5.15 Surge voltage		See 5.15.3		≤ initial limit
5.15.2 Initial inspections				
Capacitance		See 5.6.2.2		
5.15.4 Recovery		See 5.15.4		
5.15.5 Final inspections				
Visual examination		See 5.5.2		No visible damage
Leakage current		See 5.6.1.2 and 5.6.1.3		≤ initial limit
Capacitance		See 5.6.2.2		$ \Delta C/C \leq 15\%$ of the value measured in 5.15.2
Tangent of loss angle		See 5.6.3.2		≤ 1,5 times the initial limit
^a Subclause numbers of test and performance requirements refer to Clause 5. ^b In this table: D = destructive, ND = non-destructive. ^c This test may be carried out on surface mount capacitors mounted on a substrate. ^d C_N = nominal capacitance in microfarad; U_R = rated voltage in volt. ^e If applicable required.				

8.5 Quality conformance inspections

8.5.1 Formation of inspection lots

8.5.1.1 Groups A and B inspection

These tests shall be carried out on a lot-by-lot basis.

A manufacturer may aggregate the current production into inspection lots subject to the following safeguards.

- a) The inspection lot shall consist of structurally similar capacitors (see 8.2).
- b) The sample tested shall be representative of the values (rated voltage and nominal capacitance) and dimensions contained in the inspection lot:
 - in relation to their number;
 - with a minimum of five of any one value.
- c) If there are fewer than five of any one value in the sample, the basis for the drawing of samples shall be agreed between the manufacturer and the certification body (CB).

8.5.1.2 Group C inspections

These tests shall be carried out on a periodic basis.

Samples shall be representative of the current production of the specified periods and shall be divided into high-, medium- and low-voltage ratings. In order to cover the range of approvals in any period, one case size shall be tested from each voltage group. In subsequent periods, other case sizes and/or voltage ratings in production shall be tested with the aim of covering the whole range.

8.5.2 Test schedule

The test schedule for the lot-by-lot and periodic tests for quality conformance inspection is given in the blank detail specification.

8.5.3 Delayed delivery

When, in accordance with the procedures of IEC 60384-1:2008/2016, Q.1.7, re-inspection should be made, capacitance, tangent of loss angle, leakage current and solderability shall be checked as specified in Groups A and B inspection.

8.5.4 Assessment levels

The assessment levels given in the blank detail specification shall ~~preferably~~ be selected from Table 4 and Table 5 as assessment level EZ.

Table 4 – Lot-by-lot inspection

Inspection subgroup ^a	EZ		
	IL ^b	<i>n</i> ^b	<i>c</i> ^b
A0	100 % ^c		
A1	S – 3	<i>d</i>	0
A2	S – 3	<i>d</i>	0
B1	S – 3	<i>d</i>	0

^a The content of the inspection subgroup is described in Clause 2 of the blank detail specification.

^b IL = inspection level
n = sample size
c = permissible number of non-conforming items

^c After removal of nonconforming items by 100 % testing during the manufacturing process, sampling inspection shall be performed in order to monitor outgoing quality level by nonconforming items per million ($\times 10^{-6}$). The sampling level shall be established by the manufacture, ~~preferably~~ in accordance with IEC 61193-2:2007, Annex A. In the case where one or more nonconforming items occur in a sample, this lot shall be rejected, but the whole sample shall be inspected and all nonconforming items shall be counted for the calculation of quality level values. Outgoing quality level by nonconforming items per million ($\times 10^{-6}$) values shall be calculated by accumulating inspection data in accordance with the method given in IEC 61193-2:2007, 6.2.

^d Number to be tested: Sample size shall be determined in accordance with IEC 61193-2:2007, 4.3.2.

Table 5 – Periodic inspection

Inspection subgroup ^a	EZ		
	p^b	n^b	c^b
C1	3	12	0
C2	3	12	0
C3.1	6	12	0
C3.2	6	24	0
C3.3A	6	12	0
C3.3B	6	12	0
C3.4	3	36	0
C3.5	6	12	0
^a The content of the inspection subgroup is described in Clause 2 of the blank detail specification. ^b p = periodicity in months n = sample size c = permissible number of non-conforming items			

IECNORM.COM : Click to view the full PDF of IEC 60384-25:2021 RLV

Annex X (informative)

Cross-references to the prior edition of this document

The revision of this sectional specification has resulted in a new structure. Table X.1 provides cross-references to specific elements of the prior edition of this sectional specification.

Table X.1 – Reference to IEC 60384-25 for clauses/subclauses and tables

IEC 60384-25:2015 (Edition 2.0) Clause/subclause	IEC 60384-25:2021 (Edition 3.0) Clause/subclause	Notes
1	-	This is covered by Clauses 1, 2, 3, 4, 6, 7.
1.1	1	The prior scope and object are merged into Clause 1
1.2		
1.3	2	-
1.4	7	-
1.4.1	7.1	-
1.4.2	7.2	-
1.4.3	7.3	-
1.4.4	7.4	-
1.4.4.1	7.4.1	-
1.4.4.2	7.4.2	-
1.4.4.3	7.4.3	-
1.4.4.4	7.4.4	-
1.4.5	7.5	-
1.5	3	
1.6	6	
1.6.1	6.1	
1.6.2	6.2	
1.6.3	6.3	
1.6.4	6.4	
2	4	Clause 2 is transferred to become Clause 4. Otherwise numbering kept unchanged.
3	8	Clause 3 is transferred to become Clause 8. Otherwise numbering kept unchanged.
4	5	Clause 4 is transferred to become Clause 5. Otherwise numbering kept unchanged.
Table 1	Table 1	-
Table 2	Table 2	-
Table 3	Table 3	-
Table 4	Table 4	-
Table 5	Table 5	-

Bibliography

~~IEC 60068-2-58:2004, *Environmental testing – Part 2-58: Tests – Test Td: Test methods for solderability, resistance to dissolution of metallization and to soldering heat of surface mounting devices (SMD)*~~

IEC 60384-18, *Fixed capacitors for use in electronic equipment – Part 18: Sectional specification – Fixed aluminium electrolytic surface mount capacitors with solid (MnO₂) and non-solid electrolyte*

ISO 3, *Preferred numbers – Series of preferred numbers*

IECNORM.COM : Click to view the full PDF of IEC 60384-25:2021 RLV

INTERNATIONAL STANDARD

NORME INTERNATIONALE

**Fixed capacitors for use in electronic equipment –
Part 25: Sectional specification – Fixed aluminium electrolytic surface mount
capacitors with conductive polymer solid electrolyte**

**Condensateurs fixes utilisés dans les équipements électroniques –
Partie 25: Spécification intermédiaire – Condensateurs fixes électrolytiques
en aluminium pour montage en surface à électrolyte solide en polymère
conducteur**

CONTENTS

FOREWORD	5
1 Scope	7
2 Normative references	7
3 Terms and definitions	7
4 Preferred ratings and characteristics	8
4.1 Preferred characteristics	8
4.2 Preferred values of ratings	8
4.2.1 Nominal capacitance (C_N)	8
4.2.2 Tolerance on nominal capacitance	8
4.2.3 Rated voltage (U_R)	8
4.2.4 Category voltage (U_C)	8
4.2.5 Surge voltage (U_{RS})	9
4.2.6 Rated temperature	9
5 Test and measurement procedures	9
5.1 General	9
5.2 Preliminary drying	9
5.3 Measuring conditions	9
5.4 Mounting	9
5.4.1 General	9
5.4.2 Initial inspections	9
5.4.3 Test conditions	9
5.4.4 Final inspections and requirements	9
5.5 Visual examination and check of dimensions	9
5.5.1 General	9
5.5.2 Visual examination and check of dimensions	10
5.5.3 Requirements	10
5.6 Electrical tests	10
5.6.1 Leakage current	10
5.6.2 Capacitance	10
5.6.3 Tangent of loss angle ($\tan \delta$)	11
5.6.4 Equivalent series resistance (ESR) (if required)	11
5.6.5 Impedance (if required)	11
5.7 Resistance to soldering heat	12
5.7.1 General	12
5.7.2 Initial inspections	12
5.7.3 Test conditions	12
5.7.4 Recovery	12
5.7.5 Final inspections and requirements	12
5.8 Solderability	12
5.8.1 General	12
5.8.2 Final inspections and requirements	12
5.9 Shear test (if required)	12
5.10 Substrate bending test (if required)	12
5.10.1 General	12
5.10.2 Initial inspections	13
5.10.3 Test conditions	13

5.10.4	Final inspections and requirements.....	13
5.11	Rapid change of temperature	13
5.11.1	General	13
5.11.2	Initial inspections	13
5.11.3	Test conditions	13
5.11.4	Recovery	13
5.11.5	Final inspections and requirements.....	13
5.12	Climatic sequence	13
5.12.1	General	13
5.12.2	Initial inspections.....	13
5.12.3	Dry heat	13
5.12.4	Damp heat, cyclic, Test Db, first cycle	14
5.12.5	Cold	14
5.12.6	Damp heat, cyclic, Test Db, remaining cycles	14
5.12.7	Recovery	14
5.12.8	Final inspections and requirements.....	14
5.13	Damp heat, steady state	14
5.13.1	General	14
5.13.2	Initial inspections.....	14
5.13.3	Test conditions	14
5.13.4	Recovery	14
5.13.5	Final inspections and requirements.....	14
5.14	Characteristics at high and low temperature.....	14
5.14.1	General	14
5.14.2	Inspections and requirements	15
5.15	Surge voltage	15
5.15.1	General	15
5.15.2	Initial inspections.....	15
5.15.3	Test conditions	15
5.15.4	Recovery	15
5.15.5	Final inspections and requirements.....	15
5.16	Endurance.....	16
5.16.1	General	16
5.16.2	Initial inspections.....	16
5.16.3	Test conditions	16
5.16.4	Recovery	16
5.16.5	Final inspections and requirements.....	16
5.17	Storage at high temperature.....	16
5.17.1	General	16
5.17.2	Initial inspections.....	16
5.17.3	Test conditions	16
5.17.4	Recovery	16
5.17.5	Final inspections and requirements.....	16
5.18	Charge and discharge (if required).....	16
5.18.1	General	16
5.18.2	Initial inspections.....	17
5.18.3	Test conditions	17
5.18.4	Final inspections and requirements.....	17
5.19	Component solvent resistance (if required)	17

5.20	Solvent resistance of marking (if required)	17
5.21	High surge current (if required)	17
5.21.1	General	17
5.21.2	Final inspections and requirements.....	17
6	Marking	17
6.1	General.....	17
6.2	Information for marking	18
6.3	Marking on capacitors	18
6.4	Marking on packaging	18
7	Information to be given in a detail specification.....	18
7.1	General.....	18
7.2	Outline drawing and dimensions	18
7.3	Mounting.....	19
7.4	Ratings and characteristics	19
7.4.1	General	19
7.4.2	Nominal capacitance range.....	19
7.4.3	Particular characteristics	19
7.4.4	Soldering	19
7.5	Marking.....	19
8	Quality assessment procedures	19
8.1	Primary stage of manufacture	19
8.2	Structurally similar components	20
8.3	Certified test records of released lots.....	20
8.4	Qualification approval (QA) procedures.....	20
8.4.1	General	20
8.4.2	Qualification approval on the basis of the fixed sample size procedure	20
8.4.3	Tests	20
8.5	Quality conformance inspections.....	28
8.5.1	Formation of inspection lots.....	28
8.5.2	Test schedule.....	29
8.5.3	Delayed delivery	29
8.5.4	Assessment levels	29
Annex X (informative)	Cross-references to the prior edition of this document.....	31
Bibliography.....		32
Table 1 – Surge voltages		9
Table 2 – Sampling plan for qualification approval, assessment level EZ		22
Table 3 – Test schedule for qualification approval.....		23
Table 4 – Lot-by-lot inspection		29
Table 5 – Periodic inspection		30
Table X.1 – Reference to IEC 60384-25 for clauses/subclauses and tables		31

INTERNATIONAL ELECTROTECHNICAL COMMISSION

FIXED CAPACITORS FOR USE IN ELECTRONIC EQUIPMENT –**Part 25: Sectional specification – Fixed aluminium electrolytic surface mount capacitors with conductive polymer solid electrolyte****FOREWORD**

- 1) The International Electrotechnical Commission (IEC) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, IEC publishes International Standards, Technical Specifications, Technical Reports, Publicly Available Specifications (PAS) and Guides (hereafter referred to as "IEC Publication(s)"). Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations liaising with the IEC also participate in this preparation. IEC collaborates closely with the International Organization for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.
- 2) The formal decisions or agreements of IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC National Committees.
- 3) IEC Publications have the form of recommendations for international use and are accepted by IEC National Committees in that sense. While all reasonable efforts are made to ensure that the technical content of IEC Publications is accurate, IEC cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.
- 4) In order to promote international uniformity, IEC National Committees undertake to apply IEC Publications transparently to the maximum extent possible in their national and regional publications. Any divergence between any IEC Publication and the corresponding national or regional publication shall be clearly indicated in the latter.
- 5) IEC itself does not provide any attestation of conformity. Independent certification bodies provide conformity assessment services and, in some areas, access to IEC marks of conformity. IEC is not responsible for any services carried out by independent certification bodies.
- 6) All users should ensure that they have the latest edition of this publication.
- 7) No liability shall attach to IEC or its directors, employees, servants or agents including individual experts and members of its technical committees and IEC National Committees for any personal injury, property damage or other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication, use of, or reliance upon, this IEC Publication or any other IEC Publications.
- 8) Attention is drawn to the Normative references cited in this publication. Use of the referenced publications is indispensable for the correct application of this publication.
- 9) Attention is drawn to the possibility that some of the elements of this IEC Publication may be the subject of patent rights. IEC shall not be held responsible for identifying any or all such patent rights.

International Standard IEC 60384-25 has been prepared by IEC technical committee 40: Capacitors and resistors for electronic equipment.

This third edition cancels and replaces the second edition published in 2015. This edition constitutes a technical revision.

This edition includes the following significant technical changes with respect to the previous edition:

- a) Revision of the structure in accordance with ISO/IEC Directives, Part 2:2018, to the extent practicable, and harmonization between other similar kinds of documents.
- b) In addition, Clause 5 and all the tables have been reviewed in order to prevent duplications and contradictions.

The text of this standard is based on the following documents:

FDIS	Report on voting
40/2850/FDIS	40/2861/RVD

Full information on the voting for its approval can be found in the report on voting indicated in the above table.

The language used for the development of this International Standard is English.

A list of all parts in the IEC 60384 series, published under the general title *Fixed capacitors for use in electronic equipment*, can be found on the IEC website.

This document was drafted in accordance with ISO/IEC Directives, Part 2, and developed in accordance with ISO/IEC Directives, Part 1 and ISO/IEC Directives, IEC Supplement, available at www.iec.ch/members_experts/refdocs. The main document types developed by IEC are described in greater detail at <http://www.iec.ch/standardsdev/publications>.

The committee has decided that the contents of this document will remain unchanged until the stability date indicated on the IEC website under webstore.iec.ch in the data related to the specific document. At this date, the document will be

- reconfirmed,
- withdrawn,
- replaced by a revised edition, or
- amended.

IECNORM.COM : Click to view the full PDF of IEC 60384-25:2021 RLV

FIXED CAPACITORS FOR USE IN ELECTRONIC EQUIPMENT –

Part 25: Sectional specification – Fixed aluminium electrolytic surface mount capacitors with conductive polymer solid electrolyte

1 Scope

This part of IEC 60384 applies to fixed aluminium electrolytic surface mount capacitors with conductive polymer solid electrolyte, primarily intended for DC applications for use in electronic equipment.

Fixed aluminium electrolytic surface mount capacitors with solid (MnO_2) are not included but are covered by IEC 60384-18.

These capacitors are primarily intended for use in electronic equipment to be mounted directly on substrates for hybrid circuits or to printed boards.

Capacitors for special-purpose applications can need additional requirements.

The object of this document is to prescribe preferred ratings and characteristics and to select from IEC 60384-1:2016, the appropriate quality assessment procedures, tests and measuring methods and to give general performance requirements for this type of capacitor.

2 Normative references

The following documents are referred to in the text in such a way that some or all of their content constitutes requirements of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

IEC 60063, *Preferred number series for resistors and capacitors*

IEC 60068-1:2013, *Environmental testing – Part 1: General and guidance*

IEC 60384-1:2016, *Fixed capacitors for use in electronic equipment – Part 1: Generic specification*

IEC 61193-2:2007, *Quality assessment systems – Part 2: Selection and use of sampling plans for inspection of electronic components and packages*

3 Terms and definitions

For the purposes of this document, the terms and definitions given in IEC 60384-1:2016 and the following apply.

ISO and IEC maintain terminological databases for use in standardization at the following addresses:

- IEC Electropedia: available at <http://www.electropedia.org/>
- ISO Online browsing platform: available at <http://www.iso.org/obp>

3.1

capacitance

<electrolytic capacitor> capacitance of an equivalent circuit whose capacitance and resistance in series is measured with an alternating current having an approximately sinusoidal waveform at a specified frequency

4 Preferred ratings and characteristics

4.1 Preferred characteristics

Preferred climatic categories only shall be given in the preferred characteristics.

The capacitors covered by this sectional specification are classified into categories in accordance with the general rules given in IEC 60068-1:2013, Annex A.

The lower and upper category temperatures shall be taken from the following:

- lower category temperature: $-55\text{ }^{\circ}\text{C}$;
- upper category temperature: $+105\text{ }^{\circ}\text{C}$ and $+125\text{ }^{\circ}\text{C}$.

The severities for the cold and dry heat tests are the lower and upper category temperatures respectively.

4.2 Preferred values of ratings

4.2.1 Nominal capacitance (C_N)

Preferred values of nominal capacitance are indicated in microfarad (μF).

Preferred values of nominal capacitance shall be taken from the E 12 series of IEC 60063 as follows:

1,0 – 1,2 – 1,5 – 1,8 – 2,2 – 2,7 – 3,3 – 3,9 – 4,7 – 5,6 – 6,8 – 8,2;

and their decimal multiples ($\times 10^n$, n : integer).

4.2.2 Tolerance on nominal capacitance

Preferred value of tolerance on nominal capacitance is:

$\pm 20\text{ } \%$.

4.2.3 Rated voltage (U_R)

The preferred values of rated DC voltages taken from the R10 and R20 series of ISO 3 are:

- from R 10: 1,0 – 1,25 – 1,6 – 2,0 – 2,5 – 3,15 – 4,0 – 5,0 – 6,3 – 8,0;
- from R 20: 3,5¹ – 4,5;
- and their decimal multiples ($\times 10^n$, n : integer).

4.2.4 Category voltage (U_C)

The category voltage is equal to the rated voltage.

¹ ISO 3 indicates the value 3,55 for R20.

4.2.5 Surge voltage (U_{RS})

The surge voltage shall be 1,15 times the rated or category voltage rounded off to the nearest volt (two significant digits) (see Table 1 and Table 2).

Table 1 – Surge voltages

Values in volts

Rated voltage	2,0	2,5	4,0	5,0	6,3	8,0	10	12,5	16	20	25	35	50
Surge voltage	2,3	2,9	4,6	5,8	7,2	9,2	12	14	18	23	29	40	58

4.2.6 Rated temperature

The value of the rated temperature is +105 °C and +125 °C.

5 Test and measurement procedures

5.1 General

Test severities and requirements prescribed in detail specifications referring to this sectional specification are of equal or higher performance level, because lower performance levels are not permitted.

This clause supplements the information given in IEC 60384-1:2016, Clause 4.

5.2 Preliminary drying

See IEC 60384-1:2016, 4.3.

5.3 Measuring conditions

See IEC 60384-1:2016, 4.2.1.

5.4 Mounting

5.4.1 General

See IEC 60384-1:2016, 4.33, with 5.4.2 to 5.4.4 of this document.

5.4.2 Initial inspections

See Table 3.

5.4.3 Test conditions

The test method shall be the reflow method and reflow temperature profile specified in the detail specification.

5.4.4 Final inspections and requirements

See Table 3.

5.5 Visual examination and check of dimensions

5.5.1 General

See IEC 60384-1:2016, 4.4, with 5.5.2 and 5.5.3 of this document.

5.5.2 Visual examination and check of dimensions

Visual examination shall be carried out with suitable equipment with approximately 10× magnification and lighting appropriate to the specimen under test and the quality level required. The operator should have available facilities for incident or transmitted illumination, as well as an appropriate measuring facility. The capacitors shall be examined to verify that the materials, design, construction, and physical dimensions are appropriate.

5.5.3 Requirements

The workmanship shall be in accordance with the applicable requirements given in the detail specification.

5.6 Electrical tests

5.6.1 Leakage current

5.6.1.1 General

See IEC 60384-1:2016, 4.9, with 5.6.1.2 to 5.6.1.4 of this document.

5.6.1.2 Pre-conditioning

If the leakage current of the capacitor increases, the following processing can be performed as pre-conditioning.

The capacitor should be serially attached to a protective resistor ranging from 10 Ω to 1 000 Ω and DC voltage equivalent to the rated voltage should be applied for 2 h at 105 °C $\pm$ 2 °C. Applied voltage to the capacitors shall be maintained within ± 3 % of the rated voltage.

Next, after letting the capacitor cool to room temperature, it should be discharged through a resistor of approximately 1 Ω /V and then stored at standard atmospheric conditions for 12 h to 24 h.

5.6.1.3 Measuring conditions

The rated voltage shall be applied across the capacitor and its protective resistor placed in series with the capacitor to limit the charging current.

The protective resistor shall have a value of 1 000 Ω .

The measurement of each test should be carried out after pre-conditioning.

5.6.1.4 Requirements

See Table 3.

5.6.2 Capacitance

5.6.2.1 General

See IEC 60384-1:2016, 4.7, with 5.6.2.2 and 5.6.2.3 of this document.

5.6.2.2 Measuring conditions

Unless otherwise specified in the detail specifications, the capacitance shall be measured at a frequency of 120 Hz.

The peak alternating voltage actually applied across the capacitor terminations shall not exceed 0,5 V (RMS).

A DC bias voltage of 0,7 V to 1,0 V may be applied during the measurement to avoid negative voltage application to the capacitor by the applied AC voltage.

The inaccuracy of the measuring instruments shall not exceed $\pm 2\%$ of the limit specified in the detail specification, whether this is given as an absolute value or as a change of capacitance.

5.6.2.3 Requirements

See Table 3.

5.6.3 Tangent of loss angle ($\tan \delta$)

5.6.3.1 General

See IEC 60384-1:2016, 4.8.1, with 5.6.3.2 and 5.6.3.3 of this document.

5.6.3.2 Measuring conditions

The measurement shall be made under the conditions as specified in 5.6.2.

The inaccuracy of the measuring equipment shall not exceed 0,01 absolute value.

5.6.3.3 Requirements

See Table 3.

5.6.4 Equivalent series resistance (ESR) (if required)

5.6.4.1 General

See IEC 60384-1:2016, 4.8.2, with 5.6.4.2 and 5.6.4.3 of this document.

5.6.4.2 Measuring conditions

Unless otherwise specified in the detail specifications, test conditions are as follows:

- temperature: $20\text{ °C} \pm 2\text{ °C}$;
- applied voltage: peak AC value $\leq 0,5\text{ V (RMS)}$;
- voltage frequency: $100\text{ kHz} \pm 10\text{ kHz}$;

The error of measurement shall not exceed 5 % of the requirement, or 0,02 Ω , whichever is greater.

5.6.4.3 Requirements

See Table 3.

5.6.5 Impedance (if required)

5.6.5.1 General

See IEC 60384-1:2016, 4.10, with 5.6.5.2 and 5.6.5.3 of this document.

5.6.5.2 Measuring conditions

The frequency of measurement: 120 Hz, with a tolerance of $\pm 10\%$.

Measurement voltage should be set sufficiently low, and the change of impedance value should be in the range of measurement error when the voltage is applied to capacitors for 1 min.

The error of measurement shall not exceed 5 % of the requirement, or 0,02 Ω , whichever is greater.

5.6.5.3 Requirements

See Table 3.

5.7 Resistance to soldering heat

5.7.1 General

See IEC 60384-1:2016, 4.14, with 5.7.2 to 5.7.5 of this document, unless otherwise specified in the detail specification.

5.7.2 Initial inspections

See Table 3.

5.7.3 Test conditions

The test method shall be the reflow method, and the reflow temperature profile shall be specified in the detail specification.

5.7.4 Recovery

The recovery period shall be 24 h $\pm$ 2 h.

5.7.5 Final inspections and requirements

After recovery, the surface mount capacitors shall be visually examined under normal lighting and approximately 10 $\times$ magnification and the measured electrical characteristics given in Table 3.

5.8 Solderability

5.8.1 General

See IEC 60384-1:2016, 4.15, with 5.8.2 of this document.

5.8.2 Final inspections and requirements

See Table 3.

5.9 Shear test (if required)

See IEC 60384-1:2016, 4.34.

5.10 Substrate bending test (if required)

5.10.1 General

See IEC 60384-1:2016, 4.35, with 5.10.2 to 5.10.4 of this document.

5.10.2 Initial inspections

See Table 3.

5.10.3 Test conditions

Deflection D and the number of bends shall be specified in the detail specification.

5.10.4 Final inspections and requirements

See Table 3.

5.11 Rapid change of temperature

5.11.1 General

See IEC 60384-1:2016, 4.16, with 5.11.2 to 5.11.5 of this document:

The capacitors shall be mounted in accordance with 5.4.

5.11.2 Initial inspections

See Table 3.

5.11.3 Test conditions

Test conditions are as follows:

- T_A = lower category temperature;
- T_B = upper category temperature;
- the capacitors shall be tested for 5 cycles;
- the duration of the exposure at each temperature limit shall be 30 min.

5.11.4 Recovery

The recovery period shall be 1 h to 2 h.

5.11.5 Final inspections and requirements

See Table 3.

5.12 Climatic sequence

5.12.1 General

See IEC 60384-1:2016, 4.21, with 5.12.2 to 5.12.8 of this document.

5.12.2 Initial inspections

See Table 3.

5.12.3 Dry heat

See IEC 60384-1:2016, 4.21.3, with the following details:

- temperature: upper category temperature;
- duration: 16 h.

5.12.4 Damp heat, cyclic, Test Db, first cycle

See IEC 60384-1:2016, 4.21.4.

5.12.5 Cold

See IEC 60384-1:2016, 4.21.5, with the following details:

- temperature: lower category temperature;
- duration: 2 h.

5.12.6 Damp heat, cyclic, Test Db, remaining cycles

See IEC 60384-1:2016, 4.21.7.

5.12.7 Recovery

The recovery period shall be 1 h to 2 h.

5.12.8 Final inspections and requirements

See Table 3.

5.13 Damp heat, steady state

5.13.1 General

See IEC 60384-1:2016, 4.22, with 5.13.2 to 5.13.5 of this document:

The capacitors shall be mounted in accordance with 5.4.

5.13.2 Initial inspections

See Table 3.

5.13.3 Test conditions

Test conditions are as follows:

- temperature: $40\text{ °C} \pm 2\text{ °C}$;
- relative humidity: $(93 \pm 3)\%$;
- applied voltage: No voltage shall be applied;
- duration: 21 days.

5.13.4 Recovery

The recovery period shall be 1 h to 2 h.

5.13.5 Final inspections and requirements

See Table 3.

5.14 Characteristics at high and low temperature

5.14.1 General

See IEC 60384-1:2016, 4.29, with 5.14.2 of this document:

The capacitors shall be mounted in accordance with 5.4.

5.14.2 Inspections and requirements

The capacitors shall be measured at each temperature step and shall meet the requirements given in Table 3.

5.15 Surge voltage

5.15.1 General

See IEC 60384-1:2016, 4.26, with 5.15.2 to 5.15.5 of this document.

5.15.2 Initial inspections

See Table 3.

5.15.3 Test conditions

Test conditions are as follows:

- number of cycles: 1 000;
- temperature: 15 °C to upper category temperature with the applicable requirements given in the detail specification;
- voltage: 1,15 U_R or 1,15 U_C ;
- charge resistor: 1 000 $\Omega \pm 100 \Omega$ or a value calculated by Formula (1);

$$RC = 0,1 \pm 0,05 \text{ (s)} \quad (1)$$

Where

If the internal resistance of the power supply is negligibly smaller than 1 000 Ω , R is equal to the resistance of the charging circuit. If the internal resistance of the power supply affects the charging resistance of the circuit, the current value possibly gets too small to measure correctly. On the other hand, if the time constant is 0,1 s and the capacitance is 1 000 μF , the R value is 100 Ω . Since an excessive inrush current then flows depending on the applied voltage, it is not possible to distinguish whether a defect, even if it occurs, is caused by the inrush current or the surge. Therefore, either of the two conditions above should be selectable depending on the situation at measurement.

R is the sum of the internal resistance of the power supply and resistance of the charge circuit (Ω).

C is the value of nominal capacitance (F)

$R(\Omega)$ is the sum of the internal resistance of the power supply and resistance of the charge circuit

$C(\text{F})$ is the value of nominal capacitance;

- duration of charge: 30 s;
- duration of no-load: 5 min 30 s.

5.15.4 Recovery

The recovery period shall be 1 h to 2 h.

5.15.5 Final inspections and requirements

See Table 3.

5.16 Endurance

5.16.1 General

See IEC 60384-1:2016, 4.23, with 5.16.2 to 5.16.5 of this document:

The capacitors shall be mounted in accordance with 5.4.

5.16.2 Initial inspections

See Table 3.

5.16.3 Test conditions

Test conditions are as follows:

- applied voltage: rated voltage, unless otherwise specified in the detail specification;
- temperature: upper category temperature;
- duration: 1 000 h.

5.16.4 Recovery

The recovery period shall be 1 h to 2 h.

5.16.5 Final inspections and requirements

See Table 3.

5.17 Storage at high temperature

5.17.1 General

See IEC 60384-1:2016, 4.25.1, with 5.17.2 to 5.17.5 of this document.

5.17.2 Initial inspections

See Table 3.

5.17.3 Test conditions

Test conditions are as follows:

- temperature: upper category temperature;
- duration: 96 h $\pm$ 4 h.

5.17.4 Recovery

The minimum recovery period shall be 16 h.

5.17.5 Final inspections and requirements

See Table 3.

5.18 Charge and discharge (if required)

5.18.1 General

See IEC 60384-1:2016, 4.27, with 5.18.2 to 5.18.4 of this document.

5.18.2 Initial inspections

See Table 3.

5.18.3 Test conditions

Charge and discharge shall be performed up to the specified cycles at the temperature (within the ambient temperature range of 15 °C to the upper category temperature) specified in the detail specification.

The capacitors shall be subjected to the specified number of cycles, each cycle consisting of a charge in accordance with a), followed by a discharge in accordance with b).

a) Charge:

- applied voltage: rated direct voltage;
- internal resistance of the voltage source plus external series resistor: as required for $RC = 0,1$ s;
- duration: 0,5 s;
- number of cycles: 10^6 .

b) Discharge:

- no voltage applied;
- discharge resistor: as required for $RC = 0,1$ s;
- duration: 0,5 s;
- number of cycles: 10^6 .

5.18.4 Final inspections and requirements

See Table 3.

5.19 Component solvent resistance (if required)

See IEC 60384-1:2016, 4.31.

5.20 Solvent resistance of marking (if required)

See IEC 60384-1:2016, 4.32.

5.21 High surge current (if required)

5.21.1 General

See IEC 60384-1:2016, 4.39, with 5.21.2 of this document.

5.21.2 Final inspections and requirements

See Table 3.

6 Marking

6.1 General

See IEC 60384-1:2016, 2.4, with 6.2 to 6.4 of this document.

6.2 Information for marking

Information given in the marking is normally selected from the following list; the relative importance of each item is indicated by its position in the list:

- a) polarity of the terminations (unless identified by the construction);
- b) nominal capacitance;
- c) rated voltage (DC voltage may be indicated by the symbol: $\equiv$ (IEC 60417-5031-2002-10) or —);
- d) category temperature;
- e) tolerance on nominal capacitance;
- f) year and month (or, year and week) of manufacture;
- g) manufacturer's name and/or trademark;
- h) manufacturer's type designation;
- i) reference to the detail specification.

6.3 Marking on capacitors

Polarity of the terminations shall be marked. Other elements are marked, as necessary.

Any marking shall be legible and not easily smeared or removed by rubbing with fingers.

6.4 Marking on packaging

The packaging containing the capacitors should be clearly marked with the information listed in 6.2 as necessary.

7 Information to be given in a detail specification

7.1 General

Detail specifications shall be derived from the blank detail specification.

Detail specifications shall not specify requirements inferior to those of the generic, sectional or blank detail specification. When more severe requirements are included, they shall be listed in 1.9 of the detail specification and indicated in the test schedules, for example, by an asterisk.

The information given in 7.2 may, for convenience, be presented in tabular form.

The following information shall be given in each detail specification and the values quoted shall preferably be selected from those given in the appropriate clause of this sectional specification.

7.2 Outline drawing and dimensions

There shall be an illustration of the capacitors as an aid to easy recognition and for comparison of the capacitors with others.

Dimensions and their associated tolerances, which affect interchangeability and mounting, shall be given in the detail specification. All dimensions shall be stated in millimetres; when the original dimensions are given in inches, the converted metric dimensions in millimetres shall be added.

The numerical values of the body shall be given as follows:

- for general: width, length and height.
- for cylindrical body: diameter and length.

The numerical values of the terminals shall be given as follows:

- for terminals: width, length and spacing.

When the configuration is other than described above, the detail specification shall state such dimensional information as will adequately describe the capacitor.

7.3 Mounting

The method of mounting for tests and measurements are given in 5.4. The detail specification shall specify the methods of mounting for normal use.

7.4 Ratings and characteristics

7.4.1 General

The ratings and characteristics shall be given in accordance with the relevant subclauses of this sectional specification, including the items specified in 7.4.2 to 7.4.4.

7.4.2 Nominal capacitance range

See 4.2.1.

When products approved to the detail specification have different nominal capacitance ranges, the following statement should be added:

“The nominal capacitance range available in each voltage range is given in the register of approvals, available for example on the IECQ on-line certificate system website www.iecq.org”.

7.4.3 Particular characteristics

Additional characteristics may be listed when they are considered necessary to specify adequately the component for design and application purposes.

7.4.4 Soldering

The detail specification shall specify the test methods, severities and requirements applicable for the solderability and the resistance to soldering heat tests.

7.5 Marking

The detail specification shall specify the content of the marking on the capacitor and on the packaging.

When there are deviations from Clause 6, these shall be given in the detail specification.

8 Quality assessment procedures

8.1 Primary stage of manufacture

The primary stage of manufacture is the capacitor manufacturer's evaluation of the formed anode foil.

8.2 Structurally similar components

Capacitors, considered as being structurally similar, produced with similar are capacitors produced with similar processes and materials, though they may be of different case sizes and values.

8.3 Certified test records of released lots

The information required in IEC 60384-1:2016, Q.1.5, shall be made available when prescribed in the detail specification and when requested by a purchaser. After the endurance test, the required parameters are the capacitance change, tangent of loss angle, equivalent series resistance, and leakage current.

8.4 Qualification approval (QA) procedures

8.4.1 General

The procedures for qualification approval testing are given in IEC 60384-1:2016, Q.2.

The schedule to be used for qualification approval testing on the basis of lot-by-lot and periodic tests is given in 8.5. The procedure using a fixed sample size schedule is given in 8.4.2 and 8.4.3.

8.4.2 Qualification approval on the basis of the fixed sample size procedure

The fixed sample size procedure is described in IEC 60384-1:2016, Q.2.4. The sample shall be representative of the range of capacitors for which approval is sought. The range of approval may be the whole or the part of the range given in the detail specification.

The sample shall consist of four specimens having the maximum and minimum rated voltages and, for these voltages, the maximum and minimum case size. When there are more than four case sizes, an intermediate case size shall also be tested. In each of these case size/voltage combinations (values), the maximum capacitance shall be chosen. Thus, for the approval of a range, testing is required for either four or six values. When the range consists of fewer than four values, the number of specimens to be tested shall be that required for four values.

Two (for 6 values) or three (for 4 values) specimens per value may be used as replacements for specimens, that are non-conforming because of incidents not attributable to the manufacturer.

The numbers given in Group 0 assume that all groups are applicable. If this is not so, the numbers may be reduced accordingly.

When additional groups are introduced into the qualification approval test schedule, the number of specimens required for Group 0 shall be increased by the same number as that required for the additional groups.

Table 2 gives the number of samples to be tested in each group or subgroup together with the number of permissible non-conformances for qualification approval test.

8.4.3 Tests

The complete series of tests specified in Table 2 and Table 3 are required for the approval of capacitors covered by a detail specification. The tests of each group shall be carried out in the order given.

The whole sample shall be subjected to the tests of Group 0 and then divided for the other groups.

Specimens found to be non-conforming in the tests of Group 0 shall not be used for the other groups.

Approval is granted when the number of non-conforming items is zero.

Table 2 and Table 3 together form the fixed sample size test schedule for the qualification approval on the basis of the fixed sample size procedure.

Table 2 gives the number of the samples and permissible non-conforming items for each test or test group.

Table 3 gives a summary of the test conditions and performance requirements, and when a choice shall be made in the detail specification.

The test conditions and performance requirements for the qualification approval on the basis of the fixed sample size procedure should be identical to those for quality conformance inspection given in the detail specification.

IECNORM.COM : Click to view the full PDF of IEC 60384-25:2021 RLV

Table 2 – Sampling plan for qualification approval, assessment level EZ

Group no.	Test	Subclause	Number of specimens n^d	Permissible number of non-conforming items c^g
0	High surge current ^c	5.21	120+12 ^f	0
	Visual examination	5.5		
	Dimensions	5.5		
	Leakage current	5.6.1		
	Capacitance	5.6.2		
	Tangent of loss angle	5.6.3		
	Equivalent series resistance ^c	5.6.4		
	Spare specimens			
	1A Resistance to soldering heat	5.7	12	0
	Component solvent resistance ^c	5.19		
	1B Solderability	5.8	12	0
	Solvent resistance of the marking ^c	5.20		
	2 Substrate bending test ^e	5.10	12	0
	3 ^a Mounting	5.4	84	0 ^b
	Visual examination	5.5		
	Leakage current	5.6.1		
	Capacitance	5.6.2		
	Tangent of loss angle	5.6.3		
	Equivalent series resistance ^c	5.6.4		
	3.1 Shear test ^c	5.9		
	Rapid change of temperature	5.11		
	Climatic sequence	5.12		
	3.2 Damp heat, steady state	5.13	12	0
	3.3 Characteristics at high and low temperature	5.14	12	0
	Charge and discharge ^c	5.18		
	3.4 Endurance	5.16	36	0
	3.5 Storage at high temperature	5.17	12	0
	Surge voltage	5.15		

^a The values of these measurements serve as initial measurements for the tests of Group 3.

^b The capacitors found non-conforming after mounting shall not be taken into account when calculating the non-conforming items for the following tests. They shall be replaced by spare capacitors.

^c If required.

^d For case size/voltage combinations, see 8.4.2.

^e Not applicable to capacitors, which shall be mounted on alumina substrates only, according to their detail specification.

^f Spare specimens.

^g This is the acceptance number, which is not to be exceeded for acceptance.

Table 3 – Test schedule for qualification approval (1 of 6)

Subclause number and test ^a , inspection items	D or ND ^b	Conditions of test ^a , and measurements	Number of specimens (<i>n</i>) and permissible number of non-conforming items (<i>c</i>)	Performance requirements ^a
GROUP 0	ND		See Table 2	
5.21 High surge current ^e		See IEC 60384-1:2016, 4.39		See detail specification
5.5 Dimension (detail)		See 5.5.2		See detail specification
5.5.2 Visual examination		See 5.5.2		Legible marking and as specified in detail specification
5.6.1 Leakage current		See 5.6.1.2 and 5.6.1.3		$\leq 0,2 \text{ C}_{NCR}$ or 500 μA , whichever is greater (at $20^\circ\text{C} \pm 2^\circ\text{C}$) ^d
5.6.2 Capacitance		See 5.6.2.2		See detail specification
5.6.3 Tangent of loss angle ($\tan \delta$)		See 5.6.3.2		See detail specification
5.6.4 Equivalent series resistance ^e		See 5.6.4.2		See detail specification
GROUP 1A	D		See Table 2	
5.7 Resistance to soldering heat		See 5.7.3		
5.7.2 Initial inspections				
Capacitance		See 5.6.2.2		
5.7.4 Recovery		See 5.7.4		
5.7.5 Final inspections				
Visual examination		See 5.5.2		There shall be no signs of damage
Leakage current		See 5.6.1.2 and 5.6.1.3		See detail specification
Capacitance		See 5.6.2.2		See detail specification
Tangent of loss angle		See 5.6.3.2		See detail specification
Equivalent series resistance ^e		See 5.6.4.2		See detail specification
5.19 Component solvent resistance ^e		See IEC 60384-1:2016, 4.31		See IEC 60384-1:2016, 4.31

Table 3 (2 of 6)

Subclause number and test ^a , inspection items	D or ND ^b	Conditions of test ^a , and measurements	Number of specimens (<i>n</i>) and permissible number of non-conforming items (<i>c</i>)	Performance requirements ^a
GROUP 1B 5.8 Solderability 5.8.2 Final inspections Visual examination 5.20 Solvent resistance of the marking ^{c,e}	D	See IEC 60384-1:2016, 4.15 See 5.5.2 See IEC 60384-1:2016, 4.32	See Table 2	No signs of damage. Areas to be soldered shall be covered with a new solder coating with no more than a small number of scattered imperfections such as pinholes or un-wetted or de-wetted areas. These imperfections shall not be concentrated in one area. Areas in which plating does not exist, such as tip of the terminal, shall not be evaluated. See IEC 60384-1:2016, 4.32
GROUP 2 5.10 Substrate bending test ^e 5.10.2 Initial inspections Capacitance 5.10.4 Final inspections Visual examination Change of capacitance	D	See 5.10.3 See 5.6.2.2 See 5.5.2 See 5.6.2.2	See Table 2	No visible damage See detail specification
GROUP 3 5.4 Mounting 5.4.2 Initial inspections Capacitance 5.4.4 Final inspections Visual examination Leakage current Capacitance Tangent of loss angle Equivalent series resistance ^e	D	See 5.4.3 See 5.6.2.2 See 5.5.2 See 5.6.1.2 and 5.6.1.3 See 5.6.2.2 See 5.6.3.2 See 5.6.4.2	See Table 2	No visible damage $\leq 0,2 C_N U_R$ or 500 μA , whichever is greater (at 20 °C $\pm$ 2 °C) ^d See detail specification See detail specification See detail specification

Table 3 (3 of 6)

Subclause number and test ^a , inspection items	D or ND ^b	Conditions of test ^a , and measurements	Number of specimens (<i>n</i>) and permissible number of non-conforming items (<i>c</i>)	Performance requirements ^a
GROUP 3.1	D		See Table 2	
5.9 Shear test ^e		See IEC 60384-1:2016, 4.34		
5.11 Rapid change of temperature		See 5.11.3		
5.11.2 Initial inspections				
Capacitance		See 5.6.2.2		
5.11.4 Recovery		See 5.11.4		
5.11.5 Final inspections				
Leakage current		See 5.6.1.2 and 5.6.1.3		≤ initial limit
Capacitance		See 5.6.2.2		$ \Delta C/C \leq 10\%$ of the value measured in 5.11.2
Tangent of loss angle		See 5.6.3.2		≤ initial limit
5.12 Climatic sequence		See IEC 60384-1:2016, 4.21		
5.12.2 Initial inspections				
Capacitance		See 5.6.2.2		
5.12.3 Dry heat		See 5.12.3		
5.12.4 Damp heat, cyclic, test Db, first cycle		See IEC 60384-1:2016, 4.21.4		
5.12.5 Cold		See 5.12.5		
5.12.6 Damp heat, cyclic, test Db, remaining cycles		See IEC 60384-1:2016, 4.21.7		
5.12.7 Recovery		See 5.12.7		
5.12.8 Final inspections				
Visual examination		See 5.5.2		No visible damage
Capacitance		See 5.6.2.2		Legible marking
Leakage current		See 5.6.1.2 and 5.6.1.3		$ \Delta C/C \leq 20\%$ of the value measured in 5.12.2
Tangent of loss angle		See 5.6.3.2		≤ initial limit
				≤ 1,5 times the initial limit

Table 3 (4 of 6)

Subclause number and test ^a , inspection items	D or ND ^b	Conditions of test ^a , and measurements	Number of specimens (<i>n</i>) and permissible number of non-conforming items (<i>c</i>)	Performance requirements ^a
GROUP 3.2 5.13 Damp heat, steady state 5.13.2 Initial inspections Capacitance 5.13.4 Recovery 5.13.5 Final inspections Visual examination Leakage current Capacitance Tangent of loss angle	D	See 5.13.3 See 5.6.2.2 See 5.13.4 See 5.5.2 See 5.6.1.2 and 5.6.1.3 See 5.6.2.2 See 5.6.3.2	See Table 2	No visible damage Legible marking ≤ 5 times initial limit See detail specification $\leq 1,5$ times the initial limit
GROUP 3.3 5.14 Characteristics at high and low temperature Step 1: 20 °C Capacitance Impedance ^e Step 2: lower category temperature Capacitance Impedance ^e Tangent of loss angle (if required) Step 3: upper category temperature Leakage current Capacitance Tangent of loss angle (if required)	D	See IEC 60384-1:2016, 4.29 See 5.6.2.2 See 5.6.5.2 See 5.6.2.2 See 5.6.5.2 See 5.6.3.2 See 5.6.1.2 and 5.6.1.3 See 5.6.2.2 See 5.6.3.2	See Table 2	 $ \Delta C/C \leq 20$ % of the value measured in step 1 Ratio with respect to value in step 1: $\leq 1,5$ times ≤ 2 times the initial limit At 105 °C (with U_R): $\leq 12,5$ times the limit of 5.6.1 $ \Delta C/C \leq 20$ % of the value measured in step 1 At $U_R \leq 4$: ≤ 3 times the initial limit At $U_R > 4$: ≤ 2 times the initial limit

Table 3 (5 of 6)

Subclause number and test ^a , inspection items	D or ND ^b	Conditions of test ^a , and measurements	Number of specimens (<i>n</i>) and permissible number of non-conforming items (<i>c</i>)	Performance requirements ^a
5.18 Charge and discharge ^e 5.18.2 Initial inspections Capacitance 5.18.4 Final inspections Visual examination Leakage current Capacitance Tangent of loss angle Equivalent series resistance ^e	D	See 5.18.3 See 5.6.2.2 See 5.5.2 See 5.6.1.2 and 5.6.1.3 See 5.6.2.2 See 5.6.3.2 See 5.6.4.2	See Table 2	No visible damage Legible marking $\leq$ initial limit $ \Delta C/C \leq 20$ % of the value measured in 5.18.2 $\leq 1,5$ times the initial limit ≤ 2 times the initial limit
GROUP 3.4 5.16 Endurance 5.16.2 Initial inspections Capacitance 5.16.4 Recovery 5.16.5 Final inspections Visual examination Leakage current Capacitance Tangent of loss angle Equivalent series resistance ^e	D	See 5.16.3 See 5.6.2.2 See 5.16.4 See 5.5.2 See 5.6.1.2 and 5.6.1.3 See 5.6.2.2 See 5.6.3.2 See 5.6.4.2	See Table 2	No visible damage Legible marking ≤ 2 times the initial limit $ \Delta C/C \leq 20$ % of the value measured in 5.16.2 $\leq 1,5$ times the initial limit ≤ 2 times the initial limit

Table 3 (6 of 6)

Subclause number and test ^a , inspection items	D or ND ^b	Conditions of test ^a , and measurements	Number of specimens (<i>n</i>) and permissible number of non-conforming items (<i>c</i>)	Performance requirements ^a
GROUP 3.5	D		See Table 2	
5.17 Storage at high temperature		See 5.17.3		
5.17.2 Initial inspections				
Capacitance		See 5.6.2.2		
5.17.4 Recovery		See 5.17.4		
5.17.5 Final inspections				
Visual examination		See 5.5.2		No visible damage Legible marking
Leakage current		See 5.6.1.2 and 5.6.1.3		≤ 2 times the initial limit
Capacitance		See 5.6.2.2		$ \Delta C/C \leq 10\%$ of the value measured in 5.17.2
Tangent of loss angle		See 5.6.3.2		≤ initial limit
5.15 Surge voltage		See 5.15.3		
5.15.2 Initial inspections				
Capacitance		See 5.6.2.2		
5.15.4 Recovery		See 5.15.4		
5.15.5 Final inspections				
Visual examination		See 5.5.2		No visible damage
Leakage current		See 5.6.1.2 and 5.6.1.3		≤ initial limit
Capacitance		See 5.6.2.2		$ \Delta C/C \leq 15\%$ of the value measured in 5.15.2
Tangent of loss angle		See 5.6.3.2		≤ 1,5 times the initial limit
^a Subclause numbers of test and performance requirements refer to Clause 5. ^b In this table: D = destructive, ND = non-destructive. ^c This test may be carried out on surface mount capacitors mounted on a substrate. ^d C_N = nominal capacitance in microfarad; U_R = rated voltage in volt. ^e If required.				

8.5 Quality conformance inspections

8.5.1 Formation of inspection lots

8.5.1.1 Groups A and B inspection

These tests shall be carried out on a lot-by-lot basis.

A manufacturer may aggregate the current production into inspection lots subject to the following safeguards.

- a) The inspection lot shall consist of structurally similar capacitors (see 8.2).
- b) The sample tested shall be representative of the values (rated voltage and nominal capacitance) and dimensions contained in the inspection lot:
 - in relation to their number;
 - with a minimum of five of any one value.
- c) If there are fewer than five of any one value in the sample, the basis for the drawing of samples shall be agreed between the manufacturer and the certification body (CB).

8.5.1.2 Group C inspections

These tests shall be carried out on a periodic basis.

Samples shall be representative of the current production of the specified periods and shall be divided into high-, medium- and low-voltage ratings. In order to cover the range of approvals in any period, one case size shall be tested from each voltage group. In subsequent periods, other case sizes and/or voltage ratings in production shall be tested with the aim of covering the whole range.

8.5.2 Test schedule

The test schedule for the lot-by-lot and periodic tests for quality conformance inspection is given in the blank detail specification.

8.5.3 Delayed delivery

When, in accordance with the procedures of IEC 60384-1:2016, Q.1.7, re-inspection should be made, capacitance, tangent of loss angle, leakage current and solderability shall be checked as specified in Groups A and B inspection.

8.5.4 Assessment levels

The assessment levels given in the blank detail specification shall be selected from Table 4 and Table 5 as assessment level EZ.

Table 4 – Lot-by-lot inspection

Inspection subgroup ^a	EZ		
	IL ^b	<i>n</i> ^b	<i>c</i> ^b
A0	100 % ^c		
A1	S – 3	<i>d</i>	0
A2	S – 3	<i>d</i>	0
B1	S – 3	<i>d</i>	0

^a The content of the inspection subgroup is described in Clause 2 of the blank detail specification.

^b IL = inspection level
n = sample size
c = permissible number of non-conforming items

^c After removal of nonconforming items by 100 % testing during the manufacturing process, sampling inspection shall be performed in order to monitor outgoing quality level by nonconforming items per million ($\times 10^{-6}$). The sampling level shall be established by the manufacture in accordance with IEC 61193-2:2007, Annex A. In the case where one or more nonconforming items occur in a sample, this lot shall be rejected, but the whole sample shall be inspected and all nonconforming items shall be counted for the calculation of quality level values. Outgoing quality level by nonconforming items per million ($\times 10^{-6}$) values shall be calculated by accumulating inspection data in accordance with the method given in IEC 61193-2:2007, 6.2.

^d Number to be tested: Sample size shall be determined in accordance with IEC 61193-2:2007, 4.3.2.

Table 5 – Periodic inspection

Inspection subgroup ^a	EZ		
	p^b	n^b	c^b
C1	3	12	0
C2	3	12	0
C3.1	6	12	0
C3.2	6	24	0
C3.3A	6	12	0
C3.3B	6	12	0
C3.4	3	36	0
C3.5	6	12	0

^a The content of the inspection subgroup is described in Clause 2 of the blank detail specification.

^b p = periodicity in months

n = sample size

c = permissible number of non-conforming items

IECNORM.COM : Click to view the full PDF of IEC 60384-25:2021 RLV

Annex X (informative)

Cross-references to the prior edition of this document

The revision of this sectional specification has resulted in a new structure. Table X.1 provides cross-references to specific elements of the prior edition of this sectional specification.

Table X.1 – Reference to IEC 60384-25 for clauses/subclauses and tables

IEC 60384-25:2015 (Edition 2.0) Clause/subclause	IEC 60384-25:2021 (Edition 3.0) Clause/subclause	Notes
1	-	This is covered by Clauses 1, 2, 3, 4, 6, 7.
1.1	1	The prior scope and object are merged into Clause 1
1.2		
1.3	2	-
1.4	7	-
1.4.1	7.1	-
1.4.2	7.2	-
1.4.3	7.3	-
1.4.4	7.4	-
1.4.4.1	7.4.1	-
1.4.4.2	7.4.2	-
1.4.4.3	7.4.3	-
1.4.4.4	7.4.4	-
1.4.5	7.5	-
1.5	3	
1.6	6	
1.6.1	6.1	
1.6.2	6.2	
1.6.3	6.3	
1.6.4	6.4	
2	4	Clause 2 is transferred to become Clause 4. Otherwise numbering kept unchanged.
3	8	Clause 3 is transferred to become Clause 8. Otherwise numbering kept unchanged.
4	5	Clause 4 is transferred to become Clause 5. Otherwise numbering kept unchanged.
Table 1	Table 1	-
Table 2	Table 2	-
Table 3	Table 3	-
Table 4	Table 4	-
Table 5	Table 5	-

Bibliography

IEC 60384-18, *Fixed capacitors for use in electronic equipment – Part 18: Sectional specification – Fixed aluminium electrolytic surface mount capacitors with solid (MnO₂) and non-solid electrolyte*

ISO 3, *Preferred numbers – Series of preferred numbers*

IECNORM.COM : Click to view the full PDF of IEC 60384-25:2021 RLV

IECNORM.COM : Click to view the full PDF of IEC 60384-25:2021 RLV

SOMMAIRE

AVANT-PROPOS	37
1 Domaine d'application	39
2 Références normatives	39
3 Termes et définitions	39
4 Valeurs assignées et caractéristiques préférentielles	40
4.1 Caractéristiques préférentielles	40
4.2 Valeurs préférentielles des caractéristiques assignées	40
4.2.1 Capacité nominale (C_N)	40
4.2.2 Tolérance sur la capacité nominale	40
4.2.3 Tension assignée (U_R)	40
4.2.4 Tension de catégorie (U_C)	41
4.2.5 Surtension (U_{RS})	41
4.2.6 Température assignée	41
5 Procédures d'essai et de mesure	41
5.1 Généralités	41
5.2 Préséchage	41
5.3 Conditions de mesure	41
5.4 Montage	41
5.4.1 Généralités	41
5.4.2 Inspections initiales	41
5.4.3 Conditions d'essai	42
5.4.4 Inspections finales et exigences	42
5.5 Examen visuel et contrôle des dimensions	42
5.5.1 Généralités	42
5.5.2 Examen visuel et contrôle des dimensions	42
5.5.3 Exigences	42
5.6 Essais électriques	42
5.6.1 Courant de fuite	42
5.6.2 Capacité	43
5.6.3 Tangente de l'angle de perte ($\tan \delta$)	43
5.6.4 Résistance-série équivalente (RSE) (si cela est exigé)	43
5.6.5 Impédance (si cela est exigé)	44
5.7 Résistance à la chaleur de brasage	44
5.7.1 Généralités	44
5.7.2 Inspections initiales	44
5.7.3 Conditions d'essai	44
5.7.4 Reprise	44
5.7.5 Inspections finales et exigences	44
5.8 Brasabilité	44
5.8.1 Généralités	44
5.8.2 Inspections finales et exigences	45
5.9 Essai de cisaillement (si cela est exigé)	45
5.10 Essai de pliage du substrat (si cela est exigé)	45
5.10.1 Généralités	45
5.10.2 Inspections initiales	45

5.10.3	Conditions d'essai	45
5.10.4	Inspections finales et exigences	45
5.11	Variations rapides de température	45
5.11.1	Généralités	45
5.11.2	Inspections initiales	45
5.11.3	Conditions d'essai	45
5.11.4	Reprise	45
5.11.5	Inspections finales et exigences	45
5.12	Séquence climatique	46
5.12.1	Généralités	46
5.12.2	Inspections initiales	46
5.12.3	Chaleur sèche	46
5.12.4	Chaleur humide, cyclique, Essai Db, premier cycle	46
5.12.5	Froid	46
5.12.6	Chaleur humide, cyclique, Essai Db, cycles restants	46
5.12.7	Reprise	46
5.12.8	Inspections finales et exigences	46
5.13	Chaleur humide, régime établi	46
5.13.1	Généralités	46
5.13.2	Inspections initiales	46
5.13.3	Conditions d'essai	47
5.13.4	Reprise	47
5.13.5	Inspections finales et exigences	47
5.14	Caractéristiques à hautes et basses températures	47
5.14.1	Généralités	47
5.14.2	Inspections et exigences	47
5.15	Surtension	47
5.15.1	Généralités	47
5.15.2	Inspections initiales	47
5.15.3	Conditions d'essai	47
5.15.4	Reprise	48
5.15.5	Inspections finales et exigences	48
5.16	Endurance	48
5.16.1	Généralités	48
5.16.2	Inspections initiales	48
5.16.3	Conditions d'essai	48
5.16.4	Reprise	48
5.16.5	Inspections finales et exigences	48
5.17	Stockage à haute température	48
5.17.1	Généralités	48
5.17.2	Inspections initiales	49
5.17.3	Conditions d'essai	49
5.17.4	Reprise	49
5.17.5	Inspections finales et exigences	49
5.18	Charge et décharge (si cela est exigé)	49
5.18.1	Généralités	49
5.18.2	Inspections initiales	49
5.18.3	Conditions d'essai	49
5.18.4	Inspections finales et exigences	49

5.19	Résistance du composant aux solvants (si cela est exigé)	49
5.20	Résistance du marquage aux solvants (si cela est exigé).....	50
5.21	Surintensités (si cela est exigé)	50
5.21.1	Généralités	50
5.21.2	Inspections finales et exigences	50
6	Marquage	50
6.1	Généralités	50
6.2	Informations pour le marquage.....	50
6.3	Marquage sur les condensateurs	50
6.4	Marquage sur l'emballage	50
7	Informations à spécifier dans une spécification particulière.....	50
7.1	Généralités	50
7.2	Dessin d'encombrement et dimensions	51
7.3	Montage	51
7.4	Valeurs assignées et caractéristiques	51
7.4.1	Généralités	51
7.4.2	Plage de capacités nominales	51
7.4.3	Caractéristiques particulières	52
7.4.4	Brasage	52
7.5	Marquage	52
8	Procédures d'assurance de la qualité	52
8.1	Étape initiale de fabrication.....	52
8.2	Composants de structure similaire	52
8.3	Enregistrements d'essais certifiés de lots livrés	52
8.4	Procédures d'homologation.....	52
8.4.1	Généralités	52
8.4.2	Homologation fondée sur la procédure avec un effectif d'échantillon fixe	52
8.4.3	Essais	53
8.5	Contrôles de conformité de la qualité	60
8.5.1	Formation des lots d'inspection	60
8.5.2	Programme d'essai	61
8.5.3	Remise différée	61
8.5.4	Niveaux d'assurance.....	61
Annexe X (informative) Référence croisée pour les références à la révision précédente du présent document.....		63
Bibliographie.....		64
Tableau 1 – Surtensions		41
Tableau 2 – Plan d'échantillonnage pour homologation – niveau d'assurance EZ		54
Tableau 3 – Programme d'essai pour homologation		55
Tableau 4 – Inspection lot par lot.....		61
Tableau 5 – Inspection périodique		62
Tableau X.1 – Référence à l'IEC 60384-25 pour les articles/paragraphes et les tableaux.....		63

COMMISSION ÉLECTROTECHNIQUE INTERNATIONALE

**CONDENSATEURS FIXES UTILISÉS
DANS LES ÉQUIPEMENTS ÉLECTRONIQUES –****Partie 25: Spécification intermédiaire – Condensateurs fixes
électrolytiques en aluminium pour montage en surface
à électrolyte solide en polymère conducteur**

AVANT-PROPOS

- 1) La Commission Électrotechnique Internationale (IEC) est une organisation mondiale de normalisation composée de l'ensemble des comités électrotechniques nationaux (Comités nationaux de l'IEC). L'IEC a pour objet de favoriser la coopération internationale pour toutes les questions de normalisation dans les domaines de l'électricité et de l'électronique. À cet effet, l'IEC – entre autres activités – publie des Normes internationales, des Spécifications techniques, des Rapports techniques, des Spécifications accessibles au public (PAS) et des Guides (ci-après dénommés "Publication(s) de l'IEC"). Leur élaboration est confiée à des comités d'études, aux travaux desquels tout Comité national intéressé par le sujet traité peut participer. Les organisations internationales, gouvernementales et non gouvernementales, en liaison avec l'IEC, participent également aux travaux. L'IEC collabore étroitement avec l'Organisation Internationale de Normalisation (ISO), selon des conditions fixées par accord entre les deux organisations.
- 2) Les décisions ou accords officiels de l'IEC concernant les questions techniques représentent, dans la mesure du possible, un accord international sur les sujets étudiés, étant donné que les Comités nationaux de l'IEC intéressés sont représentés dans chaque comité d'études.
- 3) Les Publications de l'IEC se présentent sous la forme de recommandations internationales et sont agréées comme telles par les Comités nationaux de l'IEC. Tous les efforts raisonnables sont entrepris afin que l'IEC s'assure de l'exactitude du contenu technique de ses publications; l'IEC ne peut pas être tenue responsable de l'éventuelle mauvaise utilisation ou interprétation qui en est faite par un quelconque utilisateur final.
- 4) Dans le but d'encourager l'uniformité internationale, les Comités nationaux de l'IEC s'engagent, dans toute la mesure possible, à appliquer de façon transparente les Publications de l'IEC dans leurs publications nationales et régionales. Toutes divergences entre toutes Publications de l'IEC et toutes publications nationales ou régionales correspondantes doivent être indiquées en termes clairs dans ces dernières.
- 5) L'IEC elle-même ne fournit aucune attestation de conformité. Des organismes de certification indépendants fournissent des services d'évaluation de conformité et, dans certains secteurs, accèdent aux marques de conformité de l'IEC. L'IEC n'est responsable d'aucun des services effectués par les organismes de certification indépendants.
- 6) Tous les utilisateurs doivent s'assurer qu'ils sont en possession de la dernière édition de cette publication.
- 7) Aucune responsabilité ne doit être imputée à l'IEC, à ses administrateurs, employés, auxiliaires ou mandataires, y compris ses experts particuliers et les membres de ses comités d'études et des Comités nationaux de l'IEC, pour tout préjudice causé en cas de dommages corporels et matériels, ou de tout autre dommage de quelque nature que ce soit, directe ou indirecte, ou pour supporter les coûts (y compris les frais de justice) et les dépenses découlant de la publication ou de l'utilisation de cette Publication de l'IEC ou de toute autre Publication de l'IEC, ou au crédit qui lui est accordé.
- 8) L'attention est attirée sur les références normatives citées dans cette publication. L'utilisation de publications référencées est obligatoire pour une application correcte de la présente publication.
- 9) L'attention est attirée sur le fait que certains des éléments de la présente Publication de l'IEC peuvent faire l'objet de droits de brevet. L'IEC ne saurait être tenue pour responsable de ne pas avoir identifié de tels droits de brevets et de ne pas avoir signalé leur existence.

La Norme internationale IEC 60384-25 a été établie par le comité d'études 40 de l'IEC: Condensateurs et résistances pour équipements électroniques.

Cette troisième édition annule et remplace la deuxième édition parue en 2015. Cette édition constitue une révision technique.

Cette édition inclut les modifications techniques majeures suivantes par rapport à l'édition précédente:

- a) révision de la structure fondée sur les Directives ISO/IEC, Partie 2:2018 dans la mesure du possible, et harmonisation avec d'autres types de documents similaires;
- b) en outre, révision de l'Article 5 et des tableaux pour éviter les redondances et les contradictions.

Le texte de cette Norme est issu des documents suivants:

FDIS	Rapport de vote
40/2850/FDIS	40/2861/RVD

Le rapport de vote indiqué dans le tableau ci-dessus donne toute information sur le vote ayant abouti à son approbation.

La langue employée pour l'élaboration de cette Norme internationale est l'anglais.

Une liste de toutes les parties de la série IEC 60384, publiées sous le titre général *Condensateurs fixes utilisés dans les équipements électroniques*, peut être consultée sur le site web de l'IEC.

Le présent document a été rédigé selon les Directives ISO/IEC, Partie 2, il a été développé selon les Directives ISO/IEC, Partie 1 et les Directives ISO/IEC, Supplément IEC, disponibles sous www.iec.ch/members_experts/refdocs. Les principaux types de documents développés par l'IEC sont décrits plus en détail sous <http://www.iec.ch/standardsdev/publications>.

Le comité a décidé que le contenu du présent document ne sera pas modifié avant la date de stabilité indiquée sur le site web de l'IEC sous webstore.iec.ch dans les données relatives au document recherché. À cette date, le document sera

- reconduit,
- supprimé,
- remplacé par une édition révisée, ou
- amendé.

CONDENSATEURS FIXES UTILISÉS DANS LES ÉQUIPEMENTS ÉLECTRONIQUES –

Partie 25: Spécification intermédiaire – Condensateurs fixes électrolytiques en aluminium pour montage en surface à électrolyte solide en polymère conducteur

1 Domaine d'application

La présente partie de l'IEC 60384 s'applique aux condensateurs fixes électrolytiques en aluminium pour montage en surface à électrolyte solide en polymère conducteur principalement destinés à des applications en courant continu pour être utilisés dans des équipements électroniques.

Les condensateurs fixes électrolytiques en aluminium pour montage en surface à électrolyte solide (MnO_2) ne sont pas inclus, mais ils sont couverts par l'IEC 60384-18.

Ces condensateurs sont principalement destinés à être utilisés dans des équipements électroniques et montés directement sur des substrats pour circuits hybrides ou sur des cartes imprimées.

Les condensateurs destinés à un usage spécial peuvent nécessiter des exigences supplémentaires.

Le présent document a pour objet de spécifier les valeurs assignées et caractéristiques préférentielles, de sélectionner, en se référant à l'IEC 60384-1:2016, les procédures d'assurance de la qualité, les essais et les méthodes de mesure appropriés et de donner les exigences de performance générales pour ce type de condensateur.

2 Références normatives

Les documents suivants sont cités dans le texte de sorte qu'ils constituent, pour tout ou partie de leur contenu, des exigences du présent document. Pour les références datées, seule l'édition citée s'applique. Pour les références non datées, la dernière édition du document de référence s'applique (y compris les éventuels amendements).

IEC 60063, *Séries de valeurs normales pour résistances et condensateurs*

IEC 60068-1:2013, *Essais d'environnement – Partie 1: Généralités et lignes directrices*

IEC 60384-1:2016, *Condensateurs fixes utilisés dans les équipements électroniques – Partie 1: Spécification générique*

IEC 61193-2:2007, *Quality assessment systems – Part 2: Selection and use of sampling plans for inspection of electronic components and packages* (disponible en anglais seulement)

3 Termes et définitions

Pour les besoins du présent document, les termes et définitions de l'IEC 60384-1:2016 et les suivants s'appliquent.

L'ISO et l'IEC tiennent à jour des bases de données terminologiques destinées à être utilisées en normalisation, consultables aux adresses suivantes:

- IEC Electropedia: disponible à l'adresse <http://www.electropedia.org/>
- ISO Online browsing platform: disponible à l'adresse <http://www.iso.org/obp>

3.1

capacité

<condensateur électrolytique> capacité d'un circuit équivalent dont la capacité et la résistance en série sont mesurées avec un courant alternatif de forme d'onde approximativement sinusoïdale à une fréquence spécifiée

4 Valeurs assignées et caractéristiques préférentielles

4.1 Caractéristiques préférentielles

Les catégories climatiques préférentielles doivent être indiquées uniquement dans les caractéristiques préférentielles.

Les condensateurs couverts par la présente spécification intermédiaire sont classés en catégories selon les règles générales données dans l'Annexe A de l'IEC 60068-1:2013.

La température de catégorie inférieure et supérieure doit être choisie parmi les valeurs suivantes:

- température de catégorie inférieure: $-55\text{ }^{\circ}\text{C}$;
- température de catégorie supérieure: $+105\text{ }^{\circ}\text{C}$ et $+125\text{ }^{\circ}\text{C}$.

Les sévérités pour les essais au froid et en chaleur sèche sont les températures des catégories inférieure et supérieure respectivement.

4.2 Valeurs préférentielles des caractéristiques assignées

4.2.1 Capacité nominale (C_N)

Les valeurs préférentielles de capacité nominale sont exprimées en microfarad (μF).

Les valeurs préférentielles de capacité nominale doivent être choisies dans la série E 12 de l'IEC 60063 comme suit:

1,0 – 1,2 – 1,5 – 1,8 – 2,2 – 2,7 – 3,3 – 3,9 – 4,7 – 5,6 – 6,8 – 8,2;

et leurs multiples décimaux ($\times 10^n$, n : entier).

4.2.2 Tolérance sur la capacité nominale

La valeur préférentielle de tolérance sur la capacité nominale est:

$\pm 20\text{ } \%$.

4.2.3 Tension assignée (U_R)

Les valeurs préférentielles des tensions continues assignées choisies dans les séries R10 et R20 de l'ISO 3 sont:

- de R 10: 1,0 – 1,25 – 1,6 – 2,0 – 2,5 – 3,15 – 4,0 – 5,0 – 6,3 – 8,0;

- de R 20: 3,5¹ – 4,5;
- et leurs multiples décimaux ($\times 10^n$, n : entier).

4.2.4 Tension de catégorie (U_C)

La tension de la catégorie est égale à la tension assignée.

4.2.5 Surtension (U_{RS})

La surtension doit être 1,15 fois la tension assignée ou la tension de catégorie, arrondie (deux chiffres significatifs) au volt le plus proche (voir le Tableau 1 et le Tableau 2).

Tableau 1 – Surtensions

Valeurs en volts

Tension assignée	2,0	2,5	4,0	5,0	6,3	8,0	10	12,5	16	20	25	35	50
Surtension	2,3	2,9	4,6	5,8	7,2	9,2	12	14	18	23	29	40	58

4.2.6 Température assignée

La valeur de la température assignée est +105 °C et +125 °C.

5 Procédures d'essai et de mesure

5.1 Généralités

Les sévérités et les exigences d'essai précisées dans les spécifications particulières se rapportant à la présente spécification intermédiaire présentent des niveaux de performance supérieurs ou égaux parce que les niveaux de performance inférieurs ne sont pas admis.

Le présent article complète les informations données dans l'Article 4 de l'IEC 60384-1:2016.

5.2 Préséchage

Voir 4.3 de l'IEC 60384-1:2016.

5.3 Conditions de mesure

Voir 4.2.1 de l'IEC 60384-1:2016.

5.4 Montage

5.4.1 Généralités

Voir 4.33 de l'IEC 60384-1:2016, ainsi que 5.4.2 à 5.4.4 du présent document.

5.4.2 Inspections initiales

Voir le Tableau 3.

¹ Pour R20, l'ISO 3 donne la valeur 3,55.

5.4.3 Conditions d'essai

La méthode d'essai doit être la méthode de refusion et le profil de la température de refusion doit être précisé dans la spécification particulière.

5.4.4 Inspections finales et exigences

Voir le Tableau 3.

5.5 Examen visuel et contrôle des dimensions

5.5.1 Généralités

Voir 4.4 de l'IEC 60384-1:2016, ainsi que 5.5.2 et 5.5.3 du présent document.

5.5.2 Examen visuel et contrôle des dimensions

L'équipement utilisé pour l'examen visuel doit être approprié avec un grossissement d'environ 10×, un éclairage approprié de l'éprouvette en essai et le niveau de qualité exigé. Il convient que l'opérateur dispose d'équipements adaptés pour l'éclairage incident ou transmis ainsi que d'équipements de mesure appropriés. Les condensateurs doivent être examinés pour vérifier que les matériaux, la conception, la fabrication et les dimensions physiques sont appropriés.

5.5.3 Exigences

La qualité d'exécution doit être conforme aux exigences applicables données dans la spécification particulière.

5.6 Essais électriques

5.6.1 Courant de fuite

5.6.1.1 Généralités

Voir 4.9 de l'IEC 60384-1:2016, ainsi que 5.6.1.2 à 5.6.1.4 du présent document.

5.6.1.2 Préconditionnement

Si le courant de fuite du condensateur augmente, le traitement suivant peut être appliqué en tant que preconditionnement.

Il convient de relier le condensateur en série à une résistance de protection dans la plage de 10 Ω à 1 000 Ω et il convient d'appliquer une tension continue équivalente à la tension assignée pendant 2 h à 105 °C $\pm$ 2 °C. La tension appliquée aux bornes des condensateurs doit être maintenue dans la limite de $\pm$ 3 % de la tension assignée.

Ensuite, lorsque le condensateur est refroidi à la température ambiante, il convient de le décharger dans une résistance d'environ 1 Ω/V , puis de le stocker dans des conditions atmosphériques normalisées pendant 12 h à 24 h.

5.6.1.3 Conditions de mesure

La tension assignée doit être appliquée aux bornes du condensateur et de sa résistance de protection placée en série avec le condensateur pour limiter le courant de charge.

La valeur de la résistance de protection doit être 1 000 Ω .

Il convient de réaliser le mesurage de chaque essai après le preconditionnement.

5.6.1.4 Exigences

Voir le Tableau 3.

5.6.2 Capacité

5.6.2.1 Généralités

Voir 4.7 de l'IEC 60384-1:2016, ainsi que 5.6.2.2 et 5.6.2.3 du présent document.

5.6.2.2 Conditions de mesure

Sauf indication contraire dans les spécifications particulières, la capacité doit être mesurée à une fréquence de 120 Hz.

La tension alternative de crête réellement appliquée aux connexions de sortie du condensateur ne doit pas dépasser la valeur efficace de 0,5 V.

Une tension de polarisation continue de 0,7 V à 1,0 V peut être appliquée pendant le mesurage pour éviter une application de tension négative sur le condensateur par la tension alternative appliquée.

L'inexactitude des instruments de mesure ne doit pas dépasser ± 2 % de la limite indiquée dans la spécification particulière, qu'il s'agisse d'une valeur absolue ou d'une variation de capacité.

5.6.2.3 Exigences

Voir le Tableau 3.

5.6.3 Tangente de l'angle de perte ($\tan \delta$)

5.6.3.1 Généralités

Voir 4.8. 1 de l'IEC 60384-1:2016, ainsi que 5.6.3.2 et 5.6.3.3 du présent document.

5.6.3.2 Conditions de mesure

Le mesurage doit respecter les conditions spécifiées en 5.6.2.

L'inexactitude de l'équipement de mesure ne doit pas dépasser 0,01 en valeur absolue.

5.6.3.3 Exigences

Voir le Tableau 3.

5.6.4 Résistance-série équivalente (RSE) (si cela est exigé)

5.6.4.1 Généralités

Voir 4.8. 2 de l'IEC 60384-1:2016, ainsi que 5.6.4.2 et 5.6.4.3 du présent document.

5.6.4.2 Conditions de mesure

Sauf indication contraire dans les spécifications particulières, les conditions d'essai sont les suivantes:

- température: $20\text{ °C} \pm 2\text{ °C}$;
- tension appliquée: valeur de crête en courant alternatif $\leq 0,5\text{ V (eff.)}$;
- fréquence de tension: $100\text{ kHz} \pm 10\text{ kHz}$.

L'erreur de mesure ne doit pas dépasser la valeur exigée de 5 % ou 0,02 Ω , selon la valeur la plus élevée.

5.6.4.3 Exigences

Voir le Tableau 3.

5.6.5 Impédance (si cela est exigé)

5.6.5.1 Généralités

Voir 4.10 de l'IEC 60384-1:2016, ainsi que 5.6.5.2 et 5.6.5.3 du présent document.

5.6.5.2 Conditions de mesure

La fréquence de mesure: 120 Hz, avec une tolérance de ± 10 %.

Il convient que la tension de mesure soit suffisamment basse, et il convient que la variation de la valeur d'impédance se situe dans la plage d'erreurs de mesure lorsque la tension est appliquée aux condensateurs pendant 1 min.

L'erreur de mesure ne doit pas dépasser la valeur exigée de 5 % ou 0,02 Ω , selon la valeur la plus élevée.

5.6.5.3 Exigences

Voir le Tableau 3.

5.7 Résistance à la chaleur de brasage

5.7.1 Généralités

Voir 4.14 de l'IEC 60384-1:2016, ainsi que 5.7.2 à 5.7.5 du présent document, sauf indication contraire dans la spécification particulière.

5.7.2 Inspections initiales

Voir le Tableau 3.

5.7.3 Conditions d'essai

La méthode d'essai doit être la méthode de refusion et le profil de la température de refusion doit être précisé dans la spécification particulière.

5.7.4 Reprise

La période de reprise doit être de 24 h $\pm$ 2 h.

5.7.5 Inspections finales et exigences

Après reprise, les condensateurs pour montage en surface doivent être soumis à un examen visuel sous un éclairage normal et avec un grossissement d'environ 10 et selon les caractéristiques électriques mesurées du Tableau 3.

5.8 Brasabilité

5.8.1 Généralités

Voir 4.15 de l'IEC 60384-1:2016, et 5.8.2 du présent document.

5.8.2 Inspections finales et exigences

Voir le Tableau 3.

5.9 Essai de cisaillement (si cela est exigé)

Voir 4.34 de l'IEC 60384-1:2016.

5.10 Essai de pliage du substrat (si cela est exigé)

5.10.1 Généralités

Voir 4.35 de l'IEC 60384-1:2016, ainsi que 5.10.2 à 5.10.4 du présent document.

5.10.2 Inspections initiales

Voir le Tableau 3.

5.10.3 Conditions d'essai

La déviation D et le nombre de pliages doivent être précisés dans la spécification particulière.

5.10.4 Inspections finales et exigences

Voir le Tableau 3.

5.11 Variations rapides de température

5.11.1 Généralités

Voir 4.16 de l'IEC 60384-1:2016, ainsi que 5.11.2 à 5.11.5 du présent document:

Les condensateurs doivent être montés conformément au 5.4.

5.11.2 Inspections initiales

Voir le Tableau 3.

5.11.3 Conditions d'essai

Les conditions d'essai sont les suivantes:

- T_A = température de catégorie inférieure;
- T_B = température de catégorie supérieure;
- les condensateurs doivent être soumis à l'essai pendant 5 cycles;
- la durée d'exposition à chaque limite de température doit être de 30 min.

5.11.4 Reprise

La période de reprise doit être comprise entre 1 h et 2 h.

5.11.5 Inspections finales et exigences

Voir le Tableau 3.

5.12 Séquence climatique

5.12.1 Généralités

Voir 4.21 de l'IEC 60384-1:2016, ainsi que 5.12.2 à 5.12.8 du présent document.

5.12.2 Inspections initiales

Voir le Tableau 3.

5.12.3 Chaleur sèche

Voir 4.21.3 de l'IEC 60384-1:2016, avec les précisions suivantes:

- température: température de catégorie supérieure;
- durée: 16 h.

5.12.4 Chaleur humide, cyclique, Essai Db, premier cycle

Voir 4.21.4 de l'IEC 60384-1:2016.

5.12.5 Froid

Voir 4.21.5 de l'IEC 60384-1:2016, avec les précisions suivantes:

- température: température de catégorie inférieure;
- durée: 2 h.

5.12.6 Chaleur humide, cyclique, Essai Db, cycles restants

Voir 4.21.7 de l'IEC 60384-1:2016.

5.12.7 Reprise

La période de reprise doit être comprise entre 1 h et 2 h.

5.12.8 Inspections finales et exigences

Voir le Tableau 3.

5.13 Chaleur humide, régime établi

5.13.1 Généralités

Voir 4.22 de l'IEC 60384-1:2016, ainsi que 5.13.2 à 5.13.5 du présent document.

Les condensateurs doivent être montés conformément au 5.4.

5.13.2 Inspections initiales

Voir le Tableau 3.