

COMMISSION ÉLECTROTECHNIQUE INTERNATIONALE
NORME DE LA CEI

INTERNATIONAL ELECTROTECHNICAL COMMISSION
IEC STANDARD

Modification

n° 1
Juillet 1985
à la


Publication 694
1980

Amendment

No. 1
July 1985
to

Clauses communes pour les normes de
l'appareillage à haute tension

Common clauses for high-voltage switchgear
and controlgear standards



Bureau Central de la Commission Electrotechnique Internationale

3, rue de Varembe
Genève, Suisse

IECNORM.COM · Click to view the full PDF of IEC 60694:1980/AMD1:1985

Withdrawn

COMMISSION ÉLECTROTECHNIQUE INTERNATIONALE
NORME DE LA CEI

INTERNATIONAL ELECTROTECHNICAL COMMISSION
IEC STANDARD

Modification

n° 1
Juillet 1985
à la

Publication 694
1980

Clauses communes pour les normes de
l'appareillage à haute tension

Common clauses for high-voltage switchgear
and controlgear standards

Amendment

No. 1
July 1985
to

The amendments contained in this document
have been approved under the Six Months'
Rule.

The draft amendments, discussed by Sub-
Committee 17A of Technical Committee No. 17,
were circulated for approval under the Six
Months' Rule in May 1984, as Document
17A(Central Office)182.

Further details can be found in the follow-
ing Report on Voting: Document 17A(Central
Office)193.

Les modifications contenues dans le présent
document ont été approuvées suivant la Règle
des Six Mois.

Les projets de modifications, discutés par
le Sous-Comité 17A du Comité d'Etudes n° 17,
furent diffusés en mai 1984 pour approbation
suivant la Règle des Six Mois, sous forme de
document 17A(Bureau Central)182.

Pour de plus amples renseignements, consul-
ter le rapport de vote suivant: Document
17A(Bureau Central)193.

© CEI 1985

Droits de reproduction réservés — Copyright - all rights reserved

Page 30

5.3 *Raccordement à la terre des appareils de connexion*

Remplacer la dernière phrase de ce paragraphe par la suivante:

Le point de raccordement est marqué du symbole "Terre de protection" n° 5019 de la Publication 417 de la CEI: Symboles graphiques utilisables sur le matériel. Index, relevé et compilation des feuilles individuelles.

Page 31

5.3 *Earthing of switching devices*

Replace the last sentence of this sub-clause by the following:

The connecting point shall be marked with the symbol for protective earth, No. 5019 of IEC Publication 417: Graphical Symbols for Use on Equipment. Index, Survey and Compilation of the Single Sheets.
