

NORME
INTERNATIONALE
INTERNATIONAL
STANDARD

CEI
IEC
726

1982

AMENDEMENT 1
AMENDMENT 1

1986

Amendement 1

Transformateurs de puissance de type sec

Amendment 1

Dry-type power transformers

© CEI 1986 Droits de reproduction réservés — Copyright — all rights reserved

Bureau Central de la Commission Electrotechnique Internationale 3, rue de Varembe Genève, Suisse



Commission Electrotechnique Internationale
International Electrotechnical Commission
Международная Электротехническая Комиссия

CODE PRIX
PRICE CODE

A

Pour prix, voir catalogue en vigueur
For price, see current catalogue

TRANSFORMATEURS DE PUISSANCE DE TYPE SEC

PREFACE

La présente modification a été établie par le Comité d'Etudes n° 14 de la CEI: Transformateurs de puissance.

Le texte de cette modification est issu des documents suivants:

Règle des Six Mois	Rapport de vote
14(BC)61	14(BC)64

Pour de plus amples renseignements, consulter le rapport de vote mentionné dans le tableau ci-dessus.

Page 18

Tableau IV: Limites d'échauffement

Dans la colonne 2 de ce tableau, remplacer "185 (H)" par "180 (H)".

DRY-TYPE POWER TRANSFORMERS

PREFACE

This amendment has been prepared by IEC Technical Committee No. 14: Power Transformers.

The text of this amendment is based upon the following documents:

Six Months' Rule	Report on Voting
14(C0)61	14(C0)64

Further information can be found in the Report on Voting indicated in the table above.

Page 19

Table IV: Temperature-rise limits

In column 2 of this table, replace "185 (H)" by "180 (H)".