

INTERNATIONAL ELECTROTECHNICAL COMMISSION
COMMISSION ÉLECTROTECHNIQUE INTERNATIONALE

IEC 61215-2
Edition 1.0 2016-03

**TERRESTRIAL PHOTOVOLTAIC (PV) MODULES –
DESIGN QUALIFICATION AND TYPE APPROVAL**

Part 2: Test procedures

IEC 61215-2
Édition 1.0 2016-03

**MODULES PHOTOVOLTAIQUES (PV) POUR
APPLICATIONS TERRESTRES – QUALIFICATION
DE LA CONCEPTION ET HOMOLOGATION**

Partie 2: Procédures d'essai

CORRIGENDUM 1

Corrections to the French version appear after the English text.

Les corrections à la version française sont données après le texte anglais.

4.9.4 Apparatus

Replace:

a) "Radiant source: Natural sunlight, or a class BBB (or better) steady-state solar simulator conforming to IEC 60904-9 with an irradiance of $(1\,000 \pm 100)$ W/m²."

By:

a) "Radiant source: Natural sunlight, or a class BBB (or better) steady-state solar simulator conforming to IEC 60904-9 with an irradiance of 800 W/m² to 1 100 W/m²."

4.9.5.3.1 General

Replace:


"The hot-spot test is performed with the module exposed to 800 W/m² to 1 000 W/m²."

By:

"The hot-spot test is performed with the module exposed to $(1\,000 \pm 100)$ W/m²."

4.14.3 Test of cord anchorage (MQT 14.2)

Replace:



NOTE For module testing setup depends on the module construction.

Figure 11 – Typical arrangement for the cord anchorage pull test for component testing

By:




Figure 11 – a) Typical arrangement for the cord anchorage pull test for component testing from IEC 62790. b) Typical schematic arrangement for cord anchorage pull test on PV module mounted junction box

Replace:





Figure 12 – Typical arrangement for torsion test

By:



If the test is performed with the manufacturer's cable, the fixture for securing the cable shall be as close as possible to the cable securing plate of the junction box.

Figure 12 – Typical arrangement for torsion test

4.17.3 Procedure

Table 4 – Impact locations

Replace:

3, 4	Over edges of the circuit (e.g. individual cells).
5, 6	Over the circuit near interconnects (i.e. cell interconnects and bus ribbons).

By:

3, 4	Over the circuit near interconnects (i.e. cell interconnects and bus ribbons).
5, 6	Over edges of the circuit (e.g. individual cells).

Withd
IECNORM.COM: Click to view the full PDF of IEC 61215-2:2016/COR1:2018

Corrections à la version française:

4.9.4 Appareillage

Remplacer:

a) "Source de rayonnement : Éclairement solaire naturel, ou simulateur solaire à éclairement continu de classe BBB minimum conforme à l'IEC 60904-9 produisant un éclairement de $(1\,000 \pm 100) \text{ W/m}^2$."

par:

a) "Source de rayonnement : Éclairement solaire naturel, ou simulateur solaire à éclairement continu de classe BBB minimum conforme à l'IEC 60904-9 produisant un éclairement de 800 W/m^2 à $1\,100 \text{ W/m}^2$."

4.9.5.3.1 Généralités

Remplacer:


"L'essai de tenue à l'échauffement localisé est réalisé avec le module exposé à un éclairement compris entre 800 W/m^2 et $1\,000 \text{ W/m}^2$."

par:

"L'essai de tenue à l'échauffement localisé est réalisé avec le module exposé à un éclairement compris entre $(1\,000 \pm 100) \text{ W/m}^2$."

4.14.3 Essai du serre-câble (MQT 14.2)

Remplacer:



NOTE Pour les essais de modules, la disposition dépend de la construction du module.

Figure 11 – Disposition type pour l'essai de traction du serre-câble (essais de composants)

Par :




Figure 11 – a) Disposition type pour l'essai de traction du serre-câble pour les essais de composants issus de l'IEC 62790. b) Disposition schématique typique pour l'essai de traction du serre-câble sur boîte de jonction montée sur le module PV