

INTERNATIONAL STANDARD

IEC
61968-4

First edition
2007-07

Application integration at electric utilities – System interfaces for distribution management –

Part 4: Interfaces for records and asset management



Reference number
IEC 61968-4:2007(E)



THIS PUBLICATION IS COPYRIGHT PROTECTED

Copyright © 2007 IEC, Geneva, Switzerland

All rights reserved. Unless otherwise specified, no part of this publication may be reproduced or utilized in any form or by any means, electronic or mechanical, including photocopying and microfilm, without permission in writing from either IEC or IEC's member National Committee in the country of the requester.

If you have any questions about IEC copyright or have an enquiry about obtaining additional rights to this publication, please contact the address below or your local IEC member National Committee for further information.

IEC Central Office
3, rue de Varembe
CH-1211 Geneva 20
Switzerland
Email: inmail@iec.ch
Web: www.iec.ch

About the IEC

The International Electrotechnical Commission (IEC) is the leading global organization that prepares and publishes International Standards for all electrical, electronic and related technologies.

About IEC publications

The technical content of IEC publications is kept under constant review by the IEC. Please make sure that you have the latest edition, a corrigenda or an amendment might have been published.

- Catalogue of IEC publications: www.iec.ch/searchpub

The IEC on-line Catalogue enables you to search by a variety of criteria (reference number, text, technical committee,...). It also gives information on projects, withdrawn and replaced publications.

- IEC Just Published: www.iec.ch/online_news/justpub

Stay up to date on all new IEC publications. Just Published details twice a month all new publications released. Available on-line and also by email.

- Customer Service Centre: www.iec.ch/webstore/custserv

If you wish to give us your feedback on this publication or need further assistance, please visit the Customer Service Centre FAQ or contact us:

Email: csc@iec.ch

Tel.: +41 22 919 02 11

Fax: +41 22 919 03 00

INTERNATIONAL STANDARD

IEC
61968-4

First edition
2007-07

Application integration at electric utilities – System interfaces for distribution management –

Part 4: Interfaces for records and asset management



Commission Electrotechnique Internationale
International Electrotechnical Commission
Международная Электротехническая Комиссия

PRICE CODE **XA**

For price, see current catalogue

CONTENTS

FOREWORD.....	3
INTRODUCTION.....	5
1 Scope.....	6
2 Normative references	6
3 Reference and information models	6
3.1 General.....	6
3.2 Interface reference model.....	6
3.3 Records and asset management functions and components.....	6
3.4 Static information model.....	7
4 Records and Asset message types	7
4.1 Summary.....	7
4.2 Network Data Set message type.....	7
4.2.1 Message content	7
4.2.2 Message format.....	7
4.3 Change Set message type.....	24
4.3.1 Message content	24
4.3.2 Message format.....	24
4.4 Presentation message type	24
4.4.1 Message content	24
4.4.2 Message format.....	24
4.5 Asset List message type.....	29
4.5.1 Message content	29
4.5.2 Message format.....	29
4.6 Asset Catalogue message type	36
4.6.1 Message content	36
4.6.2 Message format.....	36
4.7 Type Asset Catalogue message type.....	42
4.7.1 Message content	42
4.7.2 Message format.....	42
Annex A (informative) Use of the Geography Markup Language (GML).....	51
Figure 1 – Network Data Set message format	8
Figure 2 – Change Set message format	24
Figure 3 – Presentations message format	25
Figure 4 – Asset List message format	30
Figure 5 – Asset Catalogue message format.....	37
Figure 6 – Type Asset Catalogue message format	43
Table 1 – Document overview for IEC 61968-4	5

INTERNATIONAL ELECTROTECHNICAL COMMISSION

**APPLICATION INTEGRATION AT ELECTRIC UTILITIES –
SYSTEM INTERFACES FOR DISTRIBUTION MANAGEMENT –****Part 4: Interfaces for records and asset management**

FOREWORD

- 1) The International Electrotechnical Commission (IEC) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, IEC publishes International Standards, Technical Specifications, Technical Reports, Publicly Available Specifications (PAS) and Guides (hereafter referred to as "IEC Publication(s)"). Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations liaising with the IEC also participate in this preparation. IEC collaborates closely with the International Organization for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.
- 2) The formal decisions or agreements of IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC National Committees.
- 3) IEC Publications have the form of recommendations for international use and are accepted by IEC National Committees in that sense. While all reasonable efforts are made to ensure that the technical content of IEC Publications is accurate, IEC cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.
- 4) In order to promote international uniformity, IEC National Committees undertake to apply IEC Publications transparently to the maximum extent possible in their national and regional publications. Any divergence between any IEC Publication and the corresponding national or regional publication shall be clearly indicated in the latter.
- 5) IEC provides no marking procedure to indicate its approval and cannot be rendered responsible for any equipment declared to be in conformity with an IEC Publication.
- 6) All users should ensure that they have the latest edition of this publication.
- 7) No liability shall attach to IEC or its directors, employees, servants or agents including individual experts and members of its technical committees and IEC National Committees for any personal injury, property damage or other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication, use of, or reliance upon, this IEC Publication or any other IEC Publications.
- 8) Attention is drawn to the Normative references cited in this publication. Use of the referenced publications is indispensable for the correct application of this publication.
- 9) Attention is drawn to the possibility that some of the elements of this IEC Publication may be the subject of patent rights. IEC shall not be held responsible for identifying any or all such patent rights.

International Standard IEC 61968 has been prepared by IEC technical committee 57: Power systems management and associated information exchange.

The text of this standard is based on the following documents:

FDIS	Report on voting
57/880/FDIS	57/901/RVD

Full information on the voting for the approval of this standard can be found in the report on voting indicated in the above table.

A list of all parts of the IEC 61968 series, under the general title *Application integration at electric utilities – System interfaces for distribution management*, can be found on the IEC website.

The committee has decided that the contents of this publication will remain unchanged until the maintenance result date indicated on the IEC web site under "<http://webstore.iec.ch>" in the data related to the specific publication. At this date, the publication will be

- reconfirmed;
- withdrawn;
- replaced by a revised edition, or
- amended.

A bilingual version of this publication may be issued at a later date.

IECNORM.COM: Click to view the full PDF of IEC 61968-4:2007

Withdrawn

INTRODUCTION

The IEC 61968 series of standards is intended to facilitate *inter-application integration* as opposed to *intra-application integration*. Intra-application integration is aimed at programs in the same application system, usually communicating with each other using middleware that is embedded in their underlying runtime environment, and tends to be optimized for close, real-time, synchronous connections and interactive request/reply or conversation communication models. IEC 61968, by contrast, is intended to support the inter-application integration of a utility enterprise that needs to connect disparate applications that are already built or new (legacy or purchased applications), each supported by dissimilar runtime environments. Therefore, these interface standards are relevant to loosely coupled applications with more heterogeneity in languages, operating systems, protocols and management tools. This series of standards is intended to support applications that need to exchange data every few seconds, minutes, or hours rather than waiting for a nightly batch run. This series of standards, which are intended to be implemented with middleware services that exchange messages among applications, will complement, not replace utility data warehouses, database gateways, and operational stores.

As used in the IEC 61968 series, a DMS consists of various distributed application components for the utility to manage electrical distribution networks. These capabilities include monitoring and control of equipment for power delivery, management processes to ensure system reliability, voltage management, demand-side management, outage management, work management, automated mapping and facilities management. Standards interfaces are defined for each class of applications identified in the Interface Reference Model (IRM), which is described in IEC 61968-1.

This Part of IEC 61968 contains the Clauses shown in Table 1.

Table 1 – Document overview for IEC 61968-4

Clause	Title	Purpose
1	Scope	The scope and purpose of the document are described.
2	Normative references	Documents that contain provisions which, through reference in this text, constitute provisions of this International Standard.
3	Reference and information models	Description of the relevant parts of the interface reference model, static information model and message type naming convention.
4	Records and asset management message types	Message types related to the exchange of information for network data sets, assets, and asset catalogues.

APPLICATION INTEGRATION AT ELECTRIC UTILITIES – SYSTEM INTERFACES FOR DISTRIBUTION MANAGEMENT –

Part 4: Interfaces for records and asset management

1 Scope

This Part of IEC 61968 specifies the information content of a set of message types that can be used to support many of the business functions related to records and asset management. Typical uses of the message types defined in this Part of IEC 61968 include network extension planning, copying feeder or other network data between systems, network or diagram edits and asset inspection. Message types defined in other Parts of IEC 61968 may also be relevant to these use cases.

2 Normative references

The following referenced documents are indispensable for the application of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

IEC 61968-1, *Application integration at electric utilities – System interfaces for distribution management – Part 1: Interface architecture and general requirements*

IEC 61968-3, *Application integration at electric utilities – System interfaces for distribution management – Part 3: Interface for network operations*

3 Reference and information models

3.1 General

The message types defined in IEC 61968-4 are based on a logical partitioning of the DMS business functions and components called the IEC 61968-1 Interface reference model.

As described, in IEC 61968-1, the contents of the message types are based on a static information model to ensure consistency of field names and data types. Each message type is defined as a set of fields copied from the information model classes. The message types defined in this standard are intended to satisfy a majority of typical applications. In some particular project implementations, it may be desirable to modify the set of fields using a methodology such as that described in IEC 61968-1.

3.2 Interface reference model

It is not the intention of the IEC 61968 series to define the applications and systems that vendors should produce. It is expected that a concrete (physical) application will provide the functionality of one or more abstract (logical) components as listed in this standard. These abstract components are grouped by the business functions of the IEC 61968-1 interface reference model.

3.3 Records and asset management functions and components

The Records and Asset Management part of the IEC 61968-1 Interface reference model shows those functions and typical components that are applicable to the message types defined in IEC 61968-4.

For the message types defined in IEC 61968-4, it is expected that the typical abstract components listed below will be producers of information. Typical consumers of the information are the other components as listed in IEC 61968-1.

3.4 Static information model

The information model relevant to records and asset management consists of classes that provide a template for the attributes for each message. The classes are defined in detail in IEC 61970-301 or in future document IEC 61968-11.

4 Records and Asset message types

4.1 Summary

The records and asset message types describe information for the following types of document:

- network data set,
- change set,
- presentation,
- asset list,
- asset catalogue,
- type asset catalogue.

For all message types shown in IEC 61968-4, elements that correspond with CIM classes contain all native and inherited attributes of that class. Unless explicitly shown otherwise, all message type associations are simple associations.

4.2 Network Data Set message type

4.2.1 Message content


A NetworkDataSet message can contain data for any part of a distribution network typically selected for operational or extension planning studies. The message contents could be part of a feeder, a single feeder or more than one feeder. The data could be either the 'As built' network or a proposed network selected for analysis.

A NetworkDataSet message may contain references to other Documents containing static reference data such as TypeAssetCatalogue or AssetCatalogue. It may also contain references to Assets performing the roles of the associated types of PowerSystemResources. The same is true for other "leaf node" elements such as Organisations, Locations, and Measurements. In these cases, only the identifier for the referenced data is to be included in this message type. The actual data for referenced elements are provided through other types of messages (e.g., TypeAssetCatalogue, AssetCatalogue, AssetList, Measurements).

The basic structure is a hierarchy as shown in Figure 1. The initial dynamic state of the network including switch positions is defined as a set of MeasurementValues. These values can be updated using the ShowMeasurementList message defined in IEC 61968-3.

4.2.2 Message format

Created NetworkDataSet, changed NetworkDataSet, show NetworkDataSet and deleted NetworkDataSet have the same message formats as shown in Figure 1.



IEC 1108/07

Figure 1 – Network Data Set message format (continued on next page)




Figure 1 (continued)




Figure 1 (continued)




Figure 1 (continued)




Figure 1 (continued)




Figure 1 (continued)




Figure 1 (continued)




Figure 1 (continued)




Figure 1 (continued)




Figure 1 (continued)




Figure 1 (continued)




Figure 1 (continued)




Figure 1 (continued)




Figure 1 (continued)




Figure 1 (continued)




Figure 1 (end)

4.3 Change Set message type

4.3.1 Message content

A ChangeSet message type contains updates required in a transaction for an existing NetworkDataSet, which is referenced in the uppermost hierarchy of this message type. Each step in the ChangeSet is described through a separate Changeltem. A change item identifies the change type (add, delete, modify) and sequence number for a particular change within a set of changes of a ChangeSet. The changes for this change item are articulated in an instance of NetworkDataSet, which is a child element of the Changeltem. Only the identifiers of the relevant NetworkDataSet messages are to be included in a ChageSet message. The actual contents are provided in accompanying NetworkDataSets messages.

The basic structure is a hierarchy as shown in the Figure 2.

4.3.2 Message format

Created ChangeSet, changed ChangeSet, show ChangeSet and deleted ChangeSet have the same message formats as shown in Figure 2.




Figure 2 – Change Set message format


4.4 Presentation message type

4.4.1 Message content

A Presentation message can contain location information for most any element represented in the Common Information Model, particularly elements of the distribution network. It can be used for providing location information of individual assets or power system resources or to provide a set of location information as a companion to the NetworkDataSet. The basic structure is a hierarchy as shown in Figure 3. Refer to Annex A for information regarding the use of Georaphy Markup Language (GML).

4.4.2 Message format

Created Presentation, changed Presentation, show Presentation and deleted Presentation have the same message formats as shown in Figure 3.



IEC 1125/07

Figure 3 – Presentations message format (continued)




Figure 3 (continued)



Figure 3 (continued)




Figure 3 (continued)




Figure 3 (end)

IEC 1129/07


4.5 Asset List message type

4.5.1 Message content

An AssetList message can contain various amounts of data for any set of utility assets. An AssetList message may contain references to static reference data such as elements of a AssetCatalogue or TypeAssetCatalogue. It may also contain references to the types of PowerSystemResources that specify the role in which the Asset is being used (i.e., if it has been installed rather than sitting in inventory). The same is true for other “leaf node” elements such as Organisations, Locations, and Measurements. In these cases, only the identifier for the referenced data is to be included in this message type. The actual data for referenced elements are provided through other types of messages (e.g., TypeAssetCatalogue, AssetCatalogue, NetworkDataSet, Measurements).

4.5.2 Message format

Created AssetList, changed AssetList, show AssetList and deleted AssetList have the same message formats as shown in Figure 4.



IEC 1130/07

Figure 4 – Asset List message format (continued)




Figure 4 (continued)

IEC 1131/07






Figure 4 (continued)




IEC 1133/07

Figure 4 (continued)




IEC 1134/07



IEC 1135/07

Figure 4 (continued)



IEC 1136/07

Figure 4 (end)


4.6 Asset Catalogue message type

4.6.1 Message content

An AssetCatalogue is a collection of information regarding available types of products and materials that are used to build or install an Asset(s), to maintain an Asset(s) or to operate an Asset(s). Each catalogue item is for a specific product available from a specific supplier. An AssetCatalogue message may contain references to static reference data such as elements of a TypeAssetCatalogue or Specifications. The same is true for other “leaf node” elements such as Organisations. In these cases, only the identifier for the referenced data is to be included in this message type. The actual data for referenced elements are provided through other types of messages (e.g., TypeAssetCatalogue).

4.6.2 Message format

Created AssetCatalogue, changed AssetCatalogue, show AssetCatalogue and deleted AssetCatalogue have the same message formats as shown in Figure 5.



IEC 1137/07

Figure 5 – Asset Catalogue message format (continued)




Figure 5 (continued)




Figure 5 (continued)




Figure 5 (continued)




Figure 5 (end)