

INTERNATIONAL STANDARD

NORME INTERNATIONALE

**Energy performance of lamp controlgear –
Part 3: Controlgear for tungsten-halogen lamps and LED light sources –
Method of measurement to determine the efficiency of controlgear**

**Performance énergétique des appareillages de lampes –
Partie 3: Appareillage de lampes tungstène-halogène et sources lumineuses
à LED – Méthode de mesure pour la détermination du rendement des
appareillages**

IECNORM.COM : Click to view the full PDF of IEC 62442-3:2018



THIS PUBLICATION IS COPYRIGHT PROTECTED

Copyright © 2018 IEC, Geneva, Switzerland

All rights reserved. Unless otherwise specified, no part of this publication may be reproduced or utilized in any form or by any means, electronic or mechanical, including photocopying and microfilm, without permission in writing from either IEC or IEC's member National Committee in the country of the requester. If you have any questions about IEC copyright or have an enquiry about obtaining additional rights to this publication, please contact the address below or your local IEC member National Committee for further information.

Droits de reproduction réservés. Sauf indication contraire, aucune partie de cette publication ne peut être reproduite ni utilisée sous quelque forme que ce soit et par aucun procédé, électronique ou mécanique, y compris la photocopie et les microfilms, sans l'accord écrit de l'IEC ou du Comité national de l'IEC du pays du demandeur. Si vous avez des questions sur le copyright de l'IEC ou si vous désirez obtenir des droits supplémentaires sur cette publication, utilisez les coordonnées ci-après ou contactez le Comité national de l'IEC de votre pays de résidence.

IEC Central Office
3, rue de Varembe
CH-1211 Geneva 20
Switzerland

Tel.: +41 22 919 02 11
info@iec.ch
www.iec.ch

About the IEC

The International Electrotechnical Commission (IEC) is the leading global organization that prepares and publishes International Standards for all electrical, electronic and related technologies.

About IEC publications

The technical content of IEC publications is kept under constant review by the IEC. Please make sure that you have the latest edition, a corrigenda or an amendment might have been published.

IEC Catalogue - webstore.iec.ch/catalogue

The stand-alone application for consulting the entire bibliographical information on IEC International Standards, Technical Specifications, Technical Reports and other documents. Available for PC, Mac OS, Android Tablets and iPad.

IEC publications search - webstore.iec.ch/advsearchform

The advanced search enables to find IEC publications by a variety of criteria (reference number, text, technical committee,...). It also gives information on projects, replaced and withdrawn publications.

IEC Just Published - webstore.iec.ch/justpublished

Stay up to date on all new IEC publications. Just Published details all new publications released. Available online and also once a month by email.

Electropedia - www.electropedia.org

The world's leading online dictionary of electronic and electrical terms containing 21 000 terms and definitions in English and French, with equivalent terms in 16 additional languages. Also known as the International Electrotechnical Vocabulary (IEV) online.

IEC Glossary - std.iec.ch/glossary

67 000 electrotechnical terminology entries in English and French extracted from the Terms and Definitions clause of IEC publications issued since 2002. Some entries have been collected from earlier publications of IEC TC 37, 77, 86 and CISPR.

IEC Customer Service Centre - webstore.iec.ch/csc

If you wish to give us your feedback on this publication or need further assistance, please contact the Customer Service Centre: sales@iec.ch.

A propos de l'IEC

La Commission Electrotechnique Internationale (IEC) est la première organisation mondiale qui élabore et publie des Normes internationales pour tout ce qui a trait à l'électricité, à l'électronique et aux technologies apparentées.

A propos des publications IEC

Le contenu technique des publications IEC est constamment revu. Veuillez vous assurer que vous possédez l'édition la plus récente, un corrigendum ou amendement peut avoir été publié.

Catalogue IEC - webstore.iec.ch/catalogue

Application autonome pour consulter tous les renseignements bibliographiques sur les Normes internationales, Spécifications techniques, Rapports techniques et autres documents de l'IEC. Disponible pour PC, Mac OS, tablettes Android et iPad.

Recherche de publications IEC - webstore.iec.ch/advsearchform

La recherche avancée permet de trouver des publications IEC en utilisant différents critères (numéro de référence, texte, comité d'études,...). Elle donne aussi des informations sur les projets et les publications remplacées ou retirées.

IEC Just Published - webstore.iec.ch/justpublished

Restez informé sur les nouvelles publications IEC. Just Published détaille les nouvelles publications parues. Disponible en ligne et aussi une fois par mois par email.

Electropedia - www.electropedia.org

Le premier dictionnaire en ligne de termes électroniques et électriques. Il contient 21 000 termes et définitions en anglais et en français, ainsi que les termes équivalents dans 16 langues additionnelles. Egalement appelé Vocabulaire Electrotechnique International (IEV) en ligne.

Glossaire IEC - std.iec.ch/glossary

67 000 entrées terminologiques électrotechniques, en anglais et en français, extraites des articles Termes et Définitions des publications IEC parues depuis 2002. Plus certaines entrées antérieures extraites des publications des CE 37, 77, 86 et CISPR de l'IEC.

Service Clients - webstore.iec.ch/csc

Si vous désirez nous donner des commentaires sur cette publication ou si vous avez des questions contactez-nous: sales@iec.ch.

INTERNATIONAL STANDARD

NORME INTERNATIONALE

**Energy performance of lamp controlgear –
Part 3: Controlgear for tungsten-halogen lamps and LED light sources –
Method of measurement to determine the efficiency of controlgear**

**Performance énergétique des appareillages de lampes –
Partie 3: Appareillage de lampes tungstène-halogène et sources lumineuses
à LED – Méthode de mesure pour la détermination du rendement des
appareillages**

INTERNATIONAL
ELECTROTECHNICAL
COMMISSION

COMMISSION
ELECTROTECHNIQUE
INTERNATIONALE

ICS 29.140.99

ISBN 978-2-8322-5643-5

**Warning! Make sure that you obtained this publication from an authorized distributor.
Attention! Veuillez vous assurer que vous avez obtenu cette publication via un distributeur agréé.**

CONTENTS

FOREWORD	3
1 Scope	5
2 Normative references	5
3 Terms and definitions	6
4 General	9
4.1 Applicability	9
4.2 General notes on tests	9
4.3 Controllable controlgear	9
4.4 Measurement uncertainty	9
4.5 Sampling of controlgear for testing	9
4.6 Size of the test sample	9
4.7 Power supply	9
4.8 Supply voltage waveform	10
4.9 Substitution load	10
4.10 Thermocouple and temperature indicator	10
4.11 Instrument accuracy	10
4.12 Measuring circuits	11
4.13 Multi-rated voltage controlgear	11
4.14 Multi-power controlgear	11
4.15 Sensor and network connections	11
5 Method of measurement and calculation of the efficiency of controlgear (transformer, convertor) for tungsten-halogen lamps and for LED light sources	12
5.1 Measurement setup: input and output power	12
5.2 Efficiency calculation for electromagnetic (transformer) and electronic (convertor) controlgear	12
5.3 Measurement setup: input power in no-load mode	13
5.4 Standby power measurement of convertor-electronic controlgear	13
Bibliography	15
Figure 1 – Power losses measurement setup for electromagnetic controlgear (transformer) and input and output power measurement setup for convertor (electronic controlgear)	12
Figure 2 – Input power in no-load mode measurement setup for electromagnetic controlgear (transformer) and for convertor (electronic controlgear)	13
Figure 3 – Measurement setup of the standby power of convertor-electronic controlgear	14
Table 1 – Typical nominal electricity supply details for some regions	10

INTERNATIONAL ELECTROTECHNICAL COMMISSION

ENERGY PERFORMANCE OF LAMP CONTROLGEAR –

**Part 3: Controlgear for tungsten-halogen lamps and LED light sources –
Method of measurement to determine the efficiency of controlgear**

FOREWORD

- 1) The International Electrotechnical Commission (IEC) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, IEC publishes International Standards, Technical Specifications, Technical Reports, Publicly Available Specifications (PAS) and Guides (hereafter referred to as “IEC Publication(s)”). Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations liaising with the IEC also participate in this preparation. IEC collaborates closely with the International Organization for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.
- 2) The formal decisions or agreements of IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC National Committees.
- 3) IEC Publications have the form of recommendations for international use and are accepted by IEC National Committees in that sense. While all reasonable efforts are made to ensure that the technical content of IEC Publications is accurate, IEC cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.
- 4) In order to promote international uniformity, IEC National Committees undertake to apply IEC Publications transparently to the maximum extent possible in their national and regional publications. Any divergence between any IEC Publication and the corresponding national or regional publication shall be clearly indicated in the latter.
- 5) IEC itself does not provide any attestation of conformity. Independent certification bodies provide conformity assessment services and, in some areas, access to IEC marks of conformity. IEC is not responsible for any services carried out by independent certification bodies.
- 6) All users should ensure that they have the latest edition of this publication.
- 7) No liability shall attach to IEC or its directors, employees, servants or agents including individual experts and members of its technical committees and IEC National Committees for any personal injury, property damage or other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication, use of, or reliance upon, this IEC Publication or any other IEC Publications.
- 8) Attention is drawn to the Normative references cited in this publication. Use of the referenced publications is indispensable for the correct application of this publication.
- 9) Attention is drawn to the possibility that some of the elements of this IEC Publication may be the subject of patent rights. IEC shall not be held responsible for identifying any or all such patent rights.

International Standard IEC 62442-3 has been prepared by subcommittee 34C: Auxiliaries for lamps, of IEC technical committee 34: Lamps and related equipment.

This second edition cancels and replaces the first edition published in 2014. This edition constitutes a technical revision and has been harmonized with IEC 62442-1 and IEC 62442-2.

The text of this International Standard is based on the following documents:

CDV	Report on voting
34C/1344/CDV	34C/1378/RVC

Full information on the voting for the approval of this International Standard can be found in the report on voting indicated in the above table.

This document has been drafted in accordance with the ISO/IEC Directives, Part 2.

A list of all parts in the IEC 62442 series, published under the general title *Energy performance of lamp controlgear*, can be found on the IEC website.

The committee has decided that the contents of this document will remain unchanged until the stability date indicated on the IEC website under "<http://webstore.iec.ch>" in the data related to the specific document. At this date, the document will be

- reconfirmed,
- withdrawn,
- replaced by a revised edition, or
- amended.

IECNORM.COM : Click to view the full PDF of IEC 62442-3:2018

ENERGY PERFORMANCE OF LAMP CONTROLGEAR –

Part 3: Controlgear for tungsten-halogen lamps and LED light sources – Method of measurement to determine the efficiency of controlgear

1 Scope

This part of IEC 62442 defines a measurement method for the power losses of electromagnetic transformers as well as the power losses and the standby power of electronic convertors for tungsten-halogen lamps and for LED light source(s).

It is applicable for controlgear that are designed for use on DC supplies up to 1 000 V and/or AC supplies up to 1 000 V at 50 Hz or 60 Hz.

A calculation method of the efficiency of the mentioned controlgear for tungsten-halogen lamps and LED light source(s) is also defined.

This document applies to electrical controlgear-lamp circuits comprised solely of the controlgear and of the lamp(s) (LED light sources).

For multipurpose power supplies only the lighting part will be considered.

NOTE Requirements for testing individual controlgear during production are not included.

This document specifies the measurement method for the total input power, the standby power and the calculation method of the controlgear efficiency for all controlgear sold for domestic and normal commercial purposes operating with tungsten-halogen lamps and LED light source(s). The term "LED light sources" includes LED modules and LED lamps.

This document does not apply to:

- controlgear which form an integral part of lamps (LED light sources);
- controlgear circuits with capacitors connected in series;
- controllable electromagnetic controlgear.

2 Normative references

The following documents are referred to in the text in such a way that some or all of their content constitutes requirements of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

IEC 61047:2004, *DC or AC supplied electronic step-down convertors for filament lamps – Performance requirements*

IEC 61347-1:2015, *Lamp controlgear – Part 1: General and safety requirements*

IEC 61347-2-2, *Lamp controlgear – Part 2-2: Particular requirements for DC or AC supplied electronic step-down convertors for filament lamps*

IEC 61347-2-13, *Lamp controlgear – Part 2-13: Particular requirements for DC or AC supplied electronic controlgear for LED modules*

IEC 61558-1, *Safety of transformers, reactors, power supply units and combinations thereof – Part 1: General requirements and tests*

IEC 61558-2-6, *Safety of transformers, reactors, power supply units and similar products for supply voltages up to 1 100 V – Part 2-6: Particular requirements and tests for safety isolating transformers and power supply units incorporating safety isolating transformers*

IEC 62301:2011, *Household electrical appliances – Measurement of standby power*

IEC Guide 115:2007, *Application of uncertainty of measurement to conformity assessment activities in the electrotechnical sector*

3 Terms and definitions

For the purposes of this document, the following terms and definitions apply.

ISO and IEC maintain terminological databases for use in standardization at the following addresses:

- IEC Electropedia: available at <http://www.electropedia.org/>
- ISO Online browsing platform: available at <http://www.iso.org/obp>

3.1

nominal value

suitable approximate quantity value used to designate or identify a component, device or equipment

[SOURCE: IEC 62442-1:2018, 3.1]

3.2

rated value

quantity value for specified operating conditions of a component, device or equipment

Note 1 to entry: The value and conditions are specified in the relevant standard or assigned by the manufacturer or responsible vendor.

[SOURCE: IEC 62442-1:2018, 3.3, modified – Note 2 has been deleted.]

3.3

controlgear

one or more components between supply and one or more lamps (LED light source(s)) which may serve to transform the supply voltage, limit the current of the lamp(s) (LED light source(s)) to the required value, the correct power factor or reduce radio interference

[SOURCE: IEC 62442-1:2018, 3.4 modified – “provide starting voltage and preheating current, prevent cold starting” has been deleted and “(LED light source(s))” has been added.]

3.4

electromagnetic controlgear

magnetic controlgear

controlgear which, by means of inductance, or a combination of inductance and capacitance, serves mainly to limit the current of lamp(s) (LED light source(s)) to the required value and operates the lamp(s) at the same frequency as the supply frequency

[SOURCE: IEC 62442-1:2018, 3.5, modified – “(LED light source(s))” has been added.]

3.5**electromagnetic transformer
magnetic transformer
transformer**

electromagnetic controlgear which transform the supply voltage to operate lamp(s) (LED light source(s)) with the same frequency as the supply frequency at the lamps (light sources) rated voltage

3.6**electronic controlgear**

<filament lamp(s) or LED light sources> AC and/or DC supplied electronic circuit including stabilizing elements for operating one or more filament lamp(s) or one or more LED light sources

3.7**electronic step-down convertor
convertor**

unit inserted between the supply and one or more tungsten-halogen or other filament lamps which serves to supply the lamp(s) with its (their) rated voltage, generally at high frequency

Note 1 to entry: The unit may consist of one or more separate components and may include means for dimming, correcting the power factor and suppressing radio interference.

[SOURCE: IEC 61347-2-2:2011, 3.1, modified – Additional information has been transferred to a note to entry.]

3.8**controlgear for LED light sources****3.8.1****electronic controlgear for LED light sources
convertor**

unit inserted between the supply and one or more LED light sources which serves to supply the LED light source(s) with its (their) rated voltage or rated current

Note 1 to entry: The unit may consist of one or more separate components and may include means for dimming, correcting the power factor and suppressing radio interference, and further control functions

Note 2 to entry: The controlgear consists of a power supply and a control unit.

Note 3 to entry: The controlgear may be partly or totally integrated in the LED module.

Note 4 to entry: When there is no risk of confusion, as in a LED standard for example, “controlgear” may also be used. Both terms “controlgear” or “control gear” are acceptable.

[SOURCE: IEC 61347-2-13:2014, 3.1, modified – “LED modules” has been replaced with “LED light sources” and Note 4 has been added.]

3.8.2**power supply of the controlgear**

electronic device, being part of the controlgear, capable of controlling current, voltage or power within design limits and containing no additional LED control capabilities

Note 1 to entry: For LEDsi modules, the power supply of the controlgear is separate from the LED module on a distant location.

Note 2 to entry: The energy source of a power supply can be either a battery or the electrical supply system.

3.8.3

control unit of the controlgear

electronic device, being part of the controlgear, responsible for controlling the electrical energy to the LED light sources as well as colour mixing, response to depreciating luminous flux and further performance features

Note 1 to entry: In LEDsi modules, the control unit of the controlgear is on board the LED module and separate from the power supply of the controlgear.

3.9

controlgear-light source circuit

electrical circuit, or part thereof, normally built in a luminaire, consisting of the controlgear and light source(s)

[SOURCE: IEC 62442-1:2018, 3.8, modified – "lamp" has been replaced with "light source".]

3.10

standby power

average power consumption of a controlgear when subjected to standby mode

Note 1 to entry: Power supplied by controlgear to sensors, network connections and other auxiliaries is not included in the standby power.

Note 2 to entry: Standby power is expressed in W.

3.11

standby mode

mode of the controlgear, in which the light source is switched off by a control signal, while the controlgear remains connected to the mains supply not including failed lamp(s) or light source(s)

Note 1 to entry: Failed light source(s) could lead to incorrect measurements.

3.12

no-load mode

mode relevant for those controlgear which are permanently connected to the mains, where the lamp(s) or light source(s) are switched off via a switch on the output circuit of the controlgear

3.13

total input power

total power consumed by the controlgear-lamp (light source) circuit measured at rated input voltage

[SOURCE: IEC 62442-1:2018, 3.13, modified – "supplied to" has been replaced with "consumed by", "(light source)" has been added and the note has been deleted.]

3.14

controlgear efficiency

η_{CG}

<filament lamp(s) or LED light source(s)> ratio of the output power to lamp(s) (light source) and the input power of the controlgear

Note 1 to entry: Detailed measurement method and conditions are given in Clause 5.

Note 2 to entry: Loads from sensors, network connections or other auxiliaries are disconnected or, if not possible, otherwise, eliminated from the result.

4 General

4.1 Applicability

The measurement and calculation methods in this document shall only be used for magnetic transformers which conform to IEC 61558-1 and IEC 61558-2-6 or for electronic convertors which conform to IEC 61347-2-2 or for electronic controlgear for LED modules which conforms to IEC 61347-2-13.

4.2 General notes on tests

The measurement conditions specified in IEC 61347-1:2015, Clauses H.1, H.2, H.4, H.8 and H.11 shall be applied; unless otherwise specified in this document. The device under test (DUT) shall be placed according to IEC 61347-1:2015, Figure H.1.

An AC or DC voltage source shall be used to provide input voltage to the DUT. During the tests, the supply voltage and the frequency shall be maintained constant within $\pm 0,5$ % during the warm-up period. However, during the actual measurement, the voltage shall be adjusted to within $\pm 0,2$ % of the specified testing value.

The input voltage source should be capable of delivering at least three times the input power of the DUT.

4.3 Controllable controlgear

In the case of controllable controlgear the test shall be carried out with the maximum output power.

In case a controlgear has multiple channels, each channel shall be set at the same power level. The sum of the power per channel shall be equal to the maximum allowed output power of the controlgear.

Requirements relevant for the efficiency during the dimming condition of controllable controlgear are under consideration.

4.4 Measurement uncertainty

Measurement uncertainty shall be managed in accordance with the accuracy method in IEC Guide 115:2007, 4.4.3.

4.5 Sampling of controlgear for testing

The requirements and tolerances specified in this document are based on the testing of a type test sample submitted by the manufacturer for that purpose. This sample should consist of units having characteristics typical of the manufacturer's production and be as close to the production centre point values as possible.

4.6 Size of the test sample

Tests are carried out with one test specimen.

4.7 Power supply

Where the test voltage and frequency are not defined by national or regional requirements, the controlgear manufacturer shall declare the nominal voltage(s) at which the given efficiency is valid.

Test voltage(s) and test frequency(ies) shall be the nominal voltage and the nominal frequency of the country for which the measurement is being determined (refer to Table 1).

Table 1 – Typical nominal electricity supply details for some regions

Country / Region	Nominal voltage and frequency ^a
Europe	230 V; 50 Hz
North America	120 V, 277 V; 60 Hz
Japan ^b	100 V, 200 V; 50/60 Hz
China	220 V; 50 Hz
Australia and New Zealand	230 V; 50 Hz
^a Values are for single phase only. Some single phase supply voltages can be double the nominal voltage above (centre transformer tap). The voltage between two phases of a three-phase system is 1,73 times single phase values. (e.g. 400 V for Europe). ^b 50 Hz is applicable for the Eastern part and 60 Hz for the Western part.	

4.8 Supply voltage waveform

The total harmonic content of the supply voltage when supplying the DUT shall not exceed 3 %; harmonic content is defined as the root-mean-square (RMS) summation of the individual components using the fundamant as 100 %.

The ratio of peak value to RMS value of the test voltage (i.e. crest factor) shall be between 1,34 and 1,49.

4.9 Substitution load

To give reproducible measurement results, a resistor R_{load} shall be used as a replacement for the lamp(s) (light source(s)). R_{load} is determined from the rated output power and the rated output voltage or rated output current of the controlgear.

During the test, R_{load} shall be within 1% of the calculated resistance.

For electronic controlgear for LED light sources, a pure resistive load may cause malfunction of the DUT. In these cases a combination of diodes and variable resistor equivalent to the LED light source shall be used, to ensure the maximum rated output current at the rated output voltage.

NOTE When a special starting procedure is used to allow the constant current controlgear to function properly, the method with the equivalent resistor can be used.

In the case of controlgear with an output frequency higher than 70 Hz for tungsten-halogen lamps, the load shall always be a lamp as indicated in IEC 61047:2004, 4.2.

The measurement setup circuit for constant power controlgear shall also be used in a suitable way with the current defined in the data sheets of the lamp(s) (LED light source(s)).

4.10 Thermocouple and temperature indicator

The resolution of the temperature indicator shall be at least 0,1 °C, when used with the appropriate thermocouple.

4.11 Instrument accuracy

For electromagnetic transformers, calibrated and traceable AC power meters, power analysers or digital power meters shall be used. For measurement uncertainty and traceability see ISO/IEC Guide 98-3:2008 and IEC Guide 115.

For electronic step-down convertors, all output power measurements shall be made with a calibrated and traceable wideband power analyser or digital power meter.

The power measuring instrument shall be capable of measuring DC and AC 10 Hz to 2 000 Hz components.

For measurements made under the scope of this document, measurement instruments with the following minimum accuracies shall be used.

a) For frequencies up to and including 1 kHz:

- voltage: 0,5 %
- current: 0,5 %
- power: 1,0 %
- frequency: 0,1 %

b) For frequencies above 1 kHz:

- voltage: 1,0 %
- current: 1,0 %
- power: 2,0 %

The power consumption shall be measured by applying the procedure of IEC 62301:2011, 5.3 excluding 5.3.4.

Stability of the measurement values (V, A or W) is given if the data does not deviate from more than 1 % in a time frame of 15 min. If any of these values vary with time, the power is determined as the arithmetic mean value over a sufficient period.

Measurement shall be done in such a way that the line losses are limited (for example with a four wire measurement system).

4.12 Measuring circuits

When the controlgear has supplementary connections to the output circuit or sensors (e.g. to detect fault or temperatures for example to ensure a safe function of the controlgear), all these sensors and circuits shall be connected as in normal use; sensors or networks which are not involved in power conversion shall be disconnected (see 4.15).

4.13 Multi-rated voltage controlgear

If a controlgear is designed for more than one rated voltage, the controlgear manufacturer shall declare the rated voltage(s) at which the given efficiency and the standby power are valid.

4.14 Multi-power controlgear

If a controlgear is designed for more than one output power, the test shall be carried out with the maximum output power.

4.15 Sensor and network connections


For the measurement of all kinds of controlgear power (also standby) the power consumed by all circuits (internal or external) which are not involved in power conversion for the controlgear operation (e.g. communication devices, external sensors, auxiliary load, battery charging circuits) shall be excluded from the measurements. If the auxiliary cannot be disconnected, its effect shall be otherwise eliminated from the result.

NOTE Power consumed by circuits necessary for the proper operation of power conversion is considered in the measurement (e.g. cooling fan, signalling lighting).

5 Method of measurement and calculation of the efficiency of controlgear (transformer, convertor) for tungsten-halogen lamps and for LED light sources

5.1 Measurement setup: input and output power

Figure 1 shows the setup for the measurement of the power losses of electromagnetic controlgear and the input and output power of convertor-electronic controlgear.



Key

DUT	device under test
U	voltage
I	current
P	power
R_{load}	substitution load

Figure 1 – Power losses measurement setup for electromagnetic controlgear (transformer) and input and output power measurement setup for convertor (electronic controlgear)

The information regarding the substitution load is given under 4.9. The measurements are carried out with power meters connected to measure the total input power into and the output power (lamp (light source) power) of the DUT.

The value of the total input power $P_{tot.meas}$ is recorded when a steady state has been reached (temperature of the DUT).

The supply voltage for the measurement according to Figure 1 is defined in 4.7 and 4.13.

The measurement sequence is as follows:

- 1) Connect the DUT according to Figure 1.
- 2) Switch on the mains voltage.
- 3) Await the thermal equilibrium.
- 4) Measure the input and the output power.

The total input power $P_{tot.meas}$ of a DUT is measured on one DUT.

$P_{tot.meas}$ is the measured total input power into the DUT (in W);

P_{Lamp} is the measured output power of the DUT (lamp (light source) power-power on the substitution resistor) in the test circuit (in W).

In the case of multi output controlgear, P_{Lamp} is the sum of all the power measured in each channel.


5.2 Efficiency calculation for electromagnetic (transformer) and electronic (convertor) controlgear

For the calculation of the efficiency of a DUT (η_{CG}), Equation (1) should be used:

$$\eta_{CG} = \frac{P_{\text{light source}}}{P_{\text{tot meas}}} \quad (1)$$

5.3 Measurement setup: input power in no-load mode

Figure 2 shows the setup for the measurement of the input power losses in no-load mode for electromagnetic controlgear and for a convertor (electronic controlgear).



Key

DUT	device under test
U	voltage
I	current
P	power

Figure 2 – Input power in no-load mode measurement setup for electromagnetic controlgear (transformer) and for convertor (electronic controlgear)

The substitution load is disconnected from the DUT-open output circuit (see Figure 2). The measurements are carried out with a power meter connected to measure the total input power into the DUT. Measurement of power shall be current correct (i.e. measurement in the DUT path).

The value of the total input power in no-load mode $P_{\text{tot meas no-load}}$ is recorded when a steady state has been reached (temperature of the DUT).

The supply voltage for the measurement according to Figure 2 is defined in 4.7 and 4.13.

The measurement sequence is as follows:

- 1) Connect the DUT according to Figure 2.
- 2) Switch on the mains voltage.
- 3) Await the thermal equilibrium.
- 4) Measure the input power.

The measured total input power in no-load mode $P_{\text{tot meas no-load}}$ of a DUT is measured on one DUT.

$P_{\text{tot meas no-load}}$ is the measured total input power into the DUT (in W) in no-load mode.

5.4 Standby power measurement of convertor-electronic controlgear

Figure 3 shows the measurement setup of the standby power of convertor-electronic controlgear.




Figure 3 – Measurement setup of the standby power of convertor-electronic controlgear

Information regarding the substitution load is given under 4.9.

The measurements are carried out with a power meter connected to measure the total input power into the convertor-electronic controlgear. Measurement of power shall be current correct (i.e. measurement in the DUT path).

The value of the standby power $P_{CGstandby}$ (total input power) is recorded when a steady state has been reached (temperature of the convertor-electronic controlgear).

The supply voltage for the measurement according to Figure 3 is defined in 4.7 and 4.13.

The measurement sequence is as follows:

- 1) Connect the DUT according to Figure 3.
- 2) Switch on the mains voltage.
- 3) Set the controlgear via the interface port (for example “digital addressable lighting interface”) to the standby mode.
- 4) Await the thermal equilibrium.
- 5) Measure the standby power (total input power).

The standby power $P_{CGstandby}$ (total input power) of a convertor-controlgear is measured with one electronic lamp controlgear.

Bibliography

IEC 60357, *Tungsten halogen lamps (non-vehicle) – Performance specifications*

IEC 62384, *DC or AC supplied electronic control gear for LED modules – Performance requirements*

IEC 62442-1:2018, *Energy performance of lamp controlgear – Part 1: Controlgear for fluorescent lamps – Method of measurement to determine the total input power of controlgear circuits and the efficiency of the controlgear*

IEC 62442-2, *Energy performance of lamp controlgear – Part 2: Controlgear for high intensity discharge lamps (excluding fluorescent lamps) – Method of measurement to determine the efficiency of the controlgear*

ISO/IEC Guide 98-3:2008, *Uncertainty of measurement – Part 3: Guide to the expression of uncertainty in measurement (GUM:1995)*

IECNORM.COM : Click to view the full PDF of IEC 62442-3:2018

SOMMAIRE

AVANT-PROPOS	17
1 Domaine d'application	19
2 Références normatives	19
3 Termes et définitions	20
4 Généralités	23
4.1 Applicabilité	23
4.2 Généralités sur les essais	23
4.3 Appareillage commandable	23
4.4 Incertitude de mesure	23
4.5 Echantillonnage des appareillages pour les essais	24
4.6 Nombre d'échantillons d'essai	24
4.7 Alimentation	24
4.8 Forme d'onde de la tension d'alimentation	24
4.9 Charge de substitution	24
4.10 Thermocouple et indicateur de température	25
4.11 Précision des appareils	25
4.12 Circuits de mesure	26
4.13 Appareillage à tensions assignées multiples	26
4.14 Appareillage à puissances multiples	26
4.15 Capteur et raccordements au réseau	26
5 Méthode de mesure et calcul du rendement des appareillages (transformateur, convertisseur) pour les lampes tungstène-halogène et pour les sources lumineuses à LED	26
5.1 Montage de mesure: puissance d'entrée et de sortie	26
5.2 Calcul du rendement pour les appareillages électromagnétiques (transformateur) et électroniques (convertisseur)	27
5.3 Montage de mesure: puissance d'entrée en mode à vide	28
5.4 Mesure de la puissance de veille d'un convertisseur-appareillage électronique	28
Bibliographie	30
Figure 1 – Montage pour la mesure des pertes de puissance d'un appareillage électromagnétique (transformateur) et pour la mesure de la puissance d'entrée et de sortie d'un convertisseur (appareillage électronique)	27
Figure 2 – Montage pour la mesure de la puissance d'entrée en mode à vide d'un appareillage électromagnétique (transformateur) et d'un convertisseur (appareillage électronique)	28
Figure 3 – Montage pour la mesure de la puissance de veille d'un convertisseur-appareillage électronique	29
Tableau 1 – Détails relatifs à l'alimentation en électricité nominale type pour certaines régions	24

COMMISSION ÉLECTROTECHNIQUE INTERNATIONALE

PERFORMANCE ÉNERGÉTIQUE DES APPAREILLAGES DE LAMPES –

**Partie 3: Appareillage de lampes tungstène-halogène
et sources lumineuses à LED – Méthode de mesure
pour la détermination du rendement des appareillages**

AVANT-PROPOS

- 1) La Commission Electrotechnique Internationale (IEC) est une organisation mondiale de normalisation composée de l'ensemble des comités électrotechniques nationaux (Comités nationaux de l'IEC). L'IEC a pour objet de favoriser la coopération internationale pour toutes les questions de normalisation dans les domaines de l'électricité et de l'électronique. A cet effet, l'IEC – entre autres activités – publie des Normes internationales, des Spécifications techniques, des Rapports techniques, des Spécifications accessibles au public (PAS) et des Guides (ci-après dénommés "Publication(s) de l'IEC"). Leur élaboration est confiée à des comités d'études, aux travaux desquels tout Comité national intéressé par le sujet traité peut participer. Les organisations internationales, gouvernementales et non gouvernementales, en liaison avec l'IEC, participent également aux travaux. L'IEC collabore étroitement avec l'Organisation Internationale de Normalisation (ISO), selon des conditions fixées par accord entre les deux organisations.
- 2) Les décisions ou accords officiels de l'IEC concernant les questions techniques représentent, dans la mesure du possible, un accord international sur les sujets étudiés, étant donné que les Comités nationaux de l'IEC intéressés sont représentés dans chaque comité d'études.
- 3) Les Publications de l'IEC se présentent sous la forme de recommandations internationales et sont agréées comme telles par les Comités nationaux de l'IEC. Tous les efforts raisonnables sont entrepris afin que l'IEC s'assure de l'exactitude du contenu technique de ses publications; l'IEC ne peut pas être tenue responsable de l'éventuelle mauvaise utilisation ou interprétation qui en est faite par un quelconque utilisateur final.
- 4) Dans le but d'encourager l'uniformité internationale, les Comités nationaux de l'IEC s'engagent, dans toute la mesure possible, à appliquer de façon transparente les Publications de l'IEC dans leurs publications nationales et régionales. Toutes divergences entre toutes Publications de l'IEC et toutes publications nationales ou régionales correspondantes doivent être indiquées en termes clairs dans ces dernières.
- 5) L'IEC elle-même ne fournit aucune attestation de conformité. Des organismes de certification indépendants fournissent des services d'évaluation de conformité et, dans certains secteurs, accèdent aux marques de conformité de l'IEC. L'IEC n'est responsable d'aucun des services effectués par les organismes de certification indépendants.
- 6) Tous les utilisateurs doivent s'assurer qu'ils sont en possession de la dernière édition de cette publication.
- 7) Aucune responsabilité ne doit être imputée à l'IEC, à ses administrateurs, employés, auxiliaires ou mandataires, y compris ses experts particuliers et les membres de ses comités d'études et des Comités nationaux de l'IEC, pour tout préjudice causé en cas de dommages corporels et matériels, ou de tout autre dommage de quelque nature que ce soit, directe ou indirecte, ou pour supporter les coûts (y compris les frais de justice) et les dépenses découlant de la publication ou de l'utilisation de cette Publication de l'IEC ou de toute autre Publication de l'IEC, ou au crédit qui lui est accordé.
- 8) L'attention est attirée sur les références normatives citées dans cette publication. L'utilisation de publications référencées est obligatoire pour une application correcte de la présente publication.
- 9) L'attention est attirée sur le fait que certains des éléments de la présente Publication de l'IEC peuvent faire l'objet de droits de brevet. L'IEC ne saurait être tenue pour responsable de ne pas avoir identifié de tels droits de brevets et de ne pas avoir signalé leur existence.

La Norme internationale IEC 62442-3 a été établie par le sous-comité 34C: Appareils auxiliaires pour lampes, du comité d'études 34 de l'IEC: Lampes et équipements associés.

Cette deuxième édition annule et remplace la première édition parue en 2014. Cette édition constitue une révision technique. Cette édition constitue une révision technique et elle a été harmonisée avec l'IEC 62442-1 et l'IEC 62442-2.

Le texte de cette Norme internationale est issu des documents suivants:

CDV	Rapport de vote
34C/1344/CDV	34C/1378/RVC

Le rapport de vote indiqué dans le tableau ci-dessus donne toute information sur le vote ayant abouti à l'approbation de cette Norme internationale.

Ce document a été rédigé selon les Directives ISO/IEC, Partie 2.

Une liste de toutes les parties de la série IEC 62442, publiées sous le titre général *Performance énergétique des appareillages de lampes*, peut être consultée sur le site web de l'IEC.

Le comité a décidé que le contenu de ce document ne sera pas modifié avant la date de stabilité indiquée sur le site web de l'IEC sous "<http://webstore.iec.ch>" dans les données relatives au document recherché. A cette date, le document sera

- reconduit,
- supprimé,
- remplacé par une édition révisée, ou
- amendé.

IECNORM.COM : Click to view the full PDF of IEC 62442-3:2018

PERFORMANCE ÉNERGÉTIQUE DES APPAREILLAGES DE LAMPES –

Partie 3: Appareillage de lampes tungstène-halogène et sources lumineuses à LED – Méthode de mesure pour la détermination du rendement des appareillages

1 Domaine d'application

La présente partie de l'IEC 62442 définit une méthode pour mesurer les pertes de puissance rencontrées par les transformateurs électromagnétiques ainsi que les pertes de puissance et la puissance de veille des convertisseurs électroniques sur les lampes tungstène-halogène et pour la ou les sources lumineuses à LED.

Elle est applicable aux appareillages conçus pour être utilisés sur des alimentations en courant continu jusqu'à 1 000 V et/ou des alimentations en courant alternatif jusqu'à 1 000 V à 50 Hz ou 60 Hz.

Une méthode de calcul du rendement des appareillages mentionnés pour les lampes tungstène-halogène et pour la ou les sources lumineuses à LED est également définie.

Le présent document s'applique aux circuits d'appareillage électrique-lampe constitués exclusivement de l'appareillage et de la ou des lampes (sources lumineuses à LED).

Pour les alimentations à usages multiples, seule la partie éclairage sera prise en compte.

NOTE Les exigences pour les essais individuels des appareillages pendant la production ne sont pas incluses.

Le présent document spécifie la méthode de mesure de la puissance d'entrée totale, de la puissance de veille et la méthode de calcul du rendement pour tous les appareillages de lampes à usage domestique et commercial normal, fonctionnant avec les lampes tungstène-halogène et la ou les sources lumineuses à LED. Le terme "sources lumineuses à LED" inclut les modules de LED et les lampes à LED.

Le présent document ne s'applique pas:

- aux appareillages qui font partie intégrante des lampes (sources lumineuses à LED);
- aux circuits d'appareillages à condensateurs reliés en série;
- aux appareillages électromagnétiques commandables.

2 Références normatives

Les documents suivants cités dans le texte constituent, pour tout ou partie de leur contenu, des exigences du présent document. Pour les références datées, seule l'édition citée s'applique. Pour les références non datées, la dernière édition du document de référence s'applique (y compris les éventuels amendements).

IEC 61047:2004, *Convertisseurs abaisseurs électroniques alimentés en courant continu ou alternatif pour lampes à incandescence – Exigences de performances*

IEC 61347-1:2015, *Appareillages de lampes – Partie 1: Exigences générales et exigences de sécurité*

IEC 61347-2-2, *Appareillages de lampes – Partie 2-2: Exigences particulières pour les convertisseurs abaisseurs électroniques alimentés en courant continu ou alternatif pour lampes à incandescence*

IEC 61347-2-13, *Appareillages de lampes – Partie 2-13: Exigences particulières pour les appareillages électroniques alimentés en courant continu ou en courant alternatif pour modules de LED*

IEC 61558-1, *Sécurité des transformateurs, bobines d'inductance, blocs d'alimentation et des combinaisons de ces éléments – Partie 1: Exigences générales et essais*

IEC 61558-2-6, *Sécurité des transformateurs, bobines d'inductance, blocs d'alimentation et produits analogues pour des tensions d'alimentation jusqu'à 1 100 V – Partie 2-6: Règles particulières et essais pour les transformateurs de sécurité et les blocs d'alimentation incorporant des transformateurs de sécurité*

IEC 62301:2011, *Appareils électrodomestiques – Mesure de la consommation en veille*

Guide IEC 115:2007, *Application de l'incertitude de mesure aux activités d'évaluation de la conformité dans le secteur électrotechnique*

3 Termes et définitions

Pour les besoins du présent document, les termes et définitions suivants s'appliquent.

L'ISO et l'IEC tiennent à jour des bases de données terminologiques destinées à être utilisées en normalisation, consultables aux adresses suivantes:

- IEC Electropedia: disponible à l'adresse <http://www.electropedia.org/>
- ISO Online browsing platform: disponible à l'adresse <http://www.iso.org/obp>

3.1

valeur nominale

valeur approchée appropriée d'une grandeur, utilisée pour dénommer ou identifier un composant, un dispositif ou un matériel

[SOURCE: IEC 62442-1:2018, 3.1]

3.2

valeur assignée

valeur d'une grandeur correspondant à des conditions de fonctionnement spécifiées d'un composant, d'un dispositif ou d'un matériel

Note 1 à l'article: La valeur et les conditions sont spécifiées dans la norme applicable, ou attribuées par le fabricant ou le fournisseur compétent.

[SOURCE: IEC 62442-1:2018, 3.3, modifiée – La note 2 a été supprimée.]

3.3

appareillage

composant unique ou ensemble de composants insérés entre l'alimentation et une ou plusieurs lampes (source(s) lumineuses à LED), pouvant servir à transformer la tension d'alimentation, limiter le courant de la ou des lampes (source(s) lumineuse(s) à LED) à la valeur requise, le facteur de puissance correct, ou réduire les perturbations radioélectriques

[SOURCE: IEC 62442-1:2018, 3.4 modifiée – la mention «fournir la tension d'amorçage et le courant de préchauffage, empêcher le démarrage à froid» a été supprimée et "(source(s) lumineuse(s) à LED)" a été ajouté.]

3.4

appareillage électromagnétique

appareillage magnétique

appareillage qui, via l'inductance, ou une combinaison de l'inductance et de la capacité, sert principalement à limiter le courant de la ou des lampes (source(s) lumineuse(s) à LED) à la valeur requise et fait fonctionner la ou les lampes à la même fréquence que la fréquence d'alimentation

[SOURCE: IEC 62442-1:2018, 3.5, modifiée – "(source(s) lumineuse(s) à LED)" a été ajouté.]

3.5

transformateur électromagnétique

transformateur magnétique

transformateur

appareillage électromagnétique qui transforme la tension d'alimentation pour faire fonctionner la ou les lampes (source(s) lumineuse(s) à LED) avec la même fréquence que la fréquence d'alimentation à la tension assignée des lampes (sources lumineuses)

3.6

appareillage électronique

<lampes à filament ou sources lumineuses à LED> circuit électronique alimenté en courant alternatif et/ou continu comprenant des éléments de stabilisation pour le fonctionnement d'une ou plusieurs lampes à filament ou d'une ou plusieurs sources lumineuses à LED

3.7

convertisseur abaisseur électronique

convertisseur

appareil inséré entre l'alimentation et une ou plusieurs lampes tungstène-halogène ou autres lampes à filament, qui a pour fonction d'alimenter la ou les lampes à leur tension assignée, généralement à haute fréquence

Note 1 à l'article: Cet appareil peut être constitué d'un ou de plusieurs éléments séparés et il peut inclure des dispositifs pour la gradation, la correction du facteur de puissance et la suppression des perturbations radioélectriques.

[SOURCE: IEC 61347-2-2:2011, 3.1, modifiée – Les informations complémentaires ont été transférées dans une note à l'article.]

3.8

appareillages pour sources lumineuses à LED

3.8.1

appareillage électronique pour sources lumineuses à LED

convertisseur

appareil inséré entre l'alimentation et une ou plusieurs sources lumineuses à LED, qui est destiné à alimenter la ou les sources lumineuses à LED à leur tension assignée ou courant assigné

Note 1 à l'article: Cet appareil peut être constitué d'un ou de plusieurs éléments séparés et il peut inclure des dispositifs pour la gradation, la correction du facteur de puissance et la suppression des perturbations radioélectriques, ainsi que pour d'autres fonctions de commande.

Note 2 à l'article: L'appareillage est constitué d'une alimentation et d'une unité de commande.

Note 3 à l'article: L'appareillage peut être partiellement ou totalement intégré dans le module de LED.

Note 4 à l'article: Lorsqu'il n'y a pas de risque de confusion, par exemple dans une norme de LED, le terme "appareillage" peut également être utilisé. En anglais, les termes "controlgear" ou "control gear" sont acceptables.

[SOURCE: IEC 61347-2-13:2014, 3.1, modifiée – "modules de LED" a été remplacé par "sources lumineuses à LED" et la note 4 a été ajoutée.]

3.8.2

alimentation de l'appareillage

dispositif électronique, faisant partie de l'appareillage, capable de contrôler le courant, la tension ou la puissance, dans les limites de conception, et ne contenant pas de moyens de contrôle de LED supplémentaires

Note 1 à l'article: Pour les modules LEDsi, l'alimentation de l'appareillage est distincte du module de LED lorsqu'ils sont éloignés.

Note 2 à l'article: La source d'énergie d'une alimentation peut être soit une batterie, soit le système d'alimentation électrique.

3.8.3

unité de commande de l'appareillage

dispositif électronique, faisant partie de l'appareillage, responsable du contrôle de l'énergie électrique vers les sources lumineuses à LED ainsi que du mélange de couleurs, de la réponse à la dépréciation du flux lumineux et autres caractéristiques de performance

Note 1 à l'article: Dans les modules LEDsi, l'unité de commande de l'appareillage se trouve sur la carte du module de LED et est séparée de l'alimentation de l'appareillage.

3.9

circuit appareillage-source lumineuse

circuit électrique, ou partie de ce circuit, habituellement intégré à un luminaire, comprenant l'appareillage et la ou les sources lumineuses

[SOURCE: IEC 62442-1:2018 3.8, modifiée – le terme "lampe" a été remplacé par "source lumineuse".]

3.10

puissance de veille

consommation de puissance moyenne d'un appareillage lorsqu'il se trouve en mode veille

Note 1 à l'article: La puissance fournie par l'appareillage aux capteurs, raccordements au réseau et autres appareils auxiliaires n'est pas prise en compte dans la puissance de veille.

Note 2 à l'article: La puissance de veille est exprimée en W.

3.11

mode veille

mode applicable à un appareillage dans lequel la source lumineuse est éteinte par l'intermédiaire d'un signal de commande, l'appareillage étant branché au réseau, ne comprenant pas la ou les lampes ou la ou les sources lumineuses défectueuses

Note 1 à l'article: La ou les sources lumineuses défectueuses seraient susceptibles de donner des mesures incorrectes.

3.12

mode à vide

mode dans lequel se trouvent les appareillages qui sont branchés en permanence au réseau, lorsque la ou les lampes ou la ou les sources lumineuses sont éteintes grâce à un interrupteur situé sur le circuit de sortie de l'appareillage

3.13

puissance d'entrée totale

puissance totale consommée par le circuit d'appareillage-lampe (source lumineuse), mesurée à la tension d'entrée assignée

[SOURCE: IEC 62442-1:2018, 3.13, modifiée – "fournie au" a été remplacé par "consommée par", "(source lumineuse)" a été ajouté et la note a été supprimée.]

3.14

rendement de l'appareillage

η_{CG}

<lampe(s) à filament ou source(s) lumineuse(s) à LED> rapport entre la puissance de sortie de la ou des lampes (source lumineuse) et la puissance d'entrée de l'appareillage

Note 1 à l'article: La méthode de mesure et les conditions détaillées sont données à l'Article 5.

Note 2 à l'article: Les charges provenant des capteurs, des raccordements au réseau ou autres appareils auxiliaires sont déconnectées ou, si cela n'est pas possible, elles sont éliminées d'une autre manière du résultat.

4 Généralités

4.1 Applicabilité

Les méthodes de mesure et de calcul spécifiées dans le présent document doivent uniquement être utilisées pour les transformateurs magnétiques conformes à l'IEC 61558-1 et l'IEC 61558-2-6 ou pour les convertisseurs électroniques conformes à l'IEC 61347-2-2, ou pour les appareillages électroniques pour les modules de LED conformes à l'IEC 61347-2-13.

4.2 Généralités sur les essais

Les conditions de mesure spécifiées dans l'IEC 61347-1:2015, Articles H.1, H.2, H.4, H.8 et H.11 doivent s'appliquer; sauf spécification contraire dans le présent document. Le dispositif en essai (DUT, *device under test*) doit être positionné conformément à l'IEC 61347-1:2015, Figure H.1.

Une source de tension alternative ou continue doit être utilisée pour fournir la tension d'entrée au dispositif en essai. Au cours des essais, la tension d'alimentation et la fréquence doivent être maintenues constantes à $\pm 0,5\%$ pendant le temps de réchauffement. Cependant, au moment de la mesure réelle, la tension doit être ajustée à $\pm 0,2\%$ de la valeur d'essai spécifiée.

Il convient que la source de tension d'entrée soit capable de délivrer au moins trois fois la puissance d'entrée du dispositif en essai.

4.3 Appareillage commandable

Dans le cas d'un appareillage commandable, l'essai doit être réalisé avec la puissance de sortie maximale.

Dans le cas d'un appareillage comportant plusieurs canaux, chaque canal doit être réglé au même niveau de puissance. La somme de la puissance par canal doit être égale à la puissance de sortie maximale autorisée de l'appareillage.

Les exigences relatives au rendement au cours d'un état de variation des appareillages commandables sont à l'étude.

4.4 Incertitude de mesure

L'incertitude de mesure doit être gérée conformément à la méthode d'exactitude du Guide IEC 115:2007, 4.4.3.

4.5 Echantillonnage des appareillages pour les essais

Les exigences et les tolérances spécifiées dans le présent document se rapportent à l'essai d'un échantillon d'essai de type présenté en tant que tel par le fabricant. Il convient que cet échantillon soit constitué d'unités présentant des caractéristiques typiques de la production du fabricant, et qu'il soit aussi proche que possible des valeurs médianes de la production.

4.6 Nombre d'échantillons d'essai

Les essais sont réalisés avec un échantillon d'essai.

4.7 Alimentation

Lorsque la tension et la fréquence d'essai ne sont pas définies par des exigences nationales ou régionales, le fabricant de l'appareillage doit déclarer la ou les tensions nominales auxquelles le rendement donné est valide.

La ou les tensions d'essai et la ou les fréquences d'essai doivent être la tension nominale et la fréquence nominale du pays pour lequel la mesure est déterminée (voir Tableau 1).

Tableau 1 – Détails relatifs à l'alimentation en électricité nominale type pour certaines régions

Pays/ Région	Tension et fréquence nominales ^a
Europe	230 V; 50 Hz
Amérique du Nord	120 V, 277 V; 60 Hz
Japon ^b	100 V, 200 V; 50/60 Hz
Chine	220 V; 50 Hz
Australie et Nouvelle-Zélande	230 V; 50 Hz
^a Les valeurs sont valables en monophasé uniquement. Certaines tensions d'alimentation monophasées peuvent être le double de la tension nominale ci-dessus (prise de transformateur centrale). La tension entre deux phases d'un système triphasé correspond à 1,73 fois les valeurs en monophasé (par exemple 400 V pour l'Europe).	
^b 50 Hz est applicable pour la partie est du pays, et 60 Hz pour la partie ouest.	

4.8 Forme d'onde de la tension d'alimentation

La teneur totale en harmoniques de la tension d'alimentation du dispositif en essai ne doit pas dépasser 3 %; la teneur en harmoniques est définie comme la somme des valeurs efficaces des composantes individuelles, la tension fondamentale étant de 100 %.

Le rapport de la valeur de crête à la valeur efficace de la tension d'essai (c'est-à-dire le facteur de crête) doit être compris entre 1,34 et 1,49.

4.9 Charge de substitution

Pour obtenir des résultats de mesure qui soient reproductibles, une résistance R_{charge} doit être utilisée en substitution de la ou des lampes (source(s) lumineuse(s)). R_{charge} est déterminée à partir de la puissance de sortie assignée et de la tension de sortie assignée ou du courant de sortie assigné de l'appareillage.

Au cours de l'essai, la valeur R_{charge} doit se situer à 1 % de la résistance calculée.

En ce qui concerne les appareillages électroniques pour les sources lumineuses à LED, une charge résistive pure peut engendrer un dysfonctionnement du dispositif en essai. Dans ces situations, une combinaison de diodes et de résistance variable équivalant à la source

lumineuse à LED doit être utilisée, en vue d'assurer un courant de sortie maximal assigné à la tension de sortie assignée.

NOTE Lorsqu'une procédure spéciale de démarrage est utilisée pour permettre à l'appareillage en courant constant de fonctionner correctement, la méthode utilisant la résistance équivalente peut être utilisée.

Dans le cas d'un appareillage doté d'une fréquence de sortie supérieure à 70 Hz pour les lampes tungstène-halogène, la charge doit toujours être une lampe, tel qu'indiqué dans l'IEC 61047:2004, 4.2.

Le circuit du montage de mesure pour un appareillage à puissance constante doit également être utilisé de manière appropriée avec le courant défini dans les feuilles de caractéristiques de la ou des lampes (source(s) lumineuse(s) à LED).

4.10 Thermocouple et indicateur de température

La résolution de l'indicateur de température doit être d'au moins 0,1 °C lorsqu'il est utilisé avec le thermocouple approprié.

4.11 Précision des appareils

Pour les transformateurs électromagnétiques, des wattmètres, analyseurs de puissance ou wattmètres numériques à courant alternatif, étalonnés et traçables, doivent être utilisés. Pour l'incertitude de mesure et la traçabilité, voir le Guide ISO/IEC 98-3 et le Guide IEC 115.

Pour les convertisseurs abaisseurs électroniques, toutes les mesures de puissance de sortie doivent être réalisées avec un analyseur de puissance ou wattmètre numérique à large bande étalonné et traçable.

L'appareil de mesure de la puissance doit être capable de mesurer les éléments en courant continu et en courant alternatif de 10 Hz à 2 000 Hz.

Pour les mesures réalisées conformément au domaine d'application du présent document, des appareils de mesure ayant les précisions minimales suivantes doivent être utilisés.

a) Pour les fréquences inférieures ou égales à 1 kHz:

- tension: 0,5 %
- courant: 0,5 %
- puissance: 1,0 %
- fréquence: 0,1 %

b) Pour les fréquences supérieures à 1 kHz:

- tension: 1,0 %
- courant: 1,0 %
- puissance: 2,0 %

La consommation de puissance doit être mesurée en appliquant la procédure de l'IEC 62301:2011, 5.3 à l'exclusion de 5.3.4.

La stabilité des valeurs mesurées (V, A ou W) est indiquée si les données ne s'écartent pas de plus de 1 % dans une durée de 15 min. Si l'une de ces valeurs varie avec le temps, la puissance est déterminée comme la valeur moyenne arithmétique sur une période suffisante.

Les mesures doivent être réalisées de manière à ce que les pertes de ligne soient limitées (par exemple avec un système de mesure à quatre fils).