

TECHNICAL REPORT



**High-voltage switchgear and controlgear –
Part 305: Capacitive current switching capability of air-insulated disconnectors
for rated voltages above 52 kV**

IECNORM.COM : Click to view the full PDF of IEC TR 62271-305:2009



THIS PUBLICATION IS COPYRIGHT PROTECTED

Copyright © 2009 IEC, Geneva, Switzerland

All rights reserved. Unless otherwise specified, no part of this publication may be reproduced or utilized in any form or by any means, electronic or mechanical, including photocopying and microfilm, without permission in writing from either IEC or IEC's member National Committee in the country of the requester.

If you have any questions about IEC copyright or have an enquiry about obtaining additional rights to this publication, please contact the address below or your local IEC member National Committee for further information.

Droits de reproduction réservés. Sauf indication contraire, aucune partie de cette publication ne peut être reproduite ni utilisée sous quelque forme que ce soit et par aucun procédé, électronique ou mécanique, y compris la photocopie et les microfilms, sans l'accord écrit de la CEI ou du Comité national de la CEI du pays du demandeur.

Si vous avez des questions sur le copyright de la CEI ou si vous désirez obtenir des droits supplémentaires sur cette publication, utilisez les coordonnées ci-après ou contactez le Comité national de la CEI de votre pays de résidence.

IEC Central Office
3, rue de Varembe
CH-1211 Geneva 20
Switzerland
Email: inmail@iec.ch
Web: www.iec.ch

About IEC publications

The technical content of IEC publications is kept under constant review by the IEC. Please make sure that you have the latest edition, a corrigenda or an amendment might have been published.

- Catalogue of IEC publications: www.iec.ch/searchpub

The IEC on-line Catalogue enables you to search by a variety of criteria (reference number, text, technical committee,...). It also gives information on projects, withdrawn and replaced publications.

- IEC Just Published: www.iec.ch/online_news/justpub

Stay up to date on all new IEC publications. Just Published details twice a month all new publications released. Available on-line and also by email.

- Electropedia: www.electropedia.org

The world's leading online dictionary of electronic and electrical terms containing more than 20 000 terms and definitions in English and French, with equivalent terms in additional languages. Also known as the International Electrotechnical Vocabulary online.

- Customer Service Centre: www.iec.ch/webstore/custserv

If you wish to give us your feedback on this publication or need further assistance, please visit the Customer Service Centre FAQ or contact us:

Email: csc@iec.ch
Tel.: +41 22 919 02 11
Fax: +41 22 919 03 00

TECHNICAL REPORT



**High-voltage switchgear and controlgear –
Part 305: Capacitive current switching capability of air-insulated disconnectors
for rated voltages above 52 kV**

INTERNATIONAL
ELECTROTECHNICAL
COMMISSION

ICS 29.130.10

ISBN 978-2-88910-659-2

CONTENTS

FOREWORD.....	3
1 Scope.....	5
2 Normative references	5
3 Terms and definitions	5
4 Background and purpose.....	5
5 Switching tests	5
5.1 Arrangement of the disconnecter for tests	5
5.2 Earthing of the test circuit and disconnecter	6
5.3 Test frequency	6
5.4 Test voltage	6
5.5 Test current.....	6
5.6 Test circuit	6
5.7 Tests.....	7
5.7.1 Test duties and measurements	7
5.7.2 Behaviour of disconnecter during tests	8
5.7.3 Condition of disconnecter after tests.....	8
5.8 Test reports.....	8
Annex A (informative) Analysis	9
Annex B (informative) Capacitive charging currents.....	14
Annex C (informative) Test circuits	15
Figure 1 – Test circuit in principle for capacitive current switching	7
Figure A.1 – Basic capacitive current switching circuit	9
Figure A.2 – Test oscillograms for current of 2 A and C_S/C_L ratios of 2,5 (Trace A) and 0,04 (Trace B).....	10
Figure A.3 – Circuit for restriking current calculation	12
Figure C.1 – Basic capacitive current switching circuit.....	15
Figure C.2 – Alternative test circuit	16
Figure C.3 – Restriking and integrated currents (in A and As, respectively) for the basic (dashed) traces) and alternative circuits (drawn traces). Horizontal axis in ms.....	17
Table 1 – Test tolerances	7
Table B.1 – Capacitive charging currents at 245 kV and below	14
Table B.2 – Capacitive charging currents at 300 kV to 550 kV	14
Table B.3 – Capacitive charging currents at 800 kV to 1200 kV	14

INTERNATIONAL ELECTROTECHNICAL COMMISSION

HIGH-VOLTAGE SWITCHGEAR AND CONTROLGEAR –

**Part 305: Capacitive current switching capability of air-insulated
disconnectors for rated voltages above 52 kV**

FOREWORD

- 1) The International Electrotechnical Commission (IEC) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, IEC publishes International Standards, Technical Specifications, Technical Reports, Publicly Available Specifications (PAS) and Guides (hereafter referred to as "IEC Publication(s)"). Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International governmental and non-governmental organizations liaising with the IEC also participate in this preparation. IEC collaborates closely with the International Organization for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.
- 2) The formal decisions or agreements of IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC National Committees.
- 3) IEC Publications have the form of recommendations for international use and are accepted by IEC National Committees in that sense. While all reasonable efforts are made to ensure that the technical content of IEC Publications is accurate, IEC cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.
- 4) In order to promote international uniformity, IEC National Committees undertake to apply IEC Publications transparently to the maximum extent possible in their national and regional publications. Any divergence between any IEC Publication and the corresponding national or regional publication shall be clearly indicated in the latter.
- 5) IEC itself does not provide any attestation of conformity. Independent certification bodies provide conformity assessment services and, in some areas, access to IEC marks of conformity. IEC is not responsible for any services carried out by independent certification bodies.
- 6) All users should ensure that they have the latest edition of this publication.
- 7) No liability shall attach to IEC or its directors, employees, servants or agents including individual experts and members of its technical committees and IEC National Committees for any personal injury, property damage or other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication, use of, or reliance upon, this IEC Publication or any other IEC Publications.
- 8) Attention is drawn to the Normative references cited in this publication. Use of the referenced publications is indispensable for the correct application of this publication.
- 9) Attention is drawn to the possibility that some of the elements of this IEC Publication may be the subject of patent rights. IEC shall not be held responsible for identifying any or all such patent rights.

The main task of IEC technical committees is to prepare International Standards. However, a technical committee may propose the publication of a technical report when it has collected data of a different kind from that which is normally published as an International Standard, for example "state of the art".

IEC 62271-305, which is a technical report, has been prepared by subcommittee 17A: High-voltage switchgear and controlgear, of IEC technical committee 17: Switchgear and controlgear.

The text of this technical report is based on the following documents:

Enquiry draft	Report on voting
17A/872/DTR	17A/885/RVC

Full information on the voting for the approval of this technical report can be found in the report on voting indicated in the above table.

This publication has been drafted in accordance with the ISO/IEC Directives, Part 2.

A list of all parts of the IEC 62271 series, published under the general title *High-voltage switchgear and controlgear*, can be found on the IEC website.

The committee has decided that the contents of this publication will remain unchanged until the maintenance result date indicated on the IEC web site under "<http://webstore.iec.ch>" in the data related to the specific publication. At this date, the publication will be

- reconfirmed,
- withdrawn,
- replaced by a revised edition, or
- amended.

A bilingual version of this publication may be issued at a later date.

The contents of the corrigendum of June 2017 have been included in this copy.

IMPORTANT – The “colour inside” logo on the cover page of this publication indicates that it contains colours which are considered to be useful for the correct understanding of its contents. Users should therefore print this publication using a colour printer.

HIGH-VOLTAGE SWITCHGEAR AND CONTROLGEAR –

Part 305: Capacitive current switching capability of air-insulated disconnectors for rated voltages above 52 kV

1 Scope

This technical report applies to high-voltage air-insulated disconnectors for rated voltages above 52 kV. The report describes the capacitive current switching duty and provides guidance on laboratory testing to demonstrate the switching capability. Air-insulated disconnectors equipped with auxiliary interrupting devices are included under this scope.

NOTE For manually operated disconnectors, the in-service safety of the operator should be considered and it should be recognized that the results of the switching tests described herein (performed using motor-operated disconnectors) are not necessarily representative of the performance of such disconnectors in actual service. Due diligence should be exercised if the switching tests indicate that prolonged arc durations are probable.

2 Normative references

The following referenced documents are indispensable for the application of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

IEC 62271-1: *High-voltage switchgear and controlgear – Part 1: Common specifications*

IEC 62271-102:2001 *High-voltage switchgear and controlgear – Part 102: Alternating current disconnectors and earthing switches*

3 Terms and definitions

For purposes of this part of IEC 62271 the terms and definitions in IEC 62271-1 and IEC 62271-102 apply.

4 Background and purpose

Disconnectors do not have current interrupting ratings but, by virtue of having one or more moving contacts during opening operations, they have a certain current switching capability. For capacitive currents and air-insulated disconnectors, this capability has in the past been taken as 0,5 A or less and no testing was defined. For gas-insulated disconnectors, the required capacitive current switching capability and test requirements are specified in Annex F of IEC 62271-102.

User requirements for capacitive current switching using air-insulated disconnectors frequently exceed the above-stated 0,5 A. The purpose, therefore, of this report is to provide an analysis of the switching duty (refer to Annex A) and to define testing procedures.

5 Switching tests

5.1 Arrangement of the disconnector for tests

The disconnector under test should be completely mounted on its own support or on an equivalent support. For safety reasons and to obtain consistent results, only motor operation should be used. Motor operation should be at the minimum supply voltage.

Before commencing switching tests, resistance measurement of the main circuit and no-load operations should be made and details of the operating characteristics of the disconnector such as contact separation (arc initiation), closing time and opening time, should be recorded. Only single-phase tests on one pole of a three-pole disconnector need be performed provided that the pole is not in a more favourable condition than the complete three-pole disconnector with respect to

- closing time;
- opening time;
- influence of adjacent phases.

NOTE Single-phase tests are adequate to demonstrate the switching performance of a disconnector provided that the arcing time and arc reach are such that there is no possibility of involvement of an adjacent phase. If excessive arc reach is encountered during single-phase testing, then three-phase testing should be performed. A reach of the tip of the arc towards an adjacent phase equal to or greater than half the metal-to-metal spacing between phases is to be considered as excessive.

5.2 Earthing of the test circuit and disconnector

The frame of the disconnector should be earthed and the current to earth should be measured.

5.3 Test frequency

Disconnectors may be tested using either 50 Hz or 60 Hz since both frequencies are considered to be equivalent.

5.4 Test voltage

The test voltage should be the phase-to-earth voltage based on the rated voltage of the disconnector. In the event of three-phase testing, the test voltage should be the rated voltage of the disconnector applied on a three-phase basis.

NOTE Due to laboratory limitations, testing on one break of double break disconnectors at half the test voltage is permissible. An even voltage distribution across the two breaks can be assumed.


5.5 Test current

The test current, or currents if more than one current level is to be tested, should be as agreed between the manufacturer and the user.

NOTE Typical capacitive charging current values for station equipment and lines are shown in Annex B.

5.6 Test circuit

The test circuit in principle should be as shown in Figure 1.

**Key** L_S Short-circuit inductance C_S Supply side capacitance C_L Load side capacitance**Figure 1 – Test circuit in principle for capacitive current switching**

L_S should be based on the rated short-time withstand current at the rated voltage of the disconnector under test. However this will require a circuit with a strong source, which is impractical in many cases. An alternative circuit is described in Annex C.

For each test current, the ratio C_S/C_L should be agreed between the manufacturer and the user.

The permissible tolerances for the test quantities are as shown in Table 1.

Table 1 – Test tolerances

Test quantity	Tolerance
Test voltage	$\pm 5 \%$
Test current	$\pm 10 \%$
C_S/C_L	$\pm 20 \%$

5.7 Tests**5.7.1 Test duties and measurements**

Twenty CO operations should be made for each test current with no trapped charge on the load capacitance prior to closing. Twenty such operations are considered to be statistically acceptable. The recovery voltage shall be maintained for ten seconds (10 s) after the disconnector reaches its fully open position.

The following measurements should be made during the test:

- power frequency source voltage and load side dc and transient overvoltages;
- current;
- arc duration;
- video recordings of arc propagation (the intent is to record the extreme vertical and horizontal reach of the arc as viewed along the longitudinal line of the disconnector).

NOTE If the tests are performed outdoors, atmospheric conditions should be recorded to include wind direction and velocity, humidity, air pressure and ambient temperature. No corrections for such elements are required.

5.7.2 Behaviour of disconnecter during tests

The disconnecter shall meet the following requirements during the tests:

- a) the disconnecter shall interrupt the current before the moving blade or blades reach their fully open position;
- b) no earth faults, or phase-to-phase faults in the event of three-phase testing, shall occur.

5.7.3 Condition of disconnecter after tests

The disconnecter shall meet the following requirements after the tests:

- a) a visual inspection is considered sufficient to verify that the mechanical parts and insulators are in essentially the same condition as before the tests;
- b) the condition of the main contacts, in particular with regard to wear, contact area, pressure and freedom of movement, shall be such that they are capable of carrying the rated normal current of the disconnecter;
- c) the resistance of the main circuit after the test shall not exceed that before the test by more than +10 %;
- d) the operating times before and after the tests shall be essentially the same.

5.8 Test reports

The results of all tests should be recorded in test reports. Sufficient information should be included so that the essential parts of the disconnecter tested can be identified.

The test report should at least contain the following information:


- a) typical oscillographic or similar records of the tests performed;
- b) test circuit;
- c) test currents;
- d) test voltages including overvoltages;
- e) arc durations;
- f) arc extreme reach in vertical and horizontal directions;
- g) number of CO operations;
- h) record of the condition of the of the main and arcing contacts after test;
- i) resistance of the main circuit before and after the test sequence;
- j) operating times before and after the tests.
- k) Atmospheric conditions: ambient temperature, air pressure, humidity and, if outdoors, wind velocity and direction.

General information concerning the supporting structure of the disconnecter should be included. The type of operating device employed during the tests should be recorded.

Annex A (informative)

Analysis

Capacitive current switching is a circuit and arc interactive event with varying severities of restriking and arc duration. The severity of restriking both in terms of frequency, current and overvoltage magnitudes, is dependent on the relative values of the source side (C_S) and load side (C_L) capacitances as shown in the basic capacitive current switching circuit Figure A.1.




Key


L_S	Short-circuit inductance
C_S	Supply side capacitance
C_L	Load side capacitance
U_S	Source side voltage
U_L	Load side voltage
U_D	Voltage across disconnecter

Figure A.1 – Basic capacitive current switching circuit

Typical test oscillograms are shown in Figure A.2 and this behaviour is explained in the following.



IEC 2229/09



IEC 2230/09

Key

C_S	Source side capacitance	U_E	Equalization voltage
C_L	Load side capacitance	U_S	Supply side voltage

Figure A.2 – Test oscillograms for current of 2 A and C_S/C_L ratios of 2,5 (Trace A) and 0,04 (Trace B)

When a restrike occurs, the voltage on C_S and C_L will first equalize at U_E (equalization voltage). Taking the voltages on the source and load side capacitances as U_S and U_L , the corresponding charges are:

$$Q_S = U_S C_S$$

$$Q_L = -U_L C_L$$

and $Q_{\text{total}} = U_S C_S + (-U_L C_L)$

After restriking and charge redistribution, U_E is given by:

$$U_E = \frac{Q_{\text{total}}}{C_S + C_L}$$

or
$$U_E = \frac{U_S C_S - U_L C_L}{C_S + C_L} \quad (\text{A.1})$$

Prior to restriking the voltage across the disconnector, U_D is:

$$U_D = U_S + U_L$$

and substituting in Equation (A.1) for U_L

$$U_E = \frac{U_S C_S - C_L (U_D - U_S)}{C_S + C_L}$$

or
$$U_E = U_S - \frac{U_D}{1 + C_S / C_L} \quad (\text{A.2})$$

The peak overvoltage value to ground U_{OV} is given by:

$$U_{OV} = U_S + \beta (U_S - U_E) \quad (\text{A.3})$$

where β is the damping factor of value less than 1.


Substituting from Equation (A.2):

$$U_{OV} = U_S + \beta \left(\frac{U_D}{1 + C_S / C_L} \right) \quad (\text{A.4})$$

The dependency on the ratio C_S / C_L is evident and can be summarized as follows:

- $C_S / C_L > 1$, the difference between U_S and U_E will be low, giving lower values of U_{OV} and shorter arcing times due to lower injected energy into the arc (Figure A.2, Trace A);
- $C_S / C_L < 1$, the difference between U_S and U_E will be high, giving higher values of U_{OV} and longer arcing times due to higher injected energy into the arc (Figure A.2, Trace B).

The restriking current I_{LR} through the arc to C_L is calculated using the circuit in Figure A.3.



Key

U_R	Supply side voltage	I_{LR}	Restriking current
L_S	Short-circuit inductance	C_S	Supply side capacitance
I_R	Supply current	C_L	Load side capacitance
I_{SR}	Current through the supply side capacitance		

Figure A.3 – Circuit for restriking current calculation

I_R is given by:

$$I_R = \frac{U_R}{\sqrt{\frac{L_S}{C_S + C_L}}}$$

where $U_R = U_S - U_E$

$$\begin{aligned}
 I_{LR} &= \frac{I_R}{\omega(C_S + C_L)} \times \omega C_L \\
 &= U_R \sqrt{\frac{C_S + C_L}{L_S}} \times \frac{C_L}{C_S + C_L} \\
 &= U_R \sqrt{\frac{C_L}{L_S} \left(\frac{1}{1 + C_S/C_L} \right)} \quad (A.5)
 \end{aligned}$$

I_{LR} is thus dependent on C_L , L_S and the ratio C_S/C_L . Equations (A.4) and (A.5) show that these parameters should be properly represented in type test circuits in order for the testing to be valid.

For switching tests, $C_S/C_L = 0,1$ is taken as being representative for the vast majority of applications. The value of L_S is selected on the basis of the disconnector being applied on a system with a fault level equal to the rated short-time current of the disconnector.

In addition to the influence of the ratio C_S/C_L and L_S , the arc may also exhibit thermal properties, which will tend to increase the arc duration. Based on field and laboratory test observations, arc duration dependency can be summarized as follows:

- For currents of 1 A or less, thermal effects are not significant and the arc duration is dependent mainly on achieving the minimum disconnector gap to withstand the recovery voltage and on the ratio C_S/C_L .
- For currents greater than 1 A, thermal effects become significant and the arc duration is dependent on the current magnitude in addition to achieving a minimum disconnector contact gap and on the ratio C_S/C_L .
- The longest arc durations at any current will occur when $C_S/C_L < 1$ and due diligence should be exercised in such cases.

IECNORM.COM : Click to view the full PDF of IEC TR 62271-305:2009

Annex B (informative)

Capacitive charging currents

Typical capacitive charging current values for station air-insulated equipment are shown in Tables B.1, B.2 and B.3.

Table B.1 – Capacitive charging currents at 245 kV and below

Equipment type	Capacitive current (A) at					
	72,5 kV		145 kV		245 kV	
	50 Hz	60 Hz	50 Hz	60 Hz	50 Hz	60 Hz
CT	≤ 0,04	≤ 0,04	≤ 0,04	≤ 0,04	≤ 0,04	≤ 0,04
CVT (4000 pF)	0,05	0,06	0,11	0,13	0,18	0,21
Busbars/m	$1,7 \times 10^{-4}$	2×10^{-4}	$0,32 \times 10^{-3}$	$0,39 \times 10^{-3}$	$0,54 \times 10^{-3}$	$0,65 \times 10^{-3}$

Table B.2 – Capacitive charging currents at 300 kV to 550 kV

Equipment type	Capacitive current (A) at					
	300 kV		420 kV		550 kV	
	50 Hz	60 Hz	50 Hz	60 Hz	50 Hz	60 Hz
CT	0,05	0,06	0,08	0,09	0,1	0,12
CVT (4 000 pF)	0,22	0,26	0,3	0,37	0,4	0,48
Busbars/m	$0,66 \times 10^{-3}$	$0,8 \times 10^{-3}$	$0,84 \times 10^{-3}$	$1,0 \times 10^{-3}$	$1,1 \times 10^{-3}$	$1,3 \times 10^{-3}$


Table B.3 – Capacitive charging currents at 800 kV to 1 200 kV

Equipment type	Capacitive current (A) at					
	800 kV		1 100 kV		1 200 kV	
	50 Hz	60 Hz	50 Hz	60 Hz	50 Hz	60 Hz
CT	0,15	0,18	TBD	TBD	TBD	TBD
CVT (5 000 pF)	0,72	0,87	1,0	1,2	1,1	1,3
Busbars/m	$1,8 \times 10^{-3}$	$2,2 \times 10^{-3}$	$2,5 \times 10^{-3}$	3×10^{-3}	$2,8 \times 10^{-3}$	$3,3 \times 10^{-3}$
TBD = To be determined.						

Optical instrument transformers, if used, will have about the same capacitance as post insulators, i.e. about 50 pF, and the associated capacitive charging currents will be negligible.

Annex C (informative)

Test circuits



Key

U_S	Supply side voltage	C_L	Load side capacitance
L_S	Short-circuit inductance	L_{hf}	Inductance C_S and C_L loop
C_S	Supply side capacitance		

Figure C.1 – Basic capacitive current switching circuit

The basic capacitive current switching circuit in Figure C.1 is considered to be a realistic representation of reality when the short-circuit impedance L_S is based on the short-time current for which the disconnector is rated. Upon restrike of the disconnector gap, the restriking current basically has three components:

- high-frequency (HF) component (indicated by the solid line loop of the circuit C_S - Disconnector - L_{hf} - C_L);
- medium frequency (MF) component (indicated by the dashed line loop of the circuit U_S - L_S Disconnector - L_{hf} - C_L);
- power frequency (PF) component (also in the dashed line loop of the circuit U_S - L_S Disconnector - L_{hf} - C_L).

These currents determine the thermal energy that is injected into the arc path, the consequent heating of the arc and the ultimate recovery of the gap. Each of these components have their own contribution to thermal processes in terms of amplitude and/or duration: HF (few kA, but very short duration), MF (few hundreds of amperes, longer duration), PF (few amperes but long duration).

The circuit above, however, is unpractical, because it implies that tests with only a few amperes must be done in circuits having a very strong source (must be able to supply the short-time current). Already for moderate voltages (> 145 kV) this would imply such tests are impossible.

As an alternative, the test circuit shown in Figure C.2 is proposed.