

TECHNICAL REPORT

AMENDMENT 1

Guideline for the system design of HVDC converter stations with line-commutated converters

IECNORM.COM : Click to view the full PDF of IEC TR 63127:2019/AMD1:2024



THIS PUBLICATION IS COPYRIGHT PROTECTED

Copyright © 2024 IEC, Geneva, Switzerland

All rights reserved. Unless otherwise specified, no part of this publication may be reproduced or utilized in any form or by any means, electronic or mechanical, including photocopying and microfilm, without permission in writing from either IEC or IEC's member National Committee in the country of the requester. If you have any questions about IEC copyright or have an enquiry about obtaining additional rights to this publication, please contact the address below or your local IEC member National Committee for further information.

IEC Secretariat
3, rue de Varembe
CH-1211 Geneva 20
Switzerland

Tel.: +41 22 919 02 11
info@iec.ch
www.iec.ch

About the IEC

The International Electrotechnical Commission (IEC) is the leading global organization that prepares and publishes International Standards for all electrical, electronic and related technologies.

About IEC publications

The technical content of IEC publications is kept under constant review by the IEC. Please make sure that you have the latest edition, a corrigendum or an amendment might have been published.

IEC publications search - webstore.iec.ch/advsearchform

The advanced search enables to find IEC publications by a variety of criteria (reference number, text, technical committee, ...). It also gives information on projects, replaced and withdrawn publications.

IEC Just Published - webstore.iec.ch/justpublished

Stay up to date on all new IEC publications. Just Published details all new publications released. Available online and once a month by email.

IEC Customer Service Centre - webstore.iec.ch/csc

If you wish to give us your feedback on this publication or need further assistance, please contact the Customer Service Centre: sales@iec.ch.

IEC Products & Services Portal - products.iec.ch

Discover our powerful search engine and read freely all the publications previews, graphical symbols and the glossary. With a subscription you will always have access to up to date content tailored to your needs.

Electropedia - www.electropedia.org

The world's leading online dictionary on electrotechnology, containing more than 22 500 terminological entries in English and French, with equivalent terms in 25 additional languages. Also known as the International Electrotechnical Vocabulary (IEV) online.

IECNORM.COM : Click to view the full PDF of IEC TR 62522-1:2024

TECHNICAL REPORT

AMENDMENT 1

Guideline for the system design of HVDC converter stations with line-commutated converters

INTERNATIONAL
ELECTROTECHNICAL
COMMISSION

ICS 29.240.01; 29.240.10

ISBN 978-2-8322-8642-5

Warning! Make sure that you obtained this publication from an authorized distributor.

INTERNATIONAL ELECTROTECHNICAL COMMISSION

GUIDELINE FOR THE SYSTEM DESIGN OF HVDC CONVERTER STATIONS WITH LINE-COMMUTATED CONVERTERS

AMENDMENT 1

FOREWORD

- 1) The International Electrotechnical Commission (IEC) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, IEC publishes International Standards, Technical Specifications, Technical Reports, Publicly Available Specifications (PAS) and Guides (hereafter referred to as "IEC Publication(s)"). Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations liaising with the IEC also participate in this preparation. IEC collaborates closely with the International Organization for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.
- 2) The formal decisions or agreements of IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC National Committees.
- 3) IEC Publications have the form of recommendations for international use and are accepted by IEC National Committees in that sense. While all reasonable efforts are made to ensure that the technical content of IEC Publications is accurate, IEC cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.
- 4) In order to promote international uniformity, IEC National Committees undertake to apply IEC Publications transparently to the maximum extent possible in their national and regional publications. Any divergence between any IEC Publication and the corresponding national or regional publication shall be clearly indicated in the latter.
- 5) IEC itself does not provide any attestation of conformity. Independent certification bodies provide conformity assessment services and, in some areas, access to IEC marks of conformity. IEC is not responsible for any services carried out by independent certification bodies.
- 6) All users should ensure that they have the latest edition of this publication.
- 7) No liability shall attach to IEC or its directors, employees, servants or agents including individual experts and members of its technical committees and IEC National Committees for any personal injury, property damage or other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication, use of, or reliance upon, this IEC Publication or any other IEC Publications.
- 8) Attention is drawn to the Normative references cited in this publication. Use of the referenced publications is indispensable for the correct application of this publication.
- 9) IEC draws attention to the possibility that the implementation of this document may involve the use of (a) patent(s). IEC takes no position concerning the evidence, validity or applicability of any claimed patent rights in respect thereof. As of the date of publication of this document, IEC had not received notice of (a) patent(s), which may be required to implement this document. However, implementers are cautioned that this may not represent the latest information, which may be obtained from the patent database available at <https://patents.iec.ch>. IEC shall not be held responsible for identifying any or all such patent rights.

Amendment 1 to IEC TR 63127:2019 has been prepared by IEC technical committee 115: High Voltage Direct Current (HVDC) transmission for DC voltages above 100 kV.

The text of this Amendment is based on the following documents:

Draft	Report on voting
115/361/DTR	115/364/RVDTR

Full information on the voting for its approval can be found in the report on voting indicated in the above table.

The language used for the development of this Amendment is English.

This document was drafted in accordance with ISO/IEC Directives, Part 2, and developed in accordance with ISO/IEC Directives, Part 1 and ISO/IEC Directives, IEC Supplement, available at www.iec.ch/members_experts/refdocs. The main document types developed by IEC are described in greater detail at www.iec.ch/publications/.

The committee has decided that the contents of this document will remain unchanged until the stability date indicated on the IEC website under webstore.iec.ch in the data related to the specific document. At this date, the document will be

- reconfirmed,
- withdrawn, or
- revised.

INTRODUCTION

Replace, in the first paragraph, "almost half of HVDC projects were commissioned after the year 2000." with "more than half of HVDC projects were commissioned after the year 2000."

Add, in the last sentence of the second paragraph, the words "line-commutated converter (LCC)" before "HVDC systems".

Replace, in the second sentence of the third paragraph, the value "660 kV" with "1 100 kV".

Delete, the last two sentences of the third paragraph, starting from "In addition" to the end of that paragraph.

5.2.4 AC/DC interaction and control

Delete, in the second sentence of the last paragraph, the words "and no extra cost added."

6.3.5 Short-circuit current or capacity level

Replace the content of the existing subclause with the following:

The interconnected AC system strength impacts the HVDC system design. A weak AC system will give rise to special requirements and extra costs for HVDC projects, such as special control strategies, need for multiple small reactive power sub-banks and additional synchronous condensers or other static reactive power devices, like synchronous compensator (STATCOM), static var compensator (SVC), TCSC, SCC, etc. The increase in the number of connections of renewable energy sources nowadays is leading to a decrease in system strength.

The short circuit ratio (SCR) is used to evaluate the strength of an AC system terminated to the HVDC link especially in planning stage. Considering the negative contribution of AC filter / shunt capacitor banks on the short-circuit current/capacity, the effective short-circuit ratio (ESCR) is usually given.

A STATCOM installed inside or near the converter station could improve the adaptability of the HVDC system to the AC system. In order to obtain enough ESCR, the capacity of installed STATCOM can be evaluated by the formula $ESCR = (S_{sc} + 2Q_{stat}) / P_{dcN}$, where Q_{stat} is the capacity of STATCOM. The performance of STATCOM should be demonstrated by simulation with real control in detail design.

A capacitor commutated converter (CCC) HVDC converter could improve the adaptability of the HVDC system to a weak AC system, too, as an alternative to STATCOM. This solution can be used to adapt the HVDC system to a weak AC system with an effective short-circuit ratio down to 1.0, as per 5.1.2 of CIGRE TB No. 352.

Both the maximum and the minimum three-phase short-circuit current can be specified for HVDC system design and study. Which short-circuit current will be used for a specific design or study can be decided on a case-by-case basis in order to derive maximum equipment stresses. For example, the maximum short-circuit current is usually used to determine the surge current rating of equipment such as valves and smoothing reactors. The minimum short-circuit current is normally used in studies such as fundamental frequency overvoltage study and AC side transient overvoltage study.

For projects constructed in stages, the short-circuit currents and HVDC power can vary from stage to stage. The SCR can be identified in each stage and scenario.

The calculation of the short-circuit current can be carried out using conventional system stability programs.

7.1.1 Rated power

Replace, in the first paragraph, the values "10 000 MW at ±800 kV" with "12 000 MW at 1 100 kV".

7.2.1 Pole and return path

Replace, in the first sentence of the second paragraph, the words "become a bipolar system." with "form a bipolar system."

7.2.3.1 General

Replace, in the second paragraph, the words "A neutral bus ground switch (NBES)" with "A neutral bus earthing switch (NBES)".

10.2.1 Reactive power consumption calculation

Replace the existing Equation (32)

$$Q_{\text{conv}} = I_d \cdot U_{\text{dio}} \frac{2u + \sin 2\alpha - \sin 2(\alpha + u)}{4(\cos \alpha - \cos(\alpha + u))}$$

with the new Equation (32):

$$Q_{\text{conv}} = I_d \cdot U_{\text{dio}} \frac{2\mu + \sin 2\alpha - \sin 2(\alpha + \mu)}{4(\cos \alpha - \cos(\alpha + \mu))} \quad (32)$$

Replace, the existing Equation (34) $u = \arccos\left(\cos \alpha - 2d_x \cdot \frac{I_d}{I_{dN}} \cdot \frac{U_{\text{dioN}}}{U_{\text{dio}}}\right) - \alpha$

with the new Equation (34):

$$\mu = \arccos \left(\cos \alpha - 2d_x \cdot \frac{I_d}{I_{dN}} \cdot \frac{U_{dioN}}{U_{dio}} \right) - \alpha \quad (34)$$

11.2.1 General

Replace, in the first paragraph, the words "a closed enclosure" with "a sealed enclosure".

Delete, in the first paragraph, the words "which is mounted on supported insulators".

11.2.5 Losses of converter valves

Delete, in the first sentence, the words "According to the methods stated in IEC 61803," and replace the initial lower-case letter of the following word "losses" with an upper-case letter as follows "Losses".

11.3.1 General

Replace, in the first paragraph, the words "isolate AC voltage from DC voltage." with "provide galvanic isolation between the AC system and the DC system."

IECNORM.COM : Click to view the full PDF of IEC TR 63127:2019/AMD1:2024

IECNORM.COM : Click to view the full PDF of IEC TR 63127:2019/AMD1:2024