



Industrial automation systems — Manufacturing Message Specification —

Part 2: Protocol specification

TECHNICAL CORRIGENDUM 2

Systèmes d'automatisation industrielle — Spécification de messagerie industrielle —

Partie 2: Spécification de protocole

RECTIFICATIF TECHNIQUE 2

Technical corrigendum 2 to International Standard ISO/IEC 9506-2:1990 was prepared by Technical Committee ISO/TC 184, *Industrial automation systems and integration*, Subcommittee SC 5, *Architecture and communications*.

NOTE — Proper application of this corrigendum requires that amendment 1, technical corrigendum 1, and amendment 2 have been applied (in that order) to the base document. Page numbers in this technical corrigendum refer to the base standard as published in 1990; subclause and paragraph references are to the base standard as modified by the prior two amendments and the prior corrigendum.

Page 18

Subclause 6.4

Add to the end of the first paragraph:

If the invalid PDU is determined to be an invalid RejectPDU, a RejectPDU shall not be sent.

Page 79

Subclause 15.6

Between

evaluationInterval[4] IMPLICIT Unsigned32 OPTIONAL
and
}