

INTERNATIONAL STANDARD

NORME INTERNATIONALE



INTERNATIONAL SPECIAL COMMITTEE ON RADIO INTERFERENCE
COMITÉ INTERNATIONAL SPÉCIAL DES PERTURBATIONS RADIOÉLECTRIQUES

Specification for radio disturbance and immunity measuring apparatus and methods –

Part 2-1: Methods of measurement of disturbances and immunity – Conducted disturbance measurements

Spécifications des méthodes et des appareils de mesure des perturbations radioélectriques et de l'immunité aux perturbations radioélectriques –

Partie 2-1: Méthodes de mesure des perturbations et de l'immunité – Mesures des perturbations conduites



THIS PUBLICATION IS COPYRIGHT PROTECTED

Copyright © 2013 IEC, Geneva, Switzerland

All rights reserved. Unless otherwise specified, no part of this publication may be reproduced or utilized in any form or by any means, electronic or mechanical, including photocopying and microfilm, without permission in writing from either IEC or IEC's member National Committee in the country of the requester.

If you have any questions about IEC copyright or have an enquiry about obtaining additional rights to this publication, please contact the address below or your local IEC member National Committee for further information.

Droits de reproduction réservés. Sauf indication contraire, aucune partie de cette publication ne peut être reproduite ni utilisée sous quelque forme que ce soit et par aucun procédé, électronique ou mécanique, y compris la photocopie et les microfilms, sans l'accord écrit de la CEI ou du Comité national de la CEI du pays du demandeur.

Si vous avez des questions sur le copyright de la CEI ou si vous désirez obtenir des droits supplémentaires sur cette publication, utilisez les coordonnées ci-après ou contactez le Comité national de la CEI de votre pays de résidence.

IEC Central Office
3, rue de Varembe
CH-1211 Geneva 20
Switzerland

Tel.: +41 22 919 02 11
Fax: +41 22 919 03 00
info@iec.ch
www.iec.ch

About the IEC

The International Electrotechnical Commission (IEC) is the leading global organization that prepares and publishes International Standards for all electrical, electronic and related technologies.

About IEC publications

The technical content of IEC publications is kept under constant review by the IEC. Please make sure that you have the latest edition, a corrigenda or an amendment might have been published.

Useful links:

IEC publications search - www.iec.ch/searchpub

The advanced search enables you to find IEC publications by a variety of criteria (reference number, text, technical committee,...).

It also gives information on projects, replaced and withdrawn publications.

IEC Just Published - webstore.iec.ch/justpublished

Stay up to date on all new IEC publications. Just Published details all new publications released. Available on-line and also once a month by email.

Electropedia - www.electropedia.org

The world's leading online dictionary of electronic and electrical terms containing more than 30 000 terms and definitions in English and French, with equivalent terms in additional languages. Also known as the International Electrotechnical Vocabulary (IEV) on-line.

Customer Service Centre - webstore.iec.ch/csc

If you wish to give us your feedback on this publication or need further assistance, please contact the Customer Service Centre: csc@iec.ch.

A propos de la CEI

La Commission Electrotechnique Internationale (CEI) est la première organisation mondiale qui élabore et publie des Normes internationales pour tout ce qui a trait à l'électricité, à l'électronique et aux technologies apparentées.

A propos des publications CEI

Le contenu technique des publications de la CEI est constamment revu. Veuillez vous assurer que vous possédez l'édition la plus récente, un corrigendum ou amendement peut avoir été publié.

Liens utiles:

Recherche de publications CEI - www.iec.ch/searchpub

La recherche avancée vous permet de trouver des publications CEI en utilisant différents critères (numéro de référence, texte, comité d'études,...).

Elle donne aussi des informations sur les projets et les publications remplacées ou retirées.

Just Published CEI - webstore.iec.ch/justpublished

Restez informé sur les nouvelles publications de la CEI. Just Published détaille les nouvelles publications parues. Disponible en ligne et aussi une fois par mois par email.

Electropedia - www.electropedia.org

Le premier dictionnaire en ligne au monde de termes électroniques et électriques. Il contient plus de 30 000 termes et définitions en anglais et en français, ainsi que les termes équivalents dans les langues additionnelles. Egalement appelé Vocabulaire Electrotechnique International (VEI) en ligne.

Service Clients - webstore.iec.ch/csc

Si vous désirez nous donner des commentaires sur cette publication ou si vous avez des questions contactez-nous: csc@iec.ch.

INTERNATIONAL STANDARD

NORME INTERNATIONALE



INTERNATIONAL SPECIAL COMMITTEE ON RADIO INTERFERENCE
COMITÉ INTERNATIONAL SPÉCIAL DES PERTURBATIONS RADIOÉLECTRIQUES

Specification for radio disturbance and immunity measuring apparatus and methods –

Part 2-1: Methods of measurement of disturbances and immunity – Conducted disturbance measurements

Spécifications des méthodes et des appareils de mesure des perturbations radioélectriques et de l'immunité aux perturbations radioélectriques –

Partie 2-1: Méthodes de mesure des perturbations et de l'immunité – Mesures des perturbations conduites

INTERNATIONAL
ELECTROTECHNICAL
COMMISSION

COMMISSION
ELECTROTECHNIQUE
INTERNATIONALE

ICS 33.100.10; 33.100.20

ISBN 978-2-8322-0692-8

Warning! Make sure that you obtained this publication from an authorized distributor.

Attention! Veuillez vous assurer que vous avez obtenu cette publication via un distributeur agréé.

CONTENTS

FOREWORD.....	7
INTRODUCTION (to amendment 1)	9
1 Scope.....	10
2 Normative references	10
3 Definitions	10
4 Types of disturbance to be measured	16
4.1 General.....	16
4.2 Types of disturbance	16
4.3 Detector functions	17
5 Connection of measuring equipment.....	17
5.1 General.....	17
5.2 Connection of ancillary equipment.....	17
5.3 Connections to RF reference ground	17
5.4 Connection between the EUT and the artificial mains network	19
6 General measurement requirements and conditions	19
6.1 General.....	19
6.2 Disturbance not produced by the equipment under test	19
6.2.1 General	19
6.2.2 Compliance testing	20
6.3 Measurement of continuous disturbance.....	20
6.3.1 Narrowband continuous disturbance.....	20
6.3.2 Broadband continuous disturbance.....	20
6.3.3 Use of spectrum analyzers and scanning receivers.....	20
6.4 Operating conditions of the EUT EUT arrangement and measurement conditions.....	20
6.4.1 General EUT arrangement.....	20
6.4.2 Normal load conditions	20
6.4.3 Duration of operation	23
6.4.4 Running-in/Warm-up time	23
6.4.5 Supply.....	23
6.4.6 Mode of operation.....	23
6.4.7 Operation of multifunction equipment.....	23
6.4.8 Determination of EUT arrangement(s) that maximizes emissions.....	24
6.4.9 Recording of measurement results	24
6.5 Interpretation of measuring results	23
6.5.1 Continuous disturbance	24
6.5.2 Discontinuous disturbance.....	24
6.5.3 Measurement of the duration of disturbances	25
6.6 Measurement times and scan rates for continuous disturbance	25
6.6.1 General	25
6.6.2 Minimum measurement times	25
6.6.3 Scan rates for scanning receivers and spectrum analyzers	26

6.6.4	Scan times for stepping receivers	27
6.6.5	Strategies for obtaining a spectrum overview using the peak detector	28
6.6.6	Timing considerations using FFT-based instruments	31
7	Measurement of disturbances conducted along leads, 9 kHz to 30 MHz	33
7.1	Introduction	33
7.2	Measuring equipment (receivers, etc.)	34
7.2.1	General	34
7.2.2	Use of detectors for conducted disturbance measurements	34
7.3	Ancillary measuring equipment	34
7.3.1	General	34
7.3.2	Artificial networks (AN)	34
7.3.3	Voltage probes	35
7.3.4	Current probes	35
7.4	Equipment under test configuration	36
7.4.1	Arrangement of the EUT and its connection to the AN	36
7.4.2	Procedure for the measurement of unsymmetric disturbance voltages with V-networks (AMNs)	44
7.4.3	Measurement of common mode voltages at differential mode signal terminals	51
7.4.4	Measurements using voltage probes	52
7.4.5	Measurement using a capacitive voltage probe (CVP)	54
7.4.6	Measurements using current probes	55
7.5	System test configuration for conducted emissions measurements	55
7.5.1	General approach to system measurements	55
7.5.2	System configuration	56
7.5.3	Measurements of interconnecting lines	58
7.5.4	Decoupling of system components	58
7.6	<i>In situ</i> measurements	59
7.6.1	General	59
7.6.2	Reference ground	59
7.6.3	Measurement with voltage probes	59
7.6.4	Selection of measuring points	60
8	Automated measurement of emissions	60
8.1	Introduction. Precautions for automating measurements	60
8.2	Generic measurement procedure	60
8.3	Prescan measurements	61
8.4	Data reduction	62
8.5	Emission maximization and final measurement	62
8.6	Post processing and reporting	62
8.7	Emission measurement strategies with FFT-based measuring instruments	62
Annex A (informative)	Guidelines to connection of electrical equipment to the artificial mains network (see Clause 5)	63
Annex B (informative)	Use of spectrum analyzers and scanning receivers (see Clause 6)	70
Annex C (informative)	Decision tree for use of detectors for conducted measurements (see 7.2.2)	73

Annex D (informative) Scan rates and measurement times for use with the average detector	75
Annex E (informative) Guidelines for the improvement of the test setup with ANs	79
Annex F (normative) Determination of suitability of spectrum analyzers for compliance tests	84
Annex G (informative) Guidance for measurements on telecommunications ports	85
Annex H (normative) Specifics for conducted disturbance on telecommunication ports	92
Annex I (informative) Examples of AANs and ANs for screened cables	99
 Bibliography.....	 108
 Figure 1 – Example of a recommended test setup with PE chokes with three AMNs and a sheath current absorber on the RF cable.....	 18
Figure 2 – Measurement of a combination of a CW signal (“NB”) and an impulsive signal (“BB”) using multiple sweeps with maximum hold.....	28
Figure 3 – Example of a timing analysis	29
Figure 4 – A broadband spectrum measured with a stepped receiver	30
Figure 5 – Intermittent narrowband disturbances measured using fast short repetitive sweeps with maximum hold function to obtain an overview of the emission spectrum.....	30
Figure 6 – Test configuration: table-top equipment for conducted disturbance measurements on power mains.....	38
Figure 7 – Arrangement of EUT and AMN at 40 cm distance with a) vertical RGP and b) horizontal RGP	27
Figure 8 – Optional example test configuration for an EUT with only a power cord attached	40
Figure 9 – Test configuration: floor-standing equipment (see 7.4.1 and 7.5.2.2).....	42
Figure 10 – Example Test configuration: floor-standing and table-top equipment (see 7.4.1 and 7.5.2.2)	43
Figure 11 – Schematic of disturbance voltage measurement configuration (see also 7.5.2.2).....	45
Figure 12a – Schematic for measurement and power circuit.....	46
Figure 12b – Equivalent voltage source and measurement circuit	46
Figure 12 – Equivalent circuit for measurement of common mode disturbance voltage for class I (grounded) EUT.....	46
Figure 13a – Schematic for power and measurement circuit.....	47
Figure 13b – Equivalent RFI source and measurement circuit	47
Figure 13 – Equivalent circuit for measurement of common mode disturbance voltage for class II (ungrounded) EUT	47
Figure 14 – RC element for artificial hand	49
Figure 15 – Portable electric drill with artificial hand	49
Figure 16 – Portable electric saw with artificial hand	49
Figure 17 – Measuring example for voltage probes	53
Figure 18 – Measurement arrangement for two-terminal regulating controls.....	53
Figure 19 – FFT scan in segments	32
Figure 20 – Frequency resolution enhanced by FFT-based measuring instrument.....	33
Figure 21 – Illustration of current I_{CCM}	36

Figure A.1	63
Figure A.2	64
Figure A.3	64
Figure A.4	64
Figure A.5	65
Figure A.6	65
Figure A.7	66
Figure A.8 – AMN configurations	68
Figure C.1 – Decision tree for optimizing speed of conducted disturbance measurements with peak, quasi-peak and average detectors	73
Figure D.1 – Weighting function of a 10 ms pulse for peak (“PK”) and average detections with (“CISPR AV”) and without (“AV”) peak reading; meter time constant 160 ms	77
Figure D.2 – Weighting functions of a 10 ms pulse for peak (“PK”) and average detections with (“CISPR AV”) and without (“AV”) peak reading; meter time constant 100 ms	77
Figure D.3 – Example of weighting functions (of a 1 Hz pulse) for peak (“PK”) and average detections as a function of pulse width: meter time constant 160 ms	78
Figure D.4 – Example of weighting functions (of a 1 Hz pulse) for peak (“PK”) and average detections as a function of pulse width: meter time constant 100 ms	78
Figure E.1 – Parallel resonance of enclosure capacitance and ground strap inductance	79
Figure E.2 – Connection of an AMN to RGP using a wide grounding sheet for low inductance grounding	80
Figure E.3 – Impedance measured with the arrangement of Figure E.2 both with reference to the front panel ground and to the grounding sheet	80
Figure E.4 – VDF in the configuration of Figure E.2 measured with reference to the front panel ground and to the grounding sheet. (The AMN used has a flat frequency response of the VDF, which may be different for other AMNs)	80
Figure E.5 – Arrangement showing the measurement grounding sheet (shown with dotted lines) when measuring the impedance with reference to RGP. The impedance measurement cable ground is connected to the measurement grounding sheet, whereas the inner conductor is connected to the EUT port pin.	81
Figure E.6 – Impedance measured with the arrangement of Figure E.5 with reference to the RGP	81
Figure E.7 – VDF measured with parallel resonances in the AMN grounding	82
Figure E.8 – Attenuation of a sheath current absorber measured in a 150-Ω test arrangement	83
Figure E.9 – Arrangement for the measurement of attenuation due to PE chokes and sheath current absorbers	83
Figure G.1 – Basic circuit for considering the limits with a defined TCM impedance of 150 Ω	88
Figure G.2 – Basic circuit for the measurement with unknown TCM impedance	88
Figure G.3 – Impedance layout of the components used in Figure H.2	90
Figure G.4 – Basic test set-up to measure combined impedance of the 150 Ω and ferrites	91
Figure H.1 – Measurement set-up using an AAN	95
Figure H.2 – Measurement set-up using a 150 Ω load to the outside surface of the shield	96
Figure H.3 – Measurement set-up using current and capacitive voltage probes	97

Figure H.4 – Characterization set-up.....	98
Figure I.1 – Example AAN for use with unscreened single balanced pairs.....	99
Figure I.2 – Example AAN with high LCL for use with either one or two unscreened balanced pairs	100
Figure I.3 – Example AAN with high LCL for use with one, two, three, or four unscreened balanced pairs	101
Figure I.4 – Example AAN, including a 50 Ω source matching network at the voltage measuring port, for use with two unscreened balanced pairs.....	102
Figure I.5 – Example AAN for use with two unscreened balanced pairs.....	103
Figure I.6 – Example AAN, including a 50 Ω source matching network at the voltage measuring port, for use with four unscreened balanced pairs	104
Figure I.7 – Example AAN for use with four unscreened balanced pairs.....	105
Figure I.8 – Example AN for use with coaxial cables, employing an internal common mode choke created by bifilar winding an insulated centre-conductor wire and an insulated screen-conductor wire on a common magnetic core (for example, a ferrite toroid).....	106
Figure I.9 – Example AN for use with coaxial cables, employing an internal common mode choke created by miniature coaxial cable (miniature semi-rigid solid copper screen or miniature double-braided screen coaxial cable) wound on ferrite toroids	106
Figure I.10 – Example AN for use with multi-conductor screened cables, employing an internal common mode choke created by bifilar winding multiple insulated signal wires and an insulated screen-conductor wire on a common magnetic core (for example, a ferrite toroid).....	107
Figure I.11 – Example AN for use with multi-conductor screened cables, employing an internal common mode choke created by winding a multi-conductor screened cable on ferrite toroids	107
Table 1 – Minimum scan times for the three CISPR bands with peak and quasi-peak detectors	25
Table 2 – Minimum measurement times for the four CISPR bands	26
Table A.1	69
Table A.2	69
Table D.1 – Pulse suppression factors and scan rates for a 100 Hz video bandwidth.....	76
Table D.2 – Meter time constants and the corresponding video bandwidths and maximum scan rates.....	77
Table F.1 – Maximum amplitude difference between peak and quasi-peak detected signals.....	84
Table G.1 – Summary of advantages and disadvantages of the methods described in the specific subclauses of Annex H	86
Table H.1 – Telecommunication port disturbance measurement procedure selection	92
Table H.2 – a_{LCL} values.....	93

INTERNATIONAL ELECTROTECHNICAL COMMISSION
INTERNATIONAL SPECIAL COMMITTEE ON RADIO INTERFERENCE

**SPECIFICATION FOR RADIO DISTURBANCE AND IMMUNITY
MEASURING APPARATUS AND METHODS –**

**Part 2-1: Methods of measurement of disturbances and immunity –
Conducted disturbance measurements**

FOREWORD

- 1) The International Electrotechnical Commission (IEC) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, IEC publishes International Standards, Technical Specifications, Technical Reports, Publicly Available Specifications (PAS) and Guides (hereafter referred to as "IEC Publication(s)"). Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations liaising with the IEC also participate in this preparation. IEC collaborates closely with the International Organization for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.
- 2) The formal decisions or agreements of IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC National Committees.
- 3) IEC Publications have the form of recommendations for international use and are accepted by IEC National Committees in that sense. While all reasonable efforts are made to ensure that the technical content of IEC Publications is accurate, IEC cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.
- 4) In order to promote international uniformity, IEC National Committees undertake to apply IEC Publications transparently to the maximum extent possible in their national and regional publications. Any divergence between any IEC Publication and the corresponding national or regional publication shall be clearly indicated in the latter.
- 5) IEC itself does not provide any attestation of conformity. Independent certification bodies provide conformity assessment services and, in some areas, access to IEC marks of conformity. IEC is not responsible for any services carried out by independent certification bodies.
- 6) All users should ensure that they have the latest edition of this publication.
- 7) No liability shall attach to IEC or its directors, employees, servants or agents including individual experts and members of its technical committees and IEC National Committees for any personal injury, property damage or other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication, use of, or reliance upon, this IEC Publication or any other IEC Publications.
- 8) Attention is drawn to the Normative references cited in this publication. Use of the referenced publications is indispensable for the correct application of this publication.
- 9) Attention is drawn to the possibility that some of the elements of this IEC Publication may be the subject of patent rights. IEC shall not be held responsible for identifying any or all such patent rights.

This consolidated version of CISPR 16-2-1 consists of the second edition (2008) [documents CISPR/A/798/FDIS and CISPR/A/809/RVD, its amendment 1 (2010) [documents CISPR/A/874/CDV and CISPR/A/897/RVC] and its amendment 2 (2013) [documents CISPR/A/1023/FDIS and CISPR/A/1029/RVD]. It bears the edition number 2.2.

The technical content is therefore identical to the base edition and its amendments and has been prepared for user convenience. A vertical line in the margin shows where the base publication has been modified by amendments 1 and 2. Additions and deletions are displayed in red, with deletions being struck through.

International Standard CISPR 16-2-1 has been prepared by CISPR subcommittee A: Radio interference measurements and statistical methods.

This edition includes significant technical changes with respect to the previous edition. In general, this new edition aims at reducing compliance uncertainty in correspondence with findings in CISPR 16-4-1. Guidelines are given on

- resonance-free connection of the AMN to reference ground,
- avoidance of ground loops, and
- avoidance of ambiguities of the test setup of EUT and AMN with respect to the reference ground plane.

In addition, terms are clarified, a new type of ancillary equipment (CVR) is applied, and a clarification for the use of the AAN and AMN on the same EUT is provided.

This publication has been drafted in accordance with the ISO/IEC Directives, Part 2.

A list of all parts of CISPR 16 series under the general title *Specification for radio disturbance and immunity measuring apparatus and methods*, can be found on the IEC website.

The committee has decided that the contents of the base publication and its amendments will remain unchanged until the stability date indicated on the IEC web site under "<http://webstore.iec.ch>" in the data related to the specific publication. At this date, the publication will be

- reconfirmed,
- withdrawn,
- replaced by a revised edition or
- amended.

IMPORTANT – The “colour inside” logo on the cover page of this publication indicates that it contains colours which are considered to be useful for the correct understanding of its contents. Users should therefore print this publication using a colour printer.

INTRODUCTION (to amendment 1)

All stated specifications in CISPR 16-2-1 are met by an instrument independent of the selected implementation or technology in order to be considered suitable for measurements in accordance with CISPR standards. The addition of FFT-based measuring instrumentation requires further specifications as addressed in this amendment. A new Annex F is added as a result of provisions recently introduced into CISPR 16-1-1 on the use of spectrum analyzers for compliance measurements.

SPECIFICATION FOR RADIO DISTURBANCE AND IMMUNITY MEASURING APPARATUS AND METHODS –

Part 2-1: Methods of measurement of disturbances and immunity – Conducted disturbance measurements

1 Scope

This part of CISPR 16 is designated a basic standard, which specifies the methods of measurement of disturbance phenomena in general in the frequency range 9 kHz to 18 GHz and especially of conducted disturbance phenomena in the frequency range 9 kHz to 30 MHz.

2 Normative references

The following referenced documents are indispensable for the application of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

IEC 60050-161:1990, *International Electrotechnical Vocabulary (IEV) – Chapter 161: Electromagnetic Compatibility*

IEC 60364-4 (all parts), *Electrical installations of buildings – Part 4: Protection for safety*

CISPR 14-1, *Electromagnetic compatibility – Requirements for household appliances, electric tools and similar apparatus – Part 1: Emission*

CISPR 16-1-1:2010, *Specification for radio disturbance and immunity measuring apparatus and methods – Part 1-1: Radio disturbance and immunity measuring apparatus – Measuring apparatus*

CISPR 16-1-2:2003, *Specification for radio disturbance and immunity measuring apparatus and methods – Part 1-2: Radio disturbance and immunity measuring apparatus – Ancillary equipment – Conducted disturbances*

Amendment 1:2004

Amendment 2:2006

~~CISPR/TR 16-3:2003, *Specification for radio disturbance and immunity measuring apparatus and methods – Part 3: CISPR technical reports*~~

~~Amendment 1:2005~~

~~Amendment 2:2006~~

3 Definitions

For the purposes of this part of CISPR 16, the definitions of IEC 60050-161 apply, as well as the following.

3.1

ancillary equipment

transducers (e.g., current and voltage probes and artificial networks) connected to a measuring receiver or (test) signal generator and used in the disturbance signal transfer between the EUT and the measuring or test equipment

3.2

associated equipment

AE

apparatus, which is not part of the system under test, but needed to help exercise the EUT

3.3

auxiliary equipment

AuxEq

peripheral equipment which is part of the system under test

3.4

EUT

equipment (devices, appliances and systems) subjected to EMC (emission) compliance tests

3.5

product publication

publication specifying EMC requirements for a product or product family, taking into account specific aspects of such a product or product family

3.6

emission limit (from a disturbing source)

specified maximum emission level of a source of electromagnetic disturbance

[IEV 161-03-12]

3.7

ground reference

~~connection that constitutes a defined parasitic capacitance to the surrounding of an EUT and serves as reference potential~~

~~NOTE See also IEC 161-04-36 (modified).~~

reference ground plane

RGP

~~flat conductive surface that constitutes a defined parasitic capacitance to the surrounding of an EUT and serves as reference potential~~

~~NOTE 1 See also IEC 60050-161, 161-04-36.~~

~~NOTE 2 A reference ground plane is needed for conducted emission measurements, and serves as reference ground for unsymmetrical and asymmetrical disturbance voltage measurements.~~

3.8

(electromagnetic) emission

phenomenon by which electromagnetic energy emanates from a source

[IEV 161-01-08]

3.9

coaxial cable

cable containing one or more coaxial lines, typically used for a matched connection of associated equipment to the measuring equipment or (test-)signal generator providing a specified characteristic impedance and a specified maximum allowable cable transfer impedance

3.10

common mode (asymmetrical) voltage

RF voltage between the artificial midpoint of a two-conductor line and reference ground, or in case of a bundle of lines, the effective RF disturbance voltage of the whole bundle (vector sum of the unsymmetrical voltages) against the reference ground measured with a clamp (current transformer) at a defined terminating impedance

NOTE See also IEC 161-04-09.

3.11

common mode current

vector sum of the currents flowing through two or more conductors at a specified cross-section of a "mathematical" plane intersected by these conductors

3.12

differential mode (symmetrical) voltage

RF disturbance voltage between the wires of a two conductor line

[IEV 161-04-08, modified]

3.13

differential mode current

half the vector difference of the currents flowing in any two of a specified set of active conductors at a specified cross-section of a "mathematical" plane intersected by these conductors

3.14

unsymmetrical mode (V-terminal) voltage

voltage between a conductor or terminal of a device, equipment or system and a specified ground reference. For the case of a two-port network, the two unsymmetrical voltages are given by:

- a) the vector sum of the asymmetrical voltage and half of the symmetrical voltage; and
- b) the vector difference between the asymmetrical voltage and half of the symmetrical voltage.

NOTE See also IEC 161-04-13.

3.15

measuring receiver

~~receiver for the measurement of disturbances with different detectors~~

NOTE ~~The receiver is specified according to CISPR 16-1-1.~~

~~instrument such as a tunable voltmeter, an EMI receiver, a spectrum analyzer or an FFT-based measuring instrument, with or without preselection, that meets the relevant clauses of CISPR 16-1-1~~

NOTE See Annex I of CISPR 16-1-1 for further information.

3.16

test configuration

combination that gives the specified measurement arrangement of the EUT in which an emission level is measured

NOTE ~~The emission and immunity levels are measured as required by IEC 161-03-11, IEC 161-03-12, IEC 161-03-14 and IEC 161-03-15, definitions of emission level.~~

3.17

artificial network

AN

agreed reference load (simulation) impedance presented to the EUT by actual networks (e.g., extended power or communication lines) across which the RF disturbance voltage is measured

3.18

artificial mains network

AMN

network inserted in the supply mains lead of apparatus to be tested which provides, in a given frequency range, a specified load impedance for the measurement of disturbance voltages and which may isolate the apparatus from the supply mains in that frequency range

[IEV 161-04-05]

NOTE There are two basic types of AMN, the V-network (V-AMN) which couples the unsymmetrical voltages, and the delta-network which couples the symmetric and the asymmetric voltages separately. The terms line impedance stabilization network (LISN) and V-AMN are used interchangeably. In this standard, the acronym "AMN" is used for "V-AMN", as delta-AMNs are not used in product publications on emission measurements.

3.19

weighting (quasi-peak detection)

~~repetition-rate dependent conversion of the peak detected pulse voltages to an indication corresponding to the psychophysical annoyance of pulsive disturbances (acoustically or visually) according to the weighting characteristics, or alternatively, specified manner in which an emission level or an immunity level is evaluated~~

NOTE 1 ~~The weighting characteristics are specified in CISPR 16 1-1.~~

NOTE 2 ~~The emission level or immunity level is evaluated as required by IEC 60050-161 definitions of level (see IEV 161-03-01, IEV 161-03-11 and IEV 161-03-14).~~

weighting (of e.g. impulsive disturbance)

pulse-repetition-frequency (PRF) dependent conversion (mostly reduction) of a peak-detected impulse voltage level to an indication that corresponds to the interference effect on radio reception

NOTE 1 For the analogue receiver, the psychophysical annoyance of the interference is a subjective quantity (audible or visual, usually not a certain number of misunderstandings of a spoken text).

NOTE 2 For the digital receiver, the interference effect is an objective quantity that may be defined by the critical bit error ratio (BER) or bit error probability (BEP) for which perfect error correction can still occur or by another, objective and reproducible parameter.

3.19.1

weighted disturbance measurement

measurement of disturbance using a weighting detector

3.19.2

weighting characteristic

peak voltage level as a function of PRF for a constant effect on a specific radiocommunication system, i.e. the disturbance is weighted by the radiocommunication system itself

3.19.3

weighting detector

detector that provides an agreed weighting function

3.19.4

weighting factor

value of the weighting function relative to a reference PRF or relative to the peak value

NOTE Weighting factor is expressed in dB.

3.19.5

weighting function weighting curve

relationship between input peak voltage level and PRF for constant level indication of a measuring receiver with a weighting detector, i.e. the curve of response of a measuring receiver to repeated pulses

3.20

continuous disturbance

RF disturbance with a duration of more than 200 ms at the IF-output of a measuring receiver, which causes a deflection on the meter of a measuring receiver in quasi-peak detection mode which does not decrease immediately

[IEV 161-02-11, modified]

~~NOTE — The measuring receiver is specified in CISPR 16-1-1.~~

3.21

discontinuous disturbance

for counted clicks, disturbance with a duration of less than 200 ms at the IF-output of a measuring receiver, which causes a transient deflection on the meter of a measuring receiver in quasi-peak detection mode

NOTE For impulsive disturbance, see IEV 161-02-08.

~~NOTE 2 — The measuring receiver is specified in CISPR 16-1-1.~~

3.22

measurement time

T_m

effective, coherent time for a measurement result at a single frequency (in some areas also called dwell time)

- for the peak detector, the effective time to detect the maximum of the signal envelope,
- for the quasi-peak detector, the effective time to measure the maximum of the weighted envelope
- for the average detector, the effective time to average the signal envelope
- for the r.m.s. detector, the effective time to determine the r.m.s. of the signal envelope

3.23

sweep

continuous frequency variation over a given frequency span

3.24

scan

continuous or stepped frequency variation over a given frequency span

3.25

sweep or scan time

T_s

time between start and stop frequencies of a sweep or scan

3.26

span

Δf

difference between stop and start frequencies of a sweep or scan

3.27

sweep or scan rate

frequency span divided by the sweep or scan time

3.28

number of sweeps per time unit (e.g. per second)

n_s
 $1/(\text{sweep time} + \text{retrace time})$

3.29

observation time

T_o

sum of measurement times T_m on a certain frequency in case of multiple sweeps. If n is the number of sweeps or scans, then $T_o = n \times T_m$

3.30

total observation time

T_{tot}

effective time for an overview of the spectrum (either single or multiple sweeps). If c is the number of channels within a scan or sweep, then $T_{tot} = c \times n \times T_m$

3.31

measurement

process of experimentally obtaining one or more quantity values that can reasonably be attributed to a quantity

[ISO/IEC Guide 99:2007, 2.1]

3.32

test

technical operation that consists of the determination of one or more characteristics of a given product, process or service according to a specified procedure

NOTE A test is carried out to measure or classify a characteristic or a property of an item by applying to the item a set of environmental and operating conditions and/or requirements.

[IEC 60050-151:2001, 151-16-13]

3.33

reference ground

reference potential connecting point

NOTE 1 In some subclauses of this standard the term "ground reference" may be used to denote reference ground.

NOTE 2 * There can only be one reference ground in a conducted disturbance measurement system.

3.34

protective earthing

earthing a point or points in a system or in an installation or in equipment, for purposes of electrical safety

[IEC 60050-195:1998, 195-01-11]

3.35

total common mode impedance

TCM impedance

impedance between the cable attached to the EUT port under test and the reference ground plane

NOTE The complete cable is seen as one wire of the circuit and the ground plane as the other wire of the circuit. The TCM wave is the transmission mode of electrical energy, which can lead to radiation of electrical energy if the cable is exposed in the real application. Vice versa, this is also the dominant mode, which results from exposure of the cable to external electromagnetic fields.

3.36

asymmetric artificial network

AAN

network used to measure (or inject) asymmetric (common mode) voltages on unshielded symmetric signal (e.g. telecommunication) lines while rejecting the symmetric (differential mode) signal

NOTE 1 An AAN is an AN (artificial network) that provides a simulation of the asymmetric load realized by the telecommunication network.

NOTE 2 The term "Y-network" is a synonym for AAN.

NOTE 3 The AAN can also be used for immunity testing, where the receiver measurement port becomes the disturbance injection port.

4 Types of disturbance to be measured

4.1 General

This clause describes the classification of different types of disturbance and the detectors appropriate for their measurement.

4.2 Types of disturbance

For physical and psychophysical reasons, dependent on the spectral distribution, measuring receiver bandwidth, the duration, rate of occurrence, and degree of annoyance during the assessment and measurement of radio disturbance, distinction is made between the following types of disturbance:

- a) *narrowband continuous disturbance*, i.e. disturbance on discrete frequencies as, for example, the fundamentals and harmonics generated with the intentional application of RF energy with ISM equipment, constituting a frequency spectrum consisting only of individual spectral lines whose separation is greater than the bandwidth of the measuring receiver so that during the measurement only one line falls into the bandwidth in contrast to b);
- b) *broadband continuous disturbance*, which normally is unintentionally produced by the repeated impulses of, for example, commutator motors, and which have a repetition frequency which is lower than the bandwidth of the measuring receiver so that during the measurement more than one spectral line falls into the bandwidth; and
- c) *broadband discontinuous disturbance* is also generated unintentionally by mechanical or electronic switching procedures, for example by thermostats or programme controls with a repetition rate lower than 1 Hz (click-rate less than 30/min).

The frequency spectra of b) and c) are characterized by having a continuous spectrum in the case of individual (single) impulses and a discontinuous spectrum in case of repeated impulses, both spectra being characterized by having a frequency range which is wider than the bandwidth of the measuring receiver specified in CISPR 16-1-1.

4.3 Detector functions

Depending on the types of disturbance, measurements may be carried out using a measuring receiver with:

- a) an average detector generally used in the measurement of narrowband disturbance and signals, and particularly to discriminate between narrowband and broadband disturbance;
- b) a quasi-peak detector provided for the weighted measurement of broadband disturbance for the assessment of audio annoyance to a radio listener, but also usable for narrowband disturbance;
- c) ~~a peak detector which may be used for either broadband or narrowband disturbance measurement.~~ an rms-average detector provided for the weighted measurement of broadband disturbance for the assessment of the effect of impulsive disturbance to digital radio communication services but also useable for narrowband disturbance;
- d) a peak detector which may be used for either broadband or narrowband disturbance measurement.

Measuring receivers incorporating these detectors are specified in CISPR 16-1-1.

5 Connection of measuring equipment

5.1 General

This clause describes the connection of measuring equipment, measuring receivers and ancillary equipment such as artificial networks (AN) and voltage and current probes.

5.2 Connection of ancillary equipment


The connecting cable between the measuring receiver and the ancillary equipment shall be shielded and its characteristic impedance shall be matched to the input impedance of the measuring receiver. The measurement result shall account for the attenuation of the connecting cable.

The output of the ancillary equipment shall be terminated with the prescribed impedance. A minimum attenuation of 10 dB between AN output and measuring receiver input is required in order to fulfill the specified tolerance of the AN impedance at its EUT port. This attenuation may be incorporated in the AN. The use of a transient limiter is recommended for the protection of the receiver input circuits. It shall be designed to provide signals of maximum receiver input level without creating nonlinear effects.

5.3 Connections to RF reference ground

The artificial network (AN) shall be connected to the reference ground by a low RF impedance, e.g. by direct bonding of the case of the AN to the reference ground ~~or reference wall~~ of a shielded room, or with a low impedance conductor as short and as wide as practical (the maximum length to width ratio of which is 3:1 and the inductance of which is less than approximately 50 nH corresponding to an impedance of less than approximately 10 Ω at 30 MHz). An in-situ test of the voltage division factor as explained in Annex E is recommended. This will help to find, e.g., a ground strap resonance in the AN grounding.

NOTE A conductor with rectangular cross section (see drawing below) with: length $l = 30$ cm, width $b = 3$ cm, thickness $c = 0,02$ cm will cause an inductance L of approximately 210 nH ($X_L = 40 \Omega$ at 30 MHz), which is excessive. The value of L was calculated using the following equation:

$$L = 2 \times l \times \left(\ln \frac{2l}{b+c} + 0,5 + 0,22 \frac{b+c}{l} \right)$$


where

L is the inductance of the conductor in nH

l, b, c are the dimensions of the conductor in cm

If such a length cannot be avoided, the width must be as large as possible.

Terminal voltage measurements shall be referenced only to the reference ground. Ground loops (common impedance coupling) shall be avoided. Ground loops will negatively affect repeatability of measurement and can, e.g., be detected if grounded components of a test setup are touch-sensitive. This should also be observed for measuring apparatus (e.g., measuring receivers and connected ancillary equipment, such as oscilloscopes, analyzers, recorders, etc.) fitted with a protective earth conductor (PE) of protection class I equipment. The measuring instrumentation shall be provided with RF isolation so that the AN has only one RF connection to ground. This can be accomplished by RF chokes and isolation transformers, or by powering the measuring apparatus from batteries. Figure 1 shows an example of a recommended test setup with three AMNs and PE chokes for the avoidance of ground loops. In this figure, also the receiver RF connecting cable to the AMN can act as a ground connection if the receiver is grounded. Therefore, either a PE choke is needed at the receiver power input, or, if the receiver is outside a shielded room, a sheath current suppressor is needed on the connecting cable. Each AMN is thus RF-grounded only once.




Figure 1 – Example of a recommended test setup with PE chokes with three AMNs and a sheath current absorber on the RF cable

For safety reasons, PE chokes shall exhibit a low impedance for the power supply voltage at the power frequency and voltage in case of any defect. The short circuit voltage across the PE choke shall be below 4 V. PE chokes may be incorporated inside the AMN.

The RF impedance of PE chokes and sheath current absorbers in the measurement frequency range should be high compared with the impedance of the AMN connection to the reference ground plane (RGP). Commercially available PE chokes have, e.g., an inductance of 1,6 mH at nominal currents up to 36 A but they are not standardized in CISPR 16-1-2. The attenuation can be tested in accordance with Annex E. Some AMNs are available with built-in PE chokes. The difference in potential between PE and RGP must be minimized to avoid saturation of PE chokes from the resulting DC or low frequency current flowing through the chokes. If the current is unknown, it may have to be measured.

NOTE Sheath currents are RF currents flowing on the shield of shielded (e.g., coaxial) cables, and are a source of measurement uncertainty. Sheath current absorbers serve the purpose of reducing these currents.

For the treatment of PE connection of the EUT to the reference ground, see A.4.

Stationary test configurations of the AMN do not require a connection with the protective earth conductor if the reference ground is connected directly and meets the safety requirements for protective earth conductors (PE connections).

5.4 Connection between the EUT and the artificial mains network

General guidelines for the selection of grounded and non-grounded connections of the EUT to the AMN are discussed in Annex A.

6 General measurement requirements and conditions

6.1 General

Radio disturbance measurements shall, within the uncertainties allowed by CISPR 16-4-2, be:

- reproducible, i.e. independent of the measurement location and environmental conditions, especially ambient noise;
- free from interactions, i.e. the connection of the EUT to the measuring equipment shall neither influence the function of the EUT nor the accuracy of the measurement equipment.

These requirements may be met by observing the following conditions:

- a) existence of a sufficient signal-to-noise ratio at the desired measurement level, e.g. the level of the relevant disturbance limit;
- b) having a defined measuring set-up, termination and operating conditions of the EUT;
- c) in the case of voltage probe measurements on the supply mains, the probe shall have an impedance of 1,5 k Ω as specified in CISPR 16-1-2; for measurements on other circuits, the impedance may need to be increased (as provided by active voltage probes) to avoid excessive loading of high impedance circuits;
- d) in the case of current probe measurements, the probe shall have an impedance in the measuring circuit of 1 Ω maximum, as specified in CISPR 16-1-2;
- e) ~~when using a spectrum analyzer or scanning receiver due considerations shall be given to its particular operating and calibration requirements.~~

6.2 Disturbance not produced by the equipment under test

6.2.1 General

The measurement signal-to-noise ratio with respect to ambient noise shall meet the following requirements. Should the ~~spurious ambient~~ noise level exceed the required level, it shall be recorded in the test report.

6.2.2 Compliance testing

A test site shall permit emissions from the EUT to be distinguished from ambient noise. The ambient noise level should be at least 20 dB below the specified limit. For in-situ tests the ambient noise level should be at least 6 dB below the specified limit. In in-situ cases, the emission plus ambient must not exceed the limit. If the emission plus ambient exceeds the limit, then other methods need to be applied, for example, reduce the bandwidth, apply ambient cancellation, change frequency etc (Annex A of CISPR 16-2-3:2006 provides recommendations for measurement of disturbances in the presence of ambient emissions). The suitability of the site for the permitted ambient level may be determined by measuring the ambient noise level with the EUT in place but not operating.

6.3 Measurement of continuous disturbance

6.3.1 Narrowband continuous disturbance

The measuring receiver shall be kept tuned to the discrete frequency under investigation and retuned if the frequency fluctuates.

6.3.2 Broadband continuous disturbance

For the assessment of broadband continuous disturbance the level of which is fluctuating, the maximum reproducible measurement value shall be found. See 6.5.1 for further details.

6.3.3 Use of spectrum analyzers and scanning receivers

Spectrum analyzers and scanning receivers are useful for disturbance measurements, particularly in order to reduce measuring time. However, special consideration must be given to certain characteristics of these instruments, which include: overload, linearity, selectivity, normal response to pulses, frequency scan rate, signal interception, sensitivity, amplitude accuracy and peak, average and quasi-peak detection. These characteristics are considered in Annex B.

6.4 ~~Operating conditions of the EUT~~ EUT arrangement and measurement conditions

6.4.1 ~~General EUT arrangement~~

~~The EUT shall be operated under the following conditions:~~

6.4.1.1 ~~General~~

~~Where not specified in the product standard, the EUT shall be configured as described in the following paragraphs.~~

~~The EUT shall be installed, arranged and operated in a manner consistent with typical applications. Where the manufacturer has specified or recommended an installation practice, such practice shall be used in the test arrangement, where possible. This arrangement shall be typical of the normal installation practice. Interface cables, loads and devices shall be connected to at least one of each type of interface port of the EUT, and where practical, each cable shall be terminated in a device typical of actual usage.~~

~~Where there are multiple interface ports of the same type, additional interconnecting cables, loads and devices may need to be added to the EUT depending upon the results of preliminary tests. The number of additional cables or wires of the same type should be limited to the condition where the addition of another cable or wire does not significantly affect the emission level, i.e. varies by less than 2 dB, provided that the EUT remains compliant. The rationale for the selection of the configuration and loading of ports shall be included in the test report.~~

Interconnecting cables should be of the type and length specified in the individual equipment requirements. If the length can be varied, the length shall be selected to produce maximum disturbance.

If shielded or special cables are used during the tests to achieve compliance, a note shall be included in the instruction manual advising of the need to use such cables.

Excess lengths of cables shall be bundled at the approximate centre of the cable with the bundles 30 cm to 40 cm in length. If it is impractical to do so because of cable bulk or stiffness, the disposition of the excess cable shall be precisely noted in the test report.

Where there are multiple interface ports all of the same type, connecting a cable to just one of that type of port is sufficient, provided it can be shown that the additional cables would not significantly affect the results.

Any set of results shall be accompanied by a complete description of the cable and equipment orientation so that results can be repeated. If specific conditions of use are required to meet the limits, those conditions shall be specified and documented, for example cable length, cable type, shielding and grounding. These conditions shall be included in the instructions to the user.

Equipment that is populated with multiple modules (such as drawers and plug-in cards) shall be tested with a mix and number representative of that used in a typical installation. The number of additional boards or plug-in cards of the same type should be limited to the condition where the addition of another board or plug-in card does not significantly affect the emission level, i.e. varies by less than 2 dB, provided that the EUT remains compliant. The rationale used for selecting the number and type of modules should be stated in the test report.

A system that consists of a number of separate units shall be configured to form a minimum representative configuration. The number and mix of units included in the test configuration shall normally be representative of that used in a typical installation. The rationale used for selecting units should be stated in the test report.

One module of each type shall be operational in each equipment evaluated in an EUT. For an EUT comprising a system, one of each type of equipment that can be included in the possible system configuration shall be included in the EUT.

The results of an evaluation of EUTs having one of each type of module can be applied to configurations having more than one of each of those modules.

NOTE It has been found that disturbances from identical modules are generally not additive in practice.

The EUT position relative to the reference ground plane shall be equivalent to that occurring in use. Therefore, floor-standing equipment is placed on, but insulated from, a reference ground plane, and tabletop equipment is placed on a non-conductive table.

Equipment designed for wall-mounted operation shall be tested as tabletop EUT. The orientation of the equipment shall be consistent with normal installation practice.

Combinations of the equipment types identified above shall also be arranged in a manner consistent with normal installation practice. Equipment designed for both tabletop and floor standing operation shall be tested as tabletop equipment unless the usual installation is floor standing, then that arrangement shall be used.

The ends of signal cables attached to the EUT that are not connected to another unit or auxiliary equipment (AuxEq) shall be terminated using the correct terminating impedance defined in the product standard. If no product standard can be applied to the particular configuration, the termination shall be defined by the EUT manufacturer and noted in the test report.

Cables or other connections to auxiliary equipment located outside the test site shall drape to the floor, and then be routed to the place where they leave the test site.

Installation of AuxEq shall be in accordance with normal installation practice. Where this means that the AuxEq is located on the test site, it shall be arranged using the same conditions applicable for the EUT (for example, distance from the ground plane and insulation from the ground plane if floor standing, layout of cabling).

6.4.1.2 Arrangement of tabletop equipment

Equipment intended for tabletop use shall be placed on a non-conductive table. The size of the table will nominally be 1,5 m by 1,0 m but may ultimately be dependent on the horizontal dimensions of EUT.

Intra-unit cables shall be draped over the back of the table. If a cable hangs closer than 0,4 m from the horizontal ground plane (or floor), the excess shall be folded at the cable centre into a bundle no longer than 0,4 m, such that the part of the bundle closest to the horizontal reference ground plane is at least 0,4 m above the plane.

Cables shall be positioned as for normal usage.

If the mains port input cable is less than 0,8 m long (including power supplies integrated in the mains plug), an extension cable shall be used such that the external power supply unit is placed on the tabletop. The extension cable shall have similar characteristics to the mains cable (including the number of conductors and the presence of a ground connection). The extension cable shall be treated as part of the mains cable.

In the above arrangements, the cable between the EUT and the power accessory shall be arranged on the tabletop in the same manner as other cables connecting components of the EUT.

6.4.1.3 Arrangement of floor-standing equipment

The EUT shall be placed on the horizontal reference ground plane, orientated for normal use, but separated from metallic contact with the reference ground plane by up to 15 cm of insulation.

The cables shall be insulated (by up to 15 cm) from the horizontal reference ground plane. If the equipment requires a dedicated ground connection, then this shall be provided and bonded to the horizontal reference ground plane.

Intra-unit cables (between units forming the EUT or between the EUT and any auxiliary equipment) shall drape to, but remain insulated from, the horizontal reference ground plane. Any excess cable shall either be folded at the cable centre into a bundle no longer than 0,4 m or arranged in a serpentine fashion. If an intra-unit cable length is not long enough to drape to the horizontal reference ground plane but drapes closer than 0,4 m, then the excess shall be folded at the cable centre into a bundle no longer than 0,4 m. The bundle shall be positioned such that it is either 0,4 m above the horizontal reference ground plane or at the height of the cable entry or connection point if this is within 0,4 m of the horizontal reference ground plane.

For equipment with a vertical cable riser, the number of risers shall be typical of installation practice. Where the riser is made of non-conductive material, a minimum spacing of at least 0,2 m shall be maintained between the closest part of the equipment and the nearest vertical cable. Where the riser structure is conductive, the minimum spacing of 0,2 m shall be between the closest parts of the equipment and riser structure.

6.4.1.4 Arrangement for combinations of tabletop and floor-standing equipment

Intra-unit cables between a tabletop unit and a floor-standing unit shall have the excess cable folded into a bundle no longer than 0,4 m. The bundle shall be positioned such that it is either 0,4 m above the horizontal reference ground plane or at the height of the cable entry or connection point if this is within 0,4 m of the horizontal reference ground plane.

6.4.2 Normal load conditions

The normal load conditions shall be as defined in the product specification relevant to the EUT, and for EUTs not so covered, as indicated in the manufacturer's instructions.

6.4.3 Duration of operation

The duration of operation (during which the emission can be measured) shall be, in the case of EUTs with a given rated operating time, in accordance with the marking; in all other cases, the time is not restricted.

6.4.4 Running-in/Warm-up time

No specific running-in/warm-up time, prior to testing, is given, but the EUT shall be operated for a sufficient period to ensure that the modes and conditions of operation (e.g., operating temperature is reached, software loading is completed and EUT is ready to perform its intended operation) are typical of those during the life of the equipment. The term "running-in time" relates to EUTs that include electrical motors. For some EUTs, special test conditions may be prescribed in the relevant product publications.

6.4.5 Supply

The EUT shall be operated from a supply having the rated voltage of the EUT. EUTs with more than one rated voltage shall be tested at the rated voltage which causes maximum disturbance. Product standards may call out additional measurements, if, for example, the levels of disturbances vary considerably with the supply voltage.

6.4.6 Mode of operation

The EUT shall be operated under conditions of use intended by the manufacturer which cause the maximum disturbance at the measurement frequency.

6.4.7 Operation of multifunction equipment

Multifunction equipment that is subjected simultaneously to different clauses of a product standard and/or different standards shall be tested with each function operated in isolation, if this can be achieved without modifying the equipment internally. The equipment thus tested shall be deemed to have complied with the requirements of all clauses/standards when each function has satisfied the requirements of the relevant clause/standard.

For equipment that it is not practical to test with each function operated in isolation, or where the isolation of a particular function would result in the equipment being unable to fulfil its primary function, or where the simultaneous operation of several functions would result in saving measurement time, the equipment shall be deemed to have complied if it meets the provisions of the relevant clause/standard with the necessary functions operated.

6.4.8 Determination of EUT arrangement(s) that maximizes emissions

Initial testing shall identify the frequency that has the highest disturbance relative to the limit. This identification shall be performed whilst operating the EUT in typical modes of operation and with cable positions in a test arrangement that is representative of typical installation practice.

The frequency of highest disturbance with respect to the limit shall be found by investigating disturbances at a number of significant frequencies. This provides confidence that the probable frequency of maximum disturbance has been found and that the associated cable, EUT arrangement and mode of operation has been identified.

For initial testing, the EUT should be arranged in accordance with the product standards as appropriate.

6.4.9 Recording of measurement results

Of those disturbances above ($L - 20$ dB), where L is the limit level in dB(μ V) or dB(μ A), the disturbance levels and the frequencies of at least the six disturbances having the smallest margin to the limit L shall be recorded.

In addition, the test report shall include the value of the measurement instrumentation uncertainty corresponding to the used test setup, calculated as per the requirements of CISPR 16-4-2.

6.5 Interpretation of measuring results

6.5.1 Continuous disturbance

- a) At each frequency for which the level of disturbance is close to the limit and not steady, the reading on the measuring receiver is observed for at least 15 s for each measurement; the highest readings shall be recorded. Some product standards allow the exclusion of isolated clicks, which shall be ignored (e.g., CISPR 14-1).
- b) If the general level of the disturbance is not steady, but shows a continuous rise or fall of more than 2 dB in the 15 s period, then the disturbance voltage levels shall be observed for a further period and the levels shall be interpreted according to the conditions of normal use of the EUT, as follows:
 - 1) if the EUT is one which may be switched on and off frequently, or the direction of rotation of which can be reversed, then at each frequency of measurement the EUT should be switched on or reversed just before each measurement, and switched off just after each measurement. The maximum level obtained during the first minute at each frequency of measurement shall be recorded;
 - 2) if the EUT is one which in normal use runs for longer periods, then it should remain switched on for the period of the complete test, and at each frequency the level of disturbance shall be recorded only after a steady reading (subject to the provision that item a) has been obtained).
- c) If the pattern of the disturbance from the EUT changes from a steady to a random character part way through a test, then that EUT shall be tested in accordance with item b).
- d) Measurements are taken throughout the complete spectrum and are recorded at least at the frequency with maximum reading and as required by the relevant CISPR publication.

6.5.2 Discontinuous disturbance

Measurement of discontinuous disturbance may be performed at a restricted number of frequencies. For further details, see CISPR 14-1.

6.5.3 Measurement of the duration of disturbances

~~For a correct measurement of disturbances and to decide whether the disturbances are discontinuous, the duration of disturbances need to be known, therefore, it may have to be measured. The EUT is connected to the relevant AN. If a measuring receiver is available, it is connected to the network and an oscilloscope is connected to the IF output of the measuring receiver. It is also possible to use the zero-span function or the timing analysis function of a measuring receiver (see Figure 3). If a receiver is not available, the oscilloscope is connected directly to the network. The time base of the oscilloscope can be triggered by the disturbances to be tested; the time base is set to a value of 1 ms/div to 10 ms/div for EUTs with instantaneous switching and 10 ms/div to 200 ms/div for other EUTs. The duration of the disturbance can either be recorded directly by a digital oscilloscope and/or hard copy recording of the screen.~~

The duration of a disturbance must be known in order to measure it correctly and to determine if it is discontinuous. The duration of a disturbance may be measured in one of the following ways:

- through the connection of an oscilloscope to a measuring receiver's IF output to allow monitoring of the disturbance in the time-domain;
- through the tuning of either an EMI receiver or a spectrum analyzer to the disturbance frequency without frequency scanning (i.e. 'zero-span' mode) to allow monitoring of the disturbance in the time-domain; or
- through the use of the time-domain output of an FFT-based measuring receiver.

Guidance for the determination of the appropriate measurement time can be found in 8.3.

6.6 Measurement times and scan rates for continuous disturbance

6.6.1 General

For manual and automated or semi-automated measurements, measurement times and scan rates of measuring and scanning receivers shall be set such that the maximum emissions are measured. Especially, where a peak detector is used for prescans, the measurement times and scan rates have to take the timing of the emission under test into account. More detailed guidance on the execution of automated measurements can be found in Clause 8.

6.6.2 Minimum measurement times

~~Subclause B.7 of this standard provides a table of minimum sweep times that are needed to perform measurements over the indicated frequency range. From this table the following minimum scan times were derived to perform measurements in the complete CISPR band:~~

The minimum measurement (dwell) times are given in Table 2. The minimum measurement (dwell) times for scanning receivers and FFT-based measuring instruments in Table 2 and the scan times for spectrum analyzers in Table 1 apply to CW signals. The minimum scan times of Table 1 were derived to perform measurements in the entire CISPR band.

**Table 1 – Minimum scan times for the three CISPR bands
with peak and quasi-peak detectors**

Frequency band		Scan time T_s for peak detection	Scan time T_s for quasi-peak detection
A	9 kHz – 150 kHz	14,1 s	2 820 s = 47 min
B	0,15 MHz – 30 MHz	2,985 s	5 970 s = 99,5 min = 1 h 39 min
C/D	30 MHz – 1 000 MHz	0,97 s	19 400 s = 323,3 min = 5 h 23 min

Table 2 – Minimum measurement times for the four CISPR bands

Frequency band		Minimum measurement time T_m
A	9 kHz to 150 kHz	10,00 ms
B	0,15 MHz to 30 MHz	0,50 ms
C and D	30 MHz to 1 000 MHz	0,06 ms
E	1 GHz to 18 GHz	0,01 ms

~~The scan times in Table 1 apply for CW signals.~~ Depending on the type of disturbance, the scan time may have to be increased – especially for swept quasi-peak measurements. In extreme cases, the measurement time T_m at a certain frequency may have to be increased to 15 s, if the level of the observed emission is not steady (see 6.5.1 above).

Scan rates and measurement times for use with the average detector will be found in Annex D.

Most product standards call out quasi-peak detection for compliance measurements which is very time consuming, if no time-saving procedures are applied (see 8). Before time-saving procedures can be applied, the emission has to be detected in a prescan. In order to ensure that e.g. intermittent signals are not overlooked during an automatic scan, the considerations in 6.6.3 to 6.6.5 need to be taken into account.

6.6.3 Scan rates for scanning receivers and spectrum analyzers

One of two conditions need to be met to ensure that signals are not missed during automatic scans over frequency spans:

- for a single sweep: the measurement time at each frequency must be larger than the intervals between pulses for intermittent signals;
- for multiple sweeps with maximum hold: the observation time at each frequency should be sufficient for intercepting intermittent signals.

The frequency scan rate is limited by the instrument's resolution bandwidth, and video bandwidth settings. If the scan rate is chosen too fast for the given instrument state, erroneous measurement results will be obtained. Therefore, a sufficiently long sweep time as defined below needs to be chosen for the selected frequency span. Intermittent signals may be intercepted by either a single sweep with sufficient observation time at each frequency or by multiple sweeps with maximum hold. Usually for an overview of unknown emissions, the latter will be highly efficient: as long as the spectrum display changes, there may still be intermittent signals to discover. The observation time has to be selected according to the periodicity at which interfering signals occur. In some cases, the sweep time may have to be varied in order to avoid synchronization effects.

When determining the minimum sweep time for measurements with a spectrum analyzer or scanning EMI receiver, based on a given instrument setting and using peak detection, two different cases have to be distinguished. If the video bandwidth is selected to be **wider** than the resolution bandwidth, the following expression can be used to calculate the minimum sweep time:

$$T_{s \min} = (k \times \Delta f) / (B_{\text{res}})^2 \quad (1)$$

where

$T_{s\min}$	is the minimum sweep time
Δf	is the frequency span
B_{res}	is the resolution bandwidth
k	is the constant of proportionality, related to the shape of the resolution filter; this constant assumes a value between 2 and 3 for synchronously-tuned, near-Gaussian filters. For nearly rectangular, stagger-tuned filters, k has a value between 10 and 15.

NOTE Actual values of k are available from manufacturers. The actual values are normally taken into consideration in the coupled mode of the receiver or spectrum analyzer firmware.

If the video bandwidth is selected to be equal to or smaller than the resolution bandwidth, the following expression can be used to calculate the minimum sweep time:

$$T_{s\min} = (k \times \Delta f) / (B_{\text{res}} \times B_{\text{video}}) \quad (2)$$

where B_{video} is the video bandwidth

Most spectrum analyzers and scanning EMI receivers automatically couple the sweep time to the selected frequency span and the bandwidth settings. Sweep time is adjusted to maintain a calibrated display. The automatic sweep time selection can be overwritten if longer observation times are required, e.g. to intercept slowly varying signals.

In addition, for repetitive sweeps, the number of sweeps per second will be determined by the sweep time $T_{s\min}$ and the retrace time (time needed to retune the local oscillator and to store the measurement results, etc.).

6.6.4 Scan times for stepping receivers

Stepping EMI receivers are consecutively tuned to single frequencies using predefined step sizes. While covering the frequency range of interest in discrete frequency steps, a minimum dwell time at each frequency is required for the instrument to accurately measure the input signal.

For the actual measurement, a frequency step size of roughly 50 % or less of the resolution bandwidth used (depending on the resolution filter shape) is required to reduce measurement uncertainty for narrowband signals due to the stepwidth. Under these assumptions the scan time $T_{s\min}$ for a stepping receiver can be calculated using the following equation:

$$T_{s\min} = T_{m\min} \times \Delta f / (B_{\text{res}} \times 0,5) \quad (3)$$

where $T_{m\min}$ is the minimum measurement (dwell) time at each frequency

In addition to the measurement time, some time has to be taken into consideration for the synthesizer to switch to the next frequency and for the firmware to store the measurement result, which in most measuring receivers is automatically done so that the selected measurement time is the effective time for the measurement result. Furthermore, the selected detector, e.g. peak or quasi-peak, determines this time period as well.


For purely broadband emissions, the frequency step size may be increased. In this case the objective is to find the maxima of the emission spectrum only.

6.6.5 Strategies for obtaining a spectrum overview using the peak detector

For each prescan measurement, the probability of intercepting all critical spectral components of the EUT spectrum shall be as close to 100 % as possible. Depending on the type of measuring receiver and the characteristics of the disturbance, which may contain narrowband and broadband elements, two general approaches are proposed:

- stepped scan: the measurement (dwell) time shall be long enough at each frequency to measure the signal peak, e.g. for an impulsive signal the measurement (dwell) time should be longer than the reciprocal of the repetition frequency of the signal.
- swept scan: the measurement time must be larger than the intervals between intermittent signals (single sweep) and the number of frequency scans during the observation time should be maximized to increase the probability of signal interception.

Figures 2, 3, 4 and 5 show examples of the relationship between various time-varying emission spectra and the corresponding display on a measuring receiver. In cases of Figures 2, 4, and 5, the upper part of the figure shows the position of the receiver bandwidth as it either sweeps or steps through the spectrum.




T_p is the pulse-repetition interval of the impulsive signal. A pulse occurs at each vertical line of the spectrum-vs.-time display (upper part of the figure).

Figure 2 – Measurement of a combination of a CW signal (“NB”) and an impulsive signal (“BB”) using multiple sweeps with maximum hold

If the type of emission is unknown, multiple sweeps with the shortest possible sweep time and peak detection allow the spectrum envelope to be determined. A short single sweep is sufficient to measure the continuous narrowband signal content of the EUT spectrum. For continuous broadband and intermittent narrowband signals, multiple sweeps at various scan rates using a “maximum hold” function may be necessary to determine the spectrum envelope. For low repetition impulsive signals, many sweeps will be necessary to fill up the spectrum envelope of the broadband component.

The reduction of measurement time requires a timing analysis of the signals to be measured. This can be done either with a measuring receiver which provides a graphical signal display, used in zero-span mode or using an oscilloscope connected to the receiver's IF or video output as e.g. shown in Figure 3.




Disturbance from a DC collector motor. Due to the number of collector segments the pulse repetition frequency is high (approximately 800 Hz) and the pulse amplitude varies strongly. Therefore for this example, the recommended measurement (dwell) time with the peak detector is > 10 ms.

Figure 3 – Example of a timing analysis

This way pulse durations and pulse repetition frequencies can be determined and scan rates or dwell times selected accordingly:

- for **continuous unmodulated narrowband** disturbances, the fastest scan time possible for the selected instrument settings may be used;
- for **pure continuous broadband** disturbances, e.g. from ignition motors, arc welding equipment, and collector motors, a stepped scan (with peak or even quasi-peak detection) for sampling of the emission spectrum may be used. In this case, the knowledge of the type of disturbance is used to draw a polyline curve as the spectrum envelope (see Figure 4). The step size has to be chosen so that no significant variations in the spectrum envelope are missed. A single swept measurement – if performed slowly enough – will also yield the spectrum envelope;
- for **intermittent narrowband** disturbances with unknown frequencies either fast short sweeps involving a “maximum hold” function (see Figure 5) or a slow single sweep may be used. A timing analysis may be required prior to the actual measurement to ensure proper signal interception.

Intermittent broadband disturbances shall be measured with a disturbance analyzer that complies with CISPR 16-1-1. For explanation of related measurement procedures see CISPR 14-1.



The measurement (dwell) time T_m should be longer than the pulse repetition interval T_p , which is the inverse of the pulse repetition frequency.

Figure 4 – A broadband spectrum measured with a stepped receiver




Figure 5 – Intermittent narrowband disturbances measured using fast short repetitive sweeps with maximum hold function to obtain an overview of the emission spectrum

NOTE In the example above, 5 sweeps are required until all spectral components are intercepted. The number of sweeps required or the sweep time may have to be increased, depending on pulse duration and pulse repetition interval.

6.6.6 Timing considerations using FFT-based instruments

FFT-based measuring instruments may combine the parallel calculation at N frequencies and a stepped scan. For this purpose, the frequency range of interest is subdivided into a number of segments N_{seg} that are scanned sequentially. The procedure is shown in Figure 19 for three segments. The total scan time for the frequency range of interest T_{scan} is calculated as:

$$T_{\text{scan}} = T_m N_{\text{seg}} \quad (4)$$

where

T_m is the measurement time for each segment and

N_{seg} is the number of segments.

FFT-based measuring instruments may also provide methods to improve the frequency resolution across a given frequency range. In general, an FFT-based measuring instrument will have a fixed frequency step $f_{\text{step FFT}}$ that is determined by the number of frequencies of the FFT. Increased frequency resolution is achieved by performing repeat calculations over a given frequency range. For each repeat calculation, the lowest frequency is incremented by a step ratio, $f_{\text{step final}}$.

Hence the first calculation over the given frequency range considers the following frequencies:

$f_{\text{min}},$
 $f_{\text{min}} + f_{\text{step FFT}},$
 $f_{\text{min}} + 2f_{\text{step FFT}},$
 $f_{\text{min}} + 3f_{\text{step FFT}} \dots$

The second calculation over the given frequency range considers the following frequencies:

$f_{\text{min}} + f_{\text{step final}},$
 $f_{\text{min}} + f_{\text{step final}} + f_{\text{step FFT}},$
 $f_{\text{min}} + f_{\text{step final}} + 2f_{\text{step FFT}},$
 $f_{\text{min}} + f_{\text{step final}} + 3f_{\text{step FFT}} \dots$

This procedure, applied for a step ratio of 3, is displayed on Figure 20.

The scan time T_{scan} is calculated as:

$$T_{\text{scan}} = T_m \frac{f_{\text{step FFT}}}{f_{\text{step final}}} \quad (5)$$

where

T_m is the measurement time and


$\frac{f_{\text{step FFT}}}{f_{\text{step final}}}$ is the step ratio.

For a system that combines both methods, the scan time T_{scan} is calculated as:

$$T_{\text{scan}} = T_m N_{\text{seg}} \frac{f_{\text{step FFT}}}{f_{\text{step final}}} \quad (6)$$

NOTE 1 FFT-based measuring instruments may combine both methods, the stepped scan as well as a method to improve the frequency resolution.

NOTE 2 Additional background information is currently in preparation for CISPR 16-3.¹




IEC 1827/10

Figure 19 – FFT scan in segments

¹

A CISPR/TR 16-3 is to be published to replace CISPR 16-3:2003 and its amendments.



IEC 1828/10

Figure 20 – Frequency resolution enhanced by FFT-based measuring instrument

7 Measurement of disturbances conducted along leads, 9 kHz to 30 MHz

7.1 Introduction

When testing for compliance with emission limits for electromagnetic disturbances conducted along leads, the following items shall be considered as minimum, both in the standardized situation (type tests) and at the place of installation (*in situ* tests):

- the types of disturbance*: there are two methods of measuring conducted disturbances, either as a voltage (prevailing method for CISPR measurements) or as a current. Both methods can be used to measure the three types of conducted disturbance, i.e.:
 - common mode (also called asymmetrical mode, i.e. the vector sum of voltages/currents in bundle or group of wires);
 - differential mode (also called symmetrical mode);
 - unsymmetrical mode (voltage between terminal and reference ground).

NOTE The unsymmetrical mode voltage is primarily measured at the power port. The common mode voltage (or current) is measured primarily at telecommunication, signal and control ports.

- the measuring equipment*: the type of measuring equipment is chosen in relation to the disturbance properties to be determined (see 7.2);
- the ancillary equipment*: the type of ancillary equipment, i.e., artificial networks, current probes or voltage probes, is chosen in accordance with the type of disturbance to be measured in accordance with 7.1 a). Each type of ancillary equipment presents RF loading to the measured signals and ports (see 7.3);
- RF load conditions of the disturbance source*: the test set-up will present certain RF load impedances to the disturbance source(s) in the EUT. These impedances are standardized in type tests or might depend on the conditions at the place of installation in the case of *in situ* tests (see 7.3 and 7.4);

- e) *the test configuration of EUT*: a standardized test configuration shall specify the reference ground, the position of the EUT and ancillary measuring equipment with respect to that reference ground, connections to that reference ground and interconnections of the EUT with the associated equipment in an unambiguous way (see 7.4 and 7.5).

7.2 Measuring equipment (receivers, etc.)

7.2.1 General

In general, a distinction is drawn between continuous and discontinuous disturbances. Continuous radio-frequency disturbances are predominantly measured in terms of frequency domain parameters. Discontinuous disturbances are also measured in terms of frequency domain parameters but may need additional time domain measurements.

The measuring receivers and other measuring equipment specified in CISPR 16-1-1 shall be used. For time domain measurements oscilloscopes etc. may be used.

7.2.2 Use of detectors for conducted disturbance measurements

CISPR 16-1-1 specifies the characteristics of detectors that are required to perform measurements per product specifications. Several of these product specifications require the use of both quasi-peak and average detectors for conducted disturbance measurements. The time constants of these two detectors are very long and make automated measurements time-consuming.

A peak detector with shorter time constants may be used to make initial measurements and to determine compliance with a limit. But if the measured disturbance levels are above a limit they shall be followed by measurements with the quasi-peak and average detectors.

Annex C provides guidance on how these measurements may be performed efficiently.

7.3 Ancillary measuring equipment

7.3.1 General

Ancillary measuring equipment for conducted disturbance measurement is divided into two categories:

- a) voltage measuring sensors, such as artificial networks (AN) and voltage probes;

NOTE The artificial network is sometimes referred to as impedance stabilization network (ISN). This term is applicable to ANs for emission measurements on telecommunication ports (i.e. AANs or Y-networks) in CISPR 22. Some standards use the terms impedance stabilization network (ISN) for ANs for emission measurements on telecommunication ports (i.e. AANs or Y-networks).

- b) current measuring sensors, such as current probes.

7.3.2 Artificial networks (AN)

7.3.2.1 General

The common mode, differential and unsymmetrical mode impedances of actual networks, such as of power mains and telecommunication networks, are location dependent and, in general, time varying. Therefore, type testing of disturbance requires standardized impedance simulation networks, referred to as artificial networks (AN). The AN provides standardized RF load impedances to the EUT. For this purpose, the AN is inserted in series with the terminals of the EUT and the actual network or signal simulator. In this way, the AN simulates extended networks (long lines) with defined impedances.

7.3.2.2 Types of artificial networks

The ANs specified in CISPR 16-1-2 shall be used, unless specific reasons call for another construction. In general three types of AN can be distinguished:

- a) *the V-type AN (typically used as V-AMN, or LISN)*: in a defined frequency range, the RF impedances between each of the EUT terminals to be measured and the reference ground have a defined value, whereas no impedance component is connected directly between these terminals. The construction defines (indirectly) the measurement of the vector sum of both the differential and common mode voltage. In principle, there is no limit for the number of EUT terminals, i.e. for the number of lines to be measured by V-type ANs;
- b) *the delta-type AN (actually not used in product publications but could be used as delta-AMN for power lines or as delta-network for signal lines)*: in a defined frequency range, the RF impedance between a pair of EUT terminals to be measured and between these terminals and the reference ground have defined value. This construction defines directly both the differential and the common mode RF load impedances. Addition of a balance/unbalance transformer makes it possible to measure the symmetric and asymmetric disturbance voltage;
- c) *the Y-type AN (also called the asymmetric artificial network, AAN, or ISN)*: in a defined frequency range, the common mode RF impedance between a pair of EUT terminals to be measured and a reference ground has a defined value. In general, no defined differential load impedance is included in a Y-type AN as such. The defined differential impedance must then be provided by the external circuit connected to the supply (line) terminals of the Y-type AN. This type of AN is used to measure common mode disturbance voltages only.

7.3.3 Voltage probes

For ~~standardized specifications~~ of voltage probes, see CISPR 16-1-2.

Disturbance voltages on terminals which are not to be measured with an AN can be measured with a voltage probe. Examples of such terminals are connecting jacks for antennas, control lines, signal lines and load lines. In general the voltage probe is used to measure the unsymmetrical disturbance voltage. The probe presents a high RF impedance between the terminal to be measured and the reference ground.

The capacitive voltage probe (CVP) is used to measure the asymmetrical (common mode) voltage of a number of conductors without making direct conductive contact. It is constructed so that it can be clamped around the conductors to be measured. Clamping the CVP around an individual conductor will allow the measurement of the unsymmetrical disturbance voltage.

7.3.4 Current probes

Current probes or current transformers allow the measurement of all three types of disturbance current (see 7.1 and CISPR 16-1-2) on mains leads, signal lines, load lines etc. A clip-on construction of the probe will facilitate its use.

The common mode current on leads is measured when the current probe is clipped around those leads, regardless of the number of wires. In this situation, the differential mode currents on the leads will induce signals with equal magnitude but opposite sign, so that these signals cancel to a high degree. The latter effect allows the measurement of a common mode current with a small amplitude in the presence of differential mode (operating) currents with large amplitude.

The current probe cannot be used for the measurement of the converted common mode (CCM) current between an AAN and the EUT. The CCM shall only be measured by the voltage at the output of the AAN [see 7.3.2.2 c)].

NOTE The purpose of the AAN is to simulate the disturbance potential of the network cabling that is attached to the telecommunication port of the EUT. Thus, in response to the differential-mode voltage launched onto the network at the telecommunication port of the EUT, the AAN generates an internal, common-mode voltage that represents the converted common-mode (CCM) voltage that would be generated by the attached network cabling. This internally generated common-mode voltage has an associated common-mode current (I_{CCM} in Figure 21). This current undergoes current division within the AAN (into I_{CCM1} and I_{CCM2} in Figure 21). The current division is determined by the common mode impedance of the AAN output (Z_T on Figure 21) and the common mode impedance presented at the AAN's EUT terminal (Z_E in Figure 21). The common-mode impedance of the AAN output is controlled and hence the common-mode voltage at the AAN output (V_{CCM} in Figure 21) should be the measure of the disturbance potential of the connected network. The common mode impedance presented at the AAN's EUT port is not controlled: rather, it varies with frequency and depends upon the EUT size and the EUT arrangement. Hence this CCM current (I_{CCM2} in Figure 21) cannot be measured with a current probe because, for IT equipment of typical size, the magnitude of Z_E varies from around 2 k Ω to around 200 Ω , in the frequency range from 150 kHz to 30 MHz.




Figure 21 – Illustration of current I_{CCM}

For already defined (and standardized) current probes, see CISPR 16-1-2.

7.4 Equipment under test configuration


7.4.1 Arrangement of the EUT and its connection to the AN

For measurement of the disturbance voltage, the EUT is connected to the power supply mains and any other extended network via one or more AN(s) (in general, the V-type network is used as an AMN for the power port, see Figure 6), in accordance with the following requirements. CISPR product publications supply additional test details relevant to particular EUTs.

An EUT, whether intended to be grounded or not, and which is to be used on a table is configured as follows:

- either the bottom or the rear of the EUT shall be at a controlled distance of 40 cm from a reference ground plane. This ground plane is normally the wall or floor of a shielded room. It may also be a grounded metal ~~plane sheet with dimensions~~ of at least 2 m by 2 m. This is physically accomplished as follows:
 - place the EUT on a table of non-conducting material which is at least 80 cm high; place the EUT so that it is 40 cm from the wall of the shielded room, or
 - place the EUT on a table of non-conducting material which is 40 cm high so that the bottom of the EUT is 40 cm above the ground plane;
- all other conductive surfaces of the EUT shall be more than 40 cm away from the reference ground plane;
- the ANs are placed on the floor as shown in Figure 6 in such a way that one side of the AN housing is 40 cm from the vertical reference ground plane and other metallic parts. V-networks (AMNs) and Y-networks (~~ISNs~~ AANs) are shown in Figure 6 and Figure 7.

- NOTE The configuration in Figure 8 may cause an ambiguity due to the fact that with some EUTs, the metallic interference source is not in the center of the nonmetallic housing (see CISPR 16-4-1).



- 1 Interconnecting cables that hang closer than 40 cm to the ground plane shall be folded back and forth forming a bundle 40 cm long or less, hanging approximately in the middle between the ground plane and the table. The minimum bend radius of the cable shall not be exceeded. ~~If the bend radius causes the cable folds to exceed 40 cm, the bend radius size shall take precedence. If the bend radius causes the bundle length to exceed 40 cm, the bend radius shall determine the bundle length.~~
 - 2 I/O cables that are connected to a peripheral shall be bundled in the centre. The end of the cable may be terminated if required using correct terminating impedance. The total length shall not exceed 1 m – if possible.
 - 3 EUT is connected to one AMN. Measurement terminals of AMNs and ~~ISNs AANs~~ must be terminated with 50 Ω if not connected to the measuring receiver. AMNs are placed directly on the horizontal ground plane 0,8 m from the EUT and 40 cm from vertical ground plane if the vertical ground plane is the reference ground plane (see also Figure 7 a)). Alternatively (as shown in Figure 7 b)), AMNs are placed on the vertical ground plane 0,8 m from the EUT, if the horizontal ground plane is the reference ground plane, which is 40 cm below the EUT. To reach the 0,8 m distance, the AMNs may have to be moved to the side. All associated equipment is connected to a second AMN if this second AMN is capable of supplying the necessary power. In cases where a single AMN is not capable of supplying the necessary power, several AMNs may be used to supply the associated equipment.
 - 4 Cables of hand-operated devices, such as keyboards, mice, etc., shall be placed as close as possible to the host.
 - 5 Non-EUT components being tested.
 - 6 Rear of EUT, including peripherals, shall all be aligned and flush with rear of table-top.
 - 7 Rear of table-top shall be at a distance of 40 cm from a vertical conducting plane that is bonded to the floor ground plane.
- Tolerances of cable lengths and distances are as practical as possible.

Figure 6 – Test configuration: table-top equipment for conducted disturbance measurements on power mains






Figure 7 – Arrangement of EUT and AMN at 40 cm distance with a) vertical RGP and b) horizontal RGP



IEC 1607/08





- 1 Metallic wall 2 m × 2 m
- 2 EUT
- 3 Excess power cord (e.g., 2 cm by 30 cm 0,02 m × 0,3 m forming a meander)
- 4 AMN
- 5 Coaxial cable
- 6 Measuring receiver
- B Reference ground connection
- M Measuring receiver input
- P Power to EUT

Tolerances of cable lengths and distances are as practical as possible.

**Figure 8 – Optional example test configuration for an EUT
with only a power cord attached**

Floor-standing EUTs are subject to the same provisions as above with the exception that they shall be placed on a floor, the points of contact being consistent with normal use. A ground-connected floor of metal shall be used which shall not make metallic contact with the floor support(s) of the EUT, but which shall make contact with intentional ground conductors of the EUT. The metal floor may be used as the reference ground plane and shall extend at least 50 cm beyond the boundaries of the EUT and have minimum dimensions of 2 m by 2 m. For examples of test configurations, see Figures 9 and 10.






IEC 502/13

- 1 Excess cables shall be bundled in the centre or shortened to appropriate length.
- 2 The EUT and cables shall be insulated (up to 15 cm) from the ground plane.
- 3 The EUT is connected to one AMN. The AMN can be placed on top of or immediately beneath the ground plane.
All other equipment is powered from the second AMN.

Tolerances of cable lengths and distances are as practical as possible.

Figure 9 – Test configuration: floor-standing equipment (see 7.4.1 and 7.5.2.2)



IEC 1609/08

- 1 The interconnecting cables which hang closer than 40 cm to the ground plane shall be folded back and forth forming a bundle 30 cm to 40 cm long or less, hanging approximately in the middle between the ground plane and the table.
 - 2 Excess power cords shall be bundled in the centre or shortened to appropriate length.
 - 3 The EUT is connected to one AMN. The AMN may alternatively be connected to the vertical reference plane. All other equipment is powered from the second AMN. To reach the 0,8 m distance, the AMNs may have to be moved to the side.
 - 4 The EUT and the cables shall be insulated (up to 15 cm) from the ground plane.
 - 5 The I/O cable to the floor standing unit drapes to the ground plane and the excess is bundled. Cables not reaching the ground plane are dropped to the height of the connector or 40 cm, whichever is lower.
- Tolerances of cable lengths and distances are as practical as possible.

Figure 10 – Example Test configuration: floor-standing and table-top equipment
(see 7.4.1 and 7.5.2.2)

The AN is RF bonded to the reference ground plane by a low RF impedance connection (as explained in 5.2).

NOTE The "low" RF impedance value should preferably be less than 10Ω at 30 MHz. This can, for example, be achieved if the housing of the AN is mounted directly to the reference ground plane or its connection strap has a length-to-width ratio not more than 3:1. Resonances in the AN grounding can be identified by an in-situ test of the voltage division factor (see Annex E).

The EUT is arranged as shown in Figures 6 through 10. The reference distance between the boundary of the EUT and the closest surface of the AN is 80 cm. A good approach for table-top EUTs as in Figures 6 and 10 is the AN mounted in the ground plane – the front panel being flush with the ground plane.

The power mains leads to an AN and the connecting cable from the network to the measuring receiver must be arranged in such a way that their locations do not influence the measurement results. EUTs, which are not equipped with fixed connecting leads, are connected to the AN with a 1 m long lead or as specified in the relevant equipment documentation. The 1 m length is preferred as it gives a lower standard compliance uncertainty.

Unless the EUT has specific requirements for ground lead impedance, the following instructions shall apply. If the EUT is to be connected to a reference ground, this shall be done by means of a lead running parallel to the EUT mains lead and of the same length at a distance of not more than 10 cm from it, unless a ground conductor is contained in the mains lead itself. If a fixed lead is attached to the EUT it shall be 1 m long, or if in excess of 1 m, part of the lead is folded back and forth in the shape of a meander between 30 cm and 40 cm in length, and arranged in the form of a non-inductive serpentine in such a way that the total length of the lead does not exceed 1 m (see also Figure 11). However, when the bundled lead may influence the measurement results, a shortening of the length to 1 m is recommended.

~~NOTE The decision whether bundling or meandering should be preferred has been excluded from the publication. Existing text of the former edition has been kept for simplicity. It has been found that meanders cause lower inductances than bundles, but resonances cannot be totally avoided. Therefore the question will be treated in a separate project.~~

7.4.2 Procedure for the measurement of unsymmetric disturbance voltages with V-networks (AMNs)

7.4.2.1 General

Generally, the measurement of disturbance voltages using ANs is the preferred CISPR measurement method. If, e.g., an AMN causes the EUT not to work, then measurements with current or voltage probes should be made.

7.4.2.2 Arrangement of equipment with ground connection


For equipment under test which is required to be grounded during its operation, or the conductive housing of which can come into contact with ground, the unsymmetric radio interference voltage of the individual mains lead is measured with reference to the reference metal wall (general ground of the measuring equipment) to which the housing of the equipment under test is connected via its protective ground conductor and the ground connection of the artificial mains network (see the equivalent circuit in Figure 12).

The parameters determining the interference potential of grounded test units are discussed in A.3.

For EUTs with two or more power and safety conductors or special ground connections, the measurement result depends much on the termination conditions of the mains terminals and the grounding conditions (refer also to 7.5 on measurement in systems).

As the ground safety conductors in the actual mains power supply installation may have a considerable length, and therefore do not guarantee a ground impedance as low and effective as in the standard test set-up with only a 1 m long ground wire connection to the reference ground, and moreover, since safety conductors need not be used on every product per IEC 60364-4, disturbance voltage measurements on pluggable safety-class I appliances shall be carried out according to 7.4.2.3, also without the safety or ground wire being connected (non-grounded measurement). If however for safety reasons it is necessary to maintain the safety function of ground wires, this can be achieved by the use of a PE choke or impedance equal to the network impedance of a V-network in the safety wire path.

Exceptions may be made for non-radiating or well-screened EUTs which have to be grounded according to special requirements or instructions (see A.2.1 and A 4.1).



IEC 1610/08

- 1 The length of the EUT power cord in excess of 80 cm shall be folded into a serpentine-like bundle and not coiled.
- 2 Connection of the AN to the ground plane shall provide a low impedance path at high frequencies. It shall be made using a solid flat metal conductor that has a length-to-width ratio of not more than 3:1.
- 3 The CISPR measuring receiver shall be isolated from the AMN using a sheath current absorber on the coaxial cable (Example in E.2).
- 4 Dotted lines represent the test set-up for the three-phase power.
- 5 Optional filter hook-up, replace with shorts if not used.
- 6 Interconnected units may be attached to a single AN via a power junction strip or box.
- 7 A table mounted or handheld EUT must be 40 cm from any grounded conducting surface of at least 2 m square and at least 80 cm from any other conductive objects, including devices that are part of the system or instrumentation.

Figure 11 – Schematic of disturbance voltage measurement configuration
(see also 7.5.2.2)




Figure 12a – Schematic for measurement and power circuit




Figure 12b – Equivalent voltage source and measurement circuit

- 1 EUT
- 2 Power cord
- 3 AMN
- 4 Inductor and decoupling capacitor
- 5 Metallic wall
- A Power input
- B₀ Reference earth connection
- L₁, L₂ Power cord connection (100 cm)
- P₁, P₂ EUT plug to mains network
- C₁ Stray capacitance within EUT to metallic parts
- C₂ Stray capacitance of EUT to metallic wall (earth)
- C_k Coupling capacitors within mains network
- D_r Inductor (PE choke) for safety ground wire
- K Conductive structural parts of the EUT
- L Inductance of connecting wires
- M Fictitious mid-point of the internal common mode voltages
- R_N Simulation resistances (50 Ω or 150 Ω)
- Z_s Symmetric internal resistance of EUT
- Z_{1u}, Z_{2u} Common mode resistance of the EUT
- U_{1u}, U_{2u} Internal common mode voltage of the EUT
- U₁₀, U₂₀ External measurable common mode voltage

Figure 12 – Equivalent circuit for measurement of common mode disturbance voltage for class I (grounded) EUT

Figure 13 – Equivalent circuit for measurement of common mode disturbance voltage for class II (ungrounded) EUT

7.4.2.4 Arrangement of handheld equipment without a ground connection

Measurements shall first be made in accordance with 7.4.2.3. Additional measurements shall then be made using the artificial hand described in CISPR 16-1-2.

The general principle to be followed in the application of the artificial hand is shown in Figure 15. Terminal M of the RC element shall be connected to any exposed non-rotating metal work and to metal foil wrapped around all handles, both fixed and detachable, supplied with the EUT. Metalwork which is covered with paint or lacquer is considered as exposed metalwork and shall be directly connected to the RC element.

The artificial hand shall consist of metal foil wrapped around the case, or part thereof, as specified below. The foil shall be connected to one terminal (terminal M) of an RC element (see Figure 14) consisting of a capacitor of $220 \text{ pF} \pm 20 \%$ in series with a resistor of $510 \Omega \pm 10 \%$; the other terminal of the RC element shall be connected to the reference ground of the measuring system.

The artificial hand is to be applied in the following way:

- a) when the case of the EUT is entirely of metal, no metal foil is needed, but the terminal M of the RC element shall be connected directly to the body of the EUT;
- b) when the case of the EUT is of insulating material, metal foil shall be wrapped around the handle B (Figure 15), and also around the second handle D, if present. Metal foil 60 mm wide shall also be wrapped around the body C at that point where the iron core of the motor stator is located or around the gearbox if this gives a higher emission level. All these pieces of metal foil, and the ring or bushing A, if present, shall be connected together and to the terminal M of the RC element;
- c) when the case of the EUT is partly metal and partly insulating material, and has insulating handles, metal foil shall be wrapped around the handles B and D (Figure 15). If the case is non-metallic at the location of the motor, a metal foil 60 mm wide shall be wrapped around the body C at that point where the iron core of the motor stator is located, or alternatively around the gearbox, if this is of insulating material and a higher emission level is obtained. The metal part of the body, the point A, the metal foil round the handles B and D and the metal foil on the body C shall be connected together and to the terminal M of the RC element;
- d) when the EUT has two handles of insulating material A and B and a case of metal C, for example an electric saw (Figure 16), metal foil shall be wrapped around the handles A and B. The metal foil at A and B and the metal body C shall be connected together and to the terminal M of the RC element.




Figure 14 – RC element for artificial hand

Figure 15 – Portable electric drill with artificial hand




Figure 16 – Portable electric saw with artificial hand

7.4.2.5 Arrangement of keyboards, electrodes and other equipment sensitive to human touch

In the case of such equipment, the artificial hand shall be applied as required by the product specifications and in general according to 7.4.2.4.

7.4.2.6 Arrangement of equipment with external suppression components

If interference suppression devices are attached outside the EUT (e.g. in a plug device for connection to the mains) or as an element inserted in the connecting cable (power cord emission suppression device), or if shielded power cords are used, an additional 1 m long unshielded cable must be connected between the emission suppression device and the AN for measurement of the disturbance voltage. The line between the device and the emission suppression device must be placed in the direct proximity of the test object.

7.4.2.7 Arrangement of equipment having auxiliary equipment (AuxEq) connected at the end of a lead other than the mains lead

NOTE 1 Regulating controls incorporating semiconductor devices are excluded from this subclause; the provisions of 7.4.4.1 shall apply.

NOTE 2 When the AuxEq is not essential to the operation of the EUT and has a separate test procedure specified elsewhere, this subclause does not apply. The main EUT is tested as an individual EUT.

NOTE 3 The ultimate decision whether to measure and apply limits is to be made in the relevant CISPR product publication.

Connecting leads exceeding 1 m in length shall be bundled in accordance with 7.4.1.

Measurements are not required when the connecting lead between EUT and AuxEq is permanently fixed on both ends and is either shorter than 2 m or shielded, provided that in the latter case the shielded lead is connected at both ends to the metal housing of the EUT and that of the AuxEq. Leads with removable plugs and sockets are considered to be extendable to a length of more than 2 m and measurements are required.

The EUT shall be arranged in accordance with previous subclauses of 7.4.2, with the following additional requirements:

- a) the AuxEq shall be placed at the same height as and at the same distance from the grounded conducting surface and if the lead is long enough, it is to be treated in accordance with 7.4.1. If the auxiliary lead is shorter than 0,8 m, its length shall be maintained, and the AuxEq shall be placed as far away as possible from the main EUT. When the AuxEq is a control, the arrangements for its operation must not affect the level of disturbance;
- b) if an EUT having an AuxEq is grounded, no artificial hand shall be connected. If the EUT itself is made to be held in the hand, the artificial hand shall be connected to the EUT and not to any AuxEq;
- c) if the EUT is not made to be held in the hand, AuxEq which is not grounded and is made to be held in the hand must be connected to the artificial hand. If the AuxEq is not made to be held in the hand either, it shall be placed in relation to a grounded conducting surface as described in 7.4.1.

In addition to the measurement on the terminals for the mains connection, measurements are conducted on all other terminals for incoming and outgoing leads (e.g., control and load lines) using a voltage probe connected to the input of the measuring receiver.

The AuxEq, control or load is connected to allow measurements to be made under all provided operating conditions and during interactions between the EUT and the AuxEq.

Measurements are performed both on the power input terminals of the EUT and the power input terminals of the AuxEq.

7.4.3 Measurement of common mode voltages at differential mode signal terminals

7.4.3.1 General

Generally, the measurement of disturbance voltages using ANs is the preferred CISPR measurement method. If e.g., an AN causes the EUT not to work, then measurements with current or capacitive voltage probes should be made.

7.4.3.2 Measurement using the delta-type network

The common mode disturbance voltage at the terminals for differential mode signal lines of telecommunication, data processing and other equipment is measured with delta-networks in accordance of CISPR 16-1-2, in the frequency range 150 kHz to 30 MHz. The delta-networks specified in CISPR 16-1-2 could be constructed so as to allow signal and d.c. current paths needed for the proper functioning of the EUT as long as the requirements on differential mode and common mode impedances of CISPR 16-1-2 are complied with.

When using the delta network for measurements on signal terminals, the differential mode rejection must be as high as needed not to give erroneous results when measuring a common mode disturbance voltage at the same frequency as the operational differential mode signal.

When the EUT is to be measured on its power supply terminals using an AMN all voltage measurements shall be carried out with both networks connected simultaneously. The provisions prescribed in 7.4.1 and 7.4.2 shall be observed.

NOTE The frequency range of the delta-network can be extended to 9 kHz using the same network impedance if decoupling of the connected signal line and coupling to the measuring receiver are designed accordingly.

7.4.3.3 Measurements using the Y-type network

Alternatively an asymmetrical (common mode) artificial network (AAN), i.e., a Y-type network according to CISPR 16-1-2, can be used for the measurement of common mode disturbance voltages in the frequency range 9 kHz to 30 MHz.

NOTE Y-type networks are frequently (e.g., in CISPR 22) called impedance stabilization networks (ISN).

In contrast to the delta-network which provides a differential mode and a common mode termination with equal simulation impedances of 150 Ω , the Y-network provides only a common mode termination of 150 Ω and with the communication line terminated with its characteristic impedance and a differential to common mode rejection characteristic of the telecommunication network to which the EUT is intended to be connected.

At the supply side of the Y-type network a signal simulator, load circuits for d.c. or the operational signal frequency of the EUT or other circuits needed for the operation of the EUT can be connected. These circuits shall either themselves provide a differential mode RF resistance of 100 Ω to 150 Ω , as required for the particular EUT, or with a termination to provide this resistance. When no external circuit is specified for the operation of the EUT a resistor of 150 Ω shall be connected as differential mode RF termination to the Y-type network. If no suitable Y-network is available, the telecommunication port is terminated with auxiliary equipment.

When an EUT with telecommunication port is to be measured on its power supply terminals using an AMN, the disturbance voltage measurements shall be carried out with AMN connected to the power port and Y-network connected to the telecommunication port simultaneously or with the associated equipment directly connected to the EUT. Figure 6 shows the measurement arrangement with AMNs and Y-networks (ISNs). The provisions prescribed in 7.4.1 and 7.4.2 shall be observed.

7.4.4 Measurements using voltage probes


7.4.4.1 With an AMN

In order to test devices and systems with several connected or connectable lines, the disturbance voltage at the line connections, which cannot be measured with AMN (e.g. for connecting lines between parts of components which are separated from the mains) as well as the connecting jacks for antennas, control and load lines, must be measured with a voltage probe (see 7.3.3) with a high input impedance ($1\,500\,\Omega$ or more) to ensure that the lines are not loaded by the probe.

For these cases, however, the primary power input wires must be isolated and RF terminated with the AMN. For the remaining lines, also those not to be measured with the probe, the corresponding conditions of 7.4.1 and the operating conditions laid down for the individual devices in the respective product specifications (e.g. CISPR 11 and CISPR 14-1) must be observed in regard to arrangement and length. The voltage probe is connected to the measuring receiver via a coaxial cable, the screen of which is connected to the ground reference and the case of the voltage probe. No connection shall be made directly from this case to live parts of the EUT.

If the measuring receiver is connected to the voltage probe, the AMN shall be terminated with $50\,\Omega$.

Figures 17 and 18 (from CISPR 14-1) shows an example for a test set-up for measuring the interference voltage of a semi-conductor regulating control.



Switch positions:

- 1 For mains measurements
- 2 For load measurements
- 3 and 4 Successive connections during load measurements

NOTE 1 The ground of the measuring receiver is connected to the AMN.

NOTE 2 The length of the coaxial cable from the probe does not exceed 2 m.

NOTE 3 When the switch is in position 2, the output of the AMN at terminal 1 is terminated by an impedance equivalent to that of the CISPR measuring receiver.

NOTE 4 Where a two-terminal regulating control is inserted in one lead only of the supply, measurements are made by connecting the second supply lead as indicated in Figure 18.

Figure 17 – Measuring example for voltage probes




Figure 18 – Measurement arrangement for two-terminal regulating controls

7.4.4.2 Without an AMN

During testing of EUTs which are not to be measured with AMNs, the disturbance voltage is measured across a defined simulation resistance (e.g., artificial fence simulation in CISPR 14-1 or under open-circuit conditions with an exactly defined arrangement and line layout taking into consideration the specifications of 7.4.1). The disturbance voltage is measured with a high-impedance voltage probe.

This is valid also for e.g., power electronic devices which are fed from their own separate power supplies or battery devices to which separately installed lines are connected which are not to be loaded.

In the case of disturbance voltage measurements on separate individual power sources for currents of more than 25 A (e.g., battery, generator, converter), an impedance measurement must be applied to ascertain that the tolerance of the simulated resistance, in accordance with CISPR 16-1-2 is not exceeded.

The flexible ground connection for probes with an input impedance R_x of more than 1 500 Ω should not be longer than 1/10 of the wave-length at the maximum measurement frequency and shall be connected in the shortest possible way to the metal surface serving as reference ground. In order to avoid additional capacitive loading of the test point by the screening of the probe, the tip of the probe should not exceed a length of approximately 3 cm. The screened connections to the measuring receiver must be arranged in such a way that the capacitance of the test object is not altered with respect to the reference ground.

7.4.4.3 AMN as a voltage probe

Where the current rating of an EUT exceeds the rating of available AMNs, the AMN can be used as a voltage probe. The EUT port of the AMN is connected to each of the supply lines of the EUT (single or three phase).

Prior to connecting an AMN to the mains supply, it must be safely connected to the local physical earth PE.

WARNING: Before disconnecting the PE, the AMN should be disconnected from the mains supply. The mains port of the AMN is left open. When the AMN is connected as a voltage probe, the pins on the AMN power input connector/plug will be energized by the supply voltage. The pins on the plug must be made safe with an insulated protective cover or other means.

In the frequency range of 150 kHz to 30 MHz, the supply lines of the EUT shall be connected to the mains via an inductance of 30 μH to 50 μH (see Figure A.8, configuration 2). The inductance may be realized by a choke, a line of 50 m length or a transformer. In the frequency range of 9 kHz to 150 kHz a greater inductance will normally be required for decoupling from the mains. This guarantees also a reduction of noise from the mains network (see A.5).

Since measurements are preferable with AMNs in their standard configuration, the AMN as a voltage probe should only be used for *in situ* tests and where practical current limitations are exceeded. It shall not be used for testing according to a product standard unless it is referred to in the product standard as an alternative measuring method.

7.4.5 Measurement using a capacitive voltage probe (CVP)

Disturbance voltage measurements on unshielded signal and telecommunication cables with more than 4 symmetrical pairs can be made using a CVP. The measurement can be combined with a current probe measurement to measure disturbance voltage and current simultaneously. The disadvantage of this method is a lack of isolation between the EUT and the actual network or simulator.

The CVP body shall be bonded to the reference ground plane using a ground connection as short as possible.

7.4.6 Measurements using current probes

Disturbance current measurements may be useful for several reasons. The first is that in some devices it may not be possible to insert an AN. This is particularly true when tests are performed on installed systems, or where the EUT has very high currents. A second reason for the use of the current probe is that at the lower end of the frequency range the mains impedance becomes very low, so the disturbance source is a current generator. The measurement of this current can be made by means of a current transformer without interrupting or disconnecting the mains connection.

Current probes shall conform to the requirements of CISPR 16-1-2.

Current probes enable the direct measurement of the common mode components of the disturbance current by enclosing the cable containing all leads. Therefore, common mode disturbance currents can be easily separated from differential mode operating currents.

If measurements are performed with known load and source impedances, the disturbance voltage can be calculated.

If only one conductor is enclosed, the superposition of the differential and common mode disturbance current components is measured. If, in this case, any extremely high (above 200 A) operating current exists, there is a risk of false data because the magnetic core of the current probe may saturate.

7.5 System test configuration for conducted emissions measurements

7.5.1 General approach to system measurements

The general objective of defining a system test configuration for conducted emission measurements has the following key points:

- avoiding common mode disturbance ground loops;
- defining a configuration which is easily duplicated;
- decoupling of lines not being measured from the line being measured;
- placing of lines to achieve decoupling;
- arrangement of lines to minimize the influence of magnetic fields on emission measurements
- duplicating requirements in 7.1 to 7.4 for the system test to the maximum extent possible.

Whenever possible, the disturbance voltage on a system line shall be measured with an AN. For currents up to 50 A, AMNs can be used quite easily. The AN shall be installed within 80 cm of the system equipment being measured, where practical. Each wire of a multi-wire power mains circuit shall be routed through an AMN. Each AN shall be terminated with a 50 Ω resistor at the measurement terminal.

The EUT shall be arranged and connected with cables terminated in accordance with the manufacturer's instructions.

For some measurements, relevant product publications may state a specific load to be used together with load voltage probes, instead of an AMN. A voltage probe may also be used for conducted measurements when the mains current is above 50 A and an appropriate AMN is not available. However, in this latter case, test results with an AMN ~~will take precedence over the results with a voltage probe, however.~~ shall be preferred.

For some measurements, the use of current probes may be specified in the relevant product publication.

7.5.2 System configuration

The system shall be carefully configured, installed, arranged and operated in a manner that is most representative of the system as typically used (i.e., as specified in the instruction manual) or as specified herein. Equipment that typically operates within a system made up of multiple interconnected units should be tested as part of such a typical operational system.

Generally, the system that is tested shall be of the same type that is supplied to the end user. If the marketing information is not available or it is not practical to assemble extraordinary amounts of equipment to replicate a complete product installation, the test shall be performed using the best judgement of the test engineer in consultation with the design engineering staff. The results of any such discussion and decision process shall be documented in the test report.

The selection and placement of cables, a.c. line cords, host and peripherals depends on the type of EUT and must be representative of expected equipment installation. The separation between different units shall be 10 cm, unless this is not possible due to their construction. Then the units should be placed as closely together as possible (greater than 10 cm) and the setup shall be documented in the test report. Three types are distinguished. First, there are systems normally used entirely on one table-top (see e.g., Figure 6). A second type of system consists of equipment normally used in a floor-standing configuration. These include systems mounted over a specially designed raised floor which facilitates intra-system connection under the raised floor. Equipment making up the floor-standing system can be interconnected with cabling lying on the floor, under the floor in a raised floor installation, or overhead according to normal installation. Third, there are systems that are a combination of floor-standing and table-top systems. The remainder of this subclause provides instructions for the testing of each of these systems. In addition, the specific requirements in 7.1 to 7.4 shall be observed.

Equipment in a system, normally being floor-standing, shall be placed on a floor in accordance with 7.4.1. Equipment designed for both table-top and floor operation shall be tested only in the table-top configuration.

7.5.2.1 Operating conditions

The system shall be operated at the rated (nominal) operating voltage and typical load conditions – mechanical or electrical, or both – for which it is designed. Loads may be actual or simulated as described in the individual equipment requirements. For some systems, it may be necessary to develop a set of explicit requirements specifying the test conditions, operations, etc. to be used in testing a specific system.

If the system includes a visual display unit or monitor, the following operating conditions apply unless the product publication specifies otherwise:

- a) set the contrast control to maximum;
- b) set the brightness control to maximum or at raster extinction if raster extinction occurs at less than maximum brightness;
- c) for colour monitors, use white letters on a black background to represent all colours;
- d) select the worst case of positive or negative video if both are available;
- e) set character size and number of characters per line so that the maximum number of characters per screen is displayed;
- f) for a monitor that has no graphics capabilities, regardless of the video card used, a pattern consisting of random text shall be displayed;

- g) for a monitor with graphics capabilities, even though another video card may be needed to accomplish a graphic display, a pattern consisting of a line of scrolling Hs should be displayed;
- h) if a monitor has no text capabilities, use a typical display.

7.5.2.2 Interfacing equipments, simulators and cables

Compliance testing is performed with peripheral and cable placement which is judged realistic and likely to be found in the final installation. Figures 6, 9, 10 and 11 describe standardized test set-ups which will provide a basis for reproducibility among testing laboratories and is consistent with the requirement for a realistic system and cable orientation. ~~Any deviation from the standard test set-ups shall be documented together with its supporting rationale.~~ Therefore, measurements with an actual interfacing unit shall be preferred.

Since a system is required to interact functionally with other units, the actual interfacing units should be used. Simulators may be used to provide representative operating conditions, provided the effects of the simulator used in lieu of an actual interfacing unit properly represent the electrical, and in some cases the mechanical, characteristics of the interfacing units, especially concerning RF signals, impedances and shield terminations. Because of the added degree of uncertainty when a simulator is used, such use should be avoided if possible. In case of a dispute, measurements made with an actual interfacing unit shall take precedence. If a device is designed for use with only a specific host computer or peripheral, it should be tested with that computer or peripheral.

Interfacing cables should be typical of normal use as supplied with the normal system and at least 2 m long unless the manufacturer's user manual specifies shorter cables. The same type of cable (that is, non-shielded, braided shield, foil shield, etc.) specified in the user manual should be used throughout the tests. Excessive lengths of cable shall be folded into a serpentine-like bundle at the approximate centre of the cable with the bundles 40 cm or less in length so that the effective length between EUT and AE does not exceed 1 m, if possible.

If shielded or special cables are used during the tests to achieve compliance, then a statement must be included in the test report and in the instruction manual advising of the need to use those types of cables.

If magnetic fields are generated by components of the system (e.g., by VDUs), loops between ground connections and measurement lines may pick up these fields and measurement results may be erroneous due to voltages coupled into these loops. In order to avoid magnetic field pickup, connecting lines (ground and measurement lines) should be as short as possible and twisted.

Interface ports (connectors) shall have a cable connected to one of each type of functional interface port of the system, and each cable shall be terminated in a device typical of actual usage. Where there are multiple interface ports all of the same type, additional connecting cables shall be added to the system to determine the effect these cables have on emissions from the system. Measurements on power ports using V-networks shall be made with telecommunication ports simultaneously terminated with Y-networks (see 7.4.3.3).

Normally, the loading of similar ports is limited to the following:

- a) availability of multiple loads (for large systems);
- b) reasonableness of multiple loads representing a typical installation.

The rationale for the selection of the configuration and loading of ports shall be included in the test report; that is 25 % of possible cables were connected and the emissions did not increase by more than 2 dB when one or more cables were added. Additional ports on support units, interfacing units or simulators, other than those associated with the system or the minimum required system, need not be connected or used during testing.

7.5.2.3 Mains connection

If the system is an assembly of equipment each having its own power cords, the point of connection for the AMNs is determined from the following rules:

- a) each power cord which terminates in a mains supply plug of a standard design (IEC/TR 60083, for example) shall be tested separately;
- b) power cords or terminals which are not specified by the manufacturer to be connected via a host unit shall be tested separately;
- c) power cords or field wiring terminals which are specified by the manufacturer to be connected to a host unit or other power-supplying equipment shall be connected to that host unit or other power-supplying equipment, and the terminals or cords of that host unit or other power-supplying equipment are connected to the AMNs and tested;
- d) where a special mains connection is specified, the necessary connection hardware to the AMN shall be supplied by the manufacturer for the purpose of the test.

The ground safety conductor of units separately powered shall be isolated from the equipment under test by a 50 μ H AN in the frequency range 0,15 MHz to 30 MHz. The normal AMN mains input is connected to the reference ground in this use of the AMN as a filter.

7.5.3 Measurements of interconnecting lines

In addition to the measurement on the terminals for the mains connection, measurements may need to be performed with a voltage probe on other terminals for incoming and outgoing leads (for example control and load lines). If the function of the equipment under test is affected by the 1 500 Ω impedance of the probe, the impedance at 50/60 Hz and at radio frequencies may need to be increased (for example 15 k Ω in series with 500 pF). In place of a voltage measurement, a current measurement with a current probe may also be used, if required (or offered as an option) in the product specification.

During the measurement, the ANs on the mains lead remain in place to provide a defined mains isolation and a defined RF termination. The auxiliary apparatus (control, load) is connected to allow measurements to be made under all provided operating conditions and during interactions between components of the equipment. Measurements are made on the specified terminals of each equipment.

If the connecting lines between components of the equipment are permanently fixed on both ends and either shorter than 2 m or shielded, no measurements are necessary, provided that in the latter case the shielded cable is connected at both ends to the reference ground, that is metal housing of the equipment. Non-shielded connecting lines with plug(s) or socket(s) are considered to be extendable to a length of more than 2 m and therefore must be extended by at least 2 m and must be tested. Shielded cables must be at least 2 m long unless the user manual specifies shorter cables.

7.5.4 Decoupling of system components

One of the sources of inaccurate conducted measurements in a system is any ground circulating current. This ground current may be interrupted by installing a 50 μ H AN (PE choke) in the frequency range 0,15 MHz to 30 MHz in the ground safety conductor to the EUT.

An additional source of circulating currents can be the shields of interconnecting cables between units. Therefore, the ground safety conductor to these units shall also be isolated by a 50 μ H AN.

The measurement receiver should be referenced to ground only at the measurement point to prevent ground loops. (Caution: shock hazard may exist if the measuring set is not supplied with an isolation transformer.)

7.6 *In situ* measurements

7.6.1 General

Where allowed by the relevant product standard, *in situ* measurements may be made for the evaluation of compliance if technical reasons prohibit emission measurement on a standard test site. Such technical reasons may include excessive size and/or weight of the EUT or situations where the interconnection to the infrastructure for the EUT is too expensive for the measurement on standard test sites. *In situ* measurement results of an EUT type will likely deviate from site to site or from results obtained on a standard test site and should therefore not be used for type testing. The applicable product standard takes precedence.

The disturbance voltage shall be measured under the existing conduction conditions with non-reactive pick-up devices (high resistance voltage probes). The conduction conditions and measurement results are affected by:

- the existing reference ground ~~or the reference mass~~ used during measurement. Neither a conducting ground plane nor an AN shall be installed for user's installation testing unless one or both are to be a permanent part of the installation;
- the RF characteristics and loading conditions for the power mains conduction;
- the ambient RF environment;
- the input impedance of the pick-up device; and
- magnetic fields caused by the EUT or in the vicinity.

7.6.2 Reference ground

The existing ground at the place of installation should be used as reference ground. This should be selected by taking high-frequency (RF) criteria into consideration. Generally, this is accomplished by connecting the EUT via wide straps, with a length-to-width ratio not exceeding 3, to structural conductive parts of buildings that are connected to earth ~~ground~~. These include metallic water pipes, central heating pipes, lightning wires to earth ~~ground~~, concrete reinforcing steel and steel beams.

In general, the safety and neutral conductors of the power installation are not suitable as reference ground as these may carry extraneous disturbance voltages and can have undefined RF impedances.

If no suitable reference ground is available in the surroundings of the test object or at the place of measurement, sufficiently large conductive structures such as metal foils, metal sheets or wire meshes set up in the proximity can be used as reference ground for measurement.

The general requirements of 7.4.2.2 and of Annex A should be observed.

7.6.3 Measurement with voltage probes

Testing of conducted disturbance voltage is made with the voltage probe. Special precautions must be taken to establish a reference ground for the measurements.

Any voltage decrease caused by loading of the circuit to be measured can be determined qualitatively by varying the voltage probe input impedance. If the input impedance of the voltage probe is high compared to the internal impedance of the test point or of the tested network, then only slight differences in the measurement of the disturbance voltage occur when the probe input impedance is increased. The input impedance of the probe can be doubled by series connection of a 1 500 Ω resistor. If the disturbance voltage is then reduced by an amount between 5 dB and 6 dB, then the 1 500 Ω probe can be used to measure the disturbance voltage.

7.6.4 Selection of measuring points

7.6.4.1 General

Radio disturbance voltage measurements at the place of installation are carried out at the boundaries of the user's premises, of industrial areas, or at points to be specified within the influence area of receiving system.

7.6.4.2 Measurements on mains and other supply leads

In power supply networks it is sufficient to measure the unsymmetric disturbance voltage with the voltage probe at accessible power outlets near the power entrance to the building.

7.6.4.3 Measurements on unshielded and shielded cables

In the case of non-shielded and shielded signal, control and load leads with non-grounded shield leaving the boundaries, the unsymmetric disturbance voltage shall be measured with a high-impedance voltage probe on the individual wires or the shields with respect to the reference ground. Common mode disturbance voltage can be measured with a capacitive voltage probe.

In the case of shielded cables with grounded shield, the common mode disturbance current is measured at a distance greater than one-tenth wavelength from the connecting and grounding points using a current probe.

8 Automated measurement of emissions

8.1 Introduction: Precautions for automating measurements

Much of the tedium of making repeated EMI measurements can be removed by automation. Operator errors in reading and recording measurement values are minimized. By using a computer to collect data, however, new forms of error can be introduced that may have been detected by an operator. Automated testing can lead, in some situations, to greater measurement uncertainty in the collected data than manual measurements performed by a skilled operator. Fundamentally, there is no difference in the accuracy with which an emission value is measured whether manually or under software control. In both cases the measurement uncertainty is based on the accuracy specifications of the equipment used in the test set-up. Difficulties may arise, however, when the current measurement situation is different from the scenarios the software was configured for.

For example, an EUT emission adjacent in frequency to a high level ambient signal may not be measured accurately, if the ambient signal is present during the time of the automated test. A knowledgeable tester, however, is more likely to distinguish between the actual interference and the ambient signal; therefore the method for measuring the EUT emission can be adapted as required. However, valuable test time can be saved by performing ambient scans prior to the actual emission measurement with the EUT turned off to record ambient signals present on the OATS. In this case the software may be able to warn the operator of the potential presence of ambient signals at certain frequencies by applying appropriate signal identification algorithms.


Operator interaction is recommended if the EUT emission is slowly varying, if the EUT emission has a low on-off cycle or when transient ambient signals (e.g. arc welding transients) may occur.

8.2 Generic measurement procedure

Signals need to be intercepted by the EMI receiver before they can be maximized and measured. The use of the quasi-peak detector during the emission maximization process for all frequencies in the spectrum of interest leads to excessive test times (see 6.6.2). Time-

consuming processes like antenna height scans are not required for each emission frequency. They should be limited to frequencies at which the measured peak amplitude of the emission is above or near the emission limit. Therefore, only the emissions at critical frequencies whose amplitudes are close to or exceed the limit will be maximized and measured.

The following generic process will yield a reduction in measurement time:



8.3 Prescan measurements

This initial step in the overall measurement procedure serves multiple purposes. Prescan places the least number of restrictions and requirements upon the test system since its main purpose is to gather a minimal amount of information upon which the parameters of additional testing or scanning will be based. This measurement mode can be used to test a new product, where the familiarity with its emission spectrum is very low. In general, prescan is a data acquisition procedure used to determine where in the frequency range of interest, significant signals are located. Improved frequency accuracy and data reduction through amplitude comparison may be necessary. These factors define the measurement sequence during the execution of prescan. In any case, the results will be stored in a signal list for further processing.

When a prescan measurement is made to quickly obtain information on an EUT's unknown emission spectrum, frequency scanning can be performed by applying the considerations of 6.6.

Determination of the required measurement time:

If the emission spectrum and especially the maximum pulse repetition interval T_p of the EUT is not known, this has to be investigated to assure the measurement time T_m is not shorter than T_p . The intermittent character of the EUT's emission is especially relevant for critical peaks of the emission spectrum. First should be determined at which frequencies the amplitude of the emission is not steady. This can be done by comparing the max-hold with a min-hold or clear/write function of the measuring equipment or software, and observing the emission for a period of 15 s. During this period no change of lead should be made. Signals with e.g. more than 2 dB difference between the max-hold result and min-hold result are marked as intermittent signals. (Care should be taken not to mark noise as intermittent signals.) The measurement is repeated, to reduce the risk that certain intermittent peaks are not found because they remain below noise level. From each intermittent signal, the pulse repetition period T_p can be measured, by applying zero span or using an oscilloscope connected to the IF-output of the measurement receiver. The correct measurement time can also be determined by increasing it until the difference between max-hold and clear/write displays is below e.g. 2 dB. During further measurements (maximization and final measurement), it has to be assured for each part of the frequency range that the measuring time T_m is not smaller than the applicable pulse repetition period T_p .

For **conducted emission measurements**, the prescan is defined as either performed on a representative lead, for example lead “L” of the power line, or on each lead using peak detection and the fastest scan time possible. If multiple leads are measured, a “maximum hold” function should be used to retain the highest emissions found during the measurement.

8.4 Data reduction

The second step in the overall measurement procedure is used to reduce the number of signals collected during prescan and thus aimed at further reduction of the overall measurement time. These processes can accomplish different tasks, e.g. determination of significant signals in the spectrum, discrimination between ambient or auxiliary equipment signals and EUT emissions, comparison of signals to limit lines, or data reduction based on user-definable rules. Another example of data-reduction methods involving the sequential use of different detectors and amplitude versus limit comparisons is given by the decision tree in Annex C of this standard. Data reduction may be performed fully automated or interactively, involving software tools or manual operator interaction. It need not be a separate section of the automated test, i.e. it may be part of a prescan.

In certain frequency ranges, an acoustic ambient discrimination is very effective. This requires signals to be demodulated to be able to listen to their modulation content. If an output list of prescan contains a large number of signals and acoustic discrimination is needed, it can be a rather lengthy process. However, if the frequency ranges for tuning and listening can be specified, only signals within these ranges will be demodulated. The results of the data reduction process are stored in a separate signal list for further processing.

8.5 Emission maximization and final measurement

During the final test the emissions are maximized to determine their highest level. After the maximization of the signals, the emission amplitude is measured using quasi-peak detection and/or average detection, allowing for the appropriate measurement time (at least 15 s if the reading shows fluctuations close to the limit).

For **conducted emission measurements**, the maximization process is defined by comparison of the emission amplitudes on the different leads of the EUT power cord and retention of the maximum levels.

NOTE Using an FFT-based measuring instrument, the final measurement may be performed at several frequencies in parallel.

8.6 Post processing and reporting

The last part of the test procedure addresses documentation requirements. The functionality for defining sorting and comparison routines which then can be automatically or interactively applied to signal lists supports a user in compiling the necessary reports and documentation. The corrected peak, quasi-peak or average signal amplitudes should be available as sorting or selection criteria. The results of these processes are stored in separate output lists or can be combined in a single list and are available for documentation or further processing.

Results shall be available in tabular or graphics format, or a combination of both, for use in a test report. Furthermore, information about the test system itself, e.g. transducers used, measuring instrumentation, and documentation of the EUT set-up as required by the product standard should also be part of the test report.

8.7 Emission measurement strategies with FFT-based measuring instruments

Depending on the implementation FFT-based measuring instruments may perform weighted measurements significantly faster than the tuneable selective voltmeters. A weighted measurement over the frequency range of interest may then be faster than a measurement consisting of a prescan and final scan performed with a superheterodyne receiver as described in 8.2.

Annex A (informative)

Guidelines to connection of electrical equipment to the artificial mains network (see Clause 5)

A.1 Introduction

This annex is intended to give general guidance in the techniques which can be used to assess the disturbance generated by certain electrical equipment in the frequency range 9 kHz to 30 MHz. It provides information on methods of connection of such equipment to the artificial mains network for the measurement of terminal voltages. A table is provided giving a general presentation of various cases encountered in practice enabling, for such cases, a suitable technique to be selected.

The cases described below in A.2 identify propagation of the EUT disturbance either:


- a) by **conduction** along the connected mains leads (designated with E_1 and I_1 in the equivalent circuit diagrams), or
- b) by **radiation** and coupled to the connected mains lead (designated with E_2 and I_2 in the equivalent circuit diagrams).

Whether conducted or radiated disturbance dominates is partly dependent on the arrangement of the EUT with respect to the ground reference (including the type of connection to the reference ground) and of the type of connection from the EUT to the artificial mains network (shielded or non-shielded cable).

A.2 Classification of the possible cases

A.2.1 Well-shielded but poorly filtered EUT (Figures A.1 and A.2)

In this case, the conducted disturbance component represented by the current I_1 dominates. The disturbance current I_1 is fed from the EUT to the artificial mains network Z . Consequently, the voltage U_1 increases when capacitance C_1 between the EUT shield and the ground reference increases (see Figure A.1). The voltage U_1 is maximized ($U_1 = ZI_1 = E_1$) when the impedance of the current return path is minimized by short-circuiting C_1 either directly or by using shielded cables to supply the EUT (see Figure A.2). (Also, see the discussion in A.3.)



IEC 1621/08

Figure A.1




Figure A.2

A.2.2 Well-filtered but incompletely shielded EUT (Figures A.3 and A.4)

In this case, the disturbance current fed to the mains is reduced practically to zero, and the voltage across the artificial mains network may be dominated by undesirable radiation either from gaps in an incomplete shield or from a protruding conductor acting as an antenna. Such leakage can be represented schematically by an external capacitor C_2 connected between an internal disturbance source of e.m.f. E_2 and ground reference. This capacitance C_2 passes a current I_2 . Part of the current I_2 which flows through C_2 to the ground reference returns via C_1 and a part of I_2 returns via the artificial mains network. If the supply leads are unshielded (Figure A.3) and the impedance of C_1 is large compared with the artificial mains impedance Z ($ZC_1 \omega \ll 1$), then I'_2 is nearly equal to I_2 and the voltage U_2 is nearly equal to $I_2 Z$ ($U_2 = ZI_2$).

If C_1 is increased, Z is shunted and U_2 will decrease. At the limit, when C_1 is short-circuited by supplying the EUT through shielded cables (Figure A.4), so that no part of I_2 flows through Z , then U_2 will be zero.




Figure A.3




Figure A.4

A.2.3 Practical general case

A.2.3.1 General

Most usually in practices, neither the shielded nor the filtering are perfect; the two preceding effects then occur simultaneously and they are additive. In such conditions, the three following cases may be encountered.

A.2.3.2 Supply through shielded conductors (Figure A.5)

The current I_1 caused by leakage due to radiation flows in a circuit closed through ground and the external surfaces of the screening of the artificial mains network and of the supply conductors; it has no effect on Z .

The voltage U_1 , which may be measured across Z , is solely due to the current I_1 injected into the supply conductors and returning through the internal surfaces of the screening of the artificial mains network and these conductors. The voltage U_1 is then maximum:

$$U_1 = ZI_1 \approx E_1$$




Figure A.5

A.2.3.3 Supply through unshielded but filtered conductors (Figure A.6)

If a highly efficient low-pass filter is connected to the input of the EUT, with its screening directly connected to the screening of the EUT, the current I_1 fed by source E_1 to the mains conductors will be stopped by the filter.

As in the case represented in Figure A.6, the current I_2 due to the radiation returns through Z and the conductors (if $ZC_1 \omega \ll 1$); the voltage U_2 measured across Z is then produced solely by the radiation.




Figure A.6

A.2.3.4 Supply through ordinary conductors (Figure A.7)

Should the filter in Figure A.6 be removed, the current I_1 from source E_1 reappears on the conductors (Figure A.7). In comparison to Figure A.5 (with the maximum possible value of I_1 for the supply of a non-filtered EUT through shielded conductors) the value of I_1 in Figure A.7 (supply of a non-filtered EUT through ordinary i.e. unshielded conductors) is, if $ZC_1 \omega \ll 1$, reduced to a minimum value in the ratio of I_1 (EUT unshielded) / I_1 (EUT shielded) = $ZC_1 \omega$ referred to its minimum value (Figure A.2). The current I_2 is the same as in the previous cases, but as the conductors are not shielded, it passes also through Z and the mains conductors.

The voltage U across the artificial mains network results then from the superposition of currents I_1 and I_2 . When electromotive forces E_1 and E_2 are themselves produced by a common internal source, these currents are synchronous and the voltage U depends not only on their values but also on their phases. For certain frequencies, it may occur that currents I_1 and I_2 are in opposition and if they are also of approximately the same magnitude, the voltage U may become very small even if I_1 and I_2 are individually quite large. Moreover, if the frequency of the source varies, the phase opposition may not remain constant and voltage U may show rapid and considerable variations.




Figure A.7

A.3 Method of grounding

In the foregoing, the connection to ground of the EUT was assumed to be made through connection of shielding of the supply conductors to the ground reference.

This is the only correct solution in order to obtain a grounding allowing a clear distinction between the two kinds of currents I_1 and I_2 , as indicated above. It may be applied, without exception to all frequencies.

For frequencies below 1,6 MHz practically the same result may be achieved by grounding through a straight lead of small length (1 m maximum), running parallel to the mains lead and not more than 10 cm distant from it.

For frequencies above a few MHz, this simplified solution should only be used with care, especially at the higher frequencies. It is then strongly recommended that screened conductors be used in all cases. At the higher frequencies, it may be necessary to take into account the characteristic impedance of the conductor.

A.4 Conditions of grounding

A.4.1 General

A.4.1.1 General rules

It appears from the considerations discussed above that the behaviour of the measuring circuit for the voltage across the artificial mains network and, hence, the result of these measurements, is largely dependent on how the frame of the EUT being tested is connected to ground. It is therefore essential to specify these conditions closely.

Essentially, the principal effect of grounding is to separate the two currents I_1 and I_2 and possibly to cause opposing variations of their respective actions on the measuring apparatus (which measures voltage U across Z). In the limiting case of a direct connection from the body of the EUT to ground, which short-circuits C_1 , the values of current I_1 and thus of voltage $U_1 = ZI_1 \approx E_1$, are maximum; on the contrary, the current I_2 due to radiation passes entirely through this short circuit and the corresponding voltage U_2 is reduced to zero.

From these remarks, the following general rules are drawn.

Direct grounding should always be used when testing:

- a non-radiating EUT (e.g. a motor) as, in such a case, the measurement yields the maximum value of the disturbance voltage which may be met in practice;

- b) a poorly filtered radiating EUT when, without troubling to measure the radiation, it is wished to measure solely the disturbance voltage due to direct injection into the supply conductors:
- 1) either for assessing the efficiency of the filter (for instance, for the time base circuits of television receivers);
 - 2) or for assessing, in the laboratory, the actual disturbance produced by an apparatus whose radiation in normal operation will be suppressed by shielding (e.g. a transformer for the ignition system of fuel for boilers).

A.4.1.2 Direct grounding

Direct grounding should not be used when testing item b1) of A.4.1.1 either for a very well-filtered EUT which generates considerable radiation (for example, ozonizer, medical apparatus with damped oscillations, arc welders, etc.). In all these cases, the voltage across the artificial mains network becomes very small with direct grounding, while without such grounding the voltage may be quite large or unsteady. The measurement may then be meaningless and it may become necessary to make the grounding through a specified impedance in order to simulate the actual impedance of the safety ground (protective earth) conductor, e.g. by a protective ground choke which additionally provides some RF isolation from the "polluted" and therefore "poor" protective earth-ground (see lower part of Table A.2).

NOTE The impedance of such an "electrical long" conductor is in case of an EUT of safety protection class I normally equal to the mains simulation impedance specified as termination for the mains terminals of the EUT provided by the artificial mains network (constituted by the network of $50 \mu\text{H} + j1 \Omega$ which, due to thermal problems in case of high current loads, may be reduced to a network of $50 \mu\text{H}$).

A.4.1.3 No grounding

Without any grounding, the voltage across the artificial mains network results from the addition of both currents I_1 and I_2 . A measurement can only be obtained when one of these currents is reduced to zero, either with a very well-screened shielded but poorly filtered EUT (e.g. a motor) or with a very well-filtered but radiating EUT (e.g. a television receiver, an ozonizer, etc.).

NOTE If in case of an EUT of safety protection class I for the purpose of analysis of I_2 , for the reduction of I_1 the impedance according to the note under A.4.1.2 is not sufficient, a high impedance RF choke (1,6 mH) may be inserted into the ground conductor path.

The measurement usually yields only the value of the total disturbance, without allowing any discrimination, the results being only valid for the conditions used during the test. Such conditions should then be very well defined, namely the values of the capacitance to the ground plane of the various elements of the EUT (for instance, the capacitance of the transmission line from the aerial in the case of a television receiver). Moreover, a single measurement for one arbitrary frequency has no significance if, for this frequency, currents I_1 and I_2 are in opposition. As a matter of principle, then, it is necessary to make measurements at a number of frequencies.

A.4.2 Classification of typical testing conditions


Tables A.1 and A.2 summarize the various testing conditions and the types of EUTs for which they are suitable. The tables also give the meaning of the measurement, that is, the physical quantity which corresponds to the voltage U measured across the artificial mains network Z and also the precautions to be taken when making the measurement.

A.5 Connection of the AMN as a voltage probe


Conducted emission measurements of EUTs with high operational currents may cause difficulties. AMNs for the frequency range 9 kHz to 150 kHz (30 MHz) are available to approximately 25 A nominal current. AMNs for the frequency range 150 kHz to 30 MHz (50 μH parallel to 50Ω) are available to approximately 200 A.

EUTs with higher current rating may be tested using the AMN as a voltage probe. This alternative solution is also helpful for *in situ* measurement, if referred to in the applicable product standard.

Configuration 1: appropriate application as a V-network



Configuration 2: application as a voltage probe



NOTE Exposed pins are made safe.

Figure A.8 – AMN configurations

Table A.1




Method of connection	Types of apparatus			Quantity measured	Details of the measurement	
	Examples	Essential characteristics				
		Earthing	Radiation			Filtering
	Motors Electro-domestic appliances	Without	Weak	Moderate	Actual interference (reduced) solely due to injected current C_1	The interference depends on C_1
	Ozonizers		Strong	Very good	Actual interference solely due to radiation current I_2	It is necessary to state accurately the position of the appliance with regard to earth or to quote the value of C_1
	Medical apparatus			Moderate	Total overall interference resulting from the superposition of the two preceding effects (I_1 and I_2)	
	Arc-welding				These two effects (I_1 and I_2) may be in phase opposition at certain frequencies	Measurement should be repeated, the frequency being varied
	Television receivers (time-base)		With		Very good	Actual interference produced with an earth connection of usual length

Table A.2

Method of connection	Types of apparatus	Quantity measured	Examples	Details of the measurement
	Non-radiating appliances provided with an earth terminal	Maximum actual interference as C_1 is short-circuited	All motors provided with an earth terminal	
	Radiating appliances when it is desired to measure only the interference caused by current feed to mains	Check on the efficacy of the screening	Television receivers Medical apparatus Ozonizers Arc-welding	
		Actual interference caused by an appliance which, in normal use, must be carefully screened	Transformer for the ignition system of oil burners Part of a screened assembly separately tested	
	Poorly filtered appliances when it is desired to measure only the interference caused by radiation	Check on the efficacy of the screening	Television receivers. High-frequency industrial apparatus	The position of the appliance with regard to earth should be specified in order that $ZC_1\omega < 1$
		Actual interference caused by an appliance which, in normal use, must be provided with a good filter	Fluorescent lighting	

Annex B (informative)

Use of spectrum analyzers and scanning receivers (see Clause 6)

B.1 Introduction

When using spectrum analyzers and scanning measuring sets, the following characteristics should be taken into account.

B.2 Overload

Most spectrum analyzers have no RF preselection in the frequency range up to 2 000 MHz; that is, the input signal is directly fed to a broadband mixer. To avoid overload, to prevent damage and to operate a spectrum analyzer linearly, the signal amplitude at the mixer should typically be less than 150 mV peak. RF attenuation or additional RF preselection may be required to reduce the input signal to this level.

B.3 Linearity test

Linearity can be measured by measuring the level of the specific signal under investigation and repeating this measurement after an X dB attenuator has been inserted at the input of the measuring set or, if used, the preamplifier ($X \geq 6$ dB). The new reading of the measuring set display should differ by X dB not more than $\pm 0,5$ dB from the first reading when the measuring system is linear.

B.4 Selectivity

The spectrum analyzer and scanning measuring set must have the bandwidth specified in CISPR 16-1-1 to correctly measure broadband and impulsive signals and narrowband disturbance with several spectrum components within the standardized bandwidth.

B.5 Normal response to pulses

The response of a spectrum analyzer and scanning measuring set with quasi-peak detection can be verified with the calibration test pulses specified in CISPR 16-1-1. The large peak voltage of the calibration test pulses typically requires an insertion of RF attenuation of 40 dB or more to satisfy the linearity requirements. This decreases the sensitivity and makes the measurement of low repetition rate and isolated calibration test pulses impossible for bands B, C and D. If a preselecting filter is used ahead of the measuring set, then the RF attenuation can be decreased. The filter limits the spectrum width of the calibration test pulse as seen by the mixer.

B.6 Peak detection

The normal (peak) detection mode of spectrum analyzers provides a display indication which, in principal, is never less than the quasi-peak indication. It is convenient to measure emissions using peak-detection because it allows faster frequency scans than quasi-peak detection. Then those signals which are close to the emission limits need to be remeasured using quasi-peak detection to record quasi-peak amplitudes.

B.7 Frequency scan rate

The scan rate of a spectrum analyzer or a scanning measuring set should be adjusted for the CISPR frequency band and the detection mode used. The minimum sweep time/frequency or the fastest scan rate is listed in the following table:

Band	Peak-detection	Quasi-peak detection
A	100 ms/kHz	20 s/kHz
B	100 ms/MHz	200 s/MHz
C&D	1 ms/MHz	20 s/MHz

For a spectrum analyzer or scanning measuring set used in a fixed tuned non-scanning mode, the display sweep time may be adjusted independently of the detection mode and according to the needs for observing the behaviour of the emission. If the level of disturbance is not steady, the reading on the measuring set must be observed for at least 15 s to determine the maximum (see 6.5.1).

B.8 Signal interception

The spectrum of intermittent emissions may be captured with peak-detection and digital display storage if provided. Multiple, fast frequency scans reduce the time to intercept an emission compared to a single, slow frequency scan. The starting time of the scans should be varied to avoid any synchronism with the emission and thereby hiding it. The total observation time for a given frequency range must be longer than the time between the emissions. Depending upon the kind of disturbance being measured, the peak detection measurements can replace all or part of the measurements needed using quasi-peak detection. Re-tests using a quasi-peak detector should then be made at frequencies where emission maxima have been found.

B.9 Average detection

Average detection with a spectrum analyzer is obtained by reducing the video bandwidth until no further smoothing of the displayed signal is observed. The sweep time must be increased with reductions in video bandwidth to maintain amplitude calibration. For such measurements, the measuring set shall be used in the linear mode of the detector. After linear detection is made, the signal may be processed logarithmically for display, in which case the value is corrected even though it is the logarithm of the linearly detected signal.

A logarithmic amplitude display mode may be used, for example, to distinguish more easily between narrowband and broadband signals. The displayed value is the average of the logarithmically distorted IF signal envelope. It results in a larger attenuation of broadband signals than in the linear detection mode without affecting the display of narrowband signals. Video filtering in log-mode is, therefore, especially useful for estimating the narrowband component in a spectrum containing both.

B.10 Sensitivity

Sensitivity can be increased with low noise RF pre-amplification ahead of the spectrum analyzer. The input signal level to the amplifier should be adjustable with an attenuator to test the linearity of the overall system for the signal under examination.

The sensitivity to extremely broadband emissions which require large RF attenuation for system linearity is increased with RF pre-selecting filters ahead of the spectrum analyzer. The filters reduce the peak amplitude of the broadband emissions and less RF attenuation can be used. Such filters may also be necessary to reject or attenuate strong out-of-band signals and the intermodulation products they cause. If such filters are used they must be calibrated with broadband signals.


B.11 Amplitude accuracy

The amplitude accuracy of a spectrum analyzer or a scanning measuring set may be verified by using a signal generator, power meter and precision attenuator. The characteristics of these instruments, cable and mismatch losses have to be analyzed to estimate the errors in the verification test.

Annex C (informative)

Decision tree for use of detectors for conducted measurements (see 7.2.2)

The following decision tree and notes provide guidance on the pass/fail criteria and the use of detectors for conducted disturbance measurements when the product specification requires measurements with both the quasi-peak and average detectors. For efficiency in performing these measurements, path 1 in Figure C.1 showing the use of the peak detector is recommended.



IEC 1630/08

Figure C.1 – Decision tree for optimizing speed of conducted disturbance measurements with peak, quasi-peak and average detectors

NOTE For the EUT to pass, the measured conducted emission must comply with both the quasi-peak and average limits. The tests may be performed using either path 1 or path 2; however, to optimize the speed of conducted disturbance measurements path 1 is recommended. Path 2, starting with a quasi-peak measurement, is slower in situations where compliance with the quasi-peak limit could already be determined from a peak measurement.

- 1) Start measurement with peak detector for rapid measurement.
- 2) Compare peak emission level to average limit.
If emissions are above limit: go to step 3.
If emissions are below limit: EUT passes.
- 3) Compare peak emission level with quasi-peak limit.
If emissions are above limit: go to step 4.
If emissions are below limit: go to step 7.
- 4) Measurement with quasi-peak detector.
- 5) Compare quasi-peak emission level to the average limit.
If emissions are above limit: go to step 6.
If emissions are below limit: EUT passes.
- 6) Compare quasi-peak emission level to the quasi-peak limit.
If emissions are above limit: EUT fails.
If emissions are below limit: go to step 7.
- 7) Measurement with average detector.
- 8) Compare average emission level to the average limit.
If emissions are above limit: EUT fails.
If emissions are below limit: EUT passes.

When frequency scanning is used during the peak measurement, the scan rate of the spectrum analyzer or scanning receiver should be adjusted not to exceed the fastest scan rate listed in Annex B.

Annex D (informative)

Scan rates and measurement times for use with the average detector

D.1 General

This annex is intended to give guidance on the selection of scan rates and measurement times when measuring impulsive disturbance with the average detector.

The average detector serves the following purposes:

- a) to suppress impulsive noise and thus to enhance the measurement of CW components in disturbance signals to be measured;
- b) to suppress amplitude modulation (AM) in order to measure the carrier level of amplitude modulated signals;
- c) to show the weighted peak reading for intermittent, unsteady or drifting narrowband disturbances using a standardized meter time constant.

CISPR 16-1-1 defines the average measuring receiver for the frequency range 9 kHz to 1 GHz.

In order to select the proper video bandwidth and the corresponding scan rate or measurement time, the following considerations apply.

D.1.1 Suppression of impulsive disturbance

D.1.1.1 General

The pulse duration T_p of impulsive disturbance is often determined by the IF bandwidth B_{res} : $T_p = 1/B_{res}$. For the suppression of such noise, the suppression factor a is then determined by the video bandwidth B_{video} relative to the IF bandwidth: $a = 20 \log (B_{res}/B_{video})$. B_{video} is determined by the bandwidth of the lowpass filter following the envelope detector. For longer pulses, the suppression factor will be lower than a . The minimum scan time $T_{s \min}$ (and maximum scan rate $R_{s \max}$) is determined using:

$$T_{s \min} = (k \times \Delta f) / (B_{res} \times B_{video}) \quad (D.1)$$

$$R_{s \max} = \Delta f / T_{s \min} = (B_{res} \times B_{video}) / k \quad (D.2)$$

where Δf is the frequency span and k is a proportionality factor which depends on the speed of the measuring receiver/spectrum analyzer.

For the longer scan times, k is very close to 1. If a video bandwidth of 100 Hz is selected, the maximum scan rates and pulse suppression factors in Table D.1 will be obtained.

Table D.1 – Pulse suppression factors and scan rates for a 100 Hz video bandwidth

	Band A	Band B	Bands C and D
Frequency range	9 kHz to 150 kHz	150 kHz to 30 MHz	30 MHz to 1 000 MHz
IF bandwidth B_{res}	200 Hz	9 kHz	120 kHz
Video bandwidth B_{video}	100 Hz	100 Hz	100 Hz
Max. scan rate	17,4 kHz/s	0,9 MHz/s	12 MHz/s
Max. suppression factor	6 dB	39 dB	61,5 dB

This can be applied for product standards calling out quasi-peak and average limits in bands B (and C) if short pulses are expected in the disturbance signal. Compliance of the EUT with both limits has to be demonstrated. If the pulse repetition frequency is greater than 100 Hz and the quasi-peak limit is not exceeded by the impulsive disturbance, then the short pulses are sufficiently suppressed for average detection with a video bandwidth of 100 Hz.

D.1.2 Suppression of impulsive disturbance by digital averaging

Average detection may be done by digital averaging of the signal amplitude. An equivalent suppression effect can be achieved if the averaging time is equal to the inverse of the video filter bandwidth. In this case, the suppression factor $a = 20 \log (T_{av} \times B_{res})$, where T_{av} is the averaging (or measuring) time at a certain frequency. Consequently a measurement time of 10 ms will result in the same suppression factor as the video bandwidth of 100 Hz. Digital averaging has the advantage of zero delay time when switching from one frequency to another. On the other hand, for averaging of a certain pulse repetition frequency f_p , the result may vary depending on whether n or $n+1$ pulses are averaged. This effect is less than 1 dB, if $T_{av} \times f_p > 10$.

D.2 Suppression of amplitude modulation

In order to measure the carrier of a modulated signal, the modulation has to be suppressed by signal averaging over a sufficiently long time, or by using a video filter of sufficient attenuation at the lowest frequency. If f_m is the lowest modulation frequency and if we assume that the max. measurement error due to the 100 % modulation is limited to 1 dB, then the measurement time T_m should be $T_m = 10 / f_m$.

D.3 Measurement of slowly intermittent, unsteady or drifting narrowband disturbances

In CISPR 16-1-1, the response to intermittent, unsteady or drifting narrowband disturbances is defined using the peak reading with meter time constants of 160 ms (for bands A and B) and 100 ms (for bands C and D). These time constants correspond to second order video filter bandwidths of 0,64 Hz or 1 Hz respectively. For correct measurements, these bandwidths would require very long measurement times (see Table D.2).

Table D.2 – Meter time constants and the corresponding video bandwidths and maximum scan rates

	Band A	Band B	Bands C and D
Frequency range	9 kHz to 150 kHz	150 kHz to 30 MHz	30 MHz to 1 000 MHz
IF bandwidth B_{res}	200 Hz	9 kHz	120 kHz
Meter time constant	160 ms	160 ms	100 ms
Video bandwidth B_{video}	0,64 Hz	0,64 Hz	1 Hz
Maximum scan rate	8,9 s/kHz	172 s/MHz	8,3 s/MHz

This applies however only for pulse repetition frequencies of 5 Hz or less. For all higher pulse widths and modulation frequencies, higher video filter bandwidths may be used (see D.1.2). Figures D.1 and D.2 show the weighting function of a pulse with 10 ms pulse duration versus pulse repetition frequency f_p with peak reading (“CISPR AV”) and with true averaging (“AV”) for meter time constants of 160 ms (Figure D.1) and 100 ms (Figure D.2).




Figure D.1 – Weighting function of a 10 ms pulse for peak (“PK”) and average detections with (“CISPR AV”) and without (“AV”) peak reading; meter time constant 160 ms




Figure D.2 – Weighting functions of a 10 ms pulse for peak (“PK”) and average detections with (“CISPR AV”) and without (“AV”) peak reading; meter time constant 100 ms

Figures D.1 and D.2 imply that the difference between average with peak reading (“CISPR AV”) and without peak reading (“AV”) is increasing as the pulse repetition frequency f_p decreases. Figures D.3 and D.4 show the difference for $f_p = 1$ Hz as a function of pulse width.




Figure D.3 – Example of weighting functions (of a 1 Hz pulse) for peak (“PK”) and average detections as a function of pulse width: meter time constant 160 ms




Figure D.4 – Example of weighting functions (of a 1 Hz pulse) for peak (“PK”) and average detections as a function of pulse width: meter time constant 100 ms

D.4 Recommended procedure for automated or semi-automated measurements

When measuring EUTs which do not emit slowly intermittent, unsteady or drifting narrowband disturbances, it is recommended to measure with the average detector using a video filter bandwidth of e.g. 100 Hz, i.e. a short averaging time during a prescan procedure. At frequencies where the emission is found to be close to the average limit, it is recommended to make a final measurement using a lower video filter bandwidth, i.e. a longer averaging time. (For the prescan/final measurement procedure, see also Clause 8 of this standard).

For slowly intermittent, unsteady or drifting narrowband disturbances, manual measurements are the preferred solution.

Annex E (informative)

Guidelines for the improvement of the test setup with ANs

E.1 In-situ verification of the AN impedance and voltage division factor

In order to minimize resonances in the AN grounding, it is recommended to verify the AN impedance (if a vector network analyzer is available) and/or the voltage division factor (VDF) in situ. This can be done by measuring these parameters with reference to the reference ground plane (RGP) instead of measuring relative to the ground connection of the AN itself. A description of the VDF measurement can be found in CISPR 16-1-2.

If the AN is bonded to the reference ground plane using a ground strap of significant inductance which appears in parallel to the AN enclosure capacitance relative to the ground plane, a parallel resonance may result within the frequency range below 30 MHz (see Figure E.1)




Figure E.1 – Parallel resonance of enclosure capacitance and ground strap inductance

Using in-situ measurements of the impedance and the VDF, solutions can be found as shown in Figure E.2, where an AMN was used as an example of an AN. The AMN impedance is shown in Figure E.3 and the VDF shown in Figure E.4. In this example, the AMN was connected to a vertical wall-mounted RGP to give a distance of 40 cm between the centre of the power plug and the RGP as required especially by Figure 8, but generally also in other test configurations. The impedance measurements into the AMN were made:

- with reference to the front panel measurement ground (see Figure E.2)
- with reference to a measurement ground on the grounding sheet (Figure E.2), and
- with reference to the vertical RGP (see Figure E.5). In this case it is important to use a low-impedance measurement ground.





Figure E.2 – Connection of an AMN to RGP using a wide grounding sheet for low inductance grounding

Figure E.3 – Impedance measured with the arrangement of Figure E.2 both with reference to the front panel ground and to the grounding sheet






Figure E.4 – VDF in the configuration of Figure E.2 measured with reference to the front panel ground and to the grounding sheet. (The AMN used has a flat frequency response of the VDF, which may be different for other AMNs)

The impedance does not differ between cases a and b. Only for case c does the phase show a significant increase at 30 MHz, where the effect on the VDF is in the order of 0,7 dB. The measurement results are shown in Figure E.6.



IEC 1635/08

CH1 511



START 9 kHz

Date: 23. APR. 04 13:58:28

STOP 30 MHz

IEC 1636/08

Figure E.5 – Arrangement showing the measurement grounding sheet (shown with dotted lines) when measuring the impedance with reference to RGP. The impedance measurement cable ground is connected to the measurement grounding sheet, whereas the inner conductor is connected to the EUT port pin.

Figure E.6 – Impedance measured with the arrangement of Figure E.5 with reference to the RGP.

The phase increase at 30 MHz is due both to the length of the connecting plate and the length of the measurement ground plate. The ideal impedance ends at 50 Ω (i.e., in the centre of the Smith diagram). Both the impedance and VDF do not show resonances.

In Figure E.7, VDF is shown for a ground connection with resonances as in Figure E.1.





Figure E.7 – VDF measured with parallel resonances in the AMN grounding

E.2 PE chokes and sheath current absorbers for the suppression of ground loops

To suppress effects resulting from ground loops, it is recommended that coaxial cables be inductively wound around ferrite rings in order to provide a sheath current absorber.


Figure E.8 shows the attenuation of a sheath current absorber with the following characteristics:

Material: N30; $AI = 5\,400\text{ nH}$
 Size: Toroidal core 58 mm by 40 mm by 17 mm
 Number of turns: 20 (cable terminated with BNC connectors)



Attenuation caused by the sheath current absorber made with a toroidal core with 20 turns of cable measured with the test setup given in Figure E.9 (150- Ω system). An attenuation of 20 dB means that the impedance of the sheath current suppressor is on the order of 1 500 Ω .

Figure E.8 – Attenuation of a sheath current absorber measured in a 150- Ω test arrangement



IEC 1639/08

Figure E.9 – Arrangement for the measurement of attenuation due to PE chokes and sheath current absorbers

The measurements can be taken in the test setup of Figure E.9. The EUT is a wire wound around a core as described above, or similar. It may also consist of two such high impedance circuits for the sheath current with a connection to ground in between for high insertion loss. The transmitter and receiver can be replaced by a network analyzer. The resistors in the transmit box and the load box may be replaced by other values for a system with higher or lower impedance. As a reference for the attenuation, the EUT is replaced by a simple wire (as shown above). The measurement arrangement can be replaced by the arrangement used with the SOLT calibration used for the verification of common-mode absorption devices (CMAD, see CISPR 16-1-4 and 4.9 of CISPR 16-3:2003, Amendment 2:2006).

Annex F (normative)

Determination of suitability of spectrum analyzers for compliance tests

The user of a spectrum analyzer shall be able to demonstrate – either through specifications from the manufacturer or by measurement - that the analyzer meets the quasi-peak detection requirements for pulse-repetition frequencies greater than 20 Hz in the frequency range of use. For the average detector the response to pulses is called out in 6.5 of CISPR 16-1-1.

Since the measurement of the pulse repetition frequency of an emission may not always be possible, a simple method to verify the validity of the quasi-peak measurement shall be applied when a spectrum analyzer is used. This method is based on a comparison of measurement results with the peak and quasi-peak detectors. From the quasi-peak weighting functions, the amplitude differences shown in Table F.1 are the results of measurements for a signal with a pulse repetition frequency of 20 Hz.

**Table F.1 – Maximum amplitude difference between peak and quasi-peak
detected signals**

Band A	Band B	Band C/D
7 dB	13 dB	21 dB

The comparison measurement is to be made at signal frequencies that show amplitudes close to the applicable limit in quasi-peak detection. If the difference between the peak and quasi-peak detected amplitude is smaller than the value in Table F.1 the quasi-peak measurement is valid and the result obtained with a spectrum analyzer can be used to demonstrate compliance. If the amplitude difference is larger than the stated values in Table F.1 a measuring receiver that fully complies with the low-prf requirements of CISPR 16-1-1 Clause 4 shall be used for the quasi-peak measurement instead of a spectrum analyzer. This comparison measurement requires an adequate signal-to-noise ratio to ensure proper results.

Annex G (informative)

Guidance for measurements on telecommunications ports

G.1 Limits

The disturbance voltage (or current) limit is defined for a TCM load impedance of $150\ \Omega$ (as seen by the EUT at the AE port during the measurement). This standardisation is necessary in order to obtain reproducible measurement results, independent of the indeterminate TCM impedance at the AE and the EUT.

NOTE 1 The common mode disturbances created from the wanted signal can be controlled at the design stage of the interface technology by giving proper consideration to the factors explained in CISPR/TR 16-3.

In general, the TCM impedance seen by the EUT at the AE port is not defined unless an AAN/CDN is used. If the AE is located outside the shielded room, the TCM impedance seen by the EUT at the AE port can be determined by the TCM impedance of the feed-through filter between the measurement set-up and the outside world. A Π -type filter has a low TCM impedance, whilst a T-type filter has a high TCM impedance.

NOTE 2 CDNs are described in IEC 61000-4-6.

AAN/CDNs do not exist for all types of cables used by EUTs. Therefore it is also necessary to define alternative test methods that do not use AAN/CDNs (i.e. “non-invasive” test methods).

Only the cable attached to the EUT port under test is shown in the figures of Annex H. Normally, there are several other cables (or ports) present at the EUT. At least the connection to the mains terminal is represented in most cases. The TCM impedance of these other connections (including a possible ground connection), and the presence or absence of these connections during the test, can influence the measurement result significantly, in particular for small EUTs. Therefore, the TCM impedance of the non-measured connections should be specified for the test of small EUTs. In addition to the port under test, it is sufficient to have at least two additional ports connected to a TCM impedance of $150\ \Omega$ (normally by using an AAN or CDN, with the RF measurement port terminated with $50\ \Omega$ load) to reduce this influence effect to a negligible amount.

Coupling devices for unshielded balanced pairs should also simulate the typical LCL (longitudinal conversion loss) of the lowest cabling category (worst LCL) specified for the telecom port under test. The intent of this requirement is to account for the transformation of the symmetrical signal into a CM (common mode) signal, which might contribute to the radiation when the EUT is in the end-use application. Asymmetry is built-in to an AAN to yield the specified LCL; this asymmetry may enhance or cancel the asymmetry of the EUT. To establish the worst case emissions and optimize test repeatability, consideration should therefore be given to repeating the testing with the LCL imbalance on each wire of a balanced pair when using the appropriate AAN.

Because imbalance on each balanced pair may contribute to the total common mode conducted emission, all combinations of imbalance on all balanced pairs should be considered. For a single balanced pair, this is a relatively minor impact on test effort – i.e. the two wires are reversed. However, for two balanced pairs, the number of LCL loading combinations is four (i.e. test configurations). For four balanced pairs, the number of loading combinations grows to sixteen. Such numbers will have a significant impact on test time and test documentation. Such testing should be undertaken with care, and properly documented if implemented.

The RF measurement port of an AAN/CDN not connected to the measuring receiver shall be terminated in a 50 Ω load.

Table G.1 summarizes the advantages and disadvantages of the methods described in Annex H.

Table G.1 – Summary of advantages and disadvantages of the methods described in the specific subclauses of Annex H

	Subclause H.5.2 (AAN)	Subclause H.5.3 (150 Ω load and cable shield)	Subclause H.5.4 (current probe and CVP)
Advantages	Smallest measurement uncertainty (Possible only if AAN/CDNs with appropriate transmission properties are available) LCL shall be known and shall be taken into account	- Non-invasive (except for the removal of the insulation of the shielded cable) - Always applicable for shielded cables - Small measurement uncertainty for higher frequencies	Non-invasive
Disadvantages	- Not applicable in all cases (needs appropriate AAN/CDNs) - Invasive (needs appropriate cable connections) - Needs an individual AAN/CDN for each cable type (results in a high number of different AAN/CDNs) - No isolation to symmetric signals from the AE is provided by an AAN	- Increased measurement uncertainty for very low frequencies (< 1 MHz) - Destruction of the cable insulation is necessary - Reduced isolation against disturbances from the AE side (compared to H.5.2) - Does not assess the interference potential that arises from the conversion of the symmetric signal into a common mode signal due to the limited LCL of the cable network to which the EUT port will be connected	- No isolation against disturbances from the AE side (compared to H.5.2) - Does not assess the interference potential that arises from the conversion of the symmetric signal into a common mode signal due to the limited LCL of the cable network to which the EUT port will be connected

G.2 Combination of current probe and capacitive voltage probe (CVP)

The method described in H.5.4 has the advantage of being applicable in a non-invasive way to all types of cables. However, unless the TCM impedance seen by the EUT at the AE connection is 150 Ω , the method of H.5.4 in general will show a result which is too high, but never too low (i.e. worst case estimation of the emission).

G.3 Basic ideas of the capacitive voltage probe

The set-up of Figure H.3 uses a capacitive voltage probe to measure the CM voltage. There are two approaches to the construction of a capacitive voltage probe. For either approach, if a TCM impedance of 150 Ω is present, the capacitance of the capacitive voltage probe to the cable attached to the EUT port under test will appear as a load in parallel with the 150 Ω TCM impedance.

NOTE 1 A CVP does not simulate the differential to common mode conversion that takes place in telecommunication networks (but which an AAN does), and therefore a CVP cannot be used to measure the converted common mode voltage. For the same reason, a combination of a CVP and a current probe cannot replace the AAN.

The TCM impedance tolerance is $\pm 20 \Omega$ over the frequency range of 0,15 MHz to 30 MHz. If the capacitive voltage probe loading acts to reduce the 150Ω TCM impedance at most down to 130Ω , the capacitance of the capacitive voltage probe to the cable attached to the EUT port under test should be $< 5 \text{ pF}$ at 30 MHz (the worst case frequency). At 30 MHz, 5 pF is an impedance of approximately $-j1\,061 \Omega$, which in parallel with 150Ω yields a combined TCM of approximately 148Ω . Refer to Figure G.2 of CISPR 16-1-2:2003, Amendment 1 (2004) for further background information.

The first approach to construction of a capacitive voltage probe is to have the probe be a single device that relies on physical distance from the cable attached to the EUT port under test to achieve the $< 5 \text{ pF}$ loading. This style of capacitive voltage probe is described in 5.2.2 of CISPR 16-1-2:2003, Amendment 1 (2004).

The second approach to construction of a CVP uses a capacitive coupling device in close proximity to the cable attached to the EUT port under test (the device is actually in physical contact with the insulation of the cable attached to the EUT port under test). A standard oscilloscope-type voltage probe having an impedance $> 10 \text{ M}\Omega$, with a probe capacitance $< 5 \text{ pF}$, is placed in series with the capacitive coupling device. The theory is that the probe capacitance in series with the capacitance of the capacitive coupling device will present only the probe capacitance to the cable attached to the EUT port under test. In practice, given the physical size of the capacitive coupling device, it is possible to have a large stray capacitance in parallel with the probe capacitance. If this occurs, the total capacitive loading will be greater than that of the probe itself, and the requirement to have loading $< 5 \text{ pF}$ may be violated. If this technique is employed, the capacitive loading should be verified by measurement, i.e. not rely only on theory.

This capacitance measurement can be made with any capacitance meter that can operate over the 150 kHz to 30 MHz frequency range. The capacitance is measured between the cable attached to the EUT port under test (all wires in the cable are connected together at the connection point to the meter) and the reference ground plane. The same type of cable used in the conducted disturbance measurement should be used for this capacitance measurement.

NOTE 2 The uncertainty of this method is lowest if the length of cable between the EUT and AE is less than 1,25 m. Significantly longer cables are subject to standing waves, which can adversely affect voltage and current measurements.

G.4 Combination of current limit and voltage limit

If the TCM impedance is not 150Ω , the measurement of the voltage or the current alone is not acceptable, because of a very high measurement uncertainty due to the undefined and unknown TCM impedances. However, if both voltage and current are measured with limits on current and voltage applied simultaneously, the result is a worst case estimation of the disturbance, as explained below.

The basic circuit for which the limits are defined is shown in Figure G.1. This circuit is the reference for which the limits expressed in terms of current and voltage are derived; any other measurement should be compared to this basic circuit. In Figure G.1, Z_1 is an unknown parameter of the EUT; Z_2 is 150Ω in the reference measurement.




Figure G.1 – Basic circuit for considering the limits with a defined TCM impedance of 150 Ω

If the measurement is performed without specifying the TCM impedance seen by the EUT, the simplified circuit is as shown in Figure G.2, where the TCM impedance Z_2 seen by the EUT is defined by the AE, and can have any value. Therefore, Z_1 as well as Z_2 are unknown parameters of the measurement.




Figure G.2 – Basic circuit for the measurement with unknown TCM impedance

If the measurement is performed using the circuit of Figure G.1, the current limit and the voltage limit are equivalent. The relation between current and voltage will always be 150 Ω, and either can be used to determine compliance. However, this is not the case if Z_2 is not 150 Ω (i.e. see Figure G.2).

It is important to note that compliance with the limit is not solely determined by the source voltage U_0 . The interference voltage measured should use a standardized Z_2 of 150 Ω, and depends on Z_1 , Z_2 and U_0 together. For example, with the set-up from Figure G.1, the voltage limit value can be reached with an EUT containing a high impedance Z_1 and a high source voltage U_0 , or with a lower U_0 combined with a lower impedance Z_1 .

In the more general case of Figure G.2, where Z_2 is not defined, it is not possible to measure the exact value of the interference voltage. Because Z_1 and U_0 are not known, it is not possible to derive the interference voltage, even if the value of Z_2 is known (or is measured or calculated from I and U). For example, if an EUT with disturbance above the limit is evaluated only by measuring the voltage in a test set-up with low Z_2 ($Z_2 < 150 \Omega$) at the AE side, the EUT might still seem to comply with the limits. In contrast, if the same EUT is measured only by measuring the current in a test set-up with high Z_2 (for example by adding ferrites), the EUT might again seem to comply with the limits.

However, it can be shown that if the current limit and the voltage limit are applied simultaneously, an EUT with disturbance results exceeding the limits will always be identified by exceeding either the current limit (if Z_2 is $< 150 \Omega$) or the voltage limit (if Z_2 is $> 150 \Omega$).


If the TCM impedance of the AE (Z_2) differs significantly from 150Ω , it is possible that an EUT which would comply with the limits if measured with $Z_2 = 150 \Omega$ may be deemed non-compliant. However, it will never happen that an EUT not complying with the limits is deemed to be compliant. A measurement according to H.5.4 is therefore a worst case estimation of the disturbance. If an EUT exceeds the limit with the H.5.4 method, it is possible the EUT would comply with the limits if it could be measured with $Z_2 = 150 \Omega$.

G.5 Adjusting the TCM impedance with ferrites

In some cases (i.e. if the TCM impedance at the AE side is originally lower than 150Ω), it is possible to adjust the impedance by adding ferrites on the cable attached to the EUT port under test. Subclause H.5.5 requires measurement of the TCM impedance, and adjustment of the ferrites at each frequency to be measured, until the TCM impedance is $150 \Omega \pm 20 \Omega$. Therefore, the method is relatively complicated and time-consuming if applied for the full frequency spectrum. If the TCM impedance at the AE side is originally higher than 150Ω , there is no way to adjust the impedance to 150Ω by adding ferrites or shifting the position of the ferrites for frequencies below 30 MHz (other methods to adjust the TCM impedance for specific frequencies could be used instead).

G.6 Ferrite specifications for use with methods of Annex H

Subclause H.5.3 defines a test set-up for measuring the common mode conducted disturbance on the shield of a coaxial cable. A load impedance of 150Ω is connected between the coaxial shield and the reference ground plane, as shown in Figure H.2. Ferrites are shown placed over the coaxial shield between the 150Ω load and the AE. The following paragraphs present methods for verifying that the ferrites are satisfying the requirements of H.5.3.



Key

V_{eutcm}	common mode voltage generated by the EUT
Z_{eutcm}	common mode source impedance of the EUT
V_{aecm}	common mode voltage generated by the AE
Z_{aecm}	common mode source impedance of the AE
$Z_{ferrite}$	impedance of the ferrites
Z	combined impedance of the 150 Ω load, $Z_{ferrite}$, and Z_{aecm}

Figure G.3 – Impedance layout of the components used in Figure H.2

Figure G.3 shows all of the basic impedances involved in Figure H.2. The ferrites are specified in H.5.3 to provide high impedance such that the common mode impedance towards the right of the 150 Ω resistor shall be sufficiently large so as to not affect the measurement (Z in Figure G.3).

The previous paragraph infers that the combined series impedance of $Z_{ferrite}$ and Z_{aecm} should not load down the 150 Ω resistor. The general approach in the CISPR 16 series is for tolerance of $\pm 20 \Omega$ on 150 Ω common mode loads over the frequency range of 0,15 MHz to 30 MHz. Combining these two concepts, the combined series impedance of $Z_{ferrite}$ and Z_{aecm} in parallel with the 150 Ω resistor (Z in Figure G.3) should be no lower than 130 Ω. This in turn implies that this relationship should hold regardless of the value of Z_{aecm} .

In order to establish the impedance characteristics of the ferrites, only two cases need to be considered, i.e. Z_{aecm} = open circuit, and Z_{aecm} = short circuit. If the ferrites can be selected to satisfy these requirements, any value of Z_{aecm} will be acceptable.

- Case 1: Z_{aecm} = open circuit

The combined series impedance of $Z_{ferrite}$ and Z_{aecm} is also an open circuit. An open circuit in parallel with the 150 Ω load yields 150 Ω. $Z_{ferrite}$ can be of any value.

- Case 2: Z_{aecm} = short circuit


The combined series impedance of $Z_{ferrite}$ and Z_{aecm} is equal to $Z_{ferrite}$. The value of $Z_{ferrite}$ in parallel with the 150 Ω resistor shall then be no lower than 130 Ω. In equation form:

$$\frac{150Z_{\text{ferrite}}}{150 + Z_{\text{ferrite}}} \geq 130 \, \Omega$$

Solving for Z_{ferrite} yields a value of $975 \, \Omega$. This implies that the ferrites selected for this application shall have a minimum impedance of $975 \, \Omega$ over the frequency range of 0,15 MHz to 30 MHz. For a given set of ferrites, the minimum impedance ($j\omega L$) will occur at the minimum frequency of 0,15 MHz.

Combining the two conditions described above, it is seen that the second condition at 0,15 MHz sets the minimum requirements for the impedance of the ferrites. Any value of impedance for the ferrites above this value would be acceptable.

In order to establish that the selected ferrites will accomplish the intended function, use of the test set-up shown in Figure G.4 is suggested. A traditional impedance meter/analyzer can be used to measure the impedance between point Z (I and V in Figure G.4) and the reference ground. Another approach is to measure the individual voltage and current at point Z then calculate the impedance. At a minimum, the impedance measurement should be made at 0,15 MHz. However, it is advisable to measure the impedance across the entire 0,15 MHz to 30 MHz range, to ensure that any stray capacitance associated with the ferrites and the coaxial cable does not degrade the ferrite impedance. This effect is of concern because laboratory data have shown that it is unlikely that the desired impedance can be achieved with only a single pass of the coaxial cable through the ferrites – i.e. multiple passes through the ferrites are necessary. This arrangement increases the chances of stray capacitance adversely affecting the impedance of the ferrites. It has been demonstrated that in the laboratory the desired impedance versus frequency can be achieved.



IEC 506/13

Figure G.4 – Basic test set-up to measure combined impedance of the 150 Ω and ferrites

Annex H (normative)

Specifics for conducted disturbance on telecommunication ports

H.1 General

The purpose of this annex is to define methods of measurement of the unwanted common mode emission at the telecommunication ports of an EUT. Various measurement procedures can be used, as summarized in Table H.1.

Where there are multiple similar ports on an EUT, it shall be shown by pre-scanning or some other technique that the ports are similar in their emissions performance, and that the conducted disturbance on the selected port is representative of the other similar ports.

Table H.1 – Telecommunication port disturbance measurement procedure selection

	Cable type	Number of pairs	Example AANs	Measurement type	Procedures
1	Balanced, unscreened	1 (2 wires) 2 (4 wires) 3 (6 wires) 4 (8 wires)	Figure I.1 Figure I.2 Figure I.3 Figure I.3	Voltage	H.5.2
2	Balanced, unscreened	1 (2 wires) 2 (4 wires) 3 (6 wires) 4 (8 wires) > 4 (>8 wires)	Not applicable	Voltage and current	H.5.4 Adjustment of the matching network (CMAD) may be required to achieve the specified impedance.
3	Screened or coaxial	Not applicable	Figure I.10 Figure I.8	Voltage	H.5.2
4	Screened or coaxial	Not applicable	Not applicable	Current or voltage	H.5.3
5	Unbalanced cables	Not applicable	Not applicable	Voltage and current	H.5.4 Adjustment of the matching network (CMAD) may be required to achieve the specified impedance.
6	Unbalanced mains	Not applicable	Relevant AMN	Voltage	The AMN shall be used as a voltage probe.

Further details:

- Where used, an AAN shall satisfy all the requirements defined in H.2.
- Where used, the current probe shall satisfy the requirements defined in H.3 and the voltage probe shall satisfy the requirements defined in H.4.
- When measuring the mains terminal emission voltages, the mains voltage shall be supplied to the EUT via the AMN used.
- The procedure described in H.5.2 gives results with the lowest measurement uncertainty.
- Each EUT unscreened symmetrical telecommunication port shall be tested with the example AAN applicable to the total number of balanced pairs in that EUT port (for example, a four-pairs EUT port shall use the example AAN shown in Figures I.3, I.6 or I.7), provided that at least one pair is used for balanced telecommunication and is independent of how the other pairs in the cable are used.
- The AANs shown in Figures I.2 and I.3 can be used for any number of pairs up to the maximum; remaining AANs from Annex I are appropriate only for use with the stated number of pairs in the cable.

H.2 Characteristics of AANs

Measurement of common mode (asymmetric mode) current or voltage emissions at wired network ports for attachment of unscreened balanced pairs shall be performed with the wired network port connected by a cable to an AAN; thus, the AAN shall define the common mode termination impedance seen by the wired network port during the disturbance measurements.

The AAN (as calibrated including all appropriate adapters required to connect to the EUT and AE) shall have the following properties:

- d) The common mode termination impedance in the frequency range 0,15 MHz to 30 MHz shall be $150 \Omega \pm 20 \Omega$, phase angle $0^\circ \pm 20^\circ$.
- e) The AAN shall provide sufficient isolation against emissions from an AE or load connected to the wired network port being measured. The attenuation of the AAN, for common mode emissions originating from the AE, shall be such that the measured level of these emissions at the measuring receiver input shall be at least 10 dB below the relevant emission limit.

The preferred isolation is:

- 150 kHz to 1,5 MHz, isolation > 35 dB to 55 dB, increasing linearly with the logarithm of the frequency;
- 1,5 MHz to 30 MHz, isolation > 55 dB.

NOTE Isolation is the decoupling of common mode emission originating in an AE and subsequently appearing at the EUT port of the AAN. Certain parameters of the test system are considered in determining the adequate requirement for emission levels.

- f) The AAN shall meet the longitudinal conversion loss (a_{LCL}) requirements from 150 kHz to 30 MHz stated in Table H.2. Actual LCL values to simulate different cable categories are defined in Table H.2.

Table H.2 – a_{LCL} values

Cable type	a_{LCL} dB	Tolerance dB
Cat 3 (or better)	$a_{LCL} = 55 - 10 \lg \left[1 + \left(\frac{f}{5} \right)^2 \right]$	± 3
Cat 5 (or better)	$a_{LCL} = 65 - 10 \lg \left[1 + \left(\frac{f}{5} \right)^2 \right]$	± 3 for $f < 2$ MHz $-3 / +4,5$ for $2 \text{ MHz} \leq f \leq 30 \text{ MHz}$
Cat 6 (or better)	$a_{LCL} = 75 - 10 \lg \left[1 + \left(\frac{f}{5} \right)^2 \right]$	± 3 for $f < 2$ MHz $-3 / +6$ for $2 \text{ MHz} \leq f \leq 30 \text{ MHz}$
NOTE 1 The equations provide the variation of LCL (a_{LCL}) in dB with frequency f in MHz.		
NOTE 2 LCL versus frequency is an approximation of the LCL of typical unscreened balanced cables in representative environments. The specification for category 3 is considered representative of the LCL of typical telecommunication access networks.		

- g) The insertion loss, or other deterioration of the signal quality in the wanted signal frequency band caused by the presence of the AAN, shall not significantly affect the normal operation of the EUT.
- h) The voltage division factor (F_{AAN}) shall be ± 1 dB from 150 kHz to 30 MHz. The AAN voltage division factor is calculated as follows:

$$F_{\text{AAN}} = 20 \lg \left| \frac{V_{\text{cm}}}{V_{\text{mp}}} \right| \text{ dB}$$

where V_{cm} is the common mode voltage appearing across the common mode impedance presented to the EUT by the AAN, and V_{mp} is the resulting receiver voltage measured directly at the voltage measuring port. The voltage division factor shall be added to the receiver voltage measured directly at the voltage measuring port and the result compared with the voltage limits as applicable. The voltage division factor is a calibrated quantity with an uncertainty and no tolerance.

H.3 Characteristics of current probe

The current probe shall have a uniform frequency response without resonances (over the frequency range of interest), and shall be capable of operating without saturation effects caused by the operating currents in the primary winding.

During measurements of currents, where an AAN is used to terminate the line, a current probe is inadequate for determining the converted common mode, and therefore shall not be used.

The insertion impedance of the current probe shall not be larger than 1Ω (see 5.1 of CISPR 16-1-2:2003).

H.4 Characteristics of capacitive voltage probe

The capacitive voltage probe defined in 5.2.2 of CISPR 16-1-2:2003, Amendment 1 (2004) shall be used.

H.5 Procedures for common mode measurements

H.5.1 General

This clause describes the measurement procedures that can be used to measure the CM conducted disturbance of wired network ports. Depending on the cable type, different procedures can be used, each with its advantages and disadvantages (see also Annex G).


H.5.2 Measurement procedure using AANs

Measurement is made at wired network ports using AANs with longitudinal conversion losses as defined in Table H.2. The EUT shall not exceed the applicable limits when measured with the AAN according to the cable category specified by the equipment documentation provided to the user.

When disturbance voltage measurements are performed, an AAN providing a voltage measuring port suitable for connection to a measuring receiver, while satisfying the wired network port common mode termination impedance requirements, shall be used.

For unscreened cables containing balanced pairs, the AAN according to H.2 shall be used. The LCL values of the AAN shall be within the tolerance in Table H.2 of an AAN appropriate to the cable category connected to the EUT.

- i) Arrange the EUT as per Figure H.1.
- j) Measure the voltage at the measurement port of the AAN, then correct the reading by adding the AAN voltage division factor (F_{AAN}) defined in list item e) of H.2, then compare to the limit.



Key

- 1 Distance to the horizontal RGP: 40 cm for tabletop equipment; up to 15 cm for floor standing equipment. Alternatively, tabletop EUT can be 40 cm from a vertical RGP.
- 2 Distance to the RGP is not critical if the AAN provides sufficient isolation against emissions from an AE.


Figure H.1 – Measurement set-up using an AAN

H.5.3 Measurement procedure using a 150 Ω load connected to the outside surface of the cable screen

This procedure can be used for all types of coaxial cables, metallic screens or strength members on fibre optic cables or shielded multi-pair cables.

- k) Arrange the EUT as per Figure H.2.
- l) Break the external protective insulation (exposing the shield), and connect a 150 Ω resistor using an electrical connection from the cable screen to the RGP (through the 150 Ω resistor). The length of this electrical connection shall be $\leq 0,3$ m from the outside surface of the screen to the RGP.
- m) Apply a ferrite tube or clamp between the 150 Ω connection and AE.
- n) Measure the current with a current probe and compare to the current limit. The common mode impedance towards the right of the 150 Ω resistor shall be sufficiently large so as not to affect the measurement. Use the method of H.5.5 to measure this impedance, which should be much larger than 150 Ω so as not to affect the measurement for frequencies emitted by the EUT.

Voltage measurement may also be performed in parallel with the 150 Ω resistor with a high impedance probe, or by using a "50 Ω to 150 Ω adaptor" (described in IEC 61000-4-6 as a 150 Ω load) and applying the appropriate correction factor (9,5 dB in case of the "50 Ω to 150 Ω adaptor").



Key


- 1 Distance to the horizontal RGP: 40 cm for tabletop equipment; up to 15 cm for floor standing equipment. Alternatively, tabletop EUT can be 40 cm from a vertical RGP.
- 2 Distance to the RGP is not critical if the impedance of the ferrite is higher than that given in G.6.

Figure H.2 – Measurement set-up using a 150 Ω load to the outside surface of the shield

H.5.4 Measurement procedure using a combination of current probe and capacitive voltage probe

Because an AAN is not used in the procedure, the common mode impedance is not stabilized; therefore the EUT has to be measured against both the voltage and the current limits, as defined in the following steps:

- p) Arrange the EUT as per Figure H.3.
- q) Measure the current with a current probe and compare the results against the current limits.
- q) Measure the voltage with a capacitive voltage probe as specified in H.4.
 - 1) Adjust the measured voltage as follows:
 - i) Current margin ≤ 6 dB: subtract the actual current margin from the measured voltage.
 - ii) Current margin > 6 dB: subtract 6 dB from the measured voltage.
 - 2) Compare the adjusted voltage with the applicable voltage limit.
 - 3) Both the measured current and the adjusted voltage shall be below the applicable current and voltage limits.
- r) If the EUT has met both limits at all frequencies, then the EUT is compliant.



NOTE It is not required to place both the current probe and the capacitive voltage probe in the measurement set-up at the same time unless simultaneous current and voltage measurements are to be made.

- 1) Distance to the horizontal RGP: 40 cm for tabletop equipment; up to 15 cm for floor standing equipment. Alternatively, tabletop EUT can be 40 cm from a vertical RGP.
- 2) The cable used in testing shall drop directly from the EUT to a position 4 cm ± 1 cm from the RGP and run at this position between the EUT and AE tables. This restriction does not apply to the section of the cable passing through the voltage probe.
- 3) Unless battery operated, the EUT shall be powered using an AMN placed on the RGP at > 10 cm from the nearest edge of the RGP. The EUT power cord shall be routed away from the cable used in testing, to minimize coupling or crosstalk effects.
- 4) The horizontal projection of the EUT to the measurement device shall be 30 cm ± 1 cm.
- 5) The current and voltage probes shall be separated by 10 cm ± 1 cm. Either the current probe (as shown) or the capacitive voltage probe may be placed on the EUT side.

Figure H.3 – Measurement set-up using current and capacitive voltage probes

H.5.5 Measurement of cable, ferrite and AE common mode impedance

One of the following three procedures is used to measure the total common mode (TCM) impedance of cable, ferrite and AE.

s) Procedure using two current probes

- 1) Characterize the "drive" probe and measurement probe 50 Ω system. See Figure H.4. Insert a drive voltage (V_1) from a signal generator into the "drive" probe and record the resulting current (I_1) in the measurement probe.
- 2) Remove the cable from the EUT and short it to ground at the EUT end.
- 3) Apply the same drive voltage (V_1) to the cable with the same "drive" probe.
- 4) Measure the current with the same measurement probe and calculate the common mode impedance of the cable, ferrite and AE combination by comparing the current (I_2) read by the measurement probe with that in the first step (common mode impedance = $50 \times I_1 / I_2$). For example, if I_2 is half I_1 , then the common mode impedance is 100 Ω.
- 5) This TCM impedance measurement technique shall be used only under the following conditions:

The loop length (circumference) in the 50 Ω characterization set-up of Figure H.4 shall be within 0,9 to 1,1 times the total loop length in Figure H.2 and both loop lengths shall be less than 1,25 m. These conditions are necessary to minimize loop resonance(s) that could affect the impedance measurement and increase measurement uncertainty.

t) Procedure using an impedance analyzer

Connect the impedance analyzer between the cable attached to the EUT port being measured and the RGP. The EUT is disconnected for this measurement, and all wires in the cable attached to the EUT port being measured, including the shield if present, are connected together at the point where they are connected to the impedance analyzer. The cable length conditions cited above shall be applied for this measurement. This measurement set-up is similar to that shown in Figure G.4.

u) Procedure using a network analyzer

Using a network analyzer, a current probe and a capacitive voltage probe, measure the common mode voltage and current. The ratio of the voltage to the current on the cable attached to the EUT port under test, as measured with the network analyzer, defines the TCM impedance. This measurement test set-up is similar to that shown in Figure G.4. All wires in the tested cable, including the shield if present, shall be connected together at the EUT end of the cable, similar to the procedure described in item b)




Figure H.4 – Characterization set-up


Annex I (informative)

Examples of AANs and ANs for screened cables

I.1 General

Figures I.1 through I.11 provide examples of AANs.


I.2 Schematic diagrams of examples of asymmetric artificial networks (AANs)



NOTE 1 Nominal voltage division factor = 9,5 dB.

NOTE 2 Z_{cat} represents the unbalance network required to adjust the LCL.

Figure I.1 – Example AAN for use with unscreened single balanced pairs




NOTE 1 Nominal voltage division factor = 9,5 dB.

NOTE 2 Z_{cat} represents the unbalance network required to adjust the applicable LCL.

NOTE 3 This AAN can be used to measure common mode emissions equally well on a single unscreened balanced pair or on two unscreened balanced pairs.

Figure I.2 – Example AAN with high LCL for use with either one or two unscreened balanced pairs



$C = 82 \text{ nF}$

$R_d = 390 \Omega$

AE = Associated equipment

EUT = Equipment under test

Rx = Receiver input

$L_3, L_4, L_5 \text{ and } L_6 = 2 \times 3,1 \text{ mH}$

$L_3, L_4, L_5 \text{ and } L_6$, provide a transverse inductance across each pair = $4 \times 3,1 \text{ mH} = 12,4 \text{ mH}$


IEC 513/13

NOTE 1 Nominal voltage division factor = 9,5 dB.

NOTE 2 Z_{cat} represents the unbalance network required to adjust the applicable LCL.

NOTE 3 This AAN can be used to measure common mode emissions equally well on a single unscreened balanced pair, or on two, three or four unscreened balanced pairs.

Figure I.3 – Example AAN with high LCL for use with one, two, three, or four unscreened balanced pairs




NOTE 1 Nominal voltage division factor = 34 dB

NOTE 2 Z_{cat} represents the unbalance network required to adjust the applicable LCL.

NOTE 3 **CAUTION** – Due to the possibility of erroneous measurement results, this AAN should not be used to measure common mode emissions on unscreened pair cables connected to telecommunication ports that contain only one active unscreened balanced pair.

Figure J.4 – Example AAN, including a 50 Ω source matching network at the voltage measuring port, for use with two unscreened balanced pairs




NOTE 1 Nominal voltage division factor = 9,5 dB.

NOTE 2 Z_{cat} represents the unbalance network required to adjust the applicable LCL.

NOTE 3 **CAUTION** – Due to the possibility of erroneous measurement results, this AAN cannot be used to measure common mode emissions on unscreened pair cables connected to wired network ports that employ only one active unscreened balanced pair.

Figure I.5 – Example AAN for use with two unscreened balanced pairs




NOTE 1 Nominal voltage division factor = 34 dB.

NOTE 2 Z_{cat} represents the unbalance network required to adjust the applicable LCL.

NOTE 3 **CAUTION** – Due to the possibility of erroneous measurement results, this AAN cannot be used to measure common mode emissions on unscreened pair cables connected to wired network ports that employ less than four active unscreened balanced pair.

Figure I.6 – Example AAN, including a 50Ω source matching network at the voltage measuring port, for use with four unscreened balanced pairs




NOTE 1 Nominal voltage division factor = 9.5 dB.

NOTE 2 Z_{cat} represents the unbalance network required to adjust the applicable LCL.

NOTE 3 **CAUTION** – Due to the possibility of erroneous measurement results, this AAN cannot be used to measure common mode emissions on unscreened pair cables connected to telecommunication ports that employ less than four unscreened balanced pairs.


Figure I.7 – Example AAN for use with four unscreened balanced pairs

I.3 Diagrams of examples of ANs for screened cables



NOTE Nominal voltage division factor = 9,5 dB


Figure I.8 – Example AN for use with coaxial cables, employing an internal common mode choke created by bifilar winding an insulated centre-conductor wire and an insulated screen-conductor wire on a common magnetic core (for example, a ferrite toroid)



NOTE 1 Nominal voltage division factor = 9,5 dB.

NOTE 2 More toroids may be needed to fully meet the requirements for ANs.


Figure I.9 – Example AN for use with coaxial cables, employing an internal common mode choke created by miniature coaxial cable (miniature semi-rigid solid copper screen or miniature double-braided screen coaxial cable) wound on ferrite toroids



AE = Associated equipment
EUT = Equipment under test
Rx = Receiver input
Common mode choke $L_1 = (n + 1) \times 7$ mH, where n = number of signal wires

NOTE Nominal voltage division factor = 9,5 dB.

Figure I.10 – Example AN for use with multi-conductor screened cables, employing an internal common mode choke created by bifilar winding multiple insulated signal wires and an insulated screen-conductor wire on a common magnetic core (for example, a ferrite toroid)



AE = Associated equipment
EUT = Equipment under test
Rx = Receiver input
Common mode choke $L_{cm} > 9$ mH, total parasitic shunt $C < 1$ pF

NOTE 1 Nominal voltage division factor = 9,5 dB.

NOTE 2 More toroids may be needed to fully meet the requirements for ANs.

Figure I.11 – Example AN for use with multi-conductor screened cables, employing an internal common mode choke created by winding a multi-conductor screened cable on ferrite toroids

Bibliography

IEC 60050-151:2001, *International Electrotechnical Vocabulary (IEV) – Part 151: Electrical and magnetic devices*

IEC 60050-195:1998, *International Electrotechnical Vocabulary (IEV) – Part 195: Earthing and protection against electric shock*

IEC/TR 60083:2006, *Plugs and socket-outlets for domestic and similar general use standardized in member countries of IEC*

IEC 61000-4-6:2008, *Electromagnetic compatibility (EMC) – Part 4-6: Testing and measurement techniques – Immunity to conducted disturbances, induced by radio-frequency fields*

IEC 61010-1:2001, *Safety requirements for electrical equipment for measurement, control, and laboratory use – Part 1: General requirements*

CISPR 11:2003, *Industrial, scientific and medical (ISM) radio-frequency equipment – Electro-magnetic disturbance characteristics – Limits and methods of measurement*

CISPR 16 (all parts), *Specification for radio disturbance and immunity measuring apparatus and methods*

CISPR 16-1-4:2010, *Specification for radio disturbance and immunity measuring apparatus and methods – Part 1-4: Radio disturbance and immunity measuring apparatus – Antennas and test sites for radiated disturbance measurements*

CISPR/TR 16-3, *Specification for radio disturbance and immunity measuring apparatus and methods – Part 3: CISPR technical reports*

CISPR 16-4-1:2003, *Specification for radio disturbance and immunity measuring apparatus and methods – Part 4-1: Uncertainties, statistics and limit modelling – Uncertainties in standardized EMC tests*

CISPR 16-4-2:2003, *Specification for radio disturbance and immunity measuring apparatus and methods – Part 4-2: Uncertainties, statistics and limit modelling – Uncertainty in EMC measurements*

CISPR/TR 16-4-3:2004, *Specification for radio disturbance and immunity measuring apparatus and methods – Part 4-3: Uncertainties, statistics and limit modelling – Statistical considerations in the determination of EMC compliance of mass-produced products*

ISO/IEC Guide 99:2007, *International vocabulary of metrology – Basic and general concepts and associated terms (VIM)*

ITU-R Recommendation BS.468-4: *Measurement of audio-frequency noise voltage level in sound broadcasting*

STANDARDSISO.COM : Click to view the full PDF of CISPR 16-2-1:2008+AMD1:2010+AMD2:2013 CSV

Withdrawn

SOMMAIRE

AVANT-PROPOS	116
INTRODUCTION (à l'amendement 1)	118
1 Domaine d'application	119
2 Références normatives	119
3 Définitions	119
4 Types de perturbations à mesurer	125
4.1 Généralités	125
4.2 Types de perturbations	125
4.3 Fonctions de détection	126
5 Connexion du matériel de mesure	126
5.1 Généralités	126
5.2 Connexion de l'équipement d'appoint	126
5.3 Connexions à la masse de référence RF	127
5.4 Connexion entre le matériel en essai et le réseau fictif d'alimentation (AMN)	128
6 Exigences et conditions générales de mesure	129
6.1 Généralités	129
6.2 Perturbation non produite par le matériel à l'essai	129
6.2.1 Généralités	129
6.2.2 Essais de conformité	129
6.3 Mesure d'une perturbation continue	129
6.3.1 Perturbation continue à bande étroite	129
6.3.2 Perturbation continue à large bande	130
6.3.3 Utilisation d'analyseurs de spectre et de récepteurs à balayage	130
6.4 Disposition et conditions de fonctionnement mesure du matériel en essai	130
6.4.1 Généralités Disposition du matériel en essai	130
6.4.2 Conditions de charge normales	130
6.4.3 Durée de fonctionnement	133
6.4.4 Durée de fonctionnement préalable/de préchauffage	133
6.4.5 Alimentation	133
6.4.6 Mode de fonctionnement	133
6.4.7 Fonctionnement d'un matériel à fonctions multiples	133
6.4.8 Détermination de la ou des disposition(s) d'émission maximale	134
6.4.9 Enregistrement des mesures	134
6.5 Interprétation des résultats de mesure	133
6.5.1 Perturbations continues	134
6.5.2 Perturbations discontinues	135
6.5.3 Mesure de la durée des perturbations	135
6.6 Temps de mesure et vitesses de balayage pour les perturbations continues	135
6.6.1 Généralités	135
6.6.2 Temps de mesure minimaux	135
6.6.3 Vitesses de balayage des récepteurs à balayage et des analyseurs de spectre	136
6.6.4 Durées de balayage pour les récepteurs à accord par palier	137

6.6.5	Stratégies pour une vue d'ensemble du spectre en utilisant le détecteur de crête.....	138
6.6.6	Considérations temporelles concernant l'utilisation d'appareils de mesure à FFT	142
7	Mesure des perturbations conduites par les câbles, de 9 kHz à 30 MHz	144
7.1	Introduction	144
7.2	Appareils de mesure (récepteurs, etc.)	145
7.2.1	Généralités.....	145
7.2.2	Utilisation des détecteurs pour les mesures des perturbations conduites.....	145
7.3	Appareils de mesure auxiliaires	145
7.3.1	Généralités.....	145
7.3.2	Réseaux fictifs (AN).....	146
7.3.3	Sondes de tension	146
7.3.4	Sondes de courant	147
7.4	Configuration du matériel en essai	147
7.4.1	Disposition des matériels en essai et leur connexion au réseau fictif	147
7.4.2	Procédure de mesure des tensions perturbatrices non symétriques avec des réseaux en V (AMN)	155
7.4.3	Mesure des tensions en mode commun aux bornes de signaux en mode différentiel.....	162
7.4.4	Mesures au moyen de sondes de tension	163
7.4.5	Mesures au moyen d'une sonde de tension capacitive (CVP)	166
7.4.6	Mesures au moyen de sondes de courant.....	166
7.5	Configuration d'essai des systèmes pour les mesures d'émissions conduites	166
7.5.1	Approche générale des mesures des systèmes	166
7.5.2	Configuration du système.....	167
7.5.3	Mesure des lignes d'interconnexion	170
7.5.4	Découplage des composantes du système	170
7.6	Mesure <i>in situ</i>	170
7.6.1	Généralités.....	170
7.6.2	Masse de référence	171
7.6.3	Mesure au moyen de sondes de tension.....	171
7.6.4	Choix des points de mesure	171
8	Mesure automatisée des émissions	172
8.1	Introduction. Précautions pour les mesures automatisées	172
8.2	Procédure générale de mesure.....	172
8.3	Mesures par pré-balayage.....	173
8.4	Réduction des données	174
8.5	Maximisation des émissions et mesures finales.....	174
8.6	Post-traitement et rapport.....	174
8.7	Stratégies de la mesure d'émissions avec des appareils de mesure à FFT	175
	Annexe A (informative) Guide pour la connexion d'un matériel électrique au réseau fictif (voir Article 5)	176
	Annexe B (informative) Utilisation des analyseurs de spectre et des récepteurs à balayage (voir Article 6)	184

Annexe C (informative) Arbre de décision pour l'utilisation des détecteurs pour les mesures en conduction (voir 7.2.2).....	187
Annexe D (informative) Durées de mesure et vitesses de balayage utilisables avec un détecteur de valeur moyenne.....	189
Annexe E (informative) Lignes directrices pour l'amélioration de la configuration d'essai avec ANs	193
Annexe F (normative) Détermination de l'adéquation des analyseurs de spectre à des essais de conformité	198
Annexe G (informative) Directives concernant les mesures sur les accès de télécommunication	199
Annexe H (normative) Spécificités de la perturbation conduite sur les accès de télécommunication	206
Annexe I (informative) Exemples d'AAN et AN pour câbles blindés	213
Bibliographie.....	222
Figure 1 – Exemple d'un montage d'essai recommandé avec bobines PE, trois réseaux fictifs d'alimentation et un absorbeur de courant de gaine sur le câble RF	128
Figure 2 – Mesure d'une combinaison d'un signal à onde entretenue ("Bande étroite") et d'un signal en impulsion ("Large bande") en utilisant des balayages multiples avec maintien du maximum	139
Figure 3 – Exemple d'analyse temporelle.....	140
Figure 4 – Spectre large bande mesuré avec un récepteur à accord par palier	141
Figure 5 – Perturbations intermittentes à bande étroite mesurées en utilisant des balayages courts, rapides et répétitifs avec la fonction «maintien du maximum» pour obtenir une vue d'ensemble du spectre d'émission.....	141
Figure 19 – Balayage FFT en segments.....	143
Figure 20 – Résolution en fréquence améliorée au moyen d'un appareil de mesure à FFT.....	144
Figure 21 – Illustration du courant I_{CCM}	147
Figure 6 – Exemple de configuration d'essai: matériels de table pour mesures des perturbations conduites sur les conducteurs d'alimentation	149
Figure 7 – Montage de matériel en essai et de AMN à 40 cm avec a) RGP vertical et b) RGP horizontal	150
Figure 8 – Exemple de configuration d'essai facultative pour un matériel en essai avec seulement un câble d'alimentation fixé	151
Figure 9 – Exemple de configuration d'essai: matériels posés sur le sol (voir 7.4.1 et 7.5.2.2)	153
Figure 10 – Exemple de configuration d'essai: matériels posés sur le sol et sur une table (voir 7.4.1 et 7.5.2.2)	154
Figure 11 – Schéma de la configuration de mesure de la tension perturbatrice (voir aussi 7.5.2.2).....	156
Figure 12a – Schéma du circuit de mesure et d'alimentation	157
Figure 12b – Circuit équivalent de source de tension et de mesure.....	157
Figure 12 – Circuit équivalent de mesure de la tension perturbatrice en mode commun pour les matériels en essai de classe I (mis à la terre).....	157
Figure 13a – Schéma du circuit d'alimentation et de mesure.....	158
Figure 13b – Circuit équivalent de source de perturbations radioélectriques et de mesure.....	158
Figure 13 – Circuit équivalent de mesure de la tension perturbatrice en mode commun pour les matériels en essai de classe II (non mis à la masse)	158
Figure 14 – Élément RC pour main artificielle	160

Figure 15 – Perceuse électrique portative avec main artificielle	160
Figure 16 – Scie électrique portative avec main artificielle	160
Figure 17 – Exemple de mesure pour les sondes de tension	164
Figure 18 – Disposition de mesure pour un dispositif de régulation à deux bornes	164
Figure A.1	176
Figure A.2	177
Figure A.3	177
Figure A.4	177
Figure A.5	178
Figure A.6	178
Figure A.7	179
Figure A.8 – Configurations du réseau fictif	182
Figure C.1 – Arbre de décision pour l'optimisation de la durée des mesures des perturbations conduites avec les détecteurs de crête, de quasi-crête et de valeur moyenne	187
Figure D.1 – Fonction de pondération d'une impulsion de 10 ms pour des détections de valeurs crêtes (PK) et moyennes avec (CISPR AV) ou sans (AV) lecteur crête; avec un contrôleur de période de 160 ms	191
Figure D.2 – Fonctions de pondération d'une impulsion de 10 ms pour des détections de valeurs crêtes (PK) et moyennes avec (CISPR AV) ou sans (AV) lecteur crête; avec un contrôleur de période de 100 ms	191
Figure D.3 – Exemple de fonctions de pondération (d'une impulsion de 1 Hz) pour des détections de valeurs crêtes («PK») et moyennes équivalentes à une fonction de largeur d'impulsion, avec un contrôleur de période de 160 ms	192
Figure D.4 – Exemple de fonctions de pondération (d'une impulsion d'1 Hz) pour des détections de valeurs crêtes («PK») et moyennes équivalentes à une fonction de largeur d'impulsion, avec un contrôleur de période de 100 ms	192
Figure E.1 – Résonance parallèle de la capacité de l'enveloppe et de l'inductance de connexion de masse	193
Figure E.2 – Connexion d'un AMN au plan de masse de référence au moyen d'une tôle large, pour réaliser une mise à la masse à faible inductance	194
Figure E.3 – Impédance mesurée avec la disposition de la Figure E.2, en référence à la fois à la masse de face avant et à la tôle de mise à la masse	194
Figure E.4 – Facteur VDF dans la configuration de la Figure E.2, mesuré en référence à la masse de face avant et à la tôle de mise à la masse. (L'AMN utilisé a une réponse plate en fréquence du facteur VDF, qui peut être différente pour d'autres AMN)	194
Figure E.5 – Disposition montrant la tôle de masse de mesure (représentée en pointillés) de l'impédance en référence au plan de masse de référence. La masse du câble de mesure de l'impédance est connectée à la tôle de masse de mesure, tandis que le conducteur interne est connecté à la broche d'accès du matériel en essai	195
Figure E.6 – Impédance mesurée avec la disposition de la Figure E.5, en référence au plan de masse de référence	195
Figure E.7 – Facteur VDF mesuré avec des résonances parallèles dans la liaison de masse de l'AMN	196
Figure E.8 – Atténuation d'un absorbeur de courant de gaine mesuré dans un dispositif d'essai de 150 Ω	197
Figure E.9 – Disposition de mesure de l'atténuation due aux bobines PE et aux absorbeurs de courant de gaine	197
Figure G.1 – Circuit de base pour considérer les limites avec une impédance totale en mode commun (TCM) de 150 Ω	202
Figure G.2 – Circuit de base pour la mesure avec une impédance totale en mode commun (TCM) inconnue	202

Figure G.3 – Configuration des impédances des composants utilisés à la Figure H.2.....	204
Figure G.4 – Montage d'essai de base pour mesurer l'impédance combinée des 150 Ω et des ferrites	205
Figure H.1 – Exemple de dispositif de mesure utilisant des réseaux fictifs asymétriques (AAN)	209
Figure H.2 – Exemple de dispositif de mesure utilisant une charge de 150 Ω à la surface extérieure du blindage	210
Figure H.3 – Dispositif de mesure utilisant des sondes de courant et de tension capacitive	211
Figure H.4 – Montage d'étalonnage	212
Figure I.1 – Exemple de réseau fictif asymétrique (AAN) destiné à être utilisé avec des paires symétriques uniques non blindées	213
Figure I.2 – Exemple de réseau fictif asymétrique (AAN) avec forte LCL (perte de conversion longitudinale) destiné à être utilisé avec une ou deux paires symétriques non blindées	214
Figure I.3 – Exemple de réseau fictif asymétrique (AAN) avec forte LCL (perte de conversion longitudinale) destiné à être utilisé avec une, deux, trois ou quatre paires symétriques non blindées	215
Figure I.4 – Exemple de réseau fictif asymétrique (AAN), incluant un réseau d'adaptation de source de 50 Ω sur l'accès de mesure de tension, destiné à être utilisé avec deux paires symétriques non blindées	216
Figure I.5 – Exemple de réseau fictif asymétrique (AAN) destiné à être utilisé avec deux paires symétriques non blindées	217
Figure I.6 – Exemple de réseau fictif asymétrique (AAN), incluant un réseau d'adaptation de source de 50 Ω sur l'accès de mesure de tension, destiné à être utilisé avec quatre paires symétriques non blindées	218
Figure I.7 – Exemple de réseau fictif asymétrique (AAN) destiné à être utilisé avec quatre paires symétriques non blindées	219
Figure I.8 – Exemple de réseau fictif (AN) destiné à être utilisé avec des câbles coaxiaux, utilisant une bobine d'arrêt interne de mode commun créée par un enroulement bifilaire d'un conducteur central isolé et d'un conducteur de blindage isolé sur un noyau magnétique commun (par exemple, un tore en ferrite)	220
Figure I.9 – Exemple de réseau fictif (AN) destiné à être utilisé avec des câbles coaxiaux, utilisant une bobine d'arrêt de mode commun interne créée par un câble coaxial miniature (câble coaxial à blindage de cuivre plein semi-rigide ou à blindage miniature à double tresse) enroulé sur des tores en ferrite.....	220
Figure I.10 – Exemple de réseau fictif (AN) destiné à être utilisé avec des câbles blindés multiconducteurs, utilisant une bobine d'arrêt de mode commun interne créée par un enroulement bifilaire de plusieurs conducteurs de signaux isolés et un conducteur de blindage isolé sur un noyau magnétique commun (par exemple, un tore en ferrite).....	221
Figure I.11 – Exemple de réseau fictif (AN) destiné à être utilisé avec des câbles blindés multiconducteurs, utilisant une bobine d'arrêt de mode commun interne créée par un enroulement d'un câble blindé multiconducteur sur des tores en ferrite	221
Tableau 1 – Durées de balayage minimales pour les trois bandes CISPR avec détecteur de crête et détecteur de quasi-crête	136
Tableau 2 – Durées de mesure minimales pour les quatre bandes de la CISPR	136
Tableau A.1	183
Tableau A.2	183
Tableau D.1 – Facteurs de suppression d'impulsion et vitesses de balayage pour une largeur de bande vidéo de 100 Hz	190

Tableau D.2 – Contrôleur de période et largeurs de bandes vidéo correspondantes et vitesses de balayages maximales correspondantes	191
Tableau F.1 – Différence d'amplitude maximale entre les signaux détectés crête et quasi-crête.....	198
Tableau G.1 – Résumé des avantages et des inconvénients des méthodes décrites dans les paragraphes spécifiques de l'Annexe H	200
Tableau H.1 – Choix du mode opératoire de mesure des perturbations sur les accès de télécommunication	206
Tableau H.2 – Valeurs de a_{LCL}	207

COMMISSION ÉLECTROTECHNIQUE INTERNATIONALE

COMITÉ INTERNATIONAL SPÉCIAL DES PERTURBATIONS RADIOÉLECTRIQUES

SPÉCIFICATIONS DES MÉTHODES ET DES APPAREILS DE MESURE DES PERTURBATIONS RADIOÉLECTRIQUES ET DE L'IMMUNITÉ AUX PERTURBATIONS RADIOÉLECTRIQUES –

Partie 2-1: Méthodes de mesure des perturbations et de l'immunité – Mesures des perturbations conduites

AVANT-PROPOS

- 1) La Commission Electrotechnique Internationale (CEI) est une organisation mondiale de normalisation composée de l'ensemble des comités électrotechniques nationaux (Comités nationaux de la CEI). La CEI a pour objet de favoriser la coopération internationale pour toutes les questions de normalisation dans les domaines de l'électricité et de l'électronique. A cet effet, la CEI – entre autres activités – publie des Normes internationales, des Spécifications techniques, des Rapports techniques, des Spécifications accessibles au public (PAS) et des Guides (ci-après dénommés "Publication(s) de la CEI"). Leur élaboration est confiée à des comités d'études, aux travaux desquels tout Comité national intéressé par le sujet traité peut participer. Les organisations internationales, gouvernementales et non gouvernementales, en liaison avec la CEI, participent également aux travaux. La CEI collabore étroitement avec l'Organisation Internationale de Normalisation (ISO), selon des conditions fixées par accord entre les deux organisations.
- 2) Les décisions ou accords officiels de la CEI concernant les questions techniques représentent, dans la mesure du possible, un accord international sur les sujets étudiés, étant donné que les Comités nationaux de la CEI intéressés sont représentés dans chaque comité d'études.
- 3) Les Publications de la CEI se présentent sous la forme de recommandations internationales et sont agréées comme telles par les Comités nationaux de la CEI. Tous les efforts raisonnables sont entrepris afin que la CEI s'assure de l'exactitude du contenu technique de ses publications; la CEI ne peut pas être tenue responsable de l'éventuelle mauvaise utilisation ou interprétation qui en est faite par un quelconque utilisateur final.
- 4) Dans le but d'encourager l'uniformité internationale, les Comités nationaux de la CEI s'engagent, dans toute la mesure possible, à appliquer de façon transparente les Publications de la CEI dans leurs publications nationales et régionales. Toutes divergences entre toutes Publications de la CEI et toutes publications nationales ou régionales correspondantes doivent être indiquées en termes clairs dans ces dernières.
- 5) La CEI elle-même ne fournit aucune attestation de conformité. Des organismes de certification indépendants fournissent des services d'évaluation de conformité et, dans certains secteurs, accèdent aux marques de conformité de la CEI. La CEI n'est responsable d'aucun des services effectués par les organismes de certification indépendants.
- 6) Tous les utilisateurs doivent s'assurer qu'ils sont en possession de la dernière édition de cette publication.
- 7) Aucune responsabilité ne doit être imputée à la CEI, à ses administrateurs, employés, auxiliaires ou mandataires, y compris ses experts particuliers et les membres de ses comités d'études et des Comités nationaux de la CEI, pour tout préjudice causé en cas de dommages corporels et matériels, ou de tout autre dommage de quelque nature que ce soit, directe ou indirecte, ou pour supporter les coûts (y compris les frais de justice) et les dépenses découlant de la publication ou de l'utilisation de cette Publication de la CEI ou de toute autre Publication de la CEI, ou au crédit qui lui est accordé.
- 8) L'attention est attirée sur les références normatives citées dans cette publication. L'utilisation de publications référencées est obligatoire pour une application correcte de la présente publication.
- 9) L'attention est attirée sur le fait que certains des éléments de la présente Publication de la CEI peuvent faire l'objet de droits de propriété intellectuelle ou de droits analogues. La CEI ne saurait être tenue pour responsable de ne pas avoir identifié de tels droits de propriété et de ne pas avoir signalé leur existence.

Cette version consolidée de la CISPR 16-2-1 comprend la deuxième édition (2008) [documents CISPR/A/798/FDIS et CISPR/A/809/RVD], son amendement 1 (2010) [documents CISPR/A/874/CDV et CISPR/A/897/RVC] et son amendement 2 (2013) [documents CISPR/A/1023/FDIS et CISPR/A/1029/RVD]. Elle porte le numéro d'édition 2.2.

Le contenu technique de cette version consolidée est donc identique à celui de l'édition de base et à ses amendements; cette version a été préparée par commodité pour l'utilisateur. Une ligne verticale dans la marge indique où la publication de base a été modifiée par les amendements 1 et 2. Les ajouts et les suppressions apparaissent en rouge, les suppressions sont barrées.

La Norme internationale CISPR 16-2-1 a été établie par le sous-comité A du CISPR: Mesures des perturbations radioélectriques et méthodes statistiques.

Cette édition inclut des modifications techniques majeures par rapport à l'édition précédente. De manière générale, cette nouvelle édition a pour objectif de réduire l'incertitude de conformité, en connexion avec les conclusions de la CISPR 16-4-1. Des indications sont fournies sur:

- la connexion sans résonance de l'AMN à la masse de référence,
- la manière d'éviter les boucles de masses, et
- la manière d'éviter les ambiguïtés sur le montage d'essai de l'équipement en essai et de l'AMN par rapport au plan de masse de référence.

De plus, des termes sont clarifiés, un nouveau type d'équipement d'appoint est introduit, et des clarifications en vue de l'utilisation d'AAN et d'AMN sur le même équipement en essai sont fournies.

Cette publication a été rédigée selon les Directives ISO/CEI, Partie 2.

Une liste de toutes les parties de la CISPR 16, sous le titre général *Spécifications des méthodes et des appareils de mesure des perturbations radioélectriques et de l'immunité aux perturbations radioélectriques*, est disponible sur le site web de la CEI.

Le comité a décidé que le contenu de la publication de base et de ses amendements ne sera pas modifié avant la date de stabilité indiquée sur le site web de la CEI sous "<http://webstore.iec.ch>" dans les données relatives à la publication recherchée. A cette date, la publication sera

- reconduite,
- supprimée,
- remplacée par une édition révisée, ou
- amendée.

IMPORTANT – Le logo "colour inside" qui se trouve sur la page de couverture de cette publication indique qu'elle contient des couleurs qui sont considérées comme utiles à une bonne compréhension de son contenu. Les utilisateurs devraient, par conséquent, imprimer cette publication en utilisant une imprimante couleur.

INTRODUCTION (à l'amendement 1)

Les spécifications énoncées dans le CISPR 16-2-1 sont satisfaites indépendamment de la mise en œuvre ou de la technologie spécifiques à l'instrument de mesure, de sorte que les mesures ainsi obtenues puissent être considérées comme conformes aux normes CISPR. L'ajout des appareils de mesure à FFT nécessite toutefois des spécifications complémentaires aux méthodes d'essai associées. Ces nouvelles exigences sont présentées dans le présent amendement. Une nouvelle Annexe F est également ajoutée en conséquence des dispositions récemment introduites dans le CISPR 16-1-1, relatives à l'utilisation d'analyseurs de spectre pour les mesures de conformité.

SPÉCIFICATIONS DES MÉTHODES ET DES APPAREILS DE MESURE DES PERTURBATIONS RADIOÉLECTRIQUES ET DE L'IMMUNITÉ AUX PERTURBATIONS RADIOÉLECTRIQUES –

Partie 2-1: Méthodes de mesure des perturbations et de l'immunité – Mesures des perturbations conduites

1 Domaine d'application

La présente partie de la CISPR 16 est une norme fondamentale qui spécifie les méthodes de mesure des phénomènes perturbateurs en général, dans la gamme de fréquences de 9 kHz à 18 GHz et spécialement les perturbations conduites dans la gamme de fréquences de 9 kHz à 30 MHz.

2 Références normatives

Les documents de référence suivants sont indispensables pour l'application du présent document. Pour les références datées, seule l'édition citée s'applique. Pour les références non datées, la dernière édition du document de référence s'applique (y compris les éventuels amendements).

CEI 60050-161:1990, *Vocabulaire Electrotechnique International (VEI) – Chapitre 161: Compatibilité électromagnétique*

CEI 60364-4 (toutes les parties), *Installations électriques des bâtiments – Partie 4: Protection pour assurer la sécurité*

CISPR 14-1, *Compatibilité électromagnétique – Exigences pour les appareils électro-domestiques, outillages électriques et appareils analogues – Partie 1: Émission*

CISPR 16-1-1:2010, *Spécifications des méthodes et des appareils de mesure des perturbations radioélectriques et de l'immunité aux perturbations radioélectriques – Partie 1-1: Appareils de mesure des perturbations radioélectriques et de l'immunité aux perturbations radioélectriques – Appareils de mesure*

CISPR 16-1-2:2003, *Spécifications des méthodes et des appareils de mesure des perturbations radioélectriques et de l'immunité aux perturbations radioélectriques – Partie 1-2: Appareils de mesure des perturbations radioélectriques et de l'immunité aux perturbations radioélectriques – Matériels auxiliaires – Perturbations conduites*

Amendement 1:2004

Amendement 2:2006

~~CISPR/TR 16-3:2003, *Specification for radio disturbance and immunity measuring apparatus and methods – Part 3: CISPR technical reports (uniquement disponible en anglais)*~~

~~Amendement 1:2005~~

~~Amendement 2:2006~~

3 Définitions

Pour les besoins de la présente partie du CISPR 16, les définitions de la CEI 60050-161 s'appliquent, ainsi que les définitions suivantes.

3.1

équipement d'appoint

transducteurs (par exemple, sondes de tension et de courant et réseaux fictifs) connectés à un récepteur de mesure ou à un générateur de signal (d'essai) et utilisés dans la transmission du signal perturbateur entre le matériel en essai et le matériel de mesure ou d'essai

3.2

matériel associé

AE, de l'anglais *Associated Equipment*

matériel nécessaire pour aider au fonctionnement du matériel en essai qui ne fait pas partie du système soumis à essai

3.3

matériel auxiliaire

AuxEq, de l'anglais *Auxiliary equipment*

périphérique faisant partie du système soumis à essai

3.4

matériel en essai

matériel (dispositifs, appareils et systèmes) soumis aux essais de conformité pour la CEM (émission)

3.5

publication de produits

publication spécifiant des exigences de CEM pour un produit ou une famille de produits et prenant en compte les aspects spécifiques de ce produit ou de cette famille de produits

3.6

limite d'émission (d'une source perturbatrice)

valeur maximale spécifiée du niveau d'émission d'une source de perturbation électromagnétique

[VEI 161-03-12]

3.7

masse de référence

~~connexion qui constitue une capacité parasite définie entre un matériel en essai et son environnement et qui est utilisée comme potentiel de référence~~

~~NOTE Voir également VET 161-04-36.~~

~~surface conductrice plate qui constitue une capacité parasite définie autour d'un EUT et sert de potentiel de référence~~

~~NOTE 1 Voir également la CEI 60050-161, 161-04-36.~~

~~NOTE 2 *Une surface de référence à la terre est nécessaire pour les mesures d'émission conduites, et sert de potentiel de référence pour les mesures de tensions perturbatrices non symétriques et asymétriques.~~

3.8

émission (électromagnétique)

processus par lequel une source fournit de l'énergie électromagnétique vers l'extérieur

[VEI 161-01-08]

3.9

câble coaxial

câble comportant une ou plusieurs lignes coaxiales, généralement utilisé pour réaliser une connexion adaptée entre un matériel associé et le matériel de mesure ou le générateur d'essai et fournissant une impédance caractéristique spécifiée et une impédance de transfert maximale tolérable spécifiée

3.10

tension (non symétrique) en mode commun

tension RF entre le point milieu fictif de deux conducteurs d'une ligne et la référence de sol, ou dans le cas d'un faisceau de lignes, la tension perturbatrice RF effective de l'ensemble du faisceau (somme vectorielle de tension non symétriques) par rapport à la référence de sol, mesurée avec une pince (transformateur de courant) pour une impédance de terminaison définie

NOTE Voir également VEI 161-04-09.

3.11

courant de mode commun

somme vectorielle des courants traversant deux ou plusieurs conducteurs à une intersection spécifiée entre ces conducteurs et un plan imaginaire

3.12

tension (symétrique) en mode différentiel

tension perturbatrice RF entre les fils d'une ligne à deux conducteurs

[VEI 161-04-08, modifié]

3.13

courant en mode différentiel

demi-différence vectorielle des courants circulant dans deux conducteurs quelconques d'un ensemble spécifié de conducteurs actifs à une intersection spécifiée entre ces conducteurs et un plan imaginaire

3.14

tension en mode non symétrique (aux bornes d'un réseau en V)

tension entre un conducteur ou la borne d'un dispositif, d'un matériel ou d'un système et une référence de sol spécifiée. Dans le cas d'un réseau à deux accès, les deux tensions non symétriques sont données par:

- a) la somme vectorielle de la tension en mode non symétrique et de la moitié de la tension symétrique; et
- b) la différence vectorielle entre la tension en mode non symétrique et la moitié de la tension symétrique.

NOTE Voir également VEI 161-04-13.

3.15

récepteur de mesure

~~récepteur pour la mesure des perturbations équipé de différents détecteurs~~

~~NOTE Le récepteur est spécifié conformément à la CISPR 16-1-1.~~

~~appareil de mesure tel qu'un voltmètre sélectif, un récepteur de perturbations électromagnétiques, un analyseur de spectre ou un appareil de mesure à FFT, avec ou sans présélection, satisfaisant les articles appropriés du CISPR 16-1-1~~

~~NOTE Voir l'Annexe I du CISPR 16-1-1 pour plus d'information.~~

3.16

configuration d'essai

combinaison qui indique la disposition de mesure spécifiée du matériel en essai et permettant la mesure d'un niveau d'émission

~~NOTE Le niveau d'émission ou le niveau d'immunité est mesuré conformément aux définitions VEI 161-03-11, VEI 161-03-12, VEI 161-03-14 et VEI 161-03-15.~~

3.17

réseau fictif

AN

impédance de charge de référence conventionnelle (simulation) présentée au matériel en essai par les réseaux réels (par exemple lignes longues d'alimentation électrique ou de communication), aux bornes de laquelle on mesure la tension perturbatrice RF

3.18

réseau fictif d'alimentation

AMN

réseau inséré dans le circuit d'alimentation en énergie électrique d'un matériel en essai, qui fournit, dans une gamme de fréquences donnée, une impédance de charge spécifiée pour mesurer des tensions perturbatrices et qui peut isoler le matériel du réseau d'alimentation aux fréquences de la gamme donnée

[VEI 161-04-05]

NOTE Il existe deux types fondamentaux de réseaux AMN, le réseau en V (AMN en V) qui accouple les tensions non-symétriques, et le réseau en triangle qui accouple séparément les tensions symétriques et non-symétriques. Les termes réseau de stabilisation d'impédance de ligne (RSIL) et réseau AMN en V sont utilisés indifféremment. Dans la présente norme, l'acronyme «AMN» est utilisé pour les «AMN en V», car les AMN en triangle ne sont pas utilisés dans les publications de produits relatives aux mesures d'émission.

3.19

pondération (détection quasi-crête)

~~conversion, dépendante du taux de répétition, des tensions impulsives de crête en une indication correspondant à la gêne psychophysique des perturbations impulsives (acoustiques ou visuelles), selon les caractéristiques de pondération ou, comme alternative, manière spécifiée par laquelle on évalue un niveau d'émission ou un niveau d'immunité~~

NOTE 1 ~~Les caractéristiques de pondération sont spécifiées dans la CISPR 16-1-1.~~

NOTE 2 ~~Le niveau d'émission ou le niveau d'immunité est évalué conformément aux définitions des niveaux de la CEI 60050-161 (voir VEI 161-03-01, VEI 161-03-11 et VEI 161-03-14).~~

pondération (par exemple, d'une perturbation par impulsion)

~~conversion (principalement réduction) dépendant de la fréquence de répétition des impulsions (PRF) d'un niveau de détection d'impulsions crête en une indication correspondant à l'effet de l'interférence sur la réception radio~~

NOTE 1 Pour le récepteur analogique, la gêne psychophysique de l'interférence est une quantité subjective (habituellement acoustique ou visuelle, et non un certain nombre d'incompréhensions d'un texte parlé).

NOTE 2 Pour le récepteur numérique, l'effet de l'interférence est une quantité objective pouvant être définie soit par le taux d'erreur critique sur les bits (BER) ou la probabilité d'erreur sur les bits (BEP) pour lequel une correction d'erreur parfaite peut toujours s'effectuer, soit au moyen d'un autre paramètre objectif et reproductible.

3.19.1

mesure pondérée d'une perturbation

~~mesure d'une perturbation à l'aide d'un détecteur à pondération~~

3.19.2

caractéristique de pondération

~~niveau de tension crête en fonction de la PRF donnant un effet constant sur un système de radiocommunication spécifique, c'est-à-dire, la perturbation étant pondérée par le système de radiocommunication lui-même~~

3.19.3

détecteur à pondération

~~détecteur fournissant une fonction de pondération admise~~

3.19.4

facteur de pondération

valeur de la fonction de pondération relative à une PRF de référence ou relative à la valeur crête

NOTE Le facteur de pondération est exprimé en décibels.

3.19.5

fonction de pondération

courbe de pondération

relation entre le niveau de tension crête d'entrée et la PRF donnant une indication de niveau constant d'un récepteur de mesure avec un détecteur pondéré, c'est-à-dire, la courbe de réponse d'un récepteur de mesure pour des impulsions répétées

3.20

perturbation continue

perturbation RF de durée supérieure à 200 ms à la sortie en fréquence intermédiaire d'un récepteur de mesure, qui provoque une déviation sur l'indicateur du récepteur de mesure, en mode de détection quasi-crête, qui ne décroît pas immédiatement

[VEI 161-02-11, modifié]

~~NOTE Le récepteur de mesure est spécifié dans la CISPR 16-1-1.~~

3.21

perturbation discontinue

pour les claquements comptés, perturbation de durée inférieure à 200 ms à la sortie en fréquence intermédiaire d'un récepteur de mesure, qui provoque une déviation transitoire sur l'indicateur du récepteur de mesure, en mode de détection quasi-crête

NOTE Pour les perturbations impulsives, voir VEI 161-02-08.

~~NOTE 2 Le récepteur de mesure est spécifié dans la CISPR 16-1-1.~~

3.22

temps de mesure

T_m

temps effectif et cohérent pour obtenir un résultat de mesure à une fréquence unique (dans certains domaines, appelé également temps de palier)

- pour le détecteur de crête, le temps effectif pour détecter le maximum de l'enveloppe du signal,
- pour le détecteur de quasi-crête, le temps effectif pour mesurer le maximum de l'enveloppe pondérée,
- pour le détecteur de valeur moyenne, le temps effectif pour effectuer la moyenne de l'enveloppe du signal,
- pour le détecteur de valeur efficace, le temps effectif pour déterminer la valeur efficace de l'enveloppe du signal

3.23

balayage (1)

variation continue de la fréquence dans un intervalle donné de fréquences

3.24

balayage (2)

variation continue ou par pas de la fréquence dans un intervalle donné de fréquences

3.25

durée de balayage

T_s

temps d'un balayage compris entre la fréquence de départ et la fréquence d'arrivée

3.26

intervalle

Δf

différence entre la fréquence de départ et la fréquence d'arrivée d'un balayage

3.27

vitesse de balayage

intervalle de fréquence divisé par la durée de balayage

3.28

nombre de balayages par unité de temps (par exemple, par seconde)

n_s

$1/(\text{durée de balayage} + \text{durée du retour})$

3.29

temps d'observation

T_o

somme des temps de mesure T_m à une certaine fréquence dans le cas de balayages multiples. Si n est le nombre de balayages, alors $T_o = n \times T_m$

3.30

temps d'observation total

T_{tot}

temps effectif pour une vue d'ensemble du spectre (soit en balayage simple soit en balayages multiples). Si c est le nombre de canaux dans un balayage, alors $T_{tot} = c \times n \times T_m$

3.31

mesurage

processus consistant à obtenir expérimentalement une ou plusieurs valeurs que l'on peut raisonnablement attribuer à une grandeur

[Guide ISO/CEI 99:2007, 2.1]

3.32

essai

opération technique qui consiste à déterminer une ou plusieurs caractéristiques d'un produit, processus ou service donné, selon un mode opératoire spécifié

NOTE Un essai est destiné à mesurer ou à classer une caractéristique ou une propriété d'une entité en appliquant à celle-ci un ensemble d'exigences et de conditions d'environnement et de fonctionnement.

[CEI 60050-151:2001, 151-16-13]

3.33

masse de référence

point de connexion au potentiel de référence

NOTE 1 Dans certains alinéas de la présente norme, l'expression 'référence de masse' peut être utilisée pour différencier la terre.

NOTE 2 Il ne peut seulement y avoir une terre de référence dans un système de mesure de perturbation conduit.

3.34

mise à la terre pour des raisons de protection

mise à la terre d'un ou de plusieurs points d'un réseau, d'une installation ou d'un matériel pour des raisons de sécurité électrique

[CEI 60050-195:1998, 195-01-11]

3.35

impédance totale en mode commun

impédance TCM, de l'anglais *total common mode*

impédance entre le câble relié à l'accès en essai du matériel en essai et le plan de masse de référence

NOTE Le câble est vu dans sa totalité comme un fil du circuit et le plan de masse comme l'autre fil du circuit. L'onde TCM est le mode de transmission de l'énergie électrique, pouvant conduire à un rayonnement d'énergie électrique si le câble est exposé dans l'application réelle. Réciproquement, c'est également le mode dominant, résultant d'une exposition du câble à des champs électromagnétiques extérieurs.

3.36

réseau fictif asymétrique

AAN, de l'anglais *asymmetric artificial network*

réseau utilisé pour mesurer (ou injecter) des tensions asymétriques (en mode commun) sur des lignes symétriques de signaux non blindées (par exemple, de télécommunication) en rejetant le signal symétrique (en mode différentiel)

NOTE 1 Un AAN est un AN (réseau fictif) permettant de simuler la charge asymétrique constituée par le réseau de télécommunications.

NOTE 2 Le terme « réseau en Y » est synonyme d'AAN.

NOTE 3 L'AAN peut également être utilisé pour les essais d'immunité lorsque le récepteur de mesure d'accès devient l'accès d'injection des perturbations.

4 Types de perturbations à mesurer

4.1 Généralités

Le présent article décrit la classification des différents types de perturbations et les détecteurs adaptés à leur mesure.

4.2 Types de perturbations

Pour des raisons physiques et psychophysiques dépendantes de la distribution spectrale, de la largeur de bande du récepteur de mesure, de la durée, du rythme d'apparition et du degré de nuisance lors de l'estimation et de la mesure des perturbations radioélectriques, on effectue une distinction entre les types de perturbations suivants:

- a) *perturbations continues à bande étroite*, c'est-à-dire sur des fréquences discrètes, comme par exemple les composantes fondamentales et les harmoniques produits intentionnellement pour générer l'énergie RF dans les matériels ISM, constituant un spectre de fréquences composé uniquement de raies spectrales individuelles dont la séparation est supérieure à la largeur de bande du récepteur de mesure de manière qu'une seule raie s'inscrive dans la largeur de bande au cours de la mesure, par opposition à b);
- b) *perturbations continues à large bande*, normalement produites non intentionnellement par les impulsions répétées, par exemple de moteurs à collecteur, et présentant une fréquence de répétition inférieure à la largeur de bande du récepteur de mesure de manière qu'une seule raie spectrale s'inscrive dans la largeur de bande au cours de la mesure; et

- c) *perturbations discontinues à large bande* produites également non intentionnellement par des commutations mécaniques ou électroniques, comme par exemple les thermostats ou programmeurs avec un taux de répétition inférieur à 1 Hz (taux de claquement inférieur à 30/min).

Les spectres de fréquences de b) et c) se caractérisent par un spectre continu, dans le cas d'impulsions individuelles (uniques), et par un spectre discontinu, dans le cas d'impulsions répétées, les deux spectres étant caractérisés par une bande de fréquences plus large que celle du récepteur de mesure spécifié dans la CISPR 16-1-1.

4.3 Fonctions de détection

En fonction du type de perturbation, il est possible d'effectuer les mesures au moyen d'un récepteur équipé des détecteurs suivants:

- a) détecteur de valeur moyenne utilisé généralement pour la mesure des perturbations à bande étroite et des signaux, en particulier pour différencier les perturbations à bande étroite des perturbations à large bande;
- b) détecteur de quasi-crête utilisé pour la mesure pondérée des perturbations à large bande permettant l'évaluation des nuisances audibles pour un auditeur radiophonique, mais également des perturbations à bande étroite;
- c) ~~détecteur de crête susceptible d'être utilisé pour la mesure des perturbations soit à large bande, soit à bande étroite.~~ détecteur de valeur efficace-moyenne utilisé pour la mesure pondérée des perturbations à large bande permettant l'évaluation de l'effet des perturbations impulsives sur des services de radiocommunication numérique, mais également des perturbations à bande étroite;
- d) un détecteur de crête qui peut être utilisé soit pour des mesures de perturbations à bandes larges soit à bandes étroites.

Les récepteurs de mesure comportant ces détecteurs sont spécifiés dans la CISPR 16-1-1.

5 Connexion du matériel de mesure

5.1 Généralités

Le présent article décrit la connexion du matériel de mesure, des récepteurs de mesure et de l'équipement d'appoint tels que réseaux fictifs (AN) et les sondes de tension et de courant.

5.2 Connexion de l'équipement d'appoint

Le câble de connexion entre le récepteur de mesure et l'équipement d'appoint doit être blindé et son impédance caractéristique doit être adaptée à l'impédance d'entrée du récepteur de mesure. Le résultat de mesure doit tenir compte de l'atténuation due au câble de connexion.


La sortie de l'équipement d'appoint doit être fermée par l'impédance prescrite. Une atténuation minimale de 10 dB entre la sortie de l'AN et l'entrée du récepteur de mesure est exigée pour satisfaire à la tolérance spécifiée de l'impédance de l'AN au niveau de son accès du côté matériel en essai. Cette atténuation peut être intégrée dans l'AN. Pour la protection des circuits d'entrée du récepteur, il est recommandé d'utiliser un limiteur de transitoires. Il doit être conçu pour fournir des signaux ayant un niveau maximal à l'entrée du récepteur sans créer d'effets non linéaires.

5.3 Connexions à la masse de référence RF

Le réseau fictif (AN) doit être connecté à la masse de référence par une impédance RF faible, par exemple en reliant directement le boîtier du réseau AN à la masse de référence ~~ou au mur de référence~~ d'une cage de Faraday, ou avec un conducteur de faible impédance aussi court et large que possible en pratique (dont le rapport de la longueur maximale sur la largeur est 3:1 et dont l'inductance est inférieure à environ 50 nH, correspondant à une impédance inférieure à environ 10 Ω à 30 MHz). Il est recommandé d'effectuer un essai in-situ du facteur de division en tension comme expliqué dans l'Annexe E. Ceci permettra de détecter par exemple une résonance de liaison de masse dans la mise à la masse de l'AN.

NOTE Un conducteur de section rectangulaire (voir dessin ci-après): d'une longueur $l = 30$ cm, d'une largeur $b = 3$ cm, d'une épaisseur $c = 0,02$ cm donnera une inductance L d'environ 210 nH ($X_L = 40$ Ω à 30 MHz), qui est excessive. La valeur de L a été calculée en utilisant l'équation ci-dessous:

$$L = 2 \times l \times \left(\ln \frac{2l}{b+c} + 0,5 + 0,22 \frac{b+c}{l} \right)$$



où

L est l'inductance du conducteur en nH

l, b, c sont les dimensions du conducteur en cm

Si une telle longueur ne peut pas être évitée, la largeur doit être aussi grande que possible.

Les mesures de tension aux bornes doivent être uniquement effectuées par rapport à la masse de référence. Les boucles de masse (couplage d'impédance de raccordement) doivent être évitées. Les boucles de masse entraîneront une reproductibilité médiocre des mesures et peuvent par exemple être détectées si les composantes mises à la masse d'un montage d'essai sont sensibles au toucher. Il convient également d'observer ceci pour les matériels de mesure (par exemple récepteurs de mesure et les équipements d'appoint connectés, tels qu'oscilloscopes, analyseurs, enregistreurs, etc.) équipés d'un conducteur de terre de protection (PE) de classe de protection I. Les appareils de mesure doivent être équipés d'une isolation RF de manière à ce que l'AN n'ait qu'une connexion RF à la masse. Ceci peut être obtenu avec des bobines RF et des transformateurs d'isolement ou en alimentant les appareils de mesure avec des batteries. La Figure 1 illustre un exemple de montage d'essai recommandé avec trois réseaux fictifs d'alimentation et des bobines PE permettant d'éviter les boucles de masse. Sur cette figure, le câble de connexion RF entre le récepteur et le réseau fictif d'alimentation peut agir comme liaison de masse si le récepteur est mis à la masse. Par conséquent, il est nécessaire de disposer d'une bobine PE au niveau de l'entrée d'alimentation du récepteur ou bien, si le récepteur ne se trouve pas dans une cage de Faraday, d'un suppresseur de courant de gaine sur le câble de connexion. Ainsi, chaque réseau fictif d'alimentation est mis à la masse RF une seule fois.




Figure 1 – Exemple d'un montage d'essai recommandé avec bobines PE, trois réseaux fictifs d'alimentation et un absorbeur de courant de gaine sur le câble RF

Pour des raisons de sécurité, en cas de défaut, les bobines PE doivent présenter une faible impédance pour la tension d'alimentation, à fréquence et tension industrielles. La tension de court circuit aux bornes de la bobine PE doit être inférieure à 4 V. Il est admis que les bobines PE soient intégrées dans le réseau fictif d'alimentation.

Il convient que l'impédance RF des bobines PE et des absorbeurs de courant de gaine dans la gamme de fréquences des mesures soit élevée par rapport à l'impédance de la connexion du réseau fictif d'alimentation au plan de masse de référence (RGP). Les bobines PE disponibles sur le marché ont, par exemple, une inductance de 1,6 mH pour des intensités nominales allant jusqu'à 36 A, mais celles-ci ne sont pas normalisées dans la CISPR 16-1-2. L'atténuation peut être vérifiée conformément à l'Annexe E. Certains réseaux fictifs d'alimentation sont disponibles avec des bobines PE intégrées. Il faut minimiser la différence de potentiel entre PE et RGP pour éviter toute saturation des bobines PE par le courant continu ou à basse fréquence qui en résulte et qui traverse les bobines. Si ce courant n'est pas connu, il peut être mesuré.

NOTE – Les courants de gaine sont des courants RF circulant sur l'écran de câbles (par exemple coaxiaux) blindés et sont une source d'incertitude des mesures. Les absorbeurs de courant de gaine ont pour but de réduire ces courants.

Pour le traitement de la connexion PE du matériel en essai à la masse de référence, voir A.4.

Les configurations d'essai fixes de réseaux fictifs d'alimentation ne nécessitent pas de connexion au conducteur de terre de protection si la masse de référence est connectée directement et satisfait aux exigences de sécurité relatives aux conducteurs de terre de protection (connexions PE).

5.4 Connexion entre le matériel en essai et le réseau fictif d'alimentation (AMN)

Les grandes lignes concernant le choix des connexions du matériel en essai au réseau AMN, avec ou sans mise à la masse, sont exposées à l'Annexe A.

6 Exigences et conditions générales de mesure

6.1 Généralités

Dans les limites d'incertitude admises par la CISPR 16-4-2, les mesures de perturbations radioélectriques doivent être:

- reproductibles, c'est-à-dire indépendantes de leur emplacement et des conditions environnementales, en particulier du bruit ambiant;
- dénuées d'interactions, c'est-à-dire que la connexion du matériel en essai au matériel de mesure ne doit influencer ni le fonctionnement du matériel en essai ni la précision du matériel de mesure.

Ces exigences sont susceptibles d'être satisfaites si l'on observe les conditions suivantes:

- a) existence d'un rapport signal/bruit suffisant au niveau de mesure souhaité, par exemple au niveau de la limite de perturbation appropriée;
- b) définition de l'installation de mesure, des conditions de raccordement et de fonctionnement du matériel en essai;
- c) dans le cas de mesure avec une sonde de tension sur le réseau d'alimentation, la sonde doit avoir une tension de 1,5 k Ω , comme spécifié dans la CISPR 16-1-2; pour des mesures sur d'autres circuits, il est admis qu'il soit nécessaire d'augmenter l'impédance (fournie par exemple par des sondes de tension actives) pour éviter une surcharge excessive des circuits à impédance élevée;
- d) dans le cas de mesures avec une sonde de tension, la sonde doit avoir une impédance dans le circuit de mesure de 1 Ω maximum, comme spécifié dans la CISPR 16-1-2;

~~e) dans le cas de l'utilisation d'un analyseur de spectre ou d'un récepteur à balayage, ses exigences spécifiques de fonctionnement et d'étalonnage doivent faire l'objet d'une attention particulière.~~

6.2 Perturbation non produite par le matériel à l'essai

6.2.1 Généralités

Le rapport signal/bruit de mesure, par rapport au bruit ambiant, doit satisfaire aux exigences suivantes. Si le bruit ~~parasite ambiant~~ dépasse le niveau requis, il doit être enregistré dans le rapport d'essai.

6.2.2 Essais de conformité

Un site d'essai doit permettre de distinguer les émissions du matériel en essai du bruit ambiant. Il convient que le niveau de bruit ambiant soit d'au moins 20 dB inférieur à la limite spécifiée. Pour les essais in-situ, il convient que le niveau de bruit ambiant soit d'au moins 6 dB inférieur à la limite spécifiée. Dans le cas des essais in-situ, le bruit d'émission plus le bruit ambiant ne doivent pas dépasser la limite. Si le bruit d'émission plus le bruit ambiant dépassent la limite, on doit prendre d'autres mesures, comme par exemple réduire la largeur de bande, appliquer des dispositions de suppression du bruit ambiant, modifier la fréquence, etc (l'Annexe A de la CISPR 16-2-3:2006 fournit des recommandations pour la mesure des perturbations en présence d'émissions de bruit ambiant). Il est permis de déterminer l'adéquation de l'emplacement pour le niveau ambiant autorisé en effectuant une mesure du niveau de bruit ambiant avec le matériel en essai en place mais hors fonctionnement.

6.3 Mesure d'une perturbation continue

6.3.1 Perturbation continue à bande étroite

Le réglage du récepteur de mesure doit être maintenu sur la fréquence discrète examinée et modifié si la fréquence fluctue.

6.3.2 Perturbation continue à large bande

Pour estimer une perturbation continue à large bande dont le niveau est fluctuant, on doit trouver la valeur maximale reproductible de la mesure. Voir 6.5.1 pour plus de détails.

6.3.3 Utilisation d'analyseurs de spectre et de récepteurs à balayage

Les analyseurs de spectre et les récepteurs à balayage sont utiles pour mesurer les perturbations, particulièrement afin de réduire le temps de mesure. Il faut cependant accorder une attention particulière à certaines caractéristiques de ces instruments, notamment: la surcharge, la linéarité, la sélectivité, la réponse normale aux impulsions, la vitesse de balayage en fréquence, l'interception du signal, la sensibilité, la précision en amplitude et la détection crête, de valeur moyenne et quasi-crête. Ces caractéristiques sont examinées à l'Annexe B.

6.4 Disposition et conditions de fonctionnement mesure du matériel en essai

6.4.1 Généralités Disposition du matériel en essai

~~Le matériel en essai doit fonctionner dans les conditions suivantes:~~

6.4.1.1 Généralités

~~Lorsque cela n'est pas spécifié dans la norme de produit, le matériel en essai doit être configuré comme décrit dans les alinéas suivants.~~

~~Le matériel en essai doit être installé, disposé et doit fonctionner d'une façon compatible avec ses applications types. Lorsque le fabricant a spécifié ou recommandé une pratique d'installation, cette pratique doit être utilisée dans la disposition d'essai, lorsque la pratique le permet. Cette disposition doit être typique d'une pratique d'installation normale. Les câbles, charges et dispositifs d'interface doivent être connectés à au moins un des accès d'interface de chaque type du matériel en essai et, lorsque la pratique le permet, chaque câble doit être raccordé à un dispositif représentatif d'une utilisation réelle.~~

~~Lorsqu'il y a des accès multiples du même type, il peut être nécessaire d'ajouter au matériel en essai des câbles, charges ou dispositifs, selon les résultats des essais préliminaires. Il convient de limiter le nombre de câbles ou fils supplémentaires du même type à condition que l'ajout d'un autre câble ou fil ne change pas significativement le niveau d'émission, c'est-à-dire ne le fasse pas varier de plus de 2 dB, du moment que le matériel en essai reste conforme. Les explications concernant le choix de la configuration et les dispositifs reliés aux accès doivent être données dans le rapport d'essai.~~

~~Il convient que les câbles d'interconnexion soient du type et de la longueur spécifiés dans le cahier des charges du matériel particulier. Si la longueur peut être modifiée, celle qui produit l'émission maximale doit être retenue.~~

~~Si des câbles blindés ou spéciaux sont utilisés lors des essais pour obtenir la conformité, une note doit être incluse dans le manuel d'instructions indiquant la nécessité d'utiliser de tels câbles.~~

~~Les longueurs excessives de câbles doivent être regroupées en faisceaux approximativement au centre du câble, chaque faisceau mesurant 30 cm à 40 cm de longueur. S'il n'est pas possible de procéder ainsi en raison de l'encombrement ou de la rigidité des câbles, la disposition du câble en excès doit être notée précisément dans le rapport d'essai.~~

~~Lorsqu'il y a plusieurs accès d'interface du même type, la connexion d'un câble à un seul accès de ce type est suffisante, à condition que l'on puisse démontrer que les câbles additionnels n'ont pas d'influence significative sur les résultats.~~

Tout ensemble de résultats doit être accompagné d'une description complète de l'orientation des câbles et du matériel de façon à pouvoir reproduire les résultats. Si des conditions spécifiques d'utilisation sont nécessaires pour satisfaire aux limites, elles doivent être spécifiées et documentées, par exemple, la longueur de câble, le type de câble, le blindage et la mise à la masse. Ces conditions doivent être incluses dans les instructions fournies à l'utilisateur.

Un matériel qui comporte un grand nombre de modules (par exemple des tiroirs et des cartes enfichables) doit être essayé avec un mélange et un nombre représentatifs de ce qui est utilisé dans une installation type. Il convient de limiter le nombre de modules ou de cartes enfichables du même type à condition que l'ajout d'un autre module ou carte enfichable ne change pas significativement le niveau d'émission, c'est-à-dire ne le fasse pas varier de plus de 2 dB, à condition que le matériel en essai reste conforme. Il convient de mentionner dans le rapport d'essai les explications concernant le choix du nombre et du type de modules.

Un système constitué d'un certain nombre d'unités distincts doit être configuré de manière à constituer une configuration représentative minimale. Le nombre et le mélange d'unités inclus dans la configuration d'essai doivent être normalement représentatifs de ce qui est utilisé dans une installation type. Il convient de mentionner dans le rapport d'essai les explications concernant le choix des unités.

Un module de chaque type doit être fonctionnel dans chaque matériel évalué dans un EST. Pour un matériel en essai comprenant un système, un de chaque type de matériel pouvant être inclus dans une configuration possible du système doit être inclus dans le matériel en essai.

Les résultats d'évaluation des matériels en essai comportant un module de chaque type peuvent être appliqués à des configurations comportant plus d'un de chaque modules.

NOTE Il a été constaté que les perturbations provenant de modules identiques ne s'additionnent généralement pas dans la pratique.

La position du matériel en essai par rapport au plan de masse de référence doit être équivalente à celle qui est utilisée. En conséquence, un matériel posé au sol est placé sur un plan de masse de référence, isolé de celui-ci, et un matériel de table est placé sur une table non conductrice.

Les matériels conçus pour être montés contre un mur doivent être soumis à l'essai comme un matériel en essai sur table. L'orientation du matériel doit être cohérente avec une pratique d'installation normale.

Des combinaisons de types de matériel identifiés ci-dessus doivent également être disposées d'une manière qui corresponde à une pratique d'installation normale. Un matériel conçu pour fonctionner à la fois sur une table et posé au sol doit être soumis à essai comme un appareil de table, à moins que l'installation habituelle soit posée au sol, dans ce cas cette disposition doit être utilisée.

Les extrémités des câbles de signaux reliés au matériel en essai qui ne sont pas connectées à une autre unité ou à un autre matériel auxiliaire (AuxEq) doivent être raccordées en utilisant l'impédance de terminaison correcte définie dans la norme de produit. Si aucune norme de produit ne peut être appliquée à la configuration particulière, la terminaison doit être définie par le fabricant du matériel en essai et indiquée dans le rapport d'essai.

Les câbles ou autres connexions à un matériel auxiliaire situé en dehors de la zone d'essai doivent descendre jusqu'au sol et être ensuite acheminés jusqu'à l'emplacement où ils quittent le site d'essai.

L'installation d'un matériel auxiliaire (AuxEq) doit être conforme à la pratique d'installation normale. Cela signifie que le matériel auxiliaire (AuxEq) se trouvant sur le site d'essai doit être disposé en utilisant les mêmes conditions que celles qui sont applicables au matériel en essai (par exemple, distance par rapport au plan de masse et isolation par rapport au plan de masse s'il repose sur le sol, disposition du câblage).

6.4.1.2 Disposition d'un matériel de table

Un matériel prévu pour être utilisé sur une table doit être placé sur une table non conductrice. Les dimensions de la table seront nominale de 1,5 m sur 1,0 m mais peuvent finalement dépendre des dimensions horizontales du matériel en essai.

Les câbles entre les unités doivent pendre à l'arrière de la table. Si un câble pend à moins de 0,4 m du plan de masse horizontal (ou du sol), l'excédent doit être plié au centre du câble en un faisceau de longueur inférieur à 0,4 m, de telle sorte que le faisceau soit à une distance d'au moins 0,4 m au-dessus du plan de masse de référence horizontal.

Les câbles doivent être positionnés comme pour une utilisation normale.

Si le câble d'entrée de l'accès « alimentation » a une longueur inférieure à 0,8 m (en incluant les alimentations incorporées dans la fiche d'alimentation électrique), un cordon prolongateur doit être utilisé de telle sorte que l'alimentation extérieure soit posée sur la table. Le cordon prolongateur doit avoir des caractéristiques similaires à celles du câble d'alimentation électrique (ce qui inclut le nombre de conducteurs et la présence d'une connexion de terre). Le cordon prolongateur doit être traité comme s'il faisait partie du câble d'alimentation électrique.

Dans les dispositions ci-dessus, le câble situé entre le matériel en essai et l'accessoire d'alimentation doit être disposé sur la table de la même manière que les autres câbles reliant les composants du matériel en essai.

6.4.1.3 Disposition d'un matériel posé au sol

Le matériel en essai doit être placé sur le plan de masse de référence horizontal, orienté pour une utilisation normale, mais l'isolation entre les contacts métalliques et le plan de masse de référence doit être de 15 cm maximum.

Les câbles doivent être isolés (jusqu'à 15 cm) du plan de masse de référence horizontal. Si le matériel nécessite une connexion de terre dédiée, celle-ci doit être prévue et fixée au plan de masse horizontal.

Les câbles entre les unités (entre les unités constituant le matériel en essai ou entre le matériel en essai et tout matériel auxiliaire) doivent descendre jusqu'au plan de masse horizontal de référence, mais demeurer isolés de ce dernier. Tout excédent doit être replié au centre du câble en un faisceau ne dépassant pas 0,4 m de longueur ou être agencé en forme de serpent. Si la longueur d'un câble entre les unités n'est pas suffisamment grande pour descendre jusqu'au plan de masse horizontal de référence mais descend jusqu'à moins de 0,4 m, la partie en excès doit être repliée au centre du câble en un faisceau ne dépassant pas 0,4 m de longueur. Le faisceau doit être disposé de telle sorte qu'il soit à 0,4 m au-dessus du plan de masse horizontal de référence ou à la hauteur du point d'entrée ou du point de connexion du câble si celui-ci est à moins de 0,4 m du plan de masse horizontal de référence.

Pour un matériel muni de support vertical de câbles, le nombre de supports doit être typique de la pratique d'une installation. Si le support est réalisé en matériau non conducteur, une distance minimale d'au moins 0,2 m doit être maintenue entre la partie la plus proche du matériel et le câble vertical le plus proche. Si la structure du support est conductrice, la distance minimale de 0,2 m doit se trouver entre les parties les plus proches du matériel et la structure du support.

6.4.1.4 Disposition de combinaisons de matériel de table et posé au sol

Les câbles entre les unités situées entre un matériel de table et un matériel posé au sol doivent voir leur excédent replié en un faisceau dont la longueur n'est pas supérieure à 0,4 m. Le faisceau doit être mis en place de sorte qu'il soit à 0,4 m au-dessus du plan de masse de référence horizontal soit à la hauteur du point d'entrée ou de connexion du câble si celui-ci est à moins de 0,4 m du plan de masse de référence horizontal.

6.4.2 Conditions de charge normales

Les conditions de charge normales doivent être celles définies dans la spécification de produit correspondant au matériel en essai; pour les matériels en essai qui ne sont pas couverts, elles doivent correspondre aux instructions du fabricant.

6.4.3 Durée de fonctionnement

La durée de fonctionnement (durée pendant laquelle les émissions peuvent être mesurées), dans le cas des matériels en essai à durée de fonctionnement assignée donnée, doit être conforme au marquage; dans tous les autres cas, il n'y a pas de limite de durée.

6.4.4 Durée de fonctionnement préalable/de préchauffage

Aucune durée de fonctionnement préalable/de préchauffage particulière n'est spécifiée mais, avant d'effectuer les mesures, le matériel en essai doit avoir fonctionné pendant un temps suffisant pour que ses modes et conditions de fonctionnement (par exemple température de fonctionnement atteinte, chargement du logiciel terminé et matériel en essai prêt à remplir sa fonction prévue) soient représentatifs de ceux qui se présentent au cours de la vie normale du matériel. L'expression «durée de fonctionnement préalable» s'applique aux matériels en essai qui comportent des moteurs électriques. Pour certains matériels en essai, il est possible que des conditions d'essai spéciales soient prescrites dans la documentation appropriée des produits.

6.4.5 Alimentation

Le matériel en essai doit être alimenté à sa tension assignée. Les matériels en essai prévus pour plusieurs tensions assignées doivent être soumis aux essais à la tension assignée qui provoque la perturbation maximale. Les normes de produit peuvent exiger des mesures supplémentaires si, par exemple, les niveaux des perturbations varient de manière importante avec la tension d'alimentation.

6.4.6 Mode de fonctionnement

Le matériel en essai doit fonctionner dans les conditions d'utilisation prévues par le fabricant qui provoquent la perturbation maximale à la fréquence de mesure.

6.4.7 Fonctionnement d'un matériel à fonctions multiples

Un matériel à fonctions multiples, qui est couvert à la fois par différents articles d'une norme de produit et/ou de normes différentes, doit être essayé avec chaque fonction opérant de manière isolée si cela peut être obtenu sans modification interne de l'équipement. L'équipement ainsi soumis à essai doit être considéré comme satisfaisant aux exigences de tous les articles/normes lorsque chacune de ses fonctions aura satisfait aux exigences de l'article/norme correspondant.

Lorsqu'il n'est en pratique pas possible d'effectuer les essais avec chaque fonction opérant séparément, ou si la séparation d'une fonction particulière pourrait empêcher l'appareil de remplir sa fonction principale, ou encore si l'opération simultanée de plusieurs fonctions pourrait conduire à un gain de temps de mesure, on doit considérer que l'appareil est conforme s'il remplit les dispositions des articles/des normes applicables lorsque les fonctions nécessaires sont activées.

6.4.8 Détermination de la ou des disposition(s) d'émission maximale

Les essais initiaux doivent permettre d'identifier la fréquence pour laquelle les perturbations sont les plus élevées par rapport à la limite. Cette identification doit être réalisée alors que l'appareil en essai présente un mode de fonctionnement typique et une position des câbles dans une disposition d'essai représentative d'une pratique d'installation typique.

La fréquence des perturbations les plus élevées par rapport à la limite doit être déterminée en caractérisant les perturbations pour un nombre de fréquences significatives. Ceci fournit la certitude que les fréquences probables pour lesquelles les perturbations sont maximales ont été déterminées et que les câbles associés, la disposition de l'appareil en essai et son mode de fonctionnement ont été identifiés.

Pour effectuer l'essai initial, il convient de disposer le matériel en essai conformément aux normes de produit, comme approprié.

6.4.9 Enregistrement des mesures

Parmi les perturbations supérieures à $(L - 20 \text{ dB})$, où L représente la limite en $\text{dB}(\mu\text{V})$ ou $\text{dB}(\mu\text{A})$, les niveaux et les fréquences d'au moins les six perturbations les plus fortes et ayant la marge la plus petite à la limite L doivent être enregistrés.

De plus, le rapport de test doit inclure la valeur de l'incertitude de l'instrumentation de mesure correspondant à la configuration utilisée durant l'essai, calculée selon les exigences de CISPR 16-4-2.

6.5 Interprétation des résultats de mesure

6.5.1 Perturbations continues

- a) A chaque fréquence à laquelle le niveau de perturbation est proche de la limite et n'est pas stable, la lecture sur le récepteur de mesure est observée pendant au moins 15 s pour chaque mesure; les valeurs lues les plus élevées doivent être enregistrées. Certaines normes de produits permettent l'exclusion de claquements isolés, qui doivent être ignorés (voir la CISPR 14-1).
- b) Si le niveau général de perturbations n'est pas stable mais présente une augmentation ou une diminution continue supérieure à 2 dB pendant une période de 15 s, alors les niveaux de tension perturbatrice doivent être observés pendant une période plus longue et doivent être interprétés en fonction des conditions normales d'utilisation du matériel en essai, comme suit:
 - 1) si le matériel en essai est susceptible d'être allumé ou éteint fréquemment ou si le sens de la rotation peut être inversé, il convient alors, à chaque fréquence de mesure, d'allumer ou d'inverser le matériel en essai juste avant chaque mesure, puis de l'éteindre juste après. Le niveau maximal obtenu durant la première minute, à chaque fréquence de mesure, doit être enregistré;
 - 2) si le matériel en essai est habituellement utilisé pendant des durées supérieures, il convient alors de le laisser allumé pendant toute la durée de l'essai; on doit enregistrer, à chaque fréquence, le niveau de perturbations mais seulement après avoir obtenu une lecture stable (soumise aux dispositions du point a).
- c) Si la nature des perturbations du matériel en essai passe d'un caractère stable à un caractère aléatoire au cours d'un essai, le matériel en essai doit alors être soumis à des essais conformément au point b).
- d) Les mesures sont effectuées sur le spectre complet et enregistrées au moins à la fréquence qui offre la lecture la plus grande, comme requis dans la publication CISPR appropriée.

6.5.2 Perturbations discontinues

La mesure des perturbations discontinues peut être effectuée à un nombre restreint de fréquences. Pour plus de détails, voir la CISPR 14-1.

6.5.3 Mesure de la durée des perturbations

~~Pour une mesure correcte des perturbations et pour décider si ces perturbations sont discontinues, leur durée doit être connue et par conséquent, il est possible qu'il faille la mesurer. Le matériel en essai est connecté à l'AN approprié. Si le récepteur de mesure est disponible, il est connecté au réseau et un oscilloscope est connecté à la sortie en fréquence intermédiaire du récepteur de mesure. Il est également possible d'utiliser la fonction « intervalle nul » ou la fonction « analyse temporelle » d'un récepteur de mesure (voir la Figure 3). S'il n'y a pas de récepteur disponible, l'oscilloscope est directement connecté au réseau. La base de temps de l'oscilloscope peut être déclenchée par les perturbations à mesurer; la vitesse de la base de temps est choisie entre 1 ms/div et 10 ms/div pour les matériels en essai à commutation instantanée et entre 10 ms/div et 200 ms/div pour les autres matériels en essai. La durée de la perturbation peut être enregistrée directement par un oscilloscope numérique, et/ou par copie d'écran.~~

La durée d'une perturbation doit être connue pour la mesurer correctement et pour déterminer si elle est discontinue. La durée d'une perturbation peut être mesurée selon l'une des manières suivantes:

- en connectant un oscilloscope à la sortie FI (fréquence intermédiaire) d'un récepteur de mesure pour pouvoir surveiller la perturbation dans le domaine temporel;
- en syntonisant un récepteur de perturbations électromagnétiques ou un analyseur de spectre sur la fréquence de la perturbation sans balayage de fréquence (c'est-à-dire, en mode « intervalle nul ») pour pouvoir surveiller la perturbation dans le domaine temporel; ou
- en utilisant la sortie dans le domaine temporel d'un récepteur de mesure à FFT.

On peut trouver en 8.3 des indications sur la détermination de la durée de mesure appropriée.

6.6 Temps de mesure et vitesses de balayage pour les perturbations continues

6.6.1 Généralités

Pour les mesures manuelles, automatiques ou semi-automatiques, les temps de mesure et les vitesses de balayage des récepteurs de mesure et des récepteurs à balayage doivent être réglés afin de mesurer les émissions maximales. Plus spécialement, lorsqu'un détecteur de crête est utilisé pour un pré-balayage, les temps de mesure et les vitesses de balayage doivent prendre en compte le rythme de l'émission à mesurer. On peut trouver à l'Article 8 des informations plus détaillées sur l'exécution des mesures automatiques.

6.6.2 Temps de mesure minimaux

~~Le Paragraphe B.7 de la présente norme donne un tableau des durées de balayage minimales nécessaires pour réaliser les mesures sur la gamme de fréquence indiquée. A partir de ce tableau, on a déduit les durées de balayage minimales pour effectuer les mesures dans la bande CISPR complète:~~

Les durées (de maintien) de mesure minimales sont données dans le Tableau 2. Les durées (de maintien) de mesure minimales pour les récepteurs à balayage et les instruments de mesure à FFT du Tableau 2 et les durées de balayage pour les analyseurs de spectre du Tableau 1 s'appliquent à des signaux en ondes entretenues (CW). Les durées de balayage minimales du Tableau 1 sont dérivées des mesures effectuées sur l'intégralité de la bande de fréquence du CISPR.

Tableau 1 – Durées de balayage minimales pour les trois bandes CISPR avec détecteur de crête et détecteur de quasi-crête

Bande de fréquences		Durée de balayage T_s pour une détection de crête	Durée de balayage T_s pour une détection de quasi-crête
A	9 kHz – 150 kHz	14,1 s	2 820 s = 47 min
B	0,15 MHz – 30 MHz	2,985 s	5 970 s = 99,5 min = 1 h 39 min
C/D	30 MHz – 1 000 MHz	0,97 s	19 400 s = 323,3 min = 5 h 23 min

Tableau 2 – Durées de mesure minimales pour les quatre bandes de la CISPR

Bande de fréquences		Durées de mesure minimales T_m
A	9 kHz à 150 kHz	10,00 ms
B	0,15 MHz à 30 MHz	0,50 ms
C et D	30 MHz à 1 000 MHz	0,06 ms
E	1 GHz à 18 GHz	0,01 ms

~~Les durées de balayage du Tableau 1 s'appliquent pour des signaux en onde entretenue.~~ En fonction du type de perturbation, on peut avoir à augmenter la durée de balayage, notamment pour des mesures quasi-crête par balayage. Dans des cas extrêmes, il peut être nécessaire d'augmenter à 15 s le temps de mesure T_m à une certaine fréquence, si le niveau de l'émission observée n'est pas stable (voir 6.5.1 ci-dessus).

On peut trouver à l'Annexe D les durées de mesure et les vitesses de balayage utilisables avec un détecteur de valeur moyenne.

La plupart des normes de produits font appel à la détection quasi-crête pour les mesures de conformité, ce qui prend beaucoup de temps si aucune procédure de réduction du temps de mesure n'est appliquée (voir l'Article 8). Avant qu'une procédure de réduction du temps de mesure ne soit appliquée, l'émission doit être détectée par un pré-balayage. Afin d'éviter que, par exemple, des signaux intermittents ne soient oubliés pendant un balayage automatique, il est nécessaire de prendre en compte les considérations de 6.6.3 à 6.6.5.

6.6.3 Vitesses de balayage des récepteurs à balayage et des analyseurs de spectre

Il est nécessaire qu'une des deux conditions suivantes soit remplie pour s'assurer que des signaux ne sont pas oubliés pendant le balayage automatique sur les intervalles de fréquences.

- pour un balayage unique: la durée de mesure à chaque fréquence doit être supérieure aux intervalles entre les impulsions pour les signaux intermittents;
- pour des balayages multiples avec maintien du maximum: il convient que la durée d'observation à chaque fréquence soit suffisante pour intercepter des signaux intermittents.

La vitesse de balayage en fréquences est limitée par la largeur de bande de résolution de l'instrument et les réglages de la largeur de bande vidéo. Si la vitesse de balayage choisie est trop rapide pour un état donné de l'instrument, on obtiendra des résultats de mesure erronés. En conséquence, il est nécessaire de choisir une durée de balayage suffisamment longue, comme définie ci-après, pour l'intervalle de fréquences considéré. Les signaux intermittents peuvent être interceptés soit par un simple balayage avec une durée d'observation suffisamment longue à chaque fréquence, soit par des balayages multiples avec maintien du maximum. Généralement pour une vue d'ensemble d'émissions inconnues, la seconde solution sera particulièrement efficace: tant que l'affichage du spectre se modifie, il peut

exister encore des signaux intermittents à découvrir. La durée d'observation doit être choisie en fonction de la périodicité à laquelle les signaux perturbateurs apparaissent. Dans certains cas, une modification de la vitesse de balayage peut s'avérer nécessaire pour éviter des effets de synchronisation.

Lorsque l'on détermine la durée de balayage minimale pour les mesures avec un analyseur de spectre ou un récepteur de perturbations électromagnétiques à balayage, sur la base d'un réglage donné de l'instrument et en utilisant une détection de crête, on doit considérer deux différents cas. Si la largeur de bande vidéo choisie est **plus large** que la largeur de bande de résolution, l'expression suivante peut être utilisée pour calculer la durée de balayage minimale:

$$T_{s \min} = (k \times \Delta f) / (B_{\text{res}})^2 \quad (1)$$

où

$T_{s \min}$ est la durée de balayage minimale

Δf est l'intervalle de fréquences

B_{res} est la largeur de bande de résolution

k est la constante de proportionnalité, relative à la forme du filtre de résolution; cette constante a une valeur estimée entre 2 et 3 pour des filtres pratiquement gaussiens, à accord synchrone. Pour des filtres pratiquement rectangulaires, à accord décalé, k a une valeur entre 10 et 15.

NOTE Des valeurs réelles de k sont disponibles auprès des fabricants. Les valeurs réelles sont normalement prises en compte en mode couplé du microprogramme du récepteur ou de l'analyseur de spectre.

Si la largeur de bande vidéo choisie doit être inférieure ou égale à la largeur de bande de résolution, l'expression suivante peut être utilisée pour calculer la durée de balayage minimale:

$$T_{s \min} = (k \times \Delta f) / (B_{\text{res}} \times B_{\text{video}}) \quad (2)$$

où B_{video} est la largeur de bande vidéo.

La plupart des analyseurs de spectre et des récepteurs de perturbations électromagnétiques à balayage règlent automatiquement la durée de balayage en fonction de l'intervalle de fréquences choisi et des réglages de largeurs de bande. La durée de balayage est réglée pour maintenir un affichage étalonné. La sélection automatique de la durée de balayage peut être annulée si des temps d'observation plus longs sont nécessaires, par exemple pour intercepter des signaux à variation lente.

De plus, pour les balayages répétitifs, le nombre de balayages par seconde est déterminé par la durée de balayage $T_{s \min}$ et la durée de retour (temps nécessaire pour faire revenir l'oscillateur local et pour enregistrer les résultats de mesure, etc.).

6.6.4 Durées de balayage pour les récepteurs à accord par palier

Les récepteurs de perturbations électromagnétiques à accord par palier sont accordés successivement sur des fréquences ponctuelles en utilisant des largeurs de pas pré-définies. Tout en couvrant la gamme des fréquences concernées par légers incréments de fréquence, une durée minimale de maintien à chaque fréquence est nécessaire pour que l'instrument mesure de façon précise le signal d'entrée.

Pour la mesure réelle, il est nécessaire d'avoir un pas de fréquence d'environ 50 % ou moins de la largeur de bande de résolution utilisée (en fonction de la forme du filtre de résolution), pour réduire les incertitudes de mesure dues à la largeur du pas pour les signaux à bande étroite. Avec ces hypothèses, la durée de balayage $T_{s \text{ min}}$ pour un récepteur à accord par palier peut être calculée en utilisant l'équation ci-dessous:

$$T_{s \text{ min}} = T_{m \text{ min}} \times \Delta f / (B_{\text{res}} \times 0,5) \quad (3)$$

où $T_{m \text{ min}}$ est le temps minimal de mesure (de maintien) à chaque fréquence

En plus du temps de mesure, on doit prendre en compte le temps nécessaire au synthétiseur pour passer à la fréquence suivante et pour le logiciel d'enregistrer le résultat de mesure, ce qui est réalisé automatiquement dans la plupart des récepteurs de telle sorte que la durée de mesure choisie soit la durée réelle pour obtenir le résultat de mesure. De plus, le détecteur choisi, par exemple crête ou quasi-crête, détermine également cette durée.


Pour des émissions purement à large bande, on peut augmenter le pas de fréquence. Dans ce cas l'objectif est de déterminer uniquement les valeurs maximales du spectre d'émission.

6.6.5 Stratégies pour une vue d'ensemble du spectre en utilisant le détecteur de crête

Pour chaque mesure par pré-balayage, la probabilité d'intercepter toutes les composantes spectrales critiques du spectre du matériel en essai doit être aussi proche que possible de 100 %. En fonction du type de récepteur de mesure et des caractéristiques de la perturbation, qui peut contenir des éléments à bande étroite et à large bande, deux approches générales sont proposées:

- balayage par pas: la durée (de maintien) de mesure doit être assez longue à chaque fréquence pour mesurer la crête du signal, par exemple pour un signal impulsif, il convient que la durée (de maintien) de mesure soit supérieure à l'inverse de la fréquence de répétition du signal.
- balayage continu: il faut que la durée de mesure soit supérieure aux intervalles entre les signaux intermittents (balayage unique) et le nombre de balayages en fréquence pendant la durée d'observation doit être rendu maximal pour augmenter la probabilité d'interception du signal.

Les Figures 2, 3, 4 et 5 montrent des exemples de la relation entre différents spectres d'émission variant dans le temps et les affichages correspondants sur le récepteur de mesure. Dans les cas des Figures 2, 4 et 5, la partie supérieure de la figure montre la position de la largeur de bande du récepteur selon qu'il balaye le spectre en continu ou par pas.




T_p est l'intervalle de répétition de l'impulsion d'un signal en impulsion. Une impulsion se produit à chaque ligne verticale en fonction de l'échelle de temps de l'affichage (partie supérieure de la figure).

Figure 2 – Mesure d'une combinaison d'un signal à onde entretenue ("Bande étroite") et d'un signal en impulsion ("Large bande") en utilisant des balayages multiples avec maintien du maximum

Si le type d'émission est inconnu, des balayages multiples avec une durée de balayage aussi courte que possible et une détection de crête permettent de déterminer l'enveloppe du spectre. Un balayage unique court est suffisant pour mesurer le contenu d'un signal à bande étroite permanent dans le spectre d'un matériel en essai. Pour les signaux permanents à large bande et les signaux intermittents à bande étroite, des balayages multiples à différentes vitesses de balayage utilisant la fonction «maintien du maximum» peuvent être nécessaires pour déterminer l'enveloppe du spectre. Pour des signaux en impulsion à faible répétition, il est nécessaire d'effectuer de nombreux balayages pour remplir l'enveloppe du spectre de la composante à large bande.

La réduction de la durée de mesure exige une analyse temporelle des signaux à mesurer. Ceci peut être effectué soit avec un récepteur de mesure qui fournit un affichage graphique du signal, utilisé en mode intervalle nul ou en utilisant un oscilloscope branché à la sortie f.i. ou vidéo du récepteur comme cela est illustré par exemple à la Figure 3.




Perturbation d'un collecteur de moteur à courant continu. Compte tenu du nombre de segments du collecteur, la fréquence de répétition des impulsions est élevée (environ 800 Hz) et l'amplitude des impulsions varie fortement. En conséquence, pour cet exemple, la durée (de maintien) de mesure recommandée avec un détecteur de crête est supérieure à 10 ms.

Figure 3 – Exemple d'analyse temporelle

De cette façon, les durées des impulsions et leurs fréquences de répétition peuvent être déterminées et les vitesses de balayage ou les durées de maintien choisies en conséquence :

- pour les perturbations **continues non modulées à bande étroite**, la durée de balayage la plus courte possible pour les réglages choisis de l'instrument peut être utilisée;
- pour les perturbations **purement continues à large bande**, par exemple pour un moteur à allumage commandé, pour des appareils de soudage à l'arc et pour des moteurs à collecteur, un balayage par pas (avec une détection de crête ou même de quasi-crête) peut être utilisé pour un échantillonnage du spectre d'émission. Dans ce cas, la connaissance du type de perturbation est utilisée pour dessiner une courbe polygone représentant l'enveloppe du spectre (voir Figure 4). La largeur du pas doit être choisie de sorte qu'aucune variation significative de l'enveloppe du spectre ne soit oubliée. Une mesure par balayage unique, si elle est effectuée suffisamment lentement, donne également l'enveloppe du spectre;
- pour les perturbations **intermittentes à bande étroite** de fréquences inconnues, on peut utiliser soit des balayages courts et rapides avec la fonction «maintien du maximum» (voir Figure 5) soit un seul balayage lent. Une analyse temporelle peut être nécessaire avant la mesure réelle pour s'assurer d'une interception correcte du signal.

Les perturbations intermittentes à large bande doivent être mesurées avec un analyseur de perturbations conforme à la CISPR 16-1-1. Pour les explications concernant les procédures de mesures liées, voir la CISPR 14-1.



Il convient que la durée (de maintien) de mesure T_m soit supérieure à l'intervalle de répétition des impulsions T_p , qui est l'inverse de la fréquence de répétition des impulsions.

Figure 4 – Spectre large bande mesuré avec un récepteur à accord par palier




Figure 5 – Perturbations intermittentes à bande étroite mesurées en utilisant des balayages courts, rapides et répétitifs avec la fonction «maintien du maximum» pour obtenir une vue d'ensemble du spectre d'émission

NOTE Dans l'exemple ci-dessus, 5 balayages sont nécessaires pour faire apparaître toutes les composantes spectrales. Il peut être nécessaire d'augmenter le nombre de balayages nécessaires ou la durée de balayage, en fonction de la durée des impulsions ou de leur intervalle de répétition.

6.6.6 Considérations temporelles concernant l'utilisation d'appareils de mesure à FFT

Les appareils de mesure à FFT peuvent associer le calcul parallèle à N fréquences et un balayage par incréments. Dans ce but, la plage de fréquences concernée est subdivisée en un certain nombre de segments égaux N_{seg} qui sont balayés en séquence. Le mode opératoire est représenté sur la Figure 19 pour trois segments. La durée totale de balayage pour la plage de fréquences concernées T_{balayage} est calculée de la manière suivante:

$$T_{\text{scan}} = T_m N_{\text{seg}} \quad (4)$$

où

T_m est la durée de mesure pour chaque segment égal et

N_{seg} est le nombre de segments.

Les appareils de mesure à FFT peuvent également fournir des méthodes pour améliorer la résolution en fréquence sur une plage de fréquences donnée. Un appareil de mesure à FFT a généralement un incrément de fréquence fixe $f_{\text{step FFT}}$ qui est déterminé par le nombre de fréquences de la FFT. On obtient une résolution de fréquence accrue en effectuant des calculs répétés sur une plage de fréquences donnée. Pour chaque calcul répété, la fréquence la plus basse est incrémentée d'un rapport d'incrément de $f_{\text{step final}}$.

Ainsi, le premier calcul sur la plage de fréquences donnée utilise les fréquences suivantes:

$$\begin{aligned} &f_{\text{min}}, \\ &f_{\text{min}} + f_{\text{step FFT}}, \\ &f_{\text{min}} + 2f_{\text{step FFT}}, \\ &f_{\text{min}} + 3f_{\text{step FFT}} \dots \end{aligned}$$

Le deuxième calcul sur la plage de fréquences donnée utilise les fréquences suivantes:

$$\begin{aligned} &f_{\text{min}} + f_{\text{step final}}, \\ &f_{\text{min}} + f_{\text{step final}} + f_{\text{step FFT}}, \\ &f_{\text{min}} + f_{\text{step final}} + 2f_{\text{step FFT}}, \\ &f_{\text{min}} + f_{\text{step final}} + 3f_{\text{step FFT}} \dots \end{aligned}$$

Ce mode opératoire, appliqué à un rapport d'incrément de 3, est représenté à la Figure 20.

La durée de balayage T_{scan} est calculée de la manière suivante:

$$T_{\text{scan}} = T_m \frac{f_{\text{step FFT}}}{f_{\text{step final}}} \quad (5)$$

où

T_m est la durée de mesure et


$\frac{f_{\text{pas FFT}}}{f_{\text{pas final}}}$ est le rapport de pas.

Pour un système associant les deux méthodes, la durée de balayage T_{scan} est calculée de la manière suivante:

$$T_{\text{scan}} = T_m N_{\text{seg}} \frac{f_{\text{pas FFT}}}{f_{\text{pas final}}} \quad (6)$$

NOTE 1 Les appareils de mesure à FFT peuvent combiner les deux méthodes, le balayage par incréments ainsi qu'une méthode d'amélioration de la résolution en fréquence.


NOTE 2 Des informations de contexte supplémentaires sont actuellement en préparation pour la CISPR 16-3.¹



IEC 1827/10

Figure 19 – Balayage FFT en segments

¹ Le CISPR/TR 16-3 est à publier pour remplacer le CISPR 16-3:2003 et ses amendements.



IEC 1828/10

Figure 20 – Résolution en fréquence améliorée au moyen d'un appareil de mesure à FFT

7 Mesure des perturbations conduites par les câbles, de 9 kHz à 30 MHz

7.1 Introduction

Lors des essais de conformité aux limites d'émission de perturbations électromagnétiques conduites le long de câbles, les points suivants doivent être considérés comme un minimum, à la fois en situation normalisée (essais de type) et sur le lieu de l'installation (essais *in situ*):

- types de perturbations:** il existe deux méthodes de mesure des perturbations conduites, soit en tant que tension (méthode la plus répandue pour les mesures CISPR) soit en tant que courant. Les deux méthodes peuvent être utilisées pour mesurer les trois types de perturbations conduites, c'est-à-dire:
 - mode commun (également appelé mode non symétrique, c'est-à-dire la somme vectorielle des tensions/intensités dans un faisceau ou dans un ensemble de fils) ;
 - mode différentiel (également appelé mode symétrique) ;
 - mode non symétrique (tension entre une borne et la masse de référence).

NOTE La tension en mode non symétrique est principalement mesurée au niveau de l'accès d'alimentation. La tension (ou le courant) en mode commun est principalement mesurée aux accès de télécommunication, de transmission et de commande.

- appareils de mesure:** le type d'appareil de mesure est choisi en fonction des propriétés de perturbation à déterminer (voir 7.2);
- équipement d'appoint:** le type d'équipement d'appoint, c'est-à-dire réseaux fictifs, sondes de courant ou sondes de tension, est choisi en fonction du type de perturbations à mesurer selon 7.1 a). Chaque type d'équipement d'appoint présente une charge RF aux signaux et accès mesurés (voir 7.3);

- d) *conditions de charge RF de la source de perturbation*: le montage d'essai présente certaines impédances de charge RF à la/aux source(s) de perturbations dans le matériel en essai. Ces impédances sont normalisées pour les essais de type ou sont susceptibles de dépendre des conditions sur le lieu de l'installation dans le cas d'essais *in situ* (voir 7.3 et 7.4);
- e) *configuration du matériel en essai*: une configuration d'essai normalisée doit spécifier, sans aucune ambiguïté, la masse de référence, la position du matériel en essai et l'appareil de mesure auxiliaire par rapport à cette masse de référence, les connexions à cette masse de référence et les interconnexions du matériel en essai avec des matériels associés (voir 7.4 et 7.5).

7.2 Appareils de mesure (récepteurs, etc.)

7.2.1 Généralités

En général, on distingue les perturbations continues des perturbations discontinues. Les perturbations radioélectriques continues se mesurent principalement dans le domaine des fréquences. Les perturbations discontinues sont également mesurées dans le domaine des fréquences, mais elles peuvent nécessiter des mesures supplémentaires dans le domaine temporel.

Les récepteurs de mesure et autres appareils de mesure spécifiés dans la CISPR 16-1-1 doivent être utilisés. Pour les mesures dans le domaine temporel, il est possible d'utiliser des oscilloscopes, etc.

7.2.2 Utilisation des détecteurs pour les mesures des perturbations conduites

La CISPR 16-1-1 spécifie les caractéristiques des détecteurs qui sont nécessaires pour effectuer les mesures conformément aux spécifications de produits. Plusieurs de ces spécifications de produits nécessitent d'utiliser deux détecteurs, de quasi-crête et de valeur moyenne, pour les mesures de perturbations conduites. Les constantes de temps de ces deux détecteurs sont très longues et entraînent des durées importantes dans le cas de mesures automatiques.

On peut utiliser un détecteur de crête, avec des constantes de temps plus faibles, pour effectuer des mesures initiales et pour déterminer la conformité à une limite. Mais si les niveaux de perturbation mesurés sont supérieurs à une limite, on doit effectuer les mesures avec les détecteurs de quasi-crête et de valeur moyenne.

L'Annexe C fournit des indications pour effectuer ces mesures de façon efficace.

7.3 Appareils de mesure auxiliaires

7.3.1 Généralités

Les appareils de mesure auxiliaires pour la mesure des perturbations conduites se divisent en deux catégories:

- a) capteurs de mesure de tension, tels que réseaux fictifs (AN) et sondes de tension;

NOTE Le réseau fictif est parfois appelé réseau de stabilisation d'impédance (RSI). Ce terme s'applique aux AN pour les mesures d'émission sur les accès de télécommunications (c'est-à-dire les AAN et les réseaux en Y) dans la CISPR 22. Certaines normes utilisent le terme impédance de stabilisation de réseau (ISN) pour les AN pour des mesures d'émission sur des accès de télécommunication (c'est-à-dire les AAN ou les réseaux en Y).

- b) capteurs de mesure de courant, tels que sondes de courant.

7.3.2 Réseaux fictifs (AN)

7.3.2.1 Généralités

Les impédances en mode commun, différentiel et non symétrique des réseaux réels, tels que les réseaux d'alimentation et de télécommunications, dépendent de la localisation et varient en général en fonction du temps. Par conséquent, les essais de type de perturbations nécessitent la présence de réseaux de simulation d'impédance normalisés, appelés réseaux fictifs (AN). L'AN fournit des impédances de charge RF normalisées au matériel en essai. A cette fin, l'AN est inséré en série avec les bornes du matériel en essai et le réseau réel ou le simulateur de signal. De cette manière, l'AN simule les réseaux étendus (lignes longues) avec les impédances définies.

7.3.2.2 Types de réseaux fictifs

Les réseaux fictifs spécifiés dans la CISPR 16-1-2 doivent être utilisés, à moins que des raisons spécifiques n'exigent une autre construction. En général, on peut distinguer trois types de réseaux fictifs:

- a) *le réseau fictif de type en V* (en général utilisé comme AMN en V ou RSIL): dans une gamme de fréquences définie, les impédances RF entre chacune des bornes du matériel en essai à mesurer et la masse de référence ont une valeur définie, alors qu'aucune impédance n'est directement connectée entre ces bornes. Cette construction définit (indirectement) la mesure de la somme vectorielle de la tension, à la fois en mode différentiel et en mode commun. En principe, le nombre de bornes du matériel en essai, c'est-à-dire le nombre de lignes à mesurer par les réseaux fictifs de type en V, n'est pas limité;
- b) *le réseau fictif de type triangle* (non utilisé en réalité dans les publications de produits mais pourrait être utilisé comme AMN Δ pour les lignes électriques ou comme réseau Δ pour des lignes de transmission): dans une gamme de fréquences définie, l'impédance RF entre deux bornes à mesurer du matériel en essai et entre ces bornes et la masse de référence a des valeurs définies. Cette construction définit directement les impédances de charge RF, à la fois en mode différentiel et en mode commun. L'ajout d'un transformateur symétrique/non symétrique permet de mesurer la tension perturbatrice symétrique et non symétrique;
- c) *le réseau fictif en Y* (également appelé réseau fictif non symétrique (AAN ou RSI)): dans une gamme de fréquences définie, l'impédance de charge RF en mode commun entre deux bornes à mesurer du matériel en essai et une masse de référence a une valeur définie. En général, aucune impédance de charge différentielle définie en tant que telle n'est incluse dans un réseau fictif en Y. Il faut alors que l'impédance différentielle définie soit fournie par le circuit externe connecté aux bornes d'alimentation du réseau fictif en Y. Ce type de réseau fictif est utilisé uniquement pour la mesure des tensions perturbatrices en mode commun.

7.3.3 Sondes de tension

~~Pour les~~ Voir les spécifications des sondes de tension normalisées, voir dans la CISPR 16-1-2.

Les tensions perturbatrices aux bornes, qui ne sont pas mesurées par un réseau fictif, peuvent l'être par une sonde de tension. Les bornes de cette sorte sont par exemple les connecteurs d'antenne, les lignes de commande, les lignes de transmission et les lignes de charge. En général, la sonde de tension est utilisée pour la mesure de la tension perturbatrice non symétrique. La sonde présente une impédance RF élevée entre la borne à mesurer et la masse de référence.

La sonde de tension capacitive (CVP) est utilisée pour mesurer la tension non symétrique (de mode commun) d'un nombre donné de conducteurs sans contact direct. Elle est conçue de façon à pouvoir être fixée autour des conducteurs à mesurer. La fixation de la sonde CVP autour d'un conducteur particulier permet de mesurer la tension perturbatrice non symétrique.

7.3.4 Sondes de courant

Les sondes de courant ou transformateurs de courant permettent de mesurer les trois types de courant perturbateurs (voir 7.1 et CISPR 16-1-2) sur les cordons d'alimentation, les lignes de transmission, les lignes de charge, etc. Une sonde construite comme une pince facilite l'utilisation.

Le courant en mode commun circulant dans les conducteurs se mesure lorsque la sonde de courant entoure ces câbles, quel que soit le nombre de fils. Dans cette situation, les courants en mode différentiel circulant dans les conducteurs entraîneront des signaux d'intensité égale mais de signe opposé qui s'annulent presque totalement. Cet effet permet de mesurer un courant en mode commun de faible amplitude en présence de courants (de fonctionnement) en mode différentiel de forte amplitude.

La sonde de courant ne peut pas être utilisée pour la mesure du courant de mode commun converti (CCM) entre un réseau fictif non symétrique (AAN) et le matériel en essai (EUT). Le CCM ne peut être mesuré que par la tension à la sortie de l'AAN [voir 7.3.2.2 c)].

NOTE Le but de l'AAN est de simuler le potentiel de perturbation du câblage de réseau relié au port de l'EUT. Ainsi, en réponse à la tension en mode différentiel envoyée sur le réseau par le port de l'EUT, l'AAN génère une tension en mode commun interne qui représente la tension en mode commun converti (CCM) qui serait générée par le câblage de réseau raccordé. Cette tension en mode commun générée de façon interne comporte un courant de mode commun associé (I_{CCM} sur la Figure 21). Ce courant fait l'objet d'une division du courant dans l'AAN (en I_{CCM1} et I_{CCM2} sur la Figure 21). La division de courant est déterminée par l'impédance en mode commun de la sortie de l'AAN (Z_T sur la Figure 21) et l'impédance en mode commun vue de la borne d'EUT de l'AAN (Z_E sur la Figure 21). L'impédance en mode commun de la sortie de l'AAN est contrôlée et ainsi, il convient que la tension en mode commun à la sortie de l'AAN (V_{CCM} sur la Figure 21) soit la mesure du potentiel de perturbation du réseau connecté. L'impédance en mode commun vue du port d'EUT de l'AAN n'est pas contrôlée, elle varie plutôt avec la fréquence et elle dépend de la taille de l'EUT et de son agencement. Ce courant de CCM (I_{CCM2} sur la Figure 21) ne peut donc pas être mesuré avec une sonde de courant, pour l'équipement informatique de taille typique, l'ordre de grandeur Z_E varie d'autour de 2 k Ω autour 200 Ω , dans une gamme de fréquence s'étendant de 150 kHz à 30 MHz.




Figure 21 – Illustration du courant I_{CCM}

Pour les sondes de courant déjà définies (et normalisées), voir la CISPR 16-1-2.

7.4 Configuration du matériel en essai


7.4.1 Disposition des matériels en essai et leur connexion au réseau fictif


Pour mesurer la tension perturbatrice, le matériel en essai est connecté au réseau d'alimentation électrique, et à tout autre réseau de grande dimension, par le biais d'un ou de plusieurs AN (en général, le réseau en V est ici utilisé comme un AMN pour l'accès d'alimentation, voir Figure 6), conformément aux exigences suivantes. D'autres publications de produits du CISPR fournissent des détails supplémentaires pour des matériels en essai particuliers.

Un matériel en essai, qu'il soit ou non destiné à être relié à la terre, qui est amené à être utilisé sur une table, est configuré de la manière suivante:

- la base ou la partie arrière du matériel en essai doit être située à une distance contrôlée de 40 cm par rapport à un plan de masse de référence. Ce plan de masse est normalement représenté par la cloison ou le sol d'une pièce blindée. Il peut s'agir également d'une ~~plan~~ plaque métallique reliée à la ~~masse terre~~ aux dimensions d'au moins 2 m sur 2 m. Concrètement, on le réalise comme suit:
 - placer le matériel en essai sur une table en matériau non conducteur, d'une hauteur minimale de 80 cm. Placer le matériel en essai de façon à ce qu'il soit situé à 40 cm de la cloison de la pièce blindée, ou
 - placer le matériel en essai sur une table en matériau non conducteur, d'une hauteur de 40 cm de façon à ce que le matériel en essai soit situé 40 cm au-dessus du plan de masse;
- toutes les autres surfaces conductrices du matériel en essai doivent être situées à plus de 40 cm du plan de masse de référence;
- les réseaux fictifs sont placés sur le sol comme indiqué à la Figure 6, de façon qu'un côté des boîtiers AN soit situé à 40 cm du plan de masse de référence vertical et d'autres pièces métalliques. Les réseaux en V (AMN) et les réseaux en Y (~~PSL~~ AAN) sont illustrés en Figure 6 et Figure 7;
- les câbles de connexions du matériel en essai doivent être conformes aux indications de la Figure 6;
- la configuration d'essai facultative pour le matériel en essai sur table avec un seul cordon d'alimentation raccordé est présentée à la Figure 8.

NOTE La configuration de la Figure 8 peut causer une ambiguïté due au fait qu'avec certains matériels en essai, la source de perturbation métallique n'est pas au centre du boîtier non métallique (voir CISPR 16-4-1).





- 1 Les câbles d'interconnexion qui pendent à moins de 40 cm du plan de masse doivent être repliés plusieurs fois sur eux-mêmes pour former un faisceau d'une longueur maximale de 40 cm suspendu approximativement au milieu de la distance qui sépare le plan de masse de la table. Le rayon de courbure minimal du câble ne doit pas être dépassé. ~~Si le rayon de courbure donne des plis de plus de 40 cm, la taille du rayon de courbure doit avoir priorité. Si le rayon de courbure donne une longueur du faisceau de plus de 40 cm, le rayon de courbure doit déterminer la longueur du faisceau.~~
- 2 Les câbles d'entrée et de sortie raccordés à un périphérique doivent être arrangés en faisceau en leur milieu. L'extrémité du câble peut être chargée par l'impédance appropriée. Dans la mesure du possible, la longueur totale ne doit pas dépasser 1 m.
- 3 L'appareil en essai est connecté à un réseau fictif (AMN). Les bornes de mesure des AMN et des ~~RSI~~ AAN doivent être terminées par des résistances de 50 Ω si elles ne sont pas branchées au récepteur de mesure. Les AMN sont placés directement sur le plan de sol horizontal à 0,8 m du matériel en essai et à 40 cm du plan de sol vertical si celui-ci est le plan de sol de référence (voir aussi Figure 7 a)). Une alternative (représentée à la Figure 7 b)) consiste à placer les AMN sur le plan de sol vertical à 0,8 m du matériel en essai, si le plan de sol horizontal est le plan de sol de référence qui est à 40 cm en-dessous du matériel en essai. Il est admis qu'il faille déplacer les AMN sur le côté pour atteindre la distance de 0,8 m. Tous les matériels associés sont connectés à un deuxième AMN si celui-ci est capable de fournir la puissance nécessaire. Dans le cas où un seul AMN ne peut pas fournir la puissance nécessaire, il est admis d'utiliser plusieurs AMN pour alimenter les matériels associés.
- 4 Les câbles des dispositifs utilisés à la main comme les claviers, souris, etc., doivent être placés aussi près que possible de leur matériel.
- 5 Eléments soumis à essai sans faire partie du matériel en essai.
- 6 L'arrière du matériel en essai, périphériques compris, doit être aligné avec l'arrière de la surface de la table.
- 7 L'arrière de la surface de la table doit être à 40 cm d'un plan conducteur vertical relié au plan de masse du sol.

Les tolérances applicables aux longueurs de câbles et aux distances sont aussi pratiques que possible.

Figure 6 – Exemple de configuration d'essai: matériels de table pour mesures des perturbations conduites sur les conducteurs d'alimentation






Figure 7 – Montage de matériel en essai et de AMN à 40 cm avec a) RGP vertical et b) RGP horizontal







- 1 Paroi métallique de 2 m × 2 m
- 2 Matériel en essai
- 3 Longueur de câble d'alimentation en excédent (par exemple ~~2 cm x 30 cm~~ 0,02 m × 0,3 m, formant un méandre)
- 4 AMN
- 5 Câble coaxial
- 6 Récepteur de mesure
- B Connexion de terre de référence
- M Entrée du récepteur de mesure
- P Alimentation du matériel en essai

Les tolérances applicables aux longueurs de câbles et aux distances sont aussi pratiques que possible.

Figure 8 – Exemple de configuration d'essai facultative pour un matériel en essai avec seulement un câble d'alimentation fixé

Les matériels en essai destinés à être posés au sol sont soumis aux mêmes dispositions que ci-dessus, à une exception près: ces matériels doivent être placés sur le sol, les points de contact étant compatibles avec l'usage courant. Un plancher métallique relié à la masse doit être utilisé mais ne doit pas créer de contact métallique avec le(s) support(s) au sol du matériel en essai, mais qui doit faire contact avec les conducteurs de terre voulus du matériel en essai. Le plancher métallique peut être utilisé comme plan de masse de référence. Il doit s'étendre au moins 50 cm au-delà des bords du matériel en essai, et présenter des dimensions minimales de 2 m sur 2 m. Pour consulter des exemples de configurations d'essai, se reporter aux Figures 9 et 10.






- 1 Les parties de câbles en excédent doivent être repliées en faisceau en leur milieu ou raccourcies à la longueur appropriée.
- 2 Le matériel en essai et les câbles doivent être isolés (jusqu'à 15 cm) du plan de masse.
- 3 Le matériel en essai est connecté à un AMN. Celui-ci est placé sur le dessus ou immédiatement en dessous du plan de masse.
Tous les autres matériels sont alimentés à travers le deuxième AMN.

Les tolérances applicables aux longueurs de câbles et aux distances sont aussi pratiques que possible.

Figure 9 – Exemple de configuration d'essai: matériels posés sur le sol
(voir 7.4.1 et 7.5.2.2)



IEC 1609/08

- 1 Les câbles d'interconnexion qui pendent à moins de 40 cm du plan de masse doivent être repliés plusieurs fois sur eux-mêmes pour former un faisceau d'une longueur maximale d'environ 30 cm à 40 cm suspendu approximativement au milieu de la distance qui sépare le plan de masse de la table.
- 2 Les parties de câbles en excédent doivent être repliées en faisceau en leur milieu ou raccourcies à la longueur appropriée.
- 3 Le matériel en essai est connecté à un AMN. L'AMN peut être connecté en variante au plan de masse de référence vertical. Tous les autres matériels sont alimentés à travers le deuxième AMN. Il est admis qu'il faille déplacer les AMN sur le côté pour atteindre la distance de 0,8 m.
- 4 Le matériel en essai et les câbles doivent être isolés (jusqu'à 15 cm) du plan de masse.
- 5 Les câbles d'entrée et de sortie raccordés à un matériel posé au sol doivent descendre jusqu'au plan de masse; leur excédent est rassemblé en faisceau. Les câbles qui n'arrivent pas au plan de masse doivent pendre de la hauteur de leur connecteur ou sur 40 cm, la valeur la plus faible étant retenue.

Les tolérances applicables aux longueurs de câbles et aux distances sont aussi pratiques que possible.

Figure 10 – Exemple de configuration d'essai: matériels posés sur le sol et sur une table (voir 7.4.1 et 7.5.2.2)

L'AN est relié en RF au plan de masse de référence par une connexion de faible impédance RF (comme expliqué en 5.2).

NOTE Il convient que la «faible» valeur d'impédance RF soit de préférence inférieure à 10 Ω à 30 MHz. Cette valeur peut par exemple être obtenue si le boîtier de l'AN est monté directement sur le plan de masse de référence ou si sa connexion présente un rapport longueur sur largeur ne dépassant pas 3:1. Les résonances de la liaison de masse de l'AN peuvent être identifiées par un essai in-situ du facteur de division en tension (voir l'Annexe E).

La disposition du matériel en essai est telle qu'illustrée dans les Figures 6 à 10. La distance de référence entre l'un des bords du matériel en essai et la surface la plus proche de l'AN est de 80 cm. Une bonne approche pour les matériels en essai sur table, comme illustré dans les Figures 6 et 10, consiste à monter l'AN dans le plan de masse – le panneau avant étant aligné au droit du plan de masse.

Il faut disposer les conducteurs d'alimentation reliés à un AN et le câble de connexion du réseau vers le récepteur de mesure de telle manière que leurs emplacements n'influent pas sur les résultats de mesure. Les matériels en essai, qui ne sont pas équipés de cordons de raccordement fixes, sont reliés à l'AN au moyen d'un câble d'un mètre de long ou comme spécifié dans la documentation relative au matériel concerné. La longueur de 1 m est la valeur préférentielle car elle donne une meilleure incertitude de conformité à la norme.

Sauf si le matériel en essai possède des exigences particulières concernant une faible impédance de masse, les instructions suivantes doivent s'appliquer. Si le matériel en essai est destiné à être relié à une masse de référence, cela doit être effectué au moyen d'un câble courant parallèlement au cordon d'alimentation du matériel en essai et éloigné de lui d'une distance ne dépassant pas 10 cm, à moins que le cordon d'alimentation lui-même ne contienne un conducteur de terre. Si le matériel en essai comporte un câble fixe, ce câble doit avoir une longueur de 1 m. S'il dépasse 1 m, une partie de ce câble est repliée sur elle-même en décrivant des méandres ne dépassant pas 30 cm et 40 cm de longueur et disposé en forme de serpent non inductif de telle manière que la longueur totale du câble ne dépasse pas 1 m (voir également la Figure 11). Toutefois, lorsque le faisceau de câble est susceptible d'influencer les résultats des mesures, une réduction de la longueur à 1 m est recommandée.

~~NOTE — La décision quant à la recommandation d'une disposition en faisceaux ou en méandres a été exclue de la présente publication. Pour plus de simplicité, le texte existant de l'édition précédente a été conservé. Il a été révélé que les méandres entraînaient des inductances moindres que les faisceaux, mais que les résonances ne pouvaient pas être totalement évitées. Par conséquent, la question sera traitée dans un projet séparé.~~

7.4.2 Procédure de mesure des tensions perturbatrices non symétriques avec des réseaux en V (AMN)

7.4.2.1 Généralités

De manière générale, la mesure des tensions perturbatrices au moyen de réseaux fictifs est la méthode de mesure préférentielle du CISPR. Si par exemple un AMN empêche le matériel en essai de fonctionner, il convient dans ce cas d'effectuer les mesures au moyen de sondes de courant ou de tension.

7.4.2.2 Disposition des matériels avec connexion de terre

Pour un matériel en essai devant être mis à la terre pendant son fonctionnement, ou dont le boîtier conducteur peut entrer en contact avec la terre, la tension perturbatrice radioélectrique non symétrique du cordon d'alimentation se mesure en se référant au mur métallique de référence (masse générale du matériel de mesure) auquel est connecté le boîtier du matériel en essai par son conducteur de protection à la terre et la connexion à la terre du réseau fictif d'alimentation (voir le circuit équivalent à la Figure 12).


Les paramètres déterminant le potentiel perturbateur des matériels en essai mis à la terre sont exposés en A.3.

Pour les matériels en essai comportant au moins deux conducteurs d'alimentation et de protection ou des connexions spéciales à la terre, le résultat des mesures dépend beaucoup des conditions de connexion de sortie des bornes d'alimentation et des conditions de mise à la terre (voir également 7.5 concernant les mesures dans les systèmes).

Les conducteurs de mise à la terre de sécurité dans les dispositifs réels d'alimentation sont susceptibles d'avoir une longueur importante et ne garantissent donc pas une impédance par rapport à la terre aussi faible et efficace que dans le cas d'un montage d'essai normalisé, qui comporte une connexion à la masse de référence par fil d'une longueur de 1 m seulement; de plus, étant donné qu'il n'est pas nécessaire d'utiliser des conducteurs de sécurité pour chaque produit selon la CEI 60364-4, les mesures de la tension perturbatrice des appareils à prise, de classe de sécurité I, doivent être effectuées conformément au 7.4.2.3, sans que le câble de sécurité ou de terre soit connecté (mesure sans mise à la terre). Si cependant, pour des raisons de sécurité, il est nécessaire de conserver la fonction de sécurité des câbles de

terre, on peut y parvenir en utilisant une bobine PE ou une impédance égale à celle d'un réseau en V pour le conducteur de sécurité.

Il est possible de faire des exceptions pour les matériels en essai non rayonnants ou correctement blindés qui sont destinés à être reliés à la terre selon des exigences ou instructions spéciales (voir A.2.1 et A 4.1).



- 1 Tout excédent de plus de 80 cm du câble du matériel en essai doit être replié en forme de serpentín sans être bobiné.
- 2 La connexion du réseau fictif (AN) au plan de masse doit présenter une impédance faible aux fréquences élevées. Elle doit être réalisée en feuille métallique pleine dont le rapport longueur/largeur ne dépasse pas 3 pour 1.
- 3 Le récepteur de mesure CISPR doit être isolé de l'AMN en utilisant un absorbeur de courant de gaine sur le câble coaxial (Exemple en E.2).
- 4 Les lignes pointillées représentent le montage d'essai dans le cas d'une alimentation triphasée.
- 5 Connexion de filtre passe-bas facultatif; à remplacer par des courts-circuits si non utilisé.
- 6 Les éléments interconnectés peuvent être raccordés à un seul AN par une barrette ou une boîte de raccordement électrique.
- 7 Les matériels en essai posés sur table ou tenus à la main doivent se trouver à 40 cm de toute surface conductrice de masse d'au moins 2 m² et à au moins 80 cm de tout autre objet conducteur, ceci comprenant les dispositifs qui font partie du système ou de l'installation.

Figure 11 – Schéma de la configuration de mesure de la tension perturbatrice
(voir aussi 7.5.2.2)




Figure 12a – Schéma du circuit de mesure et d'alimentation




Figure 12b – Circuit équivalent de source de tension et de mesure

- 1 Matériel en essai
- 2 Câble d'alimentation
- 3 AMN
- 4 Inductance et condensateur de découplage
- 5 Paroi métallique
- A Entrée alimentation
- B₀ Connexion de la terre de référence
- L₁, L₂ Raccordement du câble d'alimentation (100 cm)
- P₁, P₂ Fiche du matériel en essai vers le réseau d'alimentation
- C₁ Capacité parasite entre l'intérieur du matériel en essai et les parties métalliques
- C₂ Capacité parasite entre le matériel en essai et la paroi métallique (à la terre)
- C_k Condensateurs de couplage du réseau d'alimentation
- D_r Bobine d'arrêt (bobine PE) du conducteur de masse de sécurité
- K Parties de la structure conductrice du matériel en essai
- L Inductance des câbles de connexion
- M Point milieu fictif pour les tensions internes en mode commun
- R_N Résistances de simulation (50 Ω ou 150 Ω)
- Z_s Résistance interne symétrique du matériel en essai
- Z_{1u}, Z_{2u} Résistance en mode commun du matériel en essai
- U_{1u}, U_{2u} Tension interne en mode commun du matériel en essai
- U₁₀, U₂₀ Tension externe mesurable en mode commun

Figure 12 – Circuit équivalent de mesure de la tension perturbatrice en mode commun pour les matériels en essai de classe I (mis à la terre)

7.4.2.3 Disposition des matériels sans connexion à la terre

Les matériels sans connexion à la terre comprennent les matériels électriques avec une isolation de protection (classe de sécurité II), les matériels pouvant fonctionner sans conducteur de terre ou de sécurité (classe de sécurité III) et les matériels avec prise de classe I de sécurité, connectés par un transformateur d'isolement. Pour ces matériels, il faut mesurer la tension perturbatrice non symétrique de chaque conducteur par rapport à la masse métallique de référence du montage de mesure comme indiqué dans le circuit équivalent de la Figure 13.

Etant donné que, dans les gammes de grandes ondes et ondes moyennes (entre 0,15 MHz et 2 MHz), les résultats des mesures peuvent être considérablement influencés par les faibles capacités série C_2 entre le matériel en essai et la masse de référence, et que la distance spécifiée est déterminante, il faut suivre scrupuleusement cette disposition; il convient également d'éviter d'autres influences externes, telles que la capacité du corps ou de la main, par exemple.




Figure 13a – Schéma du circuit d'alimentation et de mesure




Figure 13b – Circuit équivalent de source de perturbations radioélectriques et de mesure

NOTE Se reporter à la Figure 12 pour les symboles.

Figure 13 – Circuit équivalent de mesure de la tension perturbatrice en mode commun pour les matériels en essai de classe II (non mis à la masse)

7.4.2.4 Disposition des matériels tenus à la main sans connexion à la terre

Les mesures doivent tout d'abord être effectuées conformément au 7.4.2.3. Des mesures supplémentaires doivent ensuite être effectuées au moyen de la main artificielle décrite dans la CISPR 16-1-2.

Le principe général à suivre dans l'utilisation de la main artificielle est indiqué à la Figure 15. La borne M de l'élément RC doit être reliée à toute pièce de métal exposée non rotative et feuille métallique enroulée autour de toutes les poignées, fixes et détachables, fournies avec le matériel en essai. Une pièce de métal recouverte de peinture ou de laque est considérée comme une pièce de métal exposée et doit être directement reliée à l'élément RC.

La main artificielle doit comporter une feuille métallique enroulée autour du revêtement, ou d'une partie de ce revêtement, comme spécifié ci-dessous. La feuille doit être reliée à une borne (borne M) d'un élément RC (voir Figure 14) comprenant un condensateur de $220 \text{ pF} \pm 20 \%$ en série avec une résistance de $510 \Omega \pm 10 \%$; l'autre borne de l'élément RC doit être reliée à la masse de référence du système de mesure.

Il faut utiliser la main artificielle de la façon suivante:

- a) lorsque le revêtement du matériel en essai est entièrement métallique, une feuille métallique n'est pas nécessaire, mais la borne M de l'élément RC doit être directement reliée au corps du matériel en essai;
- b) lorsque le revêtement du matériel en essai est constitué de matériau isolant, la feuille métallique doit être enroulée autour de la poignée B (Figure 15) et de la seconde poignée D, le cas échéant. La feuille métallique, d'une largeur de 60 mm, doit également être enroulée autour du corps C à l'endroit où se trouve le noyau de fer du stator du moteur, ou bien autour du train d'engrenage, si cela crée un niveau d'émission plus élevé. Toutes ces feuilles métalliques, et l'anneau ou la traversée A, le cas échéant, doivent être reliés entre eux et connectés à la borne M de l'élément RC;
- c) lorsque le revêtement du matériel en essai est constitué en partie de métal et en partie de matériau isolant et comporte des poignées isolantes, la feuille métallique doit être enroulée autour des poignées B et D (Figure 15). Si le revêtement est non métallique au niveau du moteur, une feuille métallique de 60 mm de largeur doit être enroulée autour du corps C à l'endroit où se trouve le noyau de fer du stator du moteur, ou bien autour du train d'engrenage, s'il est constitué de matériau isolant et qu'on obtient un niveau d'émission plus élevé. La partie métallique du corps, le point A, la feuille métallique autour des poignées B et D et la feuille métallique sur le corps C doivent être reliées ensemble ainsi qu'à la borne M de l'élément RC;
- d) lorsque le matériel en essai comporte deux poignées A et B en matériau isolant et un revêtement métallique C, une scie électrique par exemple (Figure 16), la feuille métallique doit être enroulée autour des poignées A et B. La feuille métallique en A et B, et le corps métallique C doivent être reliés ensemble ainsi qu'à la borne M de l'élément RC.




Figure 14 – Élément RC pour main artificielle

Figure 15 – Perceuse électrique portable avec main artificielle




Figure 16 – Scie électrique portable avec main artificielle

7.4.2.5 Disposition des claviers, électrodes et autres matériels sensibles au toucher

Dans le cas des matériels de ce type, la main artificielle doit être utilisée conformément aux spécifications de produits et, de manière générale, selon 7.4.2.4.

7.4.2.6 Disposition des matériels avec composants de suppression externe

Si des dispositifs d'antiparasitage sont raccordés à l'extérieur du matériel en essai (par exemple un dispositif enfichable destiné à être connecté au réseau d'alimentation) ou en tant qu'élément inséré dans le câble de raccordement (cordon d'alimentation à dispositif de suppression d'émission), ou si des cordons de raccordement blindés sont utilisés, il faut relier un câble supplémentaire non blindé d'une longueur de 1 m entre le dispositif de suppression d'émission et l'AN pour mesurer la tension perturbatrice. Il faut placer la ligne située entre le matériel et le dispositif de suppression d'émission à proximité directe du matériel à mesurer.

7.4.2.7 Disposition des matériels comportant un matériel auxiliaire (AuxEq) connecté à l'extrémité d'un câble autre que le câble d'alimentation

NOTE 1 Les commandes de régulation comportant des dispositifs à semi-conducteurs sont exclues du présent paragraphe; les dispositions de 7.4.4.1 doivent s'appliquer.

NOTE 2 Lorsque le matériel auxiliaire, AuxEq, n'est pas essentiel au fonctionnement du matériel en essai et que sa procédure d'essai est spécifiée ailleurs, le présent paragraphe ne s'applique pas. Le matériel principal est soumis aux essais comme un matériel individuel.

NOTE 3 La décision ultime, visant à déterminer s'il faut effectuer des mesures et appliquer des limites, est prise dans les publications produits correspondantes du CISPR.

Les cordons de raccordement dépassant 1 m de longueur doivent être disposés en faisceau/ en méandre conformément à 7.4.1.

Les mesures ne sont pas requises lorsque le cordon de raccordement entre le matériel en essai et le matériel auxiliaire est fixé de manière permanente aux deux extrémités et qu'il est soit de longueur inférieure à 2 m, soit blindé, à condition que, dans ce dernier cas, le câble blindé soit connecté à ses deux extrémités au boîtier métallique du matériel en essai et à celui du matériel auxiliaire. Les câbles comportant des fiches et embases amovibles sont considérés comme extensibles jusqu'à une longueur supérieure à 2 m, et des mesures sont requises.

Le matériel en essai doit être disposé conformément aux paragraphes précédents de 7.4.2, avec les exigences supplémentaires suivantes:

- a) le matériel auxiliaire doit être placé à la même hauteur et à la même distance du plan de masse, et si le câble est suffisamment long, il doit être traité conformément à 7.4.1. Si le câble auxiliaire est inférieur à 0,8 m, sa longueur doit être conservée et le matériel auxiliaire doit être placé aussi loin que possible du matériel principal. Lorsque le matériel auxiliaire est un organe de commande, il ne faut pas que les dispositions concernant son fonctionnement affectent le niveau de perturbation;
- b) si un matériel en essai disposant d'un matériel auxiliaire est mis à la masse, aucune main artificielle ne doit être connectée. Si le matériel en essai lui-même est conçu pour être tenu à la main, la main artificielle doit être connectée au matériel en essai et non au matériel auxiliaire;
- c) si le matériel en essai n'est pas conçu pour être tenu à la main, il faut que le matériel auxiliaire qui n'est pas mis à la masse et qui est, lui, conçu pour être tenu à la main, soit connecté à la main artificielle; si le matériel auxiliaire n'est pas non plus conçu pour être tenu à la main, il doit être placé par rapport à une surface conductrice reliée à la masse, comme décrit en 7.4.1.

Outre la mesure effectuée aux bornes de la connexion de l'alimentation électrique, les mesures sont effectuées à toutes les autres bornes des câbles d'entrée et de sortie (par exemple les lignes de commande et de charge) au moyen d'une sonde de tension reliée à l'entrée du récepteur de mesure.

Le matériel auxiliaire de commande ou de charge est connecté pour permettre d'effectuer des mesures dans toutes les conditions de fonctionnement fournies et pendant les interactions entre le matériel en essai et le matériel auxiliaire.

Les mesures sont effectuées à la fois sur les bornes d'entrée du matériel en essai et sur les bornes d'entrée du matériel auxiliaire.

7.4.3 Mesure des tensions en mode commun aux bornes de signaux en mode différentiel

7.4.3.1 Généralités

De manière générale, la mesure des tensions perturbatrices au moyen de réseaux fictifs est la méthode de mesure préférentielle du CISPR. Si par exemple un AN empêche le matériel en essai de fonctionner, il convient dans ce cas d'effectuer les mesures au moyen de sondes de courant ou de tension capacitive.

7.4.3.2 Mesure au moyen du réseau de type triangle

La tension perturbatrice en mode commun aux bornes des lignes de signaux de télécommunication en mode différentiel, de traitement de données et autres appareils se mesure avec les réseaux en triangle conformément à la CISPR 16-1-2, dans la gamme de fréquences comprises entre 150 kHz et 30 MHz. Les réseaux en triangle spécifiés dans la CISPR 16-1-2 peuvent être construits de manière à permettre le passage des signaux et du courant continu nécessaires au bon fonctionnement du matériel en essai, à condition de respecter les exigences sur les impédances en mode différentiel et en mode commun données dans la CISPR 16-1-2.

Lorsqu'on utilise le réseau en triangle pour les mesures aux bornes de signal, il faut que la réjection en mode différentiel soit aussi élevée que nécessaire pour ne pas donner de résultats erronés lors de la mesure d'une tension perturbatrice en mode commun à la même fréquence que le signal de fonctionnement en mode différentiel.

Lorsque le matériel en essai doit être mesuré à ses bornes d'alimentation électrique au moyen d'un AMN, toutes les mesures de tension doivent être effectuées en connectant simultanément les deux réseaux. Les dispositions prescrites en 7.4.1 et 7.4.2 doivent être observées.

NOTE La gamme de fréquences du réseau en triangle peut être étendue à 9 kHz en utilisant la même impédance de réseau si le découplage de la ligne de signal connectée et le couplage au récepteur de mesure sont conçus en conséquence.

7.4.3.3 Mesure au moyen du réseau de type en Y

A la place, un réseau fictif non symétrique (en mode commun) (AAN), c'est-à-dire un réseau en Y conforme à la CISPR 16-1-2, peut être utilisé pour mesurer les tensions perturbatrices en mode commun dans la gamme de fréquences comprises entre 9 kHz et 30 MHz.

NOTE Les réseaux en Y sont fréquemment appelés (comme par exemple dans la CISPR 22) réseaux de stabilisation d'impédance (RSI).

Contrairement au réseau en triangle qui comporte un accès en mode différentiel et en mode commun avec des impédances de simulation égales de 150 Ω , le réseau en Y ne comporte qu'une sortie en mode commun de 150 Ω , la ligne de communication se terminant par son impédance caractéristique et un rapport caractéristique de réjection mode différentiel/mode commun du réseau de télécommunications auquel il est prévu de connecter le matériel en essai.

Dans la partie du réseau en Y réservée à l'alimentation, il est possible de connecter un simulateur de signal, des circuits de charge pour courant continu ou pour la fréquence du signal utile du matériel en essai, ou pour d'autres circuits nécessaires au fonctionnement du matériel en essai. Ces circuits doivent soit fournir eux-mêmes une résistance RF en mode différentiel de 100 Ω à 150 Ω , selon la valeur prescrite pour ce matériel en essai particulier, soit fournir cette résistance au moyen d'une terminaison. Lorsqu'aucun circuit extérieur n'est spécifié pour le fonctionnement du matériel en essai, une résistance de 150 Ω doit être connectée au réseau en Y comme terminaison RF en mode différentiel. Si aucun réseau en Y approprié n'est disponible, l'accès télécommunications est fermé par un matériel auxiliaire.

Lorsqu'un matériel en essai disposant d'un accès télécommunications doit être mesuré à ses bornes d'alimentation électrique au moyen d'un AMN, les mesures de tension des perturbations doivent être effectuées en connectant l'AMN à l'accès alimentation et le réseau en Y à l'accès télécommunications simultanément ou en connectant directement le matériel associé au matériel en essai. La Figure 6 illustre le montage de mesures au moyen d'AMN et de réseaux en Y (RSI). Les dispositions prescrites en 7.4.1 et 7.4.2 doivent être observées.

7.4.4 Mesures au moyen de sondes de tension


7.4.4.1 Avec un AMN

Afin d'effectuer des essais sur des matériels et des systèmes comportant plusieurs lignes connectées ou connectables, il faut mesurer la tension perturbatrice, qui ne peut pas être mesurée avec des AMN (comme par exemple pour les lignes de connexion entre les parties des constituants qui sont séparées de l'alimentation) aux connexions des jacks de raccordement pour antennes, aux lignes de commande et de charge, avec une sonde de tension (voir 7.3.3) ayant une impédance d'entrée élevée (1 500 Ω ou plus) afin de garantir que les lignes ne sont pas chargées par la sonde.

Dans ces cas-là, cependant, les conducteurs d'entrée primaire doivent être isolés et raccordés du point de vue RF au réseau AMN. Pour les lignes restantes, y compris celles ne devant pas être mesurées avec la sonde, il faut observer les conditions correspondantes de 7.4.1 ainsi que les conditions de fonctionnement indiquées pour chaque matériel dans les spécifications de produits correspondantes (par exemple la CISPR 11 et la CISPR 14-1) en tenant compte de la disposition et de la longueur. La sonde de tension est connectée au récepteur de mesure par un câble coaxial dont le blindage est connecté à la masse de référence et au boîtier de la sonde de tension. Aucune connexion ne doit être faite directement entre ce boîtier et les parties sous tension du matériel en essai.

Si le récepteur de mesure est connecté à la sonde de tension, l'AMN doit être bouclé par une résistance de 50 Ω .

Les Figures 17 et 18 (extraites de la CISPR 14-1) donne un exemple de montage d'essai pour la mesure de la tension perturbatrice d'une commande de régulation à semi-conducteur.



Positions des commutateurs:

- 1 Pour les mesures aux bornes d'alimentation
- 2 Pour les mesures aux bornes de la charge
- 3 et 4 Connexions successives au cours des mesures côté charge

NOTE 1 La masse du récepteur de mesure est connectée à l'AMN.

NOTE 2 La longueur du câble coaxial à partir de la sonde ne dépasse pas 2 m.

NOTE 3 Lorsque le commutateur est en position 2, la sortie de l'AMN à la borne 1 est chargée par une impédance équivalente à celle du récepteur de mesure CISPR.

NOTE 4 Lorsqu'un dispositif de régulation à deux bornes est inséré dans l'un des câbles d'alimentation seulement, les mesures sont effectuées en raccordant le second câble d'alimentation comme indiqué dans la partie inférieure de la Figure 18.

Figure 17 – Exemple de mesure pour les sondes de tension




Figure 18 – Disposition de mesure pour un dispositif de régulation à deux bornes

7.4.4.2 Sans AMN

Lors des essais des matériels en essai qui ne doivent pas être mesurés avec des AMN, la tension perturbatrice est mesurée aux bornes d'une résistance de simulation définie (comme par exemple la simulation d'une clôture électrique fictive de la CISPR 14-1 ou bien dans des conditions de circuit ouvert avec une disposition exactement définie et une implantation des lignes prenant en compte les spécifications de 7.4.1). La tension perturbatrice est mesurée avec une sonde de tension d'impédance élevée.

Cela s'applique également par exemple aux dispositifs électroniques de puissance alimentés à partir de leur propre alimentation séparée ou pour des dispositifs à batterie auxquels sont connectées des lignes installées séparément qui ne doivent pas être chargées.

Dans le cas de mesures de la tension perturbatrice sur des sources de puissance séparées pour des courants supérieurs à 25 A (par exemple batterie, générateur, convertisseur), il faut effectuer une mesure de l'impédance pour s'assurer que la tolérance sur la résistance simulée, conformément à la CISPR 16-1-2, n'est pas dépassée.

Pour les sondes, il convient que la connexion flexible à la masse, avec une impédance d'entrée R_x supérieure à $1\,500\,\Omega$, ne dépasse pas de plus de $1/10$ la longueur d'onde à la fréquence de mesure maximale et cette connexion doit être reliée aussi près que possible à la surface métallique servant de masse de référence. Afin d'éviter une charge capacitive supplémentaire du point d'essai par le blindage de la sonde, il convient que la pointe de la sonde ne dépasse pas une longueur approximative de 3 cm. Il faut que les connexions blindées du récepteur de mesure soient disposées d'une manière telle que la capacité de l'objet d'essai ne soit pas modifiée par rapport à la masse de référence.

7.4.4.3 AMN comme sonde de tension

Lorsque le courant nominal d'un matériel en essai dépasse celui des AMN disponibles, un AMN peut être utilisé comme une sonde de tension. L'accès de l'AMN côté matériel en essai est connecté à chaque fil d'alimentation du matériel en essai (monophasé ou triphasé).

Avant de connecter un AMN au réseau, il doit être connecté de façon sûre à la terre physique locale (conducteur PE).

ATTENTION: Avant de déconnecter le conducteur PE, il faut déconnecter l'AMN du réseau. L'accès «alimentation» de l'AMN est laissé ouvert. Lorsque l'AMN est connecté comme une sonde de tension, les broches du connecteur d'entrée d'alimentation de l'AMN sont alimentées par la tension d'alimentation. Les broches du connecteur doivent être protégées par un capot isolant ou par d'autres moyens.

Dans la bande de fréquences de 150 kHz à 30 MHz, les fils d'alimentation du matériel en essai doivent être connectés à l'alimentation par une inductance de $30\,\mu\text{H}$ à $50\,\mu\text{H}$ (voir la Figure A.8, configuration 2). L'inductance peut être réalisée par une bobine, une ligne de 50 m ou un transformateur. Dans la bande de fréquences de 9 kHz à 150 kHz, une inductance plus grande sera en principe nécessaire pour le découplage avec l'alimentation. Ceci assure également une réduction du bruit provenant du réseau d'alimentation (voir A.5).

Puisque les mesures avec des AMN dans leur configuration conventionnelle sont préférables, il convient d'utiliser l'AMN en mode sonde de tension uniquement pour des essais *in situ* et lorsque les limitations pratiques en courant sont dépassées. Cette configuration ne doit pas être utilisée pour la mesure conformément à une norme de produits, à moins que cette méthode ne soit expressément décrite comme autre méthode possible dans la norme de produits.

7.4.5 Mesures au moyen d'une sonde de tension capacitive (CVP)

Une sonde CVP peut permettre de mesurer les tensions perturbatrices sur des câbles de transmission et de télécommunication non blindés, ayant plus de 4 paires symétriques. La mesure peut être combinée à celle d'une sonde de courant afin de mesurer simultanément la tension perturbatrice et le courant perturbateur. L'inconvénient de cette méthode est l'absence d'isolation entre le matériel en essai et le réseau réel ou le simulateur.

Le corps de la sonde CVP doit être relié au plan de masse de référence par une connexion de mise à la masse aussi courte que possible.

7.4.6 Mesures au moyen de sondes de courant

Les mesures du courant perturbateur peuvent être utiles pour plusieurs raisons. Tout d'abord, il peut être impossible, dans certains dispositifs, d'insérer un AN. Cela est tout particulièrement vrai lorsque les essais sont effectués sur des systèmes installés, ou lorsque le matériel en essai fonctionne avec des courants très élevés. D'autre part, dans la partie basse de la gamme de fréquences, l'impédance d'alimentation devient très faible; par conséquent, la source de perturbation est un générateur de courant. La mesure de ce courant peut être effectuée au moyen d'un transformateur de courant sans interrompre ou déconnecter la connexion d'alimentation.

Les sondes de courant doivent être conformes aux exigences de la CISPR 16-1-2.

Les sondes de courant permettent de mesurer directement les composantes en mode commun du courant perturbateur en entourant le câble contenant tous les conducteurs. De cette manière, les courants perturbateurs en mode commun peuvent être facilement séparés des courants utiles en mode différentiel.

Si les mesures sont effectuées avec des impédances de charge et de source connues, la tension perturbatrice peut être calculée.

Si un seul des conducteurs est entouré, on mesure la superposition des composantes de courant en mode commun et en mode différentiel. Si, dans ce cas, il existe un courant utile de valeur très élevée (supérieure à 200 A), on risque d'obtenir des données erronées en raison de la saturation possible du noyau magnétique de la sonde de courant.

7.5 Configuration d'essai des systèmes pour les mesures d'émissions conduites

7.5.1 Approche générale des mesures des systèmes

L'objectif général de définition d'une configuration d'essai d'un système pour des mesures d'émissions conduites comporte les points clés suivants:

- éviter les perturbations en mode commun par boucles de masse;
- définir une configuration qui soit facilement reproductible;
- découpler la ligne mesurée des lignes qui ne sont pas mesurées;
- placer les lignes pour obtenir un découplage;
- disposer les lignes de manière à réduire l'influence des champs magnétiques sur les mesures d'émission;
- appliquer dans toute la mesure du possible les exigences de 7.1 à 7.4 pour l'essai du système.

Lorsque cela est possible, la tension perturbatrice sur une ligne d'un système doit être mesurée au moyen d'un réseau fictif. Pour des courants jusqu'à 50 A, des AMN peuvent être utilisés relativement facilement. L'AN doit, dans toute la mesure du possible, être installé dans un rayon de 80 cm par rapport au matériel du système en essai. Chaque fil d'un circuit d'alimentation électrique multiconducteurs doit être acheminé à travers un AMN. La borne de mesure de chaque AN doit être rebouclée par une résistance de 50 Ω .

Le matériel en essai doit être disposé et connecté avec des terminaisons de câbles conformément aux instructions du fabricant.

Pour certaines mesures, il est possible de spécifier, dans les publications de produits applicables, l'usage de sondes de tension auxiliaires à une charge spécifique, au lieu d'un AMN. Une sonde de tension peut également être utilisée pour des mesures en conduction lorsque le courant d'alimentation est supérieur à 50 A et qu'un AMN approprié n'est pas disponible. Dans ce cas cependant, les résultats des essais effectués avec un AMN ~~ont la priorité sur les résultats obtenus avec une sonde de tension~~ doivent être préférés.

Pour certaines mesures, l'utilisation des sondes de courant peut être spécifiée dans la norme de produits applicable.

7.5.2 Configuration du système

Le système doit être configuré, installé, disposé et mis en fonctionnement avec soin, d'une manière qui soit la plus représentative de l'utilisation normale (c'est-à-dire comme spécifié dans le manuel d'instruction) ou comme spécifié dans le présent document. Il convient qu'un équipement fonctionnant normalement dans un système constitué de multiples unités interconnectées soit soumis aux essais comme élément d'un système opérationnel type.

En général, le système soumis à des essais doit être du même type que celui mis sur le marché pour l'utilisateur final. Si les informations de commercialisation ne sont pas disponibles, ou s'il est difficile de réunir une quantité importante d'équipements pour reproduire dans sa totalité l'installation du produit commercialisé, l'essai doit être réalisé en faisant appel aux compétences de l'ingénieur d'essai en concertation avec l'équipe d'ingénierie de conception. Les résultats de toute discussion de ce type et du processus de décision doivent être documentés dans le rapport d'essai.

Le choix et l'emplacement des câbles, des cordons d'alimentation en courant alternatif de l'unité principale et des périphériques, dépendent du type d'équipement en essai et doivent être représentatifs de l'installation prévue pour l'équipement. La séparation entre les différentes unités doit être de 10 cm, à moins que, du fait de leur construction, une telle distance ne soit pas réalisable. Il convient dans ce cas de placer les unités aussi proches que possible les unes des autres (à une distance supérieure à 10 cm) et de noter la configuration dans le rapport d'essai. On distingue trois types de systèmes. En premier lieu, les systèmes normalement utilisés dans leur totalité sur une seule table, voir par exemple la Figure 6. Le second type de système comprend des équipements normalement posés au sol. Il comprend les systèmes montés sur un plancher surélevé, spécialement conçu, ce qui facilite la connexion entre les parties du système sous le plancher surélevé. Les équipements constituant le système posé au sol peuvent être interconnectés au moyen de câbles posés sur le plancher, sous le plancher dans une installation à plancher surélevé, ou bien encore en hauteur conformément à l'installation normale. Le troisième type comprend les systèmes qui sont la combinaison des systèmes posés au sol et de ceux posés sur table. La suite de ce paragraphe fournit des instructions d'essai pour chacun de ces types. De plus, les exigences spécifiques de 7.1 à 7.4 doivent être observées.

Les équipements d'un système, normalement posés sur le sol, doivent être placés sur un plancher conformément au 7.4.1. Les équipements conçus pour fonctionner à la fois sur une table et au sol doivent être soumis aux essais uniquement dans la configuration sur table.

7.5.2.1 Conditions de fonctionnement

Le système doit être mis en œuvre à la tension de fonctionnement assignée (nominale) et dans des conditions de charge type – mécaniques ou électriques ou les deux à la fois – pour lesquelles il est conçu. Les charges peuvent être réelles ou simulées comme décrit dans les exigences particulières de l'équipement. Pour certains systèmes, il peut être nécessaire de développer un ensemble d'exigences explicites spécifiant les conditions d'essai, les types de fonctionnement, etc., devant être employés pour effectuer des essais sur un système spécifique.

Si le système comprend une console de visualisation ou un moniteur, les conditions de fonctionnement suivantes s'appliquent, sauf spécification contraire de la norme de produits:

- a) mettre le contraste au maximum;
- b) mettre la luminosité au maximum, ou au niveau d'extinction de la trame, si celle-ci apparaît avant d'atteindre le maximum de luminosité;
- c) pour les moniteurs couleur, utiliser des lettres blanches sur fond noir, pour représenter toutes les couleurs;
- d) choisir le cas le plus défavorable entre la vidéo négative ou la vidéo positive, si les deux possibilités sont disponibles;
- e) choisir la taille des caractères et leur nombre par ligne de manière à afficher sur l'écran le nombre maximal de caractères;
- f) pour un moniteur non graphique, sans tenir compte de la carte vidéo utilisée, un modèle de texte aléatoire doit être affiché;
- g) pour un moniteur graphique, même si une autre carte vidéo peut être nécessaire pour obtenir un affichage graphique, il convient d'afficher un modèle en ligne de H déroulants;
- h) si un moniteur ne dispose pas de capacités de texte, utiliser un affichage type.

7.5.2.2 Matériels d'interface, simulateurs et câbles

Les essais de conformité sont effectués en plaçant des périphériques et des câbles d'une manière qui soit jugée réaliste et susceptible d'être retrouvée dans l'installation définitive. Les Figures 6, 9, 10 et 11 décrivent les montages d'essai normalisés qui fournissent une base pour la reproductibilité des essais dans les différents laboratoires d'essai; cette base est cohérente avec les exigences d'un système et d'une disposition des câbles réalistes. ~~Tout écart par rapport aux montages d'essais normalisés doit faire l'objet d'un document comportant l'exposé des motifs. En conséquence, les mesures avec une unité d'interfaçage réelle doivent être préférées.~~

Etant donné qu'un système est nécessairement en interaction fonctionnelle avec d'autres unités, il convient d'utiliser les unités d'interface réelles. Des simulateurs peuvent être utilisés pour obtenir des conditions de fonctionnement représentatives, à condition que les effets du simulateur utilisé à l'emplacement d'une unité d'interface représentent correctement les caractéristiques électriques, et mécaniques dans certains cas, des unités d'interface, particulièrement en ce qui concerne les signaux RF, les impédances et les terminaisons blindées. En raison du degré supplémentaire d'incertitude lors de l'utilisation d'un simulateur, il convient d'éviter si possible cette utilisation. En cas de contestation, les mesures effectuées avec une unité d'interface réelle doivent faire référence. Si un dispositif est conçu pour être utilisé uniquement avec un ordinateur central ou un périphérique spécifique, il convient d'effectuer les essais avec cet ordinateur ou ce périphérique.

Il convient d'employer des câbles d'interface typiques d'utilisation normale, tels qu'ils sont fournis avec le système normal et d'au moins 2 m de longueur, sauf si le manuel de l'utilisateur, fourni par le fabricant, spécifie l'utilisation de câbles plus courts. Il convient d'utiliser tout au long des essais le même type de câble (c'est-à-dire non blindé, blindage tressé, blindage à feuilles, etc.) spécifié dans le manuel de l'utilisateur. Les longueurs de câble supplémentaires doivent être repliées en un faisceau en forme de serpent, en

approximativement situé au centre du câble, en constituant des faisceaux d'une longueur de 40 cm au maximum de façon à ce que, dans la mesure du possible, leur longueur effective entre le matériel en essai et le matériel associé ne dépasse par 1 m.

Si des câbles blindés ou spéciaux sont utilisés lors des essais pour obtenir la conformité, il faut inclure une déclaration dans le rapport d'essai et dans le manuel d'instructions indiquant la nécessité d'utiliser ces types de câbles.

Si des champs magnétiques sont générés par des éléments du système (par exemple par des unités de visualisation), les boucles entre les connexions de mise à la masse et les lignes de mesure peuvent capter ces champs magnétiques et les résultats des mesures risquent d'être erronés du fait de l'accouplement de tensions dans ces boucles. Pour éviter le captage de ces champs magnétiques, il convient que les lignes de connexion (lignes de mise à la masse et lignes de mesure) soient aussi courtes que possible et torsadées.

Les accès d'interface (connecteurs) doivent avoir un câble connecté à l'un de chacun des types d'accès d'interface fonctionnels du système et chaque câble doit être raccordé à un dispositif typique de l'utilisation réelle. Dans le cas où il existe de multiples accès d'interface tous du même type, des câbles supplémentaires de connexion doivent être ajoutés au système pour déterminer leur effet sur les émissions provenant du système. Les mesures d'accès d'alimentation au moyen de réseaux en V doivent être effectuées en connectant simultanément des réseaux en Y (voir 7.4.3.3) aux accès de télécommunications.

Normalement, la charge d'accès similaires se limite à ce qui suit:

- a) disponibilité de charges multiples (pour de grands systèmes);
- b) caractère raisonnable de charges multiples représentant une installation type.

Les raisons du choix de la configuration et du mode de charge des accès doivent figurer dans le rapport d'essai; c'est-à-dire: 25 % des câbles possibles ont été connectés et les émissions n'ont pas augmenté de plus de 2 dB lorsque un ou plusieurs câbles ont été ajoutés. Il est inutile de connecter ou d'utiliser lors des essais des accès supplémentaires sur des unités de support, d'interface, ou bien encore des simulateurs, autres que ceux associés au système ou au système minimal requis.

7.5.2.3 Connexion de l'alimentation électrique

Si le système est constitué d'un ensemble de matériels ayant chacun leur propre cordon d'alimentation, le point de connexion des AMN est déterminé à partir des règles suivantes:

- a) chaque cordon d'alimentation terminé par une fiche d'alimentation électrique de conception normalisée (CEI/TR 60083 par exemple) doit être soumis aux essais séparément;
- b) les cordons d'alimentation ou bornes dont le fabricant n'a pas spécifié qu'ils devaient être connectés par l'intermédiaire d'une unité principale doivent être soumis aux essais séparément;
- c) les cordons d'alimentation ou bornes pour le câblage dont le fabricant a spécifié qu'ils devaient être connectés à une unité principale ou tout autre matériel d'alimentation électrique doivent être connectés à cette unité principale ou à cet autre matériel d'alimentation électrique. Les bornes ou cordons de cette unité principale ou autre matériel d'alimentation électrique sont connectés aux AMN et soumis aux essais;
- d) lorsqu'une connexion spéciale de l'alimentation électrique est spécifiée, le matériel nécessaire à la connexion à l'AMN doit être fourni par le fabricant pour les besoins de l'essai.

Le conducteur de mise à la terre des unités alimentées séparément doit être isolé du matériel en essai par un AN de 50 μ H dans la gamme de fréquences comprises entre 0,15 MHz et 30 MHz. L'entrée d'alimentation normale de l'AMN est reliée à la masse de référence lorsqu'on utilise, comme dans ce cas, l'AMN en tant que filtre.

7.5.3 Mesure des lignes d'interconnexion

Outre les mesures sur les bornes d'alimentation, il peut être nécessaire d'effectuer les mesures avec une sonde de tension sur les autres bornes pour les câbles d'entrée et de sortie (par exemple lignes de commande et de charge). Si le fonctionnement du matériel en essai est affecté par l'impédance de $1\,500\,\Omega$ de la sonde, il peut être nécessaire d'augmenter l'impédance aux fréquences de 50/60 Hz et aux fréquences radioélectriques (par exemple $15\,\text{k}\Omega$ en série avec $500\,\text{pF}$). Il est possible de remplacer une mesure de tension par une mesure de courant effectuée avec une sonde de courant, si la spécification produit l'exige (ou le propose en option).

Pendant les mesures, les réseaux fictifs sur le cordon d'alimentation demeurent en place afin de fournir une isolation d'alimentation et une terminaison RF définies. Le matériel auxiliaire (commande, charge) est connecté pour pouvoir effectuer des mesures dans toutes les conditions de fonctionnement données et pendant les interactions entre constituants du matériel. Les mesures sont effectuées sur les bornes spécifiées de chaque matériel.

Si les lignes de connexion entre les constituants du matériel sont fixées de manière permanente aux deux extrémités et si elles ont une longueur inférieure à 2 m ou sont blindées, aucune mesure n'est nécessaire, à condition que, dans ce dernier cas, le câble blindé soit connecté à ses deux extrémités à la masse de référence, c'est-à-dire au boîtier métallique du matériel. Les lignes de connexion non blindées, comportant des fiches ou embases, sont considérées comme étant extensibles jusqu'à une longueur supérieure à 2 m; il faut donc les étendre sur une longueur minimale de 2 m et les soumettre aux essais. Il faut que les câbles blindés aient une longueur minimale de 2 m sauf si le manuel de l'utilisateur spécifie l'utilisation de câbles plus courts.

7.5.4 Découplage des composantes du système

L'une des sources d'erreur lors des mesures en conduction dans un système est la présence d'un courant de masse. Ce courant de masse peut être interrompu en installant un AN de $50\,\mu\text{H}$ (bobine PE), dans la gamme de fréquences de 0,15 MHz à 30 MHz, dans le conducteur de mise à la terre de protection de l'équipement en essai.

Une autre source de circulation de courant peut provenir des blindages des câbles d'interconnexion entre les unités. Par conséquent, le conducteur de protection de ces unités doit également être isolé par un AN de $50\,\mu\text{H}$.

Il convient de référencer à la masse le récepteur de mesure de perturbation, uniquement au point de mesure afin d'éviter les boucles de masse. (Attention: un risque de choc peut exister si le matériel de mesure n'est pas fourni avec un transformateur d'isolement.)

7.6 Mesure *in situ*

7.6.1 Généralités

Lorsque cela est autorisé par la norme de produits pertinente, des mesures *in situ* peuvent être effectuées pour évaluer la conformité si des raisons techniques empêchent d'effectuer des mesures d'émission sur un site d'essai normalisé. Comme raisons techniques, on peut donner une dimension et/ou un poids excessifs du matériel en essai ou des situations dans lesquelles l'interconnexion de l'infrastructure au matériel en essai est trop chère pour que les mesures soient effectuées sur des sites d'essai normalisés. Les résultats de mesures *in situ* d'un type de matériel en essai donné seront différents d'un site à l'autre ou encore lorsque les résultats sont obtenus sur un site d'essai normalisé et que par conséquent il convient de ne pas les utiliser pour les essais de type. La norme de produit applicable a priorité.

La tension perturbatrice doit être mesurée dans les conditions de conduction existantes au moyen d'appareils de lecture non réactifs (sondes de tension à résistance élevée). Les conditions de conduction et les résultats des mesures sont affectés par:

- la masse de référence existante ~~ou la masse de référence~~ utilisée lors des mesures. Ni un plan de masse conducteur ni un réseau fictif ne doivent être utilisés pour les essais dans l'installation de l'utilisateur, à moins que l'un – ou les deux – ne soient inclus de manière permanente dans l'installation;
- les caractéristiques RF et les conditions de charge pour la conduction de l'alimentation électrique;
- l'environnement RF ambiant;
- l'impédance d'entrée de la sonde; et
- les champs magnétiques induits par les équipements faisant partie du système à mesurer ou à proximité.

7.6.2 Masse de référence

Il convient d'utiliser la terre existant à l'emplacement de l'installation comme masse de référence. Il convient de la choisir en prenant en compte des critères de hautes fréquences (RF). Généralement, on obtient ce résultat en connectant le matériel en essai, par l'intermédiaire de connexions larges présentant un rapport longueur-largeur de 3:1, aux parties conductrices de la structure des bâtiments, connectées à la terre ~~de référence~~. Cela comprend, par exemple, les tuyaux d'eau métalliques, les tuyauteries de chauffage central, les conducteurs de protection contre la foudre, les armatures de béton armé, les poutres en acier.

En général, les conducteurs de protection et les conducteurs de neutre de l'installation électrique ne conviennent pas comme masse de référence car ils sont susceptibles de porter d'autres tensions de perturbation et peuvent présenter des impédances RF non définies.

Si aucune masse de référence n'est disponible aux environs du matériel à mesurer ou à l'emplacement des mesures, des structures conductrices suffisamment importantes telles que des feuilles, des tôles ou des treillis en fil métallique, installées à proximité, peuvent être utilisées comme masse de référence pour les mesures.

Il convient d'observer les exigences générales de 7.4.2.2 et de l'Annexe A.

7.6.3 Mesure au moyen de sondes de tension

Les mesures de la tension perturbatrice conduite sont effectuées avec la sonde de tension. Il faut prendre des précautions spéciales pour établir une masse de référence pour les mesures.

Toute baisse de tension provoquée par la charge du circuit à mesurer peut être déterminée qualitativement en faisant varier l'impédance d'entrée de la sonde de tension. Si l'impédance d'entrée de la sonde de tension est élevée par rapport à l'impédance interne du point d'essai ou du réseau en essai, seules de légères différences apparaissent dans les mesures de la tension perturbatrice lorsque l'on augmente l'impédance d'entrée de la sonde. L'impédance d'entrée de la sonde peut être doublée en connectant une résistance de 1 500 Ω en série. Si la tension perturbatrice est ensuite réduite d'une quantité comprise entre 5 dB et 6 dB, la sonde de 1 500 Ω peut alors être utilisée pour mesurer la tension de perturbation.

7.6.4 Choix des points de mesure

7.6.4.1 Généralités

Les mesures de tension perturbatrice radioélectrique à l'emplacement de l'installation sont effectuées aux limites des locaux de l'utilisateur, des zones industrielles, ou encore en des points qui doivent être spécifiés à l'intérieur de la zone d'influence du système de réception.

7.6.4.2 Mesures sur le réseau et sur d'autres conducteurs d'alimentation

Dans les réseaux d'alimentation électrique, il suffit de mesurer la tension perturbatrice non symétrique avec la sonde de tension au niveau des prises de courant accessibles, à proximité de l'entrée d'alimentation du bâtiment.

7.6.4.3 Mesures sur des câbles non blindés et blindés

Dans le cas des câbles de signaux non blindés et blindés, de commande et de charge avec blindage non relié à la masse quittant les limites de l'emplacement, la tension perturbatrice non symétrique doit être mesurée au moyen d'une sonde de tension d'impédance élevée sur les conducteurs individuels ou les écrans, par rapport à la masse de référence. La tension perturbatrice en mode commun peut être mesurée avec une sonde de tension capacitive.

Dans le cas de câbles blindés avec blindage relié à la masse, le courant perturbateur en mode commun se mesure à une distance supérieure à un dixième de la longueur d'onde à partir des points de connexion et de masse en utilisant une sonde de courant.

8 Mesure automatisée des émissions

8.1 Introduction: Précautions pour les mesures automatisées

L'automatisation peut supprimer une grande partie du côté fastidieux de l'exécution des mesures répétées de perturbations électromagnétiques. Les erreurs de l'opérateur dans la lecture et l'enregistrement des valeurs mesurées sont réduites. Toutefois, l'utilisation d'un ordinateur pour recueillir les données peut introduire de nouvelles formes d'erreurs qui auraient pu être détectées par un opérateur. Les essais automatisés peuvent conduire, dans certaines situations, à une plus grande incertitude de mesure dans les données recueillies que celle des mesures manuelles effectuées par un opérateur qualifié. Fondamentalement, il n'y a pas de différence dans la précision avec laquelle une valeur d'émission est mesurée, que ce soit manuellement ou sous contrôle d'un logiciel. Dans les deux cas l'incertitude de mesure est fondée sur les spécifications de précision de l'instrumentation utilisée dans le montage d'essai. Des difficultés peuvent toutefois apparaître lorsque la situation réelle de mesure est différente de celles des scénarios pour lesquels le logiciel a été configuré.


Par exemple, l'émission d'un matériel en essai à une fréquence proche d'un signal ambiant de niveau élevé peut ne pas être mesurée avec précision si le signal ambiant est présent pendant l'essai automatique. Il est plus probable qu'un opérateur entraîné distingue la perturbation réelle et le signal ambiant et qu'il puisse alors adapter la méthode de mesure du matériel en essai en conséquence. Toutefois il est possible de gagner un temps précieux sur les essais en effectuant un balayage ambiant, le matériel en essai étant coupé, avant les mesures d'émissions réelles, afin d'enregistrer les signaux ambiants présents sur l'emplacement en champ libre. Dans ce cas, le logiciel peut être capable d'avertir l'opérateur de la présence possible de signaux ambiants à certaines fréquences en utilisant des algorithmes appropriés d'identification du signal.

L'interaction de l'opérateur est recommandée si l'émission du matériel en essai varie lentement, si son cycle d'apparition est faible ou si des signaux ambiants transitoires peuvent se produire (par exemple transitoires de soudure à l'arc).

8.2 Procédure générale de mesure

Il est nécessaire que les signaux soient interceptés par le récepteur de perturbations avant qu'ils puissent être maximisés et mesurés. L'utilisation du détecteur de quasi-crête pendant le processus de maximisation pour toutes les fréquences du spectre considéré conduit à des durées d'essai excessives (voir 6.6.2). Les processus qui prennent du temps, comme le balayage en hauteur de l'antenne, ne sont pas nécessaires à chaque fréquence d'émission. Il convient que ces processus soient limités aux fréquences auxquelles l'amplitude crête de l'émission mesurée est supérieure ou proche de la limite. En conséquence, seules les émissions aux fréquences critiques dont les amplitudes sont proches ou dépassent la limite seront maximisées et mesurées.

La procédure générique suivante conduit à une réduction du temps de mesure:



IEC 1620/08

8.3 Mesures par pré-balayage

Cette étape initiale de la procédure complète de mesure a de multiples buts. Le pré-balayage impose le plus faible nombre de restrictions et d'exigences au système d'essai du fait que son but principal est de réunir une quantité minimale d'informations sur lesquelles les paramètres des essais ou des balayages complémentaires seront basés. Ce mode de mesure peut être utilisé pour les essais d'un nouveau produit, lorsque l'on est très peu familiarisé avec son spectre d'émission. En général, le pré-balayage est une procédure d'acquisition de données utilisée pour déterminer où, dans la bande de fréquences considérée, sont situés les signaux significatifs. Une amélioration de la précision en fréquence et une réduction des données par comparaison des amplitudes peuvent s'avérer nécessaires. Ces facteurs définissent la séquence de mesure pendant l'exécution du pré-balayage. Dans tous les cas, les résultats seront enregistrés dans une liste de signaux pour traitement ultérieur.

Lorsqu'une mesure par pré-balayage est effectuée pour obtenir rapidement des informations sur un équipement en essai dont le spectre d'émission est inconnu, un balayage en fréquence peut être effectué en appliquant les considérations du 6.6.

Détermination du temps de mesure nécessaire:

Si le spectre d'émission et spécialement l'intervalle maximal de répétition des impulsions T_p de l'équipement en essai est inconnu, ce point doit être étudié pour s'assurer que le temps de mesure T_m n'est pas plus court que T_p . Le caractère intermittent des émissions de l'équipement en essai est spécialement important pour les crêtes critiques du spectre d'émission. Il convient de déterminer d'abord à quelles fréquences l'amplitude de l'émission n'est pas stable. Ceci peut être effectué en comparant le maintien du maximum avec le maintien du minimum ou la fonction «effacer/écrire» de l'appareil de mesure ou du logiciel, et en observant l'émission pendant 15 s. Pendant cette période, il convient qu'aucune modification du câblage ne soit effectuée. Les signaux ayant par exemple plus de 2 dB de différence entre le résultat du maintien du maximum et le résultat du maintien du minimum sont notés comme des signaux intermittents. (On doit prendre soin de ne pas noter le bruit comme des signaux intermittents.) On répète la mesure pour réduire le risque d'omission de certaines crêtes intermittentes qui seraient restées en dessous du niveau de bruit. Pour chaque signal intermittent, l'intervalle de répétition T_p peut être mesuré en utilisant le mode intervalle nul ou en utilisant un oscilloscope branché à la sortie f.i. vidéo du récepteur. La durée de mesure correcte peut aussi être déterminée en l'augmentant jusqu'à ce que la différence entre l'affichage du maintien du maximum et celui de la fonction «effacer/écrire» soit inférieure par exemple à 2 dB. Pendant les mesures suivantes (maximisation et mesure finale), on doit s'assurer pour chaque partie de la gamme de fréquences que la durée de mesure T_m n'est pas inférieure à l'intervalle de répétition applicable T_p .

Pour les mesures des émissions conduites, le pré-balayage est défini ainsi: il peut être effectué soit sur un câble représentatif, par exemple le câble «L» d'alimentation soit sur chaque câble en utilisant une détection de crête et la durée de balayage la plus courte possible. Si la mesure est effectuée sur de multiples câbles, il convient d'utiliser une fonction «maintien du maximum» pour retenir les émissions les plus élevées trouvées pendant la mesure.

8.4 Réduction des données

La seconde étape de la procédure complète de mesure est utilisée pour réduire le nombre des signaux recueillis pendant le pré-balayage et a donc pour but de réduire davantage la durée totale de mesure. Ces procédés peuvent effectuer différentes tâches, par exemple la détermination des signaux significatifs dans le spectre, la discrimination entre les signaux ambiants ou provenant d'appareils auxiliaires et ceux du matériel en essai, la comparaison des signaux avec les limites, ou la réduction des données basées sur des règles définissables par l'utilisateur. Un autre exemple des méthodes de réduction des données par utilisation en séquence de différents détecteurs et des comparaisons de l'amplitude par rapport à la limite, est donné par l'arbre de décision de l'Annexe C de la présente norme. La réduction des données peut être effectuée de façon entièrement automatique ou interactive en utilisant des outils logiciels ou une interaction manuelle de l'opérateur. Il n'est pas nécessaire qu'elle soit une partie séparée des essais automatisés, c'est-à-dire qu'elle peut faire partie du pré-balayage.

Dans certaines gammes de fréquences, une discrimination acoustique des signaux ambiants est très efficace. Ceci demande une démodulation des signaux pour entendre le contenu de leur modulation. Si une liste en sortie d'un pré-balayage contient un grand nombre de signaux et qu'une discrimination acoustique est nécessaire, le processus peut être plutôt long. Toutefois, si les gammes de fréquences, dans lesquelles un accord et une écoute sont nécessaires, peuvent être spécifiées, alors uniquement les signaux dans ces gammes seront démodulés. Les résultats du processus de réduction des données sont enregistrés dans une liste de signaux séparée pour traitement ultérieur.

8.5 Maximisation des émissions et mesures finales

Pendant l'essai final, les émissions sont maximisées pour déterminer leur niveau le plus élevé. Après la maximisation des signaux, l'amplitude des émissions est mesurée avec une détection de quasi-crête et/ou de valeur moyenne, en tenant compte de la durée de mesure appropriée (au moins 15 s si la lecture montre des fluctuations proche de la limite).

Pour les mesures des **émissions conduites**, le processus de maximisation est défini par comparaison des amplitudes des émissions sur les différents câbles du cordon d'alimentation du matériel en essai et mémorisation des niveaux maximaux.

NOTE La mesure finale peut être effectuée en parallèle à plusieurs fréquences en utilisant un appareil de mesure à FFT.

8.6 Post-traitement et rapport

La dernière partie de la procédure d'essai concerne les exigences de documentation. Les fonctionnalités pour définir le tri et les routines de comparaison qui pourront ensuite être appliquées automatiquement ou de façon interactive aux listes de signaux, aident l'utilisateur à compiler les rapports et documents nécessaires. Il convient que les amplitudes corrigées des signaux en valeur crête, quasi-crête ou moyenne, soient disponibles, comme un tri ou des critères de sélection. Les résultats de ces processus sont enregistrés dans des listes de sortie séparées ou peuvent être rassemblés dans une seule liste et sont disponibles pour la documentation ou traitement ultérieur.

Les résultats doivent être disponibles sous forme de tableaux ou de graphiques ou d'une combinaison des deux pour pouvoir être utilisés dans un rapport d'essai. De plus, il convient que les informations sur le système d'essai lui-même, par exemple les transducteurs utilisés, l'instrumentation de mesure, et la documentation relative au montage de l'équipement en essai telle qu'exigé par la norme de produits, fassent également partie du rapport d'essai.

8.7 Stratégies de la mesure d'émissions avec des appareils de mesure à FFT

En fonction de leur mise en œuvre, les appareils de mesure à FFT peuvent effectuer des mesures pondérées d'une façon significativement plus rapide que les voltmètres sélectifs. Une mesure pondérée sur la plage de fréquences concernée peut alors être plus rapide qu'une mesure constituée d'un pré-balayage et d'un balayage final effectués avec un récepteur superhétérodyne, comme décrit en 8.2.

Annexe A (informative)

Guide pour la connexion d'un matériel électrique au réseau fictif (voir Article 5)

A.1 Introduction

La présente annexe a pour but de fournir des indications générales sur les techniques pouvant servir à évaluer les perturbations produites par certains matériels électriques dans la gamme de fréquences de 9 kHz à 30 MHz. Cette annexe donne des informations sur les méthodes de connexion de ces matériels au réseau fictif pour la mesure des tensions aux bornes. Un tableau présente les différents cas généralement rencontrés dans la pratique pour lesquels une technique appropriée peut être choisie.

Les cas décrits ci-dessous en A.2 identifient la propagation de la perturbation du matériel en essai:

- a) soit par **conduction** le long des cordons d'alimentation raccordés (désignés par E_1 et I_1 dans les schémas de circuit équivalents),
- b) soit par **rayonnement** et par un couplage avec le cordon d'alimentation raccordé (désigné par E_2 et I_2 dans les schémas de circuit équivalents).

Le fait que la perturbation soit plutôt conduite ou rayonnée dépend en partie de la disposition du matériel en essai par rapport à la référence de sol (y compris le type de connexion à la masse de référence) et du type de connexion entre le matériel en essai et le réseau fictif (câble blindé ou non).

A.2 Classification des différents cas possibles

A.2.1 Matériels en essai correctement blindés mais mal filtrés (Figures A.1 et A.2)

Dans ce cas, la composante de perturbation conduite représentée par le courant I_1 domine. Le courant perturbateur I_1 est injecté sur le réseau fictif Z par le matériel en essai. Par conséquent, la tension U_1 augmente quand on fait augmenter la capacité C_1 entre le blindage du matériel en essai et la masse de référence (voir Figure A.1). La tension U_1 atteint son maximum ($U_1 = Z I_1 = E_1$) quand on minimise l'impédance du trajet de retour du courant en court-circuitant C_1 directement ou en utilisant des câbles blindés pour alimenter le matériel en essai (voir Figure A.2). (Voir également la discussion en A.3.)




Figure A.1




Figure A.2

A.2.2 Matériels en essai correctement filtrés mais dont le blindage présente des fuites (Figures A.3 et A.4)

Dans ce cas, le courant perturbateur injecté dans le réseau est pratiquement nul, et la tension dans le réseau fictif est susceptible d'être dominée par un rayonnement parasite provenant soit d'ouvertures dans un blindage imparfait, soit d'un conducteur sortant du blindage et formant antenne. Ces fuites peuvent être représentées schématiquement par une capacité externe C_2 connectée entre une source de f.é.m. perturbatrice interne E_2 et la masse. Cette capacité C_2 est traversée par un courant I_2 . Une partie du courant I_2 qui traverse C_2 en direction de la masse de référence circule en retour au travers de C_1 et une partie de I_2 circule en retour au travers du réseau fictif. Si les cordons d'alimentation ne sont pas blindés (Figure A.3) et que l'impédance de C_1 est grande par rapport à l'impédance du réseau fictif Z ($ZC_1 \omega \ll 1$), I_2' est voisin de I_2 et la tension U_2 est voisine de $I_2 Z$ ($U_2 = ZI_2$).

Si l'on augmente C_1 , on shunte Z et U_2 diminue. A la limite, lorsque l'on court-circuite C_1 en alimentant le matériel en essai par des cordons blindés (Figure A.4), de façon que I_2 ne traverse absolument pas Z , U_2 devient nulle.




Figure A.3




Figure A.4

A.2.3 Cas général

A.2.3.1 Généralités

Le plus souvent en pratique, les blindages et filtrages sont imparfaits; les deux effets précédents se manifestent alors simultanément et se superposent. On peut, dans ces conditions, rencontrer les trois cas suivants.

A.2.3.2 Alimentation par des conducteurs blindés (Figure A.5)

Le courant I_1 dû aux fuites par rayonnement se ferme par la masse et les surfaces externes du blindage du réseau fictif et des conducteurs d'alimentation; son effet sur Z est nul.

La tension U_1 , mesurée aux bornes de Z , est produite uniquement par le courant I_1 , injecté sur les conducteurs d'alimentation, avec retour par les surfaces internes du blindage du réseau fictif et de ces conducteurs. La tension U_1 a alors sa valeur maximale:

$$U_1 = ZI_1 \approx E_1$$




Figure A.5

A.2.3.3 Alimentation par des conducteurs non blindés mais filtrés (Figure A.6)

Si l'on ajoute, à l'entrée du matériel en essai, un filtre passe-bas très efficace dont le blindage est relié directement à celui du matériel en essai, le courant I_1 injecté par la source E_1 sur le circuit d'alimentation est bloqué par le filtre.

Comme dans le cas de la Figure A.6, le courant I_2 dû au rayonnement se ferme pratiquement par Z et par les conducteurs (si $ZC_1 \omega \ll 1$); la tension U_2 mesurée aux bornes de Z est alors produite uniquement par le rayonnement.




Figure A.6