

First edition
2001-04-01

AMENDMENT 1
2014-12-15

**Fire resistance tests — Fire dampers
for air distribution systems —**

Part 4:

Test of thermal release mechanism

**AMENDMENT 1: Specific performance
requirement for thermal release
mechanism based upon performance of
thermal release mechanism used in ISO
10294-1 test specimen**

*Essai de résistance au feu — Clapets résistant au feu pour systèmes de
distribution d'air —*

Partie 4: Méthode d'essai du mécanisme de déclenchement thermique

*AMENDEMENT 1: Exigence de performance spécifique du mécanisme de
déclenchement thermique fondée sur le mécanisme de déclenchement
thermique utilisé dans l'éprouvette d'essai de l'ISO 10294-1*



Reference number
ISO 10294-4:2001/Amd.1:2014(E)

© ISO 2014

STANDARDSISO.COM : Click to view the full PDF of ISO 10294-4:2001/Amd 1:2014



COPYRIGHT PROTECTED DOCUMENT

© ISO 2014

All rights reserved. Unless otherwise specified, no part of this publication may be reproduced or utilized otherwise in any form or by any means, electronic or mechanical, including photocopying, or posting on the internet or an intranet, without prior written permission. Permission can be requested from either ISO at the address below or ISO's member body in the country of the requester.

ISO copyright office
Case postale 56 • CH-1211 Geneva 20
Tel. + 41 22 749 01 11
Fax + 41 22 749 09 47
E-mail copyright@iso.org
Web www.iso.org

Published in Switzerland

Foreword

ISO (the International Organization for Standardization) is a worldwide federation of national standards bodies (ISO member bodies). The work of preparing International Standards is normally carried out through ISO technical committees. Each member body interested in a subject for which a technical committee has been established has the right to be represented on that committee. International organizations, governmental and non-governmental, in liaison with ISO, also take part in the work. ISO collaborates closely with the International Electrotechnical Commission (IEC) on all matters of electrotechnical standardization.

The procedures used to develop this document and those intended for its further maintenance are described in the ISO/IEC Directives, Part 1. In particular the different approval criteria needed for the different types of ISO documents should be noted. This document was drafted in accordance with the editorial rules of the ISO/IEC Directives, Part 2 (see www.iso.org/directives).

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. ISO shall not be held responsible for identifying any or all such patent rights. Details of any patent rights identified during the development of the document will be in the Introduction and/or on the ISO list of patent declarations received (see www.iso.org/patents).

Any trade name used in this document is information given for the convenience of users and does not constitute an endorsement.

For an explanation on the meaning of ISO specific terms and expressions related to conformity assessment, as well as information about ISO's adherence to the WTO principles in the Technical Barriers to Trade (TBT) see the following URL: [Foreword - Supplementary information](#)

The committee responsible for this document is ISO/TC 92, *Fire safety*, Subcommittee SC 2, *Fire containment*.

STANDARDSISO.COM : Click to view the full PDF of ISO 10294-4:2001/Amd 1:2014

Fire resistance tests — Fire dampers for air distribution systems —

Part 4: Test of thermal release mechanism

AMENDMENT 1: Specific performance requirement for thermal release mechanism based upon performance of thermal release mechanism used in ISO 10294-1 test specimen

Page 3, 4.2

Amendment adds new performance requirement for thermal release mechanism based upon performance of the thermal release mechanism used in ISO 10294 test specimen. The new requirement is contained in 4.2.2.1.

The amendment places the existing performance requirement for thermal release mechanisms in 4.2.2.2.

The amendment reorganizes 4.2 by adding subclauses

The new material is underlined. Material being moved to a new location is represented by ~~strike through~~.

4.2 Response behaviour

4.2.1 Starting at an initial temperature of $(25 \pm 2) ^\circ\text{C}$, the specimen shall be exposed to an increasing air temperature such that it follows the relationship (see Figure 3):

$$T = (25 + 20t) \pm 2$$

where

T is the temperature, in degrees Celsius;

t is the time from the start of the test period, in minutes.

~~The response threshold of the thermal release mechanism shall not exceed an 80 °C rise above the starting temperature. A 25 °C initial temperature and 80 °C maximum temperature rise means that the maximum temperature of activation (threshold limit) will be 105 °C. This means that the thermal release mechanism shall operate within 4 min. This test may be applied to other operating temperatures and guidance is given Annex B.~~

The mean air velocity at the start of this test shall be $(1 \pm 0,1)$ m/s. The test shall be performed three times for each orientation and location of the thermal release mechanism. The thermal release mechanism shall operate before the threshold limit is exceeded on each of the samples tested.

4.2.2 The response threshold of the thermal release mechanism shall not exceed:

4.2.2.1 The time equaling the average of the threshold time +10% determined from a minimum of three tests on thermal release mechanisms representative of the thermal release mechanism used in the ISO 10294-1 test specimen. A thermal release mechanism that has been previously tested to ISO 10294-1 fire damper test shall be used to determine a threshold response time. Three thermal release mechanisms, selected from a batch of five, shall be evaluated using the method described in this International Standard. The threshold response time shall be determined as the average response time of these three thermal release mechanism for each orientation required (see 6.1). Or

4.2.2.2 The time required for an 80 °C rise above the starting temperature. A 25 °C initial temperature and 80 °C maximum temperature rise means that the maximum temperature of activation (threshold limit) will be 105 °C. This means that the thermal release mechanism shall operate within 4 min. This test may be applied to other operating temperatures, and guidance is given in Annex B.

STANDARDSISO.COM : Click to view the full PDF of ISO 10294-4:2001/Amd 1:2014