
**Measurement of radioactivity in the
environment — Air: radon-222 —**

**Part 4:
Integrated measurement method
for determining average activity
concentration using passive sampling
and delayed analysis**

Mesurage de la radioactivité dans l'environnement — Air: radon 222 —

*Partie 4: Méthode de mesure intégrée pour la détermination de
l'activité volumique moyenne du radon avec un prélèvement passif et
une analyse en différé*



STANDARDSISO.COM : Click to view the full PDF of ISO 11665-4:2020



COPYRIGHT PROTECTED DOCUMENT

© ISO 2020

All rights reserved. Unless otherwise specified, or required in the context of its implementation, no part of this publication may be reproduced or utilized otherwise in any form or by any means, electronic or mechanical, including photocopying, or posting on the internet or an intranet, without prior written permission. Permission can be requested from either ISO at the address below or ISO's member body in the country of the requester.

ISO copyright office
CP 401 • Ch. de Blandonnet 8
CH-1214 Vernier, Geneva
Phone: +41 22 749 01 11
Fax: +41 22 749 09 47
Email: copyright@iso.org
Website: www.iso.org

Published in Switzerland

Contents

Page

Foreword	iv
Introduction	v
1 Scope	1
2 Normative references	1
3 Terms, definitions and symbols	1
3.1 Terms and definitions	1
3.2 Symbols	2
4 Principle	2
5 Equipment	3
6 Sampling	3
6.1 Sampling objective	3
6.2 Sampling characteristics	3
6.3 Sampling conditions	3
6.3.1 General	3
6.3.2 Installation of the sensor	3
6.3.3 Sampling duration	4
6.3.4 Volume of air sampled	4
7 Detection	5
8 Measurement	5
8.1 Procedure	5
8.2 Influence quantities	5
8.3 Calibration	5
9 Expression of results	5
9.1 Average radon activity concentration	5
9.2 Standard uncertainty	5
9.3 Decision threshold and detection limit	6
9.4 Limits of the confidence interval	6
10 Test report	6
Annex A (informative) Measurement method using a solid-state nuclear track detector (SSNTD)	8
Annex B (informative) Measurement method using an electret detector	14
Annex C (informative) Measurement method using activated charcoal	22
Bibliography	31

Foreword

ISO (the International Organization for Standardization) is a worldwide federation of national standards bodies (ISO member bodies). The work of preparing International Standards is normally carried out through ISO technical committees. Each member body interested in a subject for which a technical committee has been established has the right to be represented on that committee. International organizations, governmental and non-governmental, in liaison with ISO, also take part in the work. ISO collaborates closely with the International Electrotechnical Commission (IEC) on all matters of electrotechnical standardization.

The procedures used to develop this document and those intended for its further maintenance are described in the ISO/IEC Directives, Part 1. In particular the different approval criteria needed for the different types of ISO documents should be noted. This document was drafted in accordance with the editorial rules of the ISO/IEC Directives, Part 2 (see www.iso.org/directives).

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. ISO shall not be held responsible for identifying any or all such patent rights. Details of any patent rights identified during the development of the document will be in the Introduction and/or on the ISO list of patent declarations received (see www.iso.org/patents).

Any trade name used in this document is information given for the convenience of users and does not constitute an endorsement.

For an explanation on the voluntary nature of standards, the meaning of ISO specific terms and expressions related to conformity assessment, as well as information about ISO's adherence to the World Trade Organization (WTO) principles in the Technical Barriers to Trade (TBT) see the following URL: www.iso.org/iso/foreword.html.

This document was prepared by Technical Committee ISO/TC 85, *Nuclear energy, nuclear technologies, and radiological protection*, Subcommittee SC 2, *Radiological protection*.

This second edition cancels and replaces the first edition (ISO 11665-4:2012), of which it constitutes a minor revision. The changes compared to the previous edition are as follows:

- update of the Introduction;
- update of the Bibliography.

A list of all the parts in the ISO 11665 series can be found on the ISO website.

Any feedback or questions on this document should be directed to the user's national standards body. A complete listing of these bodies can be found at www.iso.org/members.html.

Introduction

Radon isotopes 222, 219 and 220 (also known as thoron) are radioactive gases produced by the disintegration of radium isotopes 226, 223 and 224, which are decay products of uranium-238, uranium-235 and thorium-232 respectively, and are all found in the earth's crust (see [Annex A](#) for further information). Solid elements, also radioactive, followed by stable lead are produced by radon disintegration^[1].

When disintegrating, radon emits alpha particles and generates solid decay products, which are also radioactive (polonium, bismuth, lead, etc.). The potential effects on human health of radon lie in its solid decay products rather than the gas itself. Whether or not they are attached to atmospheric aerosols, radon decay products can be inhaled and deposited in the bronchopulmonary tree to varying depths according to their size^{[2][3][4][5]}.

Radon is today considered to be the main source of human exposure to natural radiation. UNSCEAR^[6] suggests that, at the worldwide level, radon accounts for around 52 % of global average exposure to natural radiation. The radiological impact of isotope 222 (48 %) is far more significant than isotope 220 (4 %), while isotope 219 is considered negligible (see [Annex A](#)). For this reason, references to radon in this document refer only to radon-222.

Radon activity concentration can vary from one to more orders of magnitude over time and space. Exposure to radon and its decay products varies tremendously from one area to another, as it depends on the amount of radon emitted by the soil and building materials, weather conditions, and on the degree of containment in the areas where individuals are exposed.

As radon tends to concentrate in enclosed spaces like houses, the main part of the population exposure is due to indoor radon. Soil gas is recognized as the most important source of residential radon through infiltration pathways. Other sources are described in other parts of ISO 11665 and ISO 13164 series for water^[7].

Radon enters into buildings via diffusion mechanism caused by the all-time existing difference between radon activity concentrations in the underlying soil and inside the building, and via convection mechanism inconstantly generated by a difference in pressure between the air in the building and the air contained in the underlying soil. Indoor radon activity concentration depends on radon activity concentration in the underlying soil, the building structure, the equipment (chimney, ventilation systems, among others), the environmental parameters of the building (temperature, pressure, etc.) and the occupants' lifestyle.

To limit the risk to individuals, a national reference level of 100 Bq·m⁻³ is recommended by the World Health Organization^[8]. Wherever this is not possible, this reference level should not exceed 300 Bq·m⁻³. This recommendation was endorsed by the European Community Member States that shall establish national reference levels for indoor radon activity concentrations. The reference levels for the annual average activity concentration in air shall not be higher than 300 Bq·m⁻³^[5].

To reduce the risk to the overall population, building codes should be implemented that require radon prevention measures in buildings under construction and radon mitigating measures in existing buildings. Radon measurements are needed because building codes alone cannot guarantee that radon concentrations are below the reference level.

The activity concentration of radon-222 in the atmosphere can be measured by spot, continuous and integrated measurement methods with active or passive air sampling (see ISO 11665-1). This document deals with radon-222 integrated measurement techniques with passive sampling.

NOTE The origin of radon-222 and its short-lived decay products in the atmospheric environment and other measurement methods are described generally in ISO 11665-1.

STANDARDSISO.COM : Click to view the full PDF of ISO 11665-4:2020

Measurement of radioactivity in the environment — Air: radon-222 —

Part 4:

Integrated measurement method for determining average activity concentration using passive sampling and delayed analysis

1 Scope

This document describes radon-222 integrated measurement techniques with passive sampling. It gives indications for determining the average activity concentration of the radon-222 in the air from measurements based on easy-to-use and low-cost passive sampling, and the conditions of use for the sensors.

This document covers samples taken without interruption over periods varying from a few days to one year.

This measurement method is applicable to air samples with radon activity concentrations greater than 5 Bq/m³.

2 Normative references

The following documents are referred to in the text in such a way that some or all of their content constitutes requirements of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

ISO 11665-1, *Measurement of radioactivity in the environment — Air: radon-222 — Part 1: Origins of radon and its short-lived decay products and associated measurement methods*

ISO 11929 (all parts), *Determination of the characteristic limits (decision threshold, detection limit and limits of the coverage interval) for measurements of ionizing radiation — Fundamentals and application*

ISO/IEC Guide 98-3, *Uncertainty of measurement — Part 3: Guide to the expression of uncertainty in measurement (GUM:1995)*

ISO/IEC 17025, *General requirements for the competence of testing and calibration laboratories*

IEC 61577-1, *Radiation protection instrumentation — Radon and radon decay product measuring instruments — Part 1: General principles*

3 Terms, definitions and symbols

3.1 Terms and definitions

For the purposes of this document, the terms and definitions given in ISO 11665-1 apply.

ISO and IEC maintain terminological databases for use in standardization at the following addresses:

- ISO Online browsing platform: available at <http://www.iso.org/obp>
- IEC Electropedia: available at <http://www.electropedia.org/>

3.2 Symbols

For the purposes of this document, the symbols given in ISO 11665-1 and the following apply.

$\bar{C}$	average activity concentration, in becquerels per cubic metre
$\bar{C}^*$	decision threshold of the average activity concentration, in becquerels per cubic metre
$\bar{C}^\#$	detection limit of the average activity concentration, in becquerels per cubic metre
$\bar{C}^\Delta$	lower limit of the confidence interval of the average activity concentration, in becquerels per cubic metre
$\bar{C}^\triangleright$	upper limit of the confidence interval of the average activity concentration, in becquerels per cubic metre
t	sampling duration, in hours
U	expanded uncertainty calculated by $U = k \cdot u(\)$ with $k = 2$
$u(\)$	standard uncertainty associated with the measurement result
$u_{\text{rel}}(\)$	relative standard uncertainty
μ	quantity to be measured
μ_0	background level
ω	correction factor linked to the calibration factor and the sampling duration

4 Principle

Integrated measurement of the average radon activity concentration is based on the following elements:

- continuous, passive sampling of an air sample representative of the atmosphere under investigation, by free convection and natural diffusion for a sensor in an open configuration (open to the air) or by natural diffusion for a sensor in a closed configuration (with an accumulation chamber);
- simultaneous accumulation of a measurable physical quantity (etched tracks, electrostatic potential drop, radioactive atoms, etc.) on a suitable sensor;
- measurement of the accumulated physical quantity with a direct link to the average radon activity concentration over the sampling period in question.

Several measurement methods meet the requirements of this document. They are basically distinguished by the type of accumulated physical quantity and how it is measured. The physical quantity and its related measurement may be as follows, for example:

- “latent tracks” produced in a polymer [solid-state nuclear track detector (SSNTD)] by ionization from alpha particles of the radon and its decay products; these latent tracks are detected and counted (see [Annex A](#));
- charges produced in a solid [semi-conductor medium (silicon)] by ionisation from alpha particles of the radon and its decay products; they are detected by related electronics;
- discharge of an electret (non-rechargeable, positively charged element) by ionisation of the air due to the radioactive disintegration of radon and its decay products; the voltage variation relating to this discharge is measured (see [Annex B](#));

- atoms of ^{222}Rn adsorbed on charcoal; the gamma emission rates of the decay products ^{214}Pb and ^{214}Bi are measured with a gamma spectrometer (see [Annex C](#)).

Analysis of the physical quantity might not be immediate and might require laboratory operations.

The result of integrated measurement is the exposure of a sensor to radon over the sampling duration in question. The average radon activity concentration is calculated by dividing the exposure result by the sampling duration.

5 Equipment

The apparatus shall include the following:

- a sensor which collects the physical quantity (SSNTD, silicon detector, electret detector, activated charcoal, etc.), either alone or with an accumulation chamber made from a conductive plastic material with a known detection volume; in closed configuration, the sensor is placed in a closed accumulation chamber with a filter and in open configuration, the sensor is in direct relation with the atmosphere (no accumulation chamber);
- a detection system adapted to the accumulated physical quantity.

The necessary equipment for each measurement method is specified in [Annexes A](#), [B](#) and [C](#) respectively.

6 Sampling

6.1 Sampling objective

The sampling objective is to place the sensor (SSNTD, silicon detector, electret detector, activated charcoal, etc.), within the normal occupied space of the atmospheric medium under investigation.

6.2 Sampling characteristics

Sampling is passive.

In the closed configuration, sampling is performed through a filtering medium, thus only radon alpha particles are detected by the sensor (see [Clause 5](#)). Sampling shall be performed in conditions that preclude clogging of the filtering medium, which would result in modified measuring conditions. Clogging during sampling can lead to the non-renewal of air in the accumulation chamber.

Using an open configuration, the sensor simultaneously records the alpha emissions of the radon and those of its decay products near its surface. It also records any alpha emitter present in the analysed atmosphere, in the energy range specified by the manufacturer. This configuration shall be used under conditions that preclude fouling (dust-filled atmosphere, grease deposit, etc.) of the sensor, which would result in modified measuring conditions.

6.3 Sampling conditions

6.3.1 General

Sampling shall be carried out as specified in ISO 11665-1.

6.3.2 Installation of the sensor

Installation of the sensor shall be carried out as specified in ISO 11665-1.

In the specific case of indoor measurement, the sensor should be placed in a normally occupied or occupiable zone on a clear surface between 1 m and 2 m above the ground, i.e. the "breathing zone" under the following conditions:

- a) a clear space of at least 20 cm should be left around the sensor to avoid the influence of thoron exhalation from the walls;
- b) the sensor should be placed away from any heat sources (radiator, chimney, electrical equipment, television, direct sunlight, etc.) and from areas of traffic, doors and windows, walls and natural ventilation sources;
- c) the installation conditions should not be disturbed during measurement (books falling, engineers working, curiosity, etc.); recommendations should be made to occupants in order to prevent the change of sampling conditions;
- d) the sensor should also be made secure during measurement, in order to prevent any damage.

6.3.3 Sampling duration

The sampling duration is equal to the time interval between installation and removal of the sensor at the sampling point.

Time of installation and removal of the sensor shall be recorded (date and hour).

The sampling duration shall be adjusted to suit the phenomenon under investigation, the assumed radioactivity and the sensor characteristics (see [Table 1](#)).

Table 1 — Examples of sampling characteristics of the various measurement methods meeting the requirements of this document

Sensor	Annex (normative)	Sampling place	Sampling duration/ Exposure time
Solid-state nuclear track detector (open configuration)	A	Indoors	One week to several months
Solid-state nuclear track detector (closed configuration)			
Electret detector	B	Outdoors or indoors	Few days to several months
Activated charcoal	C		Few days

The sampling duration shall be determined on the basis of the intended use of the measurement results.

For example, indoor concentrations vary not only over a day but also between days of the week because of variations in occupancy. In this case, it would be reasonable to sample over a whole week in order to include these variations.

To approach the annual average value of the radon activity concentration in the buildings and not under-estimate it, it is advisable to perform measurements for at least two months (see ISO 11665-8).

Users should be aware of the saturation characteristics of their sensors and should adapt the sampling duration to ensure that saturation does not occur.

6.3.4 Volume of air sampled

For passive sampling, direct measurement of the air volume sampled is not necessary. A calibration factor, in activity per unit volume, shall be used.

7 Detection

Depending on the sensor used, detection shall be carried out using solid-state nuclear track detectors (SSNTD), discharge of a polarized surface inside an ionization chamber, gamma-ray spectrometry or liquid scintillation, as described in ISO 11665-1.

8 Measurement

8.1 Procedure

The measurement procedure for each measurement method shall be as specified in [Annexes A, B and C](#) respectively.

8.2 Influence quantities

Various quantities can lead to measurement bias that could induce non-representative results. Depending on the measurement method and the control of usual influence quantities specified in IEC 61577-1 and ISO 11665-1, the influence quantities of particular importance for each measurement method described in this document are specified in [Annexes A, B and C](#) respectively.

Manufacturer recommendations in the operating instructions for the sensors shall be followed.

8.3 Calibration

The measuring system (sensor and detection system) shall be calibrated annually as specified in ISO 11665-1. Additional requirements for the devices used for particular methods are specified in the relevant annexes (see [Annexes A, B and C](#)).

The relationship between the physical quantity recorded by the sensor (number of etched tracks, number of electric charges, pulse count and amplitudes, etc.) and the activity concentration of the radon in the air shall be established based on the measurement of a radon-222 reference atmosphere. The radon-222 activity concentration in the reference atmosphere shall be traceable to a primary radon-222 gas standard.

In addition to calibration, consideration should be given to regular testing to ensure measurements remain suitable for use. These should include internal blind tests and external proficiency, validation or interlaboratory comparisons.

9 Expression of results

9.1 Average radon activity concentration

The average radon activity concentration shall be calculated as given in [Formula \(1\)](#):

$$\bar{C} = (\mu - \mu_0) \cdot \omega \quad (1)$$

9.2 Standard uncertainty

In accordance with ISO/IEC Guide 98-3, the standard uncertainty of $\bar{C}$ shall be calculated as given in [Formula \(2\)](#):

$$u(\bar{C}) = \sqrt{\omega^2 \cdot [u^2(\mu) + u^2(\mu_0)] + \bar{C}^2 \cdot u_{\text{rel}}^2(\omega)} \quad (2)$$

9.3 Decision threshold and detection limit

The characteristic limits associated with the measurand shall be calculated in accordance with ISO 11929 (all parts). Examples of the calculations of uncertainties and characteristic limits are detailed in [Annexes A, B and C](#) for each respective measurement method described.

9.4 Limits of the confidence interval

The lower, $\bar{C}^{\triangleleft}$, and upper, $\bar{C}^{\triangleright}$, limits of the confidence interval shall be calculated using [Formulae \(3\) and \(4\)](#) [see ISO 11929 (all parts)]:

$$\bar{C}^{\triangleleft} = \bar{C} - k_p \cdot u(\bar{C}); p = \omega \cdot (1 - \gamma/2) \quad (3)$$

$$\bar{C}^{\triangleright} = \bar{C} + k_q \cdot u(\bar{C}); q = 1 - \omega \cdot \gamma/2 \quad (4)$$

where

$\omega = \Phi[y/u(y)]$, Φ being the distribution function of the standardized normal distribution;

$\omega = 1$ may be set if $\bar{C} \geq 4 \cdot u(\bar{C})$, in which case:

$$\bar{C}^{\triangleleft\triangleright} = \bar{C} \pm k_{1-\gamma/2} \cdot u(\bar{C}) \quad (5)$$

$\gamma = 0,05$ with $k_{1-\gamma/2} = 1,96$ are often chosen by default.

10 Test report

10.1 The test report shall be in accordance with the requirements of ISO/IEC 17025 and shall contain the following information:

- a) reference to this document, i.e. ISO 11665-4:2020;
- b) measurement method (integrated);
- c) identification of the type of sensor;
- d) identification of the sample;
- e) sampling characteristic (passive);
- f) sampling times: start and end time (date and hour);
- g) duration of sampling;
- h) sampling location;
- i) units in which the results are expressed;
- j) test result, $\bar{C} \pm u(\bar{C})$ or $\bar{C} \pm U$, with the associated k value.

10.2 Complementary information may be provided, such as the following:

- a) purpose of the measurement;
- b) probabilities α , β and $(1-\gamma)$;

- c) the decision threshold and the detection limit; depending on the customer request, there are different ways to present the result:
- 1) when the average radon activity concentration is compared with the decision threshold [see ISO 11929 (all parts)], the result of the measurement shall be expressed as $\leq \bar{C}^*$ if the result is below the decision threshold;
 - 2) when the average radon activity concentration is compared with the detection limit, the result of the measurement shall be expressed as $\leq \bar{C}^\#$ if the result is below the detection limit or, if the detection limit exceeds the guideline value, it shall be documented that the method is not suitable for the measurement purpose;
- d) any relevant information likely to affect the results, for example:
- 1) weather conditions at the time of sampling;
 - 2) ventilation conditions for indoor measurement (mechanical ventilation system, doors and windows open or shut, etc.).

10.3 The results can be expressed in a similar format to that shown in ISO 11665-1:2019, Annex C.

Annex A (informative)

Measurement method using a solid-state nuclear track detector (SSNTD)

A.1 General

This annex deals with the solid-state nuclear track detector (SSNTD) method, which is one of several methods meeting the requirements of this document.

For the purposes of this annex, the symbols given in [Clause 3](#) and the following apply.

F_c	calibration factor, in (tracks per square centimetre) per (becquerel hour per cubic metre)
n	number of solid-state nuclear detectors used for determining the background noise
n_g	number of tracks after exposure
$\bar{n}_b$	mean number of tracks caused by the background noise
S_{SSNTD}	SSNTD area used for counting the number of “etched tracks”, in square centimetres

A.2 Principle

The integrated measurement of the average radon activity concentration using an SSNTD is based on the following elements:

- a) passive sampling, during which the alpha particles, including those produced by the disintegration of radon and its short-lived decay products, transfer their energy by ionizing or exciting the atoms in the polymer; this energy that is transferred to the medium leaves areas of damage called “latent tracks”;
- b) transport of the exposed sensors to the laboratory for the appropriate chemical, or electrochemical, processing, for example the transformation of the “latent tracks” into “etched tracks” counted with a suitable system; the number of these “etched tracks” per surface unit area is linked to the exposure of the radon by the calibration factor previously defined for sensors from the same manufacturing batch of SSNTD processed chemically, or electrochemically, and counted under the same conditions;
- c) determination of the average activity concentration from the radon exposure value, the sampling duration and consideration of the background noise.

A.3 Equipment

The apparatus shall include the following:


- a) a sensor in the form of a solid-state nuclear track detector (SSNTD), used alone or with an accumulation chamber made from a conductive plastic material with a known detection volume;
- b) equipment and suitable chemical reagents for etching the sensor;
- c) equipment suitable for scanning and counting the “etched tracks”.

The SSNTD shall be made of a polymer that is sensitive to alpha particles.

The sensor shall be fixed on a support that can be used in either an open or closed configuration (see [Figure A.1](#)).

In an open configuration, the sensor can record simultaneously the alpha emissions of radon and its decay products close to the detector and of any other alpha emitter present in the analysed atmosphere, in the energy range specified by the manufacturer. It is necessary to know the equilibrium factor, amongst other things, in order to exploit the results obtained with this sensor. If this parameter is not measured, the value commonly used inside houses is equal to 0,4^[4].

In its closed configuration, the sensor has a chamber that serves as the detection volume. This configuration is used to overcome the influence of the solid radon decay products and of any other solid alpha-emitting radionuclide present in the analysed atmosphere. This is achieved by the presence of a filter between the external environment and the accumulation chamber, which prevents the passage of solid radon decay products or any other solid alpha-emitting radionuclide. In this case, knowing the equilibrium factor is not necessary.



Key

- 1 SSNTD
- 2 support
- 3 filter
- 4 accumulation chamber

Figure A.1 — Solid-state nuclear track detectors in open and closed configurations

A.4 Sampling

Air sampling shall be passive.

Sampling of the air and generation of the “latent tracks” on the sensor shall be carried out simultaneously.

Installation of the sensor shall be performed in accordance with [6.3.2](#) and ISO 11665-1.

When the sensor is not in the measurement mode, it is normally enclosed in sealed packaging which prevents the penetration of radon and its decay products. The sensor begins measuring when it is removed from this packaging at the place of installation. The measurement ceases when the sensor is removed from the installation place and immediately returned to the sealed packaging.

Time of installation and removal phases shall be recorded (date and hour).

The sampling duration shall comply with 6.3.3.

The sampling duration shall be adapted to the assumed level of radon activity concentration. If a very high level of activity concentration is assumed, the sampling duration shall be reduced to avoid saturating the SSNTD. Conversely, if a very low level of activity concentration is assumed, the sampling duration shall be extended so as to produce a significant physical variable.

A.5 Measurement

A.5.1 Procedure

Measurement shall be carried out as follows.

- a) Select and locate the measuring site.
- b) Install the sensor.
- c) Record the location and the time (date and hour) of installation of the sensor.
- d) Carry out sampling of an air sample representative of the atmosphere under investigation.
- e) Remove the sensor.
- f) Record the time (date and hour) of removal of the sensor.
- g) Send the sensor to the laboratory within a few days of the end of the exposure period. It shall be processed as soon as possible, unless a storage method is validated, in which case the sensors may be processed later.
- h) Remove the SSNTD from the accumulation chamber if needed.
- i) Develop the sensor by etching with a suitable chemical, or electrochemical, treatment. The “latent tracks” caused by the alpha particles produced by the disintegration of the radon and its short-lived decay products are converted into “etched tracks”.
- j) Scan the sensor and count the number of “etched tracks”.
- k) Determine the background noise of the sensor using a statistically significant number of randomly chosen sensors from each manufacturing batch. Avoid reliance on data provided by the manufacturer which will not include adventitious radon exposure during storage and transit to the processing laboratory. Sensors from the same batch of SSNTD shall be developed and counted as described in steps i) to j). The number of sensors used should be sufficient to determine n_b . Typically this should be at least 10 sensors, or 1 % of the total number of available sensors per manufacturing batch, depending on the consistency of the background noise of the sensors within each batch.
- l) Determine the average activity concentration by calculation.

A.5.2 Influence quantities

Besides the influence quantities stated in IEC 61577-1 and ISO 11665-1, the following shall be taken into account:

- a) Direct exposure of a sensor with an open configuration: in an indoor environment with a highly-significant aerosol content (kitchen, bathroom, cellar, etc.), this can cause pollution on the sensor surface, thereby potentially invalidating the results. It is advisable to use closed chambers in such environments.
- b) The equilibrium factor: in an open configuration, the activity concentration of the radon decay products shall also be taken into account, as well as the variation in the equilibrium factor^{[9][10]}. Either the equilibrium factor shall be measured or a sensor with a closed configuration shall be used.

- c) The ageing effect of the SSNTD: in order to avoid the effect of ageing, the sensor shall be used before the expiry date given by the manufacturer.

A.5.3 Calibration

If the calibration factor is not provided by manufacturer, each batch of sensors shall be calibrated upon receipt.

For a batch of sensors, calibration involves exposing a statistically significant number of sensors, typically at least 10 randomly chosen sensors per manufacturing batch, to reference atmospheres and applying the same chemical, or electrochemical, processing and track counting as used for measurement samples. Avoid reliance on data provided by the manufacturer unless you have verified that your processing methods exactly replicate the manufacturer's. The number of sensors used should be sufficient to determine F_c . Typically this should be at least 10 sensors, or 1 % of the total number of available sensors per manufacturing batch, depending on the consistency of the calibration results of the sensors within each batch. The result is the calibration factor. It is the ratio between the density of the tracks (tracks/cm²) and the exposure to radon activity concentration in a reference atmosphere (Bq·h/m³). This calibration factor is expressed in (tracks per square centimetre) per (becquerel hour per cubic metre) [(tracks/cm²) per (Bq·h/m³)].

At the same time as the calibration, the background noise shall be measured on 10 sensors from the same batch.

For a sensor with an open configuration, the calibration factor, F_c , shall take into account the value of the equilibrium factor of the reference atmosphere. The results can also fluctuate due to the lack of sensor protection in a very humid medium or one loaded with aerosols. As an indication, conversion factors from 0,000 5 tracks/cm² per Bq·h/m³ up to 0,004 tracks/cm² per Bq·h/m³ are found in published works depending on the type of sensor^[10].

A.6 Expression of results

A.6.1 Average radon activity concentration

The average radon activity concentration is obtained from [Formula \(1\)](#). This yields [Formula \(A.1\)](#):

$$\bar{C} = (n_g - \bar{n}_b) \cdot \frac{1}{t \cdot S_{SSNTD} \cdot F_c} = (n_g - \bar{n}_b) \cdot \omega \quad \text{with} \quad \omega = \frac{1}{t \cdot S_{SSNTD} \cdot F_c} \quad (\text{A.1})$$

For the most accurate value, $\bar{n}_b$ is determined experimentally by reading n sensors that have not been exposed to radon and have been processed under the same physico-chemical and counting conditions. The value of $\bar{n}_b$ may also be given by the manufacturer.

A.6.2 Standard uncertainty

The standard uncertainty of $\bar{C}$ is obtained from [Formula \(2\)](#). This yields [Formula \(A.2\)](#):

$$u(\bar{C}) = \sqrt{\left(n_g + \frac{\bar{n}_b}{n} \right) \cdot \omega^2 + \bar{C}^2 \cdot u_{\text{rel}}^2(\omega)} \quad (\text{A.2})$$

with

$$u_{\text{rel}}^2(\omega) = u_{\text{rel}}^2(F_c) + u_{\text{rel}}^2(S_{SSNTD})$$

The uncertainty of the sampling duration is considered negligible.

Calculation of the characteristic limits [see ISO 11929 (all parts)] requires calculation of $\tilde{u}(\tilde{C})$, i.e. the standard uncertainty of $\tilde{C}$ as a function of its true value, calculated as given in [Formula \(A.3\)](#):

$$\tilde{u}(\tilde{C}) = \sqrt{\left[\frac{\tilde{C}}{\omega} + \bar{n}_b \cdot \left(1 + \frac{1}{n} \right) \right] \cdot \omega^2 + \tilde{C}^2 \cdot u_{\text{rel}}^2(\omega)} \quad (\text{A.3})$$

A.6.3 Decision threshold

The decision threshold, $\bar{C}^*$, is obtained from [Formula \(A.3\)](#) for $\tilde{C}=0$ [see ISO 11929 (all parts)].

This yields [Formula \(A.4\)](#):

$$\bar{C}^* = k_{1-\alpha} \cdot \tilde{u}(0) = k_{1-\alpha} \cdot \omega \cdot \sqrt{\bar{n}_b \cdot \left(1 + \frac{1}{n} \right)} \quad (\text{A.4})$$

$\alpha = 0,05$ with $k_{1-\alpha} = 1,65$ is often chosen by default.

A.6.4 Detection limit

The detection limit, $\bar{C}^\#$, is calculated as given in [Formula \(A.5\)](#) [see ISO 11929 (all parts)]:

$$\bar{C}^\# = \bar{C}^* + k_{1-\beta} \cdot \tilde{u}(\bar{C}^\#) = \bar{C}^* + k_{1-\beta} \cdot \sqrt{\left[\frac{\bar{C}^\#}{\omega} + \bar{n}_b \cdot \left(1 + \frac{1}{n} \right) \right] \cdot \omega^2 + \bar{C}^{\#2} \cdot u_{\text{rel}}^2(\omega)} \quad (\text{A.5})$$

The detection limit can be calculated by solving [Formula \(A.5\)](#) for $\bar{C}^\#$ or, more simply, by iteration with a starting approximation $\bar{C}^\# = 2 \cdot \bar{C}^*$ in terms of the right side of [Formula \(A.5\)](#).

One obtains $\bar{C}^\#$ with $k_{1-\alpha} = k_{1-\beta} = k$:

$$\bar{C}^\# = \frac{2 \cdot \bar{C}^* + k^2 \cdot \omega}{1 - k^2 \cdot u_{\text{rel}}^2(\omega)} \quad (\text{A.6})$$

Values $\alpha = \beta = 0,05$ and therefore $k_{1-\alpha} = k_{1-\beta} = 1,65$ are often chosen by default.

A.6.5 Example

The number of tracks for a sensor with a closed configuration exposed for 90 days ($t = 2\,160$ h) is $n_g = 800$ tracks.

The number of tracks, determined on 10 non-exposed sensors from the same batch, caused by the background noise over 90 days, is $\bar{n}_b = 30$ tracks.

The determination of n_g and $\bar{n}_b$ is performed over the same area: $S_{\text{SSNTD}} = 1 \pm 0,1 \text{ cm}^2$.

The calibration factor is $F_c = (8 \pm 0,8) \times 10^{-4} \text{ tracks/cm}^2 \text{ per Bq-h/m}^3$.

The average radon activity concentration, calculated from [Formula \(A.1\)](#), is:

$$\bar{C} = 446 \text{ Bq/m}^3$$

The standard uncertainty of the average radon activity concentration, calculated from [Formula \(A.2\)](#), is:

$$u(\bar{C}) = 65 \text{ Bq/m}^3$$

Thus, the average radon activity concentration is:

$$\bar{C} = (446 \pm 65) \text{ Bq/m}^3$$

The decision threshold, $\bar{C}^*$, obtained from [Equation \(A.4\)](#), is:

$$C^* = 5 \text{ Bq/m}^3$$

The detection limit, $\bar{C}^\#$, calculated by [Formula \(A.6\)](#), is:

$$C^\# = 13 \text{ Bq/m}^3$$

STANDARDSISO.COM : Click to view the full PDF of ISO 11665-4:2020

Annex B (informative)

Measurement method using an electret detector

B.1 General

This annex deals with the electret detector method, which is one of several methods meeting the requirements of this document.

For the purposes of this annex, the symbols given in [Clause 3](#) and the following apply.

U_i	initial electret voltage, in volts
U_f	final electret voltage, in volts
B_G	contribution by the ambient gamma radiation, in becquerels per cubic metre
F_c	calibration factor, in (volts per hour) per (becquerel per cubic metre)
b	electret parameter, given by the manufacturer, in (volts per hour) per (becquerel per cubic metre)
d	electret parameter, given by the manufacturer, in (per hour) per (becquerel per cubic metre)
f_{cor}	correction factor for the gamma radiation, given by the manufacturer, in (becquerels per cubic metre) per (nanogray per hour)
$\dot{D}$	average dose rate due to ambient gamma radiation during the exposure period, in nanograys per hour

B.2 Principle


The integrated measurement of the average radon activity concentration using an electret detector is based on the following elements:

- a) Passive sampling, during which the radon and its decay products formed in the accumulation chamber ionize the air. The electret being charged positively, an electrostatic field is created between the electret surface and the accumulation chamber walls. The electret serves both as the anode of the electrostatic field and the collector electrode. The electrons produced by the air ionization combine with the positive charges of the electret. This leads to a gradual decrease of its voltage.
- b) Measuring the electret voltage before and after every exposure to the atmosphere under investigation with a voltmeter specific to the device.
- c) Measuring the average dose rate due to ambient environmental (cosmic and terrestrial) gamma radiation at the sampling place. The ambient gamma radiation contributes to discharging the electret detector.
- d) Determining the average activity concentration from the voltage drop, the sampling duration and consideration of the average dose rate.

B.3 Equipment

The apparatus shall include the following:

- a measuring device, which includes a dielectric disk of polytetrafluoroethylene (PTFE) or fluorinated ethylene propylene (FEP), known as an electret and a removable accumulation chamber with a known detection volume (see [Figure B.1](#) [11]); the removable accumulation chamber shall be made of a conductive plastic material and shall contain filters;
- a voltmeter to measure the electret voltage immediately before and after exposure to the atmosphere under investigation;
- a dosimeter to measure the average dose rate at the sampling place.



Key

- 1 accumulation chamber
- 2 entry point of radon
- 3 filter
- 4 insulating support
- 5 electret detector

Figure B.1 — Configuration of a measuring device using an electret detector


There are various types of electret detector and chamber (see [Table B.1](#)). The electret detector is charged positively at the factory by the manufacturer to a potential in the order of several hundred volts (750 V). It may be used several times until its voltage limit value (200 V) is reached, as the field induced is then too low for effective ion collection. The voltage limit value is given by the manufacturer.

Table B.1 — Example of types of accumulation chamber and electret detector

Accumulation chamber		Electret detector	
Type	Volume ml	Type	Sensitivity
n	50	1	high
m	210	2	low

Several combinations are possible.

By way of example, three combinations are presented in [Figure B.2](#). For each combination, the letter (n or m) refers to the type of accumulation chamber and the number (1 or 2) indicates the type of electret detector (see [Table B.1](#)). An ambient gamma radiation equal to 100 nGy/h and a voltage drop of 30 V are considered in this example. The upper and lower limits of each response field relate, respectively, to an electret detector with the maximum charge voltage (used from 750 V to 720 V) and an electret detector at the end of its life (used from 230 V to 200 V).



Key

t time, in days

Y radon activity concentration, in becquerels per cubic metre (Bq/m^3)

Figure B.2 — Radon activity concentration measured over a given sampling duration for an electret voltage drop of 30 V (assuming a 100 nGy/h ambient gamma radiation contribution) — Example for the three combinations n1, m2 and n2

Several examples can be extracted from this graph. Thus, for an average activity concentration of $200 \text{ Bq}/\text{m}^3$ and an ambient dose rate of $100 \text{ nGy}/\text{h}$, the sampling duration for the n1 combination (see [Table B.1](#)) required to produce a drop of 30 V in the electret potential is equal to 12 days (see [Table B.2](#)).

B.4 Sampling

Air sampling shall be passive.

During the sampling duration (exposure period), radon penetrates the accumulation chamber by diffusion through filters which prevent the aerosols present in the air at the time of sampling, especially radon decay products, from entering the chamber.

Installation of the measuring device shall be carried out in accordance with [6.3.2](#) and ISO 11665-1.

Time of installation and removal phases shall be recorded (date and hour).

The sampling duration shall be in accordance with [6.3.3](#) and shall be adapted to the assumed level of radioactivity and the electret-chamber pairing (see [Table B.2](#)). Nomographs relate the average radon activity concentration and the sampling duration as well as the type of electret detector and the accumulation chamber (see [Figure B.2](#)).

Table B.2 — Examples of sampling duration, in hours, for different combinations (accumulation chamber/electret detector) and a voltage drop of 30 V

Average radon activity concentration Bq/m ³	Sampling duration for the combination		
	n1	m2	n2
200	288	672	>2 400
400	168	360	2 040
1 000	72	156	840

It is advisable to use combination n2 to assess human exposure. Combination n1 is, however, preferable for a rapid determination of the average radon activity concentration.

The graph in [Figure B.2](#) may be used for an electret voltage drop other than 30 V. This requires an understanding of the following:

- for a fixed average radon activity concentration, the electret voltage drop is proportional to the sampling duration;
- for a fixed sampling duration, the electret voltage drop is proportional to the average radon activity concentration.

B.5 Measurement

B.5.1 Procedure

Integrated measurement of the radon activity concentration using an electret detector shall be carried out as follows.

- Select and locate the sampling site.
- Select the electret-chamber pairing by using the nomographs given by the manufacturer (see [Figure B.2](#)). For a given sampling duration, the following are taken into account when choosing the electret-chamber pairing:
 - expected average radon activity concentration;
 - residual electret potential;
 - characteristics of the electret surface;
 - volume of the associated accumulation chamber.
- Measure and record the initial electret voltage before exposure.
- Assemble the accumulation chamber and the electret.
- Install the measuring device.
- Measure and record the ambient gamma dose rate at the sampling site.
- Record the location and the time (date and hour) of installation of the measuring device.
- Carry out sampling of an air sample representative of the atmosphere under investigation.
- Disassemble the accumulation chamber and the electret.
- Measure and record the final electret voltage immediately after the end of exposure.
- Measure and record the ambient gamma dose rate at the sampling site at the end of the measurement period.

- l) Record the time (date and hour) of removal of the measuring device.
- m) Determine the average activity concentration by calculation.

B.5.2 Influence quantities

Besides the influence quantities specified in IEC 61577-1 and ISO 11665-1, the following shall be taken into account:

- a) The temperature: The electret voltage shall be measured before and after exposure to the atmosphere under investigation at the same temperature conditions. The electret surface tends to become convex or concave when a substantial variation in temperature occurs. It may therefore be different to the electrometer sensor when the voltage is read. A substantial variation in the electrometer temperature affects the value of the electret voltage.
- b) The presence of dust on the electret surface: Check after measurement, and before measurement when reusing an electret.
- c) The conservation of the physical quantity collected after sampling has ended: The voltage shall be measured immediately at the end of the exposure period.
- d) The ambient gamma radiation contributes to discharging the electret. It is therefore necessary to measure the dose rate at the sampling place at least twice, once at the beginning and once at the end of the measurement period;
- e) The electrometer storage conditions: The electrometer shall always be stored in an area containing dry air (a desiccant maintains its level of humidity) to ensure that it indicates acceptable voltage values.
- f) The effect of physical shock on the response of electret detectors is well known and can cause an undetermined source of error. Care should therefore be taken to avoid shocks during the measurement.

Manufacturer recommendations in the operating instructions for the sensors shall be respected.

B.5.3 Calibration

Calibration involves exposing several measuring devices (electret and accumulation chamber) to reference radon atmospheres. The electret voltage shall be measured by a specific electrometer before and after exposure to the reference atmosphere.

The gamma radiation dose rate shall be measured simultaneously.

The difference in potential thus determined is linked to the reference activity concentration.

The result obtained is the value of the calibration factor depending on the electret detector. This calibration factor is given by the manufacturer.

The electrometer response shall be checked regularly with reference electrets.

The correction factor of gamma radiation shall be determined by exposing several measuring devices (electret and accumulation chamber) to reference gamma radiation dose rates.

B.6 Expression of results

B.6.1 Average radon activity concentration

The average radon activity concentration is calculated as given in [Formula \(B.1\)](#):

$$\bar{C} = \frac{U_i - U_f}{F_c \cdot t} - B_G \quad (\text{B.1})$$

The calibration factor, F_c , is a function of the initial and final electret voltages.

NOTE The expression of F_c depends on the type of electret detector used.

The contribution by the ambient gamma radiation, in radon equivalent, B_G , is calculated as given in [Formula \(B.2\)](#):

$$B_G = f_{\text{cor}} \cdot \dot{D} \quad (\text{B.2})$$

B.6.2 Standard uncertainty

In accordance with ISO/IEC Guide 98-3, the standard uncertainty of $\bar{C}$ shall be calculated as given in [Formula \(B.3\)](#):

$$u(\bar{C}) = \sqrt{2 \cdot \frac{1}{(F_c \cdot t)^2} \cdot u^2(U_i) + u^2(B_G) + (\bar{C} + B_G)^2 \cdot u_{\text{rel}}^2(F_c)} \quad (\text{B.3})$$

where the uncertainty of sampling duration t is considered negligible.

$$u^2(B_G) = f_{\text{cor}}^2 \cdot u^2(\dot{D}) + \dot{D}^2 \cdot u^2(f_{\text{cor}})$$

where the uncertainties of the correction factor f_{cor} and the average dose rate $\dot{D}$ are given by the manufacturer.

The electrometer reads the electret voltage to within 1 V and $u^2(U_i) = u^2(U_f) = 1/12$.

B.6.3 Decision threshold and detection limit

The characteristic limits associated with $\bar{C}$ shall be calculated according to ISO 11929 (all parts). An example of the calculations of the decision threshold and the detection limit are detailed in [B.6.4](#) for a specific type of electret detector.

B.6.4 Example

This subclause shows an example of measurement performed with a high-sensitivity electret associated with a 50 ml accumulation chamber.

The calibration factor is calculated as given in [Formula \(B.4\)](#):

$$F_c = b + d \cdot \left(\frac{U_i + U_f}{2} \right) \quad (\text{B.4})$$

where the constants b and d , provided by the manufacturer, are:

$$b = 2,94 \cdot 10^{-4} \text{ V/h per Bq/m}^3$$

$$d = 1,54 \cdot 10^{-7} \text{ h}^{-1} \text{ per Bq/m}^3$$

The relative uncertainty of the calibration factor F_c , provided by the manufacturer, is:

$$u_{\text{rel}}^2(F_c) = (0,06)^2$$

The chamber parameter is $f_{\text{cor}} = 0,594\,374\text{ Bq/m}^3/\text{nGy/h}$.

The relative uncertainty of the chamber parameter f_{cor} , provided by the manufacturer, is:

$$u_{\text{rel}}^2(f_{\text{cor}}) = 9 \times 10^{-4}$$

The initial electret voltage is $U_i = 530\text{ V}$

The final electret voltage after exposure is $U_f = 500\text{ V}$.

Sampling duration is $t = 336\text{ h}$.

The average dose rate during exposure is $\dot{D} = 100\text{ nGy/h}$.

Thus, the average radon activity concentration, calculated from [Formula \(B.1\)](#), is given by:

$$\bar{C} = 180\text{ Bq/m}^3$$

The dose rate measuring instrument indicates a dose rate with a 5 % uncertainty.

The standard uncertainty of the average radon activity concentration is calculated from [Formula \(B.3\)](#):

$$u(\bar{C}) = 15\text{ Bq/m}^3$$

Thus, the average radon activity concentration is:

$$\bar{C} = (180 \pm 15)\text{ Bq/m}^3$$

Calculation of the characteristic limits [see ISO 11929 (all parts)] requires calculation of $\tilde{u}(\tilde{C})$, i.e. the standard uncertainty of $\tilde{C}$ as a function of its true value, calculated as given in [Formula \(B.5\)](#):

$$\tilde{u}(\tilde{C}) = \sqrt{\frac{1}{6} \left[\frac{1 + d \cdot \frac{t}{2} \cdot (\tilde{C} + B_G)}{t \cdot (b + d \cdot U_i)} \right]^2 + u^2(B_G) + (\tilde{C} + B_G)^2 \cdot u_{\text{rel}}^2(F_c)} \quad (\text{B.5})$$

The decision threshold, $\bar{C}^*$, is obtained from [Formula \(B.5\)](#) for $\tilde{C} = 0$ [see ISO 11929 (all parts)].

This yields [Formula \(B.6\)](#):

$$\bar{C}^* = k_{1-\alpha} \cdot \tilde{u}(0) = k_{1-\alpha} \cdot \sqrt{\frac{1}{6} \cdot \left[\frac{1 + d \cdot \frac{t}{2} \cdot B_G}{t \cdot (b + d \cdot U_i)} \right]^2 + u^2(B_G) + B_G^2 \cdot u_{\text{rel}}^2(F_c)} \quad (\text{B.6})$$

$\alpha = 0,05$ with $k_{1-\alpha} = 1,65$ is often chosen by default.

$$\bar{C}^* = k_{1-\alpha} \cdot \tilde{u}(0) = 10 \text{ Bq/m}^3$$

The detection limit, $\bar{C}^\#$, is calculated as given in [Formula \(B.7\)](#) [see ISO 11929 (all parts)]:

$$\bar{C}^\# = \bar{C}^* + k_{1-\beta} \cdot \sqrt{\frac{1}{6} \cdot \left[\frac{1 + d \cdot \frac{t}{2} \cdot (\bar{C}^\# + B_G)}{t \cdot (b + d \cdot U_i)} \right]^2 + u^2(B_G) + (\bar{C}^\# + B_G)^2 \cdot u_{\text{rel}}^2(F_c)} \quad (\text{B.7})$$

$\beta = 0,05$ with $k_{1-\beta} = 1,65$ is often chosen by default.

The detection limit can be calculated by solving [Formula \(B.7\)](#) for $\bar{C}^\#$ or, more simply, by iteration with a starting approximation $\bar{C}^\# = 2 \cdot \bar{C}^*$ in terms of the right side of [Formula \(B.7\)](#).

$\bar{C}^\#$ is obtained with $k_{1-\alpha} = k_{1-\beta} = k$:

$$\bar{C}^\# = \frac{2 \cdot \bar{C}^* + k^2 \cdot \varepsilon_1}{1 - k^2 \cdot \varepsilon_2} \quad (\text{B.8})$$

With

$$\varepsilon_1 = \frac{1}{6} \cdot \left[\frac{d^2 \cdot \frac{t}{2} \cdot B_G + d}{t \cdot (b + d \cdot U_i)^2} \right] + 2 \cdot B_G \cdot u_{\text{rel}}^2(F_c) \quad (\text{B.9})$$

$$\varepsilon_2 = \frac{1}{6} \cdot \left(\frac{d \cdot \frac{t}{2}}{b + d \cdot U_i} \right)^2 + u_{\text{rel}}^2(F_c) \quad (\text{B.10})$$

$$\bar{C}^\# = 20 \text{ Bq/m}^3$$

Annex C (informative)

Measurement method using activated charcoal

C.1 General

This annex deals with an activated charcoal method, which is one of several methods meeting the requirements of this document.

For the purposes of this annex, the symbols given in [Clause 3](#) and the following apply.

F_c	calibration factor, in (per second) per (becquerel per cubic metre)
f_d	correction factor for the radioactive decay during the counting time and during the time between the reference instant ($t = 0$) and the measuring instant
f_H	correction factor for humidity, dimensionless
f_S	correction factor for difference between sampling period and reference calibration exposure period, dimensionless
n_b, n_{b0}	number of counts in the background of the peak, in the sample and in the background spectrum, respectively
n_g, n_{g0}	number of counts in the gross area of the peak, in the sample and in the background spectrum, respectively
n_N, n_{N0}	number of counts in the net area of the peak, in the sample and in the background spectrum, respectively
t_0	background counting duration, in seconds
t_g	sample counting duration, in seconds
t_i	measuring instant, i.e. time at which the sample measurement starts, in seconds
t_{sm}	time between mid-point of exposure and measurement of exposed detector, in seconds
λ_i	decay constant of the nuclide i , per second

C.2 Principle

Measurement includes the following stages:

- a) preparing the measurement device (sensor), as follows:
 - 1) removing the lid;
 - 2) heating the charcoal to a temperature of 110 °C in an atmosphere of nitrogen in order to remove water content (this step may be omitted but it shortens the useful life of the device);
 - 3) replacing the lid;
 - 4) weighing and recording the weight of the complete device;


- 5) adding additional sealing, if necessary, by applying adhesive tape around the seal between the lid and the base;
- b) passive sampling, during which radon is adsorbed onto the charcoal, as follows:
 - 1) the lid is removed at the beginning of the sampling period and replaced at the end of the sampling period;
 - 2) the sampling time and the start time are both recorded;
- c) sending the exposed field sensors to the laboratory for the measurement of the gamma emission rates of the two gamma emitting daughter products ^{214}Pb and ^{214}Bi :
 - 1) at least three hours shall be allowed to elapse between the end of the sampling period and the beginning of the gamma emission rate measurements;
 - 2) the emission rates are linked to the quantity of radon adsorbed;
- d) determining the average activity concentration from the gamma emission rates and the sampling period and by applying relevant calibration and correction factors.

After use, sensors should be sealed and not used again until a period of 1 month has elapsed. This ensures that any residual radon and short-lived daughters (^{214}Pb and ^{214}Bi) have decayed to levels which will not affect the results of the next measurement.

C.3 Equipment

The apparatus shall include the following:

- a) a measuring device containing a block of activated charcoal (sensor) which adsorbs radon and is used in an open or diffusion barrier configuration (see [Figure C.1](#)); in both configurations, the charcoal shall be retained in the base container by an open-mesh grille;
- b) a gamma spectrometer.



Key

- 1 lid enabling hermetic seal with base container
- 2 diffusion barrier (optional)
- 3 open-mesh grille
- 4 activated charcoal
- 5 base container

Figure C.1 — Device using activated charcoal

In the open configuration, the charcoal is exposed directly to the atmosphere under investigation. In this condition, radon also desorbs from the charcoal when the concentration of radon in the surface

layers of the charcoal is higher than that in the surrounding air. This makes the response of an open-faced activated charcoal detector very sensitive to the time-profile of the radon activity concentration in the air to which it is exposed. Open-faced activated charcoal detectors have a response which is severely weighted towards the radon activity concentration at the end of the sampling period, whereas a response indicative of the average radon activity concentration over the entire sampling period is required. For this reason, open-faced activated charcoal detectors are generally only used over periods of up to 4 days.

In the diffusion barrier configuration, a diffusion barrier is placed between the activated charcoal and the atmosphere. This results in the radon activity concentration at the surface of the activated charcoal almost always being lower than that in the air being measured and the effects of radon desorption are greatly diminished. The presence of the diffusion barrier also reduces the amount of water vapour absorbed, and these devices can be used for exposure periods of over 7 days, even where the relative humidity is as high as 75 %.

A typical activated charcoal radon detector consists of a canister about 80 mm in diameter and 25 mm in height, with a total weight of about 100 g, that can be sent by mail to domestic users and returned to a laboratory within the prescribed time after exposure. The canister shall be sealed until received and then unsealed and exposed in the area to be measured. At the end of the sampling period, the canister shall be re-sealed and returned to the supplier, together with the dates and times the sampling started and finished, as well as an estimate of the average temperature during the sampling.

During the sampling period, radon is adsorbed onto the activated charcoal but it can also desorb from the surface as well. The activated charcoal will also absorb water vapour during the sampling period and this will reduce the capacity of the charcoal to adsorb radon. The radon adsorbed at the beginning of sampling will undergo more radioactive decay than that adsorbed towards the end of the measurement period. In order to take all of these factors into account, it is important that the calibration process be undertaken across a range of different relative humidity conditions and different sampling periods to enable appropriate correction factors to be generated. It is also important to understand that these correction factors apply to just a single batch of equal-weight detectors manufactured from the same material.

[Figures C.2](#) and [C.3](#) illustrate the variation in calibration factor with relative humidity (RH) and exposure time (sampling duration).