



INTERNATIONAL STANDARD ISO 13347-4:2004
TECHNICAL CORRIGENDUM 1

Published 2006-10-15

INTERNATIONAL ORGANIZATION FOR STANDARDIZATION • МЕЖДУНАРОДНАЯ ОРГАНИЗАЦИЯ ПО СТАНДАРТИЗАЦИИ • ORGANISATION INTERNATIONALE DE NORMALISATION

**Industrial fans — Determination of fan sound power levels
under standardized laboratory conditions —**

**Part 4:
Sound intensity method**

TECHNICAL CORRIGENDUM 1

Ventilateurs industriels — Détermination des niveaux de puissance acoustique des ventilateurs dans des conditions de laboratoire normalisées —

Partie 4: Méthode de l'intensité acoustique

RECTIFICATIF TECHNIQUE 1

Technical Corrigendum 1 to ISO 13347-4:2004 was prepared by Technical Committee ISO/TC 117, *Industrial fans*.

Page 3, Table 3, third row, first column

Replace “25 to 500” with “250 to 500”.

Page 10, 4.3, second paragraph, second sentence

Replace “If it is not possible to satisfy the requirements of Figure 4, see Annex C” with

“If it is not possible to satisfy the requirements of Figure 4, see Annex B”.