
**Diesel engines — Fuel injection pump
testing — Calibrating fuel injectors**

*Moteurs diesels — Essai des pompes d'injection de carburant — Porte-
injecteurs de carburant complets de calibration*



Foreword

ISO (the International Organization for Standardization) is a worldwide federation of national standards bodies (ISO member bodies). The work of preparing International Standards is normally carried out through ISO technical committees. Each member body interested in a subject for which a technical committee has been established has the right to be represented on that committee. International organizations, governmental and non-governmental, in liaison with ISO, also take part in the work. ISO collaborates closely with the International Electrotechnical Commission (IEC) on all matters of electrotechnical standardization.

Draft International Standards adopted by the technical committees are circulated to the member bodies for voting. Publication as an International Standard requires approval by at least 75 % of the member bodies casting a vote.

International Standard ISO 14681 was prepared by Technical Committee ISO/TC 22, *Road vehicles*, Subcommittee SC 7, *Injection equipment and filters for use on road vehicles*.

Annex A of this International Standard is for information only.

STANDARDSISO.COM : Click to view the full PDF of ISO 14681:1998

© ISO 1998

All rights reserved. Unless otherwise specified, no part of this publication may be reproduced or utilized in any form or by any means, electronic or mechanical, including photocopying and microfilm, without permission in writing from the publisher.

International Organization for Standardization
Case postale 56 • CH-1211 Genève 20 • Switzerland
Internet iso@iso.ch

Printed in Switzerland

Introduction

Calibrating fuel injectors are intended to simulate closely the function of fuel injectors in the fuel injection system of a diesel (compression-ignition) engine.

Injection pumps for emission-controlled engines require a new generation of calibrating injectors in order to comply with the higher injection pressures. The field of application is similar to those of the calibrating injectors specified in ISO 7440-1 and of the calibrating nozzle specified in ISO 4010. Compared with calibrating injectors according to ISO 7440-1, the new designs show the following differences:

- change-over from high spring nozzle holder to low spring nozzle holder,
- reduction of masses,
- reduction of dead volumes, e.g. edge filter.

Therefore, the following parts are modified:

- nozzle holder body,
- nozzle retaining nut,
- edge filter,
- spring,
- needle valve assembly and pintle nozzle,
- distance sleeve.

The following parts are not modified:

- the orifice plates with the orifice diameter range from 0,4 mm to 0,8 mm,
- the optional spray damper,
- the distance sleeve of the calibrating fuel injector with the single hole orifice plate.

[STANDARDSISO.COM](https://standardsiso.com) : Click to view the full PDF of ISO 14681:1998

Diesel engines — Fuel injection pump testing — Calibrating fuel injectors

1 Scope

This International Standard specifies two types of calibrating injectors intended for testing and setting diesel fuel injection pumps on test benches.

It applies to

- a) calibrating injectors for different orifice plates, max. delivery range 400 mm³/stroke;
- b) calibrating injectors with pintle type nozzle, max. delivery range 200 mm³/stroke.

The field of application is similar to the calibrating injectors specified in ISO 7440-1 and to the calibrating nozzle specified in ISO 4010.

Compared to the calibrating injector specified in ISO 7440-1, the calibrating injectors specified in this International Standard represent an advanced stage of design which is more appropriate to modern high pressure/high performance fuel injection systems.

Specification of the type of calibrating fuel injectors to be used, the appropriate single hole orifice plate size or pintle nozzle (as applicable), high pressure pipes, exact limits, etc. is left to the manufacturer of the injection equipment and/or the manufacturer of the engine.

2 Normative references

The following standards contain provisions which, through reference in this text, constitute provisions of this International Standard. At the time of publication, the editions indicated were valid. All standards are subject to revision, and parties to agreements based on this International Standard are encouraged to investigate the possibility of applying the most recent editions of the standards indicated below. Members of IEC and ISO maintain registers of currently valid International Standards.

ISO 4010:—¹⁾, *Diesel engines — Calibrating nozzle, delay pintle type.*

ISO 4113:1988, *Road vehicles — Calibration fluid for diesel injection equipment.*

ISO 7440-1:1991, *Road vehicles — Fuel injection equipment testing — Part 1: Calibrating nozzle and holder assemblies.*

ISO 7440-2:1991, *Road vehicles — Fuel injection equipment testing — Part 2: Orifice plate flow-measurement.*

¹⁾ To be published. (Revision of ISO 4010:1977)

3 Requirements

3.1 Calibrating fuel injectors

3.1.1 With single hole orifice plate

The two alternative designs of the calibrating fuel injectors with the single hole orifice plate specified in figure 11 are shown in figure 1.

3.1.2 With delay pintle type nozzle

The two alternative designs of the calibrating fuel injectors with the delay pintle type nozzle specified in figure 14 are shown in figure 2.

3.2 Components

The calibrating fuel injectors consist of the components specified in 3.2.1 to 3.4.2 with their functionally critical dimensions.

3.2.1 Holder body

The holder body may include two spill tubes:

- one tube for the leakage fuel passing the needle valve assembly in the direction to the spring housing;
- another tube (optional) used with vented holder only.

The holder body is shown in figure 3.

3.2.2 Spring

The spring is shown in figure 5. It is designed for low stress in order to prevent fatigue.


3.2.3 Spring seat

The spring seat, which provides the connection of the low situated spring with the needle, is shown in figure 6.

3.2.4 Inlet stud with edge filter

The inlet stud with edge filter is shown in figure 7. It may be flow-tested as shown in figure 8. The outlet of the fixture (within dotted lines) shall be ambient pressure.

Dimensions in millimetres



Alternative 1: Preferably for use with calibrating test benches having open spray chamber


Alternative 2: Preferably for use with calibrating test benches having closed spray chamber

Key

- 1 Retaining nut, alternative 1
- 2 Retaining nut, alternative 2
- 3 Needle valve assembly
- 4 Single hole orifice plate
- 5 Distance sleeve
- 6 Holder body
- 7 Inlet stud with edge filter
- 8 Spring
- 9 Spring seat
- 10 Adaptor plate

Figure 1 — Calibrating fuel injector with single hole orifice plate

Dimensions in millimetres



Alternative 1: Preferably for use with calibrating test benches having open spray chamber

Alternative 2: Preferably for use with calibrating test benches having closed spray chamber

Key

- 1 Retaining nut, alternative 1
- 2 Retaining nut, alternative 2
- 3 Delay pintle type nozzle
- 4 Holder body
- 5 Inlet stud with edge filter
- 6 Spring
- 7 Distance sleeve
- 8 Spring seat
- 9 Adaptor plate

Figure 2 — Calibrating fuel injector with delay pintle type nozzle

Dimensions in millimetres




Figure 3 — Holder body

Dimensions in millimetres




Figure 4 — Adapter plate

Dimensions in millimetres




Figure 5 — Spring

Dimensions in millimetres






Figure 6 — Spring seat

Dimensions in millimetres



a) Edge filter with flutes (schematic)




b) Inlet stud with edge filter

Characteristic	Value
Filter clearance (radial)	0,02 mm to 0,031 mm
Filter clearance area	6 mm ² min.
Flow area for three flutes [see figure 7a)]	5,2 mm ²
Internal volume	700 mm ³ ± 20 mm ³
New filter flow at 0,3 MPa (3 bar) pressure ¹⁾	2 800 cm ³ /min to 4 600 cm ³ /min
Minimum flow of assembled holder body with inlet stud and edge filter at 0,3 MPa (3 bar) pressure ¹⁾	2 000 cm ³ /min
Minimum acceptable flow in service of the edge filter (to replace) at 0,3 MPa (3 bar) pressure ¹⁾	2 500 cm ³ /min
¹⁾ These tests shall be made using calibration fluid as specified in ISO 4113 at 40 ± 1°C and the tolerance of the supply pressure shall be ± 0,03 MPa (0,3 bar).	

Figure 7 — Characteristic dimensions and values of the inlet stud with edge filter

Dimensions in millimetres

**Key**

- 1 Temperature in
- 2 Flowmeter
- 3 Pump
- 4 Filter

- 5 Pressure regulator
- 6 Pressure in
- 7 Inlet

- 8 Outlet
- 9 Inlet stud with edge filter
- 10 Tank

Figure 8 — Inlet stud flow measuring system

3.2.5 Retaining nut

Figure 9 shows the retaining nut. This nut is used for both types of calibrating injectors, the orifice plate and the delay pintle type nozzle design. The different lengths of the two types, i.e. the needle valve assembly together with the orifice plate and the delay pintle type nozzle, are covered by using different distance sleeves.

Dimensions in millimetres




Figure 9 — Retaining nut

3.3 Special components for orifice plate design

3.3.1 Needle valve assembly

Figure 10 shows the needle valve assembly.

Dimensions in millimetres





Figure 10 — Needle valve assembly

3.3.2 Single hole orifice plate

Figure 11 shows the orifice plate(s) and the corresponding high pressure flow range(s). The orifice plates are also specified in ISO 7440-1.

Dimensions in millimetres



Orifice plate no.	.4	.5	.6	.7	.8
Orifice diameter, mm $\pm 0,05^1$	0,4	0,5	0,6	0,7	0,8
Flow, cm ³ /min	min.	964	1528	2190	3024
	max.	1014	1606	2302	3180

1) Tolerance of orifice hole is only a guide for manufacturing. Its purpose is to assist in meeting the final static flow limits specified in the table when flow-tested under the test conditions specified in ISO 7440-2.

Figure 11 — Single hole orifice plate

3.3.3 Distance sleeve

Figure 12 shows the distance sleeve, which corresponds to the orifice plate design. This distance sleeve is also specified in ISO 7440-1.

Dimensions in millimetres




Figure 12 — Distance sleeve

3.4 Special components for injectors with delay pintle type nozzle

3.4.1 Delay pintle type nozzle

Figure 14 shows the delay pintle type nozzle. Its design is different from the design given in ISO 4010. Therefore the control values when measuring the flow characteristics should be in accordance with table 1.

Table 1 — Control values of air flow at different needle lifts

Needle lift mm	Air flow	Pressure below ambient pressure kPa
0,1	310 ml/min to 330 ml/min	80
0,57	520 ml/min to 550 ml/min	80
end of lift	282 l/h to 288 l/h	60
NOTE — The values indicated in this table are based on — an ambient pressure of $p_a = 98 \text{ kPa}$ (0,98 bar), — an ambient air temperature of $t_a = + 20 \text{ }^\circ\text{C}$.		

A characteristic course of the air flow versus the needle lift is shown in figure 13. The measuring device for air flow shall be according to 5.1.3 of ISO 4010:—.




Figure 13 — Flow diagram

Dimensions in millimetres




Figure 14 — Delay pintle type nozzle

3.4.2 Distance sleeve

Figure 15 shows the distance sleeve, which is used together with the delay pintle type nozzle.

Dimensions in millimetres




Figure 15 — Distance sleeve

4 Designation

4.1 General

The various alternatives of nozzle, nozzle holder, nozzle retaining nut and nozzle opening pressure result in many possible combinations of component content and adjustment. To facilitate concise specification of any particular form of calibrating fuel injector,

- a) required by the injection pump test schedule, or
- b) requiring purchase, either in whole or in part, by the operator,

the range of calibrating fuel injectors shall be designated in code form as specified in 4.2 and illustrated in the following example.

EXAMPLE

ISO 14681 A13 - 207

4.2 Composition

4.2.1 First element: International Standard number

The first element is the number of the International Standard which specifies the calibrating fuel injectors.

In the example: ISO 14681

4.2.2 Second element: letter code

In the example: A

This single letter code allows extension of the present A code system if and when all the possibilities of the code tables (see 4.2.3.2) are filled by new or modified orifice plates, nozzle types and/or holder bodies; then the letter 'A' shall be changed to 'B', etc.

This presupposes that additional 'B' code tables will be established.

In the 'B' system the meaning of either one of the digits may, however, retain the same meaning as in the 'A' code but this shall be duplicated in the 'B' code tables.

4.2.3 Third element: component content

4.2.3.1 Significance

This two-digit code defines the component content according to the structure specified in 4.2.3.2.

In the example: 13

where

1– (tens-digit code) indicates delay pintle type nozzle as specified in figure 14,

–3 (units-digit code) indicates vented holder body, as specified in figure 3 with a retaining nut, without a threaded stud, as specified in figure 9.

4.2.3.2 Structure

The logic structure of the code defining the combination of components of the various calibrating fuel injectors as specified in this International Standard is given in table 2 for the tens and in table 3 for the units digit.