
**Plastics piping systems for the supply
of gaseous fuels — Unplasticized
polyamide (PA-U) piping systems
with fusion jointing and mechanical
jointing —**

**Part 2:
Pipes**

*Systèmes de canalisations en matières plastiques pour la distribution
de combustibles gazeux — Systèmes de canalisations en polyamide
non plastifié (PA-U) avec assemblages par soudage et assemblages
mécaniques —*

Partie 2: Tubes



STANDARDSISO.COM : Click to view the full PDF of ISO 16486-2:2020



COPYRIGHT PROTECTED DOCUMENT

© ISO 2020

All rights reserved. Unless otherwise specified, or required in the context of its implementation, no part of this publication may be reproduced or utilized otherwise in any form or by any means, electronic or mechanical, including photocopying, or posting on the internet or an intranet, without prior written permission. Permission can be requested from either ISO at the address below or ISO's member body in the country of the requester.

ISO copyright office
CP 401 • Ch. de Blandonnet 8
CH-1214 Vernier, Geneva
Phone: +41 22 749 01 11
Email: copyright@iso.org
Website: www.iso.org

Published in Switzerland

Contents

	Page
Foreword	iv
Introduction	v
1 Scope	1
2 Normative references	1
3 Terms and definitions	2
3.2 Abbreviated terms	2
4 Compound	2
5 General characteristics	2
5.1 Appearance	2
5.2 Colour	3
5.3 Fusion compatibility	3
6 Geometrical characteristics	3
6.1 Measurement of dimensions	3
6.2 Mean outside diameters, out-of-roundness and their tolerances	3
6.3 Wall thicknesses and tolerances	4
6.3.1 Minimum wall thickness	4
6.3.2 Tolerances on wall thickness at any point	5
7 Mechanical characteristics	6
7.1 Conditioning	6
7.2 Requirements	6
8 Physical characteristics	8
8.1 Conditioning	8
8.2 Requirements	8
9 Marking	9
Annex A (normative) Squeeze-off technique	10
Annex B (informative) Examples of the water uptake over time as a function of the sample thickness	11
Bibliography	14

Foreword

ISO (the International Organization for Standardization) is a worldwide federation of national standards bodies (ISO member bodies). The work of preparing International Standards is normally carried out through ISO technical committees. Each member body interested in a subject for which a technical committee has been established has the right to be represented on that committee. International organizations, governmental and non-governmental, in liaison with ISO, also take part in the work. ISO collaborates closely with the International Electrotechnical Commission (IEC) on all matters of electrotechnical standardization.

The procedures used to develop this document and those intended for its further maintenance are described in the ISO/IEC Directives, Part 1. In particular, the different approval criteria needed for the different types of ISO documents should be noted. This document was drafted in accordance with the editorial rules of the ISO/IEC Directives, Part 2 (see www.iso.org/directives).

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. ISO shall not be held responsible for identifying any or all such patent rights. Details of any patent rights identified during the development of the document will be in the Introduction and/or on the ISO list of patent declarations received (see www.iso.org/patents).

Any trade name used in this document is information given for the convenience of users and does not constitute an endorsement.

For an explanation of the voluntary nature of standards, the meaning of ISO specific terms and expressions related to conformity assessment, as well as information about ISO's adherence to the World Trade Organization (WTO) principles in the Technical Barriers to Trade (TBT), see www.iso.org/iso/foreword.html.

This document was prepared by Technical Committee ISO/TC 138, *Plastics pipes, fittings and valves for the transport of fluids*, Subcommittee SC 4, *Plastics pipes and fittings for the supply of gaseous fuels*, in collaboration with the European Committee for Standardization (CEN) Technical Committee CEN/TC 155, *Plastics piping systems and ducting systems*, in accordance with the Agreement on technical cooperation between ISO and CEN (Vienna Agreement).

This second edition cancels and replaces the first edition (ISO 16486-2:2012), which has been technically revised. It also incorporates ISO 16486-2:2012/Amd 1: 2014.

The main changes compared to the previous edition are as follows:

- [Tables 1](#) and [2](#) are extended with nominal outside diameters up to and including 630 mm;
- In [Table 2](#), former 6 hours has been changed to 16 hours in line with the phrasing in the table header;
- In [Table 3](#), the range for the minimum wall thickness is extended up to and including 37 mm;
- [Table 4](#) allows for $e > 12$ mm to use Type 3 specimen with 10 mm/min for the determination of the elongation at break;
- Informative [Annex A](#) – Butt fusion procedure for jointing PA-U pipes – has been deleted;
- A new normative [Annex A](#) – Squeeze-off technique – has been added;
- A new informative [Annex B](#) – Examples of the water uptake over time as a function of the sample thickness – has been added.

A list of all parts in the ISO 16486 series can be found on the ISO website.

Any feedback or questions on this document should be directed to the user's national standards body. A complete listing of these bodies can be found at www.iso.org/members.html.

Introduction

This document specifies the requirements for a piping system and its components made from unplasticized polyamide (PA-U), which is intended to be used for the supply of gaseous fuels.

Requirements and test methods for material and components, other than pipes of the piping system are specified in ISO 16486-1, ISO 16486-3, and ISO 16486-4.

Characteristics for fitness for purpose of the system and generic fusion parameters are covered in ISO 16486-5.

Recommended practice for installation is given in ISO 16486-6, which will not be implemented as a European Standard under the Vienna Agreement.

Assessment of conformity of the system is to form the subject of ISO/TS 16486-7¹⁾.

NOTE Recommended practice for installation is also given in CEN/TS 12007-6, which has been prepared by Technical Committee CEN/TC 234, *Gas infrastructure*.

Parts 1, 2 (this document), 3, 5 and 6 (and future Part 7) of the ISO 16486 series have been prepared by ISO/TC 138/SC4. Part 4 has been prepared by ISO/TC 138/SC 7.

1) Under preparation. Stage at the time of publication: ISO/WD TS 16486-7:2020.

STANDARDSISO.COM : Click to view the full PDF of ISO 16486-2:2020

Plastics piping systems for the supply of gaseous fuels — Unplasticized polyamide (PA-U) piping systems with fusion jointing and mechanical jointing —

Part 2: Pipes

1 Scope

This document specifies the physical and mechanical properties of pipes made from unplasticized polyamide (PA-U) in accordance with ISO 16486-1, intended to be buried and used for the supply of gaseous fuels. It also specifies the test parameters for the test methods to which it refers.

The ISO 16486 series of standards is applicable to PA-U piping systems, the components of which are connected by fusion jointing and/or mechanical jointing.

In addition, this document lays down dimensional characteristics and requirements for the marking of pipes.

Pipes conforming to this document are jointed typically by using mechanical, electrofusion or butt fusion techniques.

2 Normative references

The following documents are referred to in the text in such a way that some or all of their content constitutes requirements of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

ISO 291, *Plastics — Standard atmospheres for conditioning and testing*

ISO 307, *Plastics — Polyamides — Determination of viscosity number*

ISO 1133-2, *Plastics — Determination of the melt mass-flow rate (MFR) and melt volume-flow rate (MVR) of thermoplastics — Part 2: Method for materials sensitive to time-temperature history and/or moisture*

ISO 1167-1, *Thermoplastics pipes, fittings and assemblies for the conveyance of fluids — Determination of the resistance to internal pressure — Part 1: General method*

ISO 1167-2, *Thermoplastics pipes, fittings and assemblies for the conveyance of fluids — Determination of the resistance to internal pressure — Part 2: Preparation of pipe test pieces*

ISO 2505, *Thermoplastics pipes — Longitudinal reversion — Test method and parameters*

ISO 3126, *Plastics piping systems — Plastics components — Determination of dimensions*

ISO 6259-1, *Thermoplastics pipes — Determination of tensile properties — Part 1: General test method*

ISO 6259-3, *Thermoplastics pipes — Determination of tensile properties — Part 3: Polyolefin pipes*

ISO 11922-1, *Thermoplastics pipes for the conveyance of fluids — Dimensions and tolerances — Part 1: Metric series*

ISO 12176-4, *Plastics pipes and fittings — Equipment for fusion jointing polyethylene systems — Part 4: Traceability coding*

ISO 13477, *Thermoplastics pipes for the conveyance of fluids — Determination of resistance to rapid crack propagation (RCP) — Small-scale steady-state test (S4 test)*

ISO 13479, *Polyolefin pipes for the conveyance of fluids — Determination of resistance to crack propagation — Test method for slow crack growth on notched pipes*

ISO 16486-1:2020, *Plastics piping systems for the supply of gaseous fuels — Unplasticized polyamide (PA-U) piping systems with fusion jointing and mechanical jointing — Part 1: General*

EN 12106, *Plastics piping systems - Polyethylene (PE) and crosslinked polyethylene (PE-X) pipes - Test method for the resistance to internal pressure after application of squeeze-off*

3 Terms and definitions

For the purposes of this document, the terms and definitions given in ISO 16486-1 and the following apply.

ISO and IEC maintain terminological databases for use in standardization at the following addresses:

- ISO Online browsing platform: available at <https://www.iso.org/obp>
- IEC Electropedia: available at <http://www.electropedia.org/>

3.1.1

out-of-roundness

⟨pipe or fitting⟩ difference between the measured maximum outside diameter and the measured minimum outside diameter in the same cross-sectional plane of a pipe or spigot end of a fitting

3.1.2

virgin material

material in a form such as granules or powder that has not been previously processed other than for compounding and to which no rework material or recyclable material has been added

3.1.3

squeeze-off

gas flow restricted by squeezing the pipe when compressed between two clamps in such a way that the distance between both clamps is less than twice the nominal wall thickness

3.2 Abbreviated terms

MVR	melt volume-flow rate
SDR	standard dimension ratio

4 Compound

The compound from which the pipes are made shall be in accordance with ISO 16486-1.

The pipes shall be made from virgin material. Rework material shall not be used.

5 General characteristics

5.1 Appearance

When viewed without magnification, the internal and external surfaces of pipes shall be smooth, clean and free from scoring, cavities and other surface defects which can affect pipe performance. The pipe ends shall be cut cleanly and square to the axis of the pipe.

5.2 Colour

The colour of the pipes shall be yellow or black.

NOTE In addition, black PA-U pipes can be identified by yellow or orange stripes, according to national preference.

5.3 Fusion compatibility

Pipes made from PA-U 11 shall be heat fusion jointed only to pipes and/or components made from PA-U 11.

Pipes made from PA-U 12 shall be heat fusion jointed only to pipes and/or components made from PA-U 12.

Pipes made from PA-U are not fusion compatible with pipes and/or components made from other polymers.

NOTE Test methods for assuring fusibility are given in ISO 16486-3 and ISO 16486-5.

6 Geometrical characteristics

6.1 Measurement of dimensions

Dimensions shall be measured in accordance with ISO 3126 at $(23 \pm 2) ^\circ\text{C}$, after being conditioned for at least 4 h. The measurement shall not be made less than 24 h after manufacture.

6.2 Mean outside diameters, out-of-roundness and their tolerances

The mean outside diameter of the pipe, d_{em} , and the out-of-roundness and their tolerances shall be in accordance with [Table 1](#).

For maximum mean outside diameter grade B tolerances, ISO 11922-1 shall apply.

Table 1 — Mean outside diameters and out-of-roundness

Dimensions in millimetres

Nominal outside diameter	Mean outside diameter		Maximum of absolute out-of-roundness ^a	
	$d_{em,min}$	$d_{em,max}$	Grade K ^b	Grade N ^c
d_n				
16	16,0	16,3	1,2	1,2
20	20,0	20,3	1,2	1,2
25	25,0	25,3	1,5	1,2
32	32,0	32,3	2,0	1,3
40	40,0	40,4	2,4	1,4
50	50,0	50,4	3,0	1,4
63	63,0	63,4	3,8	1,5
75	75,0	75,5	—	1,6
90	90,0	90,6	—	1,8
110	110,0	110,7	—	2,2
125	125,0	125,8	—	2,5
140	140,0	140,9	—	2,8

^a Measurement of out-of-roundness shall be made at the point of manufacture according to ISO 3126.

^b For coiled pipe with $d_n \leq 63$ mm, grade K according to ISO 11922-1 applies; for pipe with $d_n \geq 75$ mm, the maximum out-of-roundness shall be specified by agreement.

^c Grade N according to ISO 11922-1.

^d The maximum out-of-roundness shall be specified by agreement.

Table 1 (continued)

Nominal outside diameter	Mean outside diameter		Maximum of absolute out-of-roundness ^a	
	$d_{em,min}$	$d_{em,max}$	Grade K ^b	Grade N ^c
d_n				
160	160,0	161,0	—	3,2
180	180,0	181,1	—	3,6
200	200,0	201,2	—	4,0
225	225,0	226,4	—	4,5
250	250,0	251,5	—	5,0
280	280,0	281,7	—	9,8
315	315,0	316,9	—	11,1
355	355,0	357,2	—	12,5
400	400,0	402,4	—	14,0
450	450,0	452,7	—	d
500	500,0	503,0	—	c, d
560	560,0	563,4	—	d
630	630,0	633,8	—	d

^a Measurement of out-of-roundness shall be made at the point of manufacture according to ISO 3126.

^b For coiled pipe with $d_n \leq 63$ mm, grade K according to ISO 11922-1 applies; for pipe with $d_n \geq 75$ mm, the maximum out-of-roundness shall be specified by agreement.

^c Grade N according to ISO 11922-1.

^d The maximum out-of-roundness shall be specified by agreement.

6.3 Wall thicknesses and tolerances

6.3.1 Minimum wall thickness

The minimum wall thickness, e_{min} , shall be in accordance with Table 2. Small diameter pipes are characterized by wall thickness. Large diameter pipes are characterized by their standard dimension ratio (SDR).

The use of any SDR derived from the pipe series S given according to ISO 4065 and ISO 161-1 is permitted.

NOTE In order to minimize the possibility of damage to small-diameter gas pipes by external influences, the use of pipes having a wall thickness of not less than 3,0 mm, even if higher than the minimal SDR value, can be considered.

Table 2 — Minimum wall thickness

Dimensions in millimetres

Nominal outside diameter ^b	Minimum wall thickness ^a						
	e_{min}						
d_n	SDR 7,4	SDR 9	SDR 11	SDR 13,6	SDR 17	SDR 21	SDR 26
16	2,2	—	—	—	—	—	—
20	2,8	2,3	—	—	—	—	—
25	3,5	2,8	2,3	—	—	—	—
32	4,4	3,6	2,9	2,4	—	—	—
40	5,5	4,5	3,7	3,0	2,4	2,0	—
50	6,9	5,6	4,6	3,7	3,0	2,4	2,0
63	8,6	7,1	5,8	4,7	3,8	3,0	2,5
75	10,3	8,4	6,8	5,6	4,5	3,6	2,9

^a For wall thickness >30 mm butt fusion jointing parameters are evaluated individually.

^b For diameters >250 mm mechanical fittings and electrofusion methods are evaluated.

Table 2 (continued)

Nominal outside diameter ^b d_n	Minimum wall thickness ^a						
	e_{min}						
	SDR 7,4	SDR 9	SDR 11	SDR 13,6	SDR 17	SDR 21	SDR 26
90	12,3	10,1	8,2	6,7	5,4	4,3	3,9
110	15,1	12,3	10,0	8,1	6,6	5,3	4,2
125	17,1	14,0	11,4	9,2	7,4	6,0	4,8
140	19,2	15,7	12,7	10,3	8,3	6,7	5,4
160	21,9	17,9	14,6	11,8	9,5	7,7	6,2
180	24,6	20,1	16,4	13,3	10,7	8,6	6,9
200	27,4	22,4	18,2	14,7	11,9	9,6	7,7
225	30,8	25,2	20,5	16,6	13,4	10,8	8,6
250	34,2	27,9	22,7	18,4	14,8	11,9	9,6
280	—	31,3	25,4	20,6	16,6	13,4	10,7
315	—	35,2	28,6	23,2	18,7	15,0	12,1
355	—	—	32,2	26,1	21,1	16,9	13,6
400	—	—	36,4	29,4	23,7	19,1	15,3
450	—	—	—	33,1	26,7	21,5	17,2
500	—	—	—	36,8	29,7	23,9	19,1
560	—	—	—	—	33,2	26,7	21,4
630	—	—	—	—	—	30,0	24,1

^a For wall thickness >30 mm butt fusion jointing parameters are evaluated individually.

^b For diameters >250 mm mechanical fittings and electrofusion methods are evaluated.

6.3.2 Tolerances on wall thickness at any point

The tolerances on the wall thickness at any point shall be in accordance with ISO 11922-1, Grade V. The maximum permissible variation between the nominal wall thickness, e_n , and the wall thickness at any point, e , shall be in accordance with Table 3.

Table 3 — Tolerances on wall thickness at any point

Minimum wall thickness e_{min}		Permitted positive deviation	Minimum wall thickness e_{min}		Permitted positive deviation
>	≤		>	≤	
2,0	3,0	0,4	22,0	23,0	2,4
3,0	4,0	0,5	23,0	24,0	2,5
4,0	5,0	0,6	24,0	25,0	2,6
5,0	6,0	0,7	25,0	26,0	2,7
6,0	7,0	0,8	26,0	27,0	2,8
7,0	8,0	0,9	27,0	28,0	2,9
8,0	9,0	1,0	28,0	29,0	3,0
9,0	10,0	1,1	29,0	30,0	3,1
10,0	11,0	1,2	30,0	31,0	3,2
11,0	12,0	1,3	31,0	32,0	3,3
12,0	13,0	1,4	32,0	33,0	3,4
13,0	14,0	1,5	33,0	34,0	3,5
14,0	15,0	1,6	34,0	35,0	3,6
15,0	16,0	1,7	35,0	36,0	3,7
16,0	17,0	1,8	36,0	37,0	3,8
17,0	18,0	1,9			
18,0	19,0	2,0			
19,0	20,0	2,1			
20,0	21,0	2,2			
21,0	22,0	2,3			

7 Mechanical characteristics

7.1 Conditioning

Unless otherwise specified in the applicable test method, the test pieces shall be conditioned for at least 16 h at 23 °C and 50 % relative humidity in accordance with ISO 291 before testing in accordance with [Table 4](#).

The test pieces shall not be tested within the period of 48 h after their manufacture.

NOTE Pipes are used for the determination of the long-term hydrostatic strength of PA-U compounds and are saturated with water before starting the tests. Therefore, in Annex B examples are given for the water uptake over time in function of the sample thickness.

7.2 Requirements

The test pieces shall be tested in accordance with [Table 4](#). When tested using the test method and parameters specified therein, the pipe shall have mechanical characteristics conforming to the requirements of [Table 4](#). The requirements for pipe that has been subject to squeeze-off are given in [Annex A](#).

Table 4 — Mechanical characteristics

Characteristic	Requirement	Test parameters		Test method(s)
		Parameter	Value	
Hydrostatic strength at 20 °C for 1 000 h	No failure of any test piece during test period	End caps	Type ^a	ISO 1167-1
		Orientation	Free	ISO 1167-2
		Conditioning period	16 h	
		Type of test	Water-in-water	
		Test temperature	20 °C	
		Test period	1 000 h	
		Circumferential (hoop) stress:		
		PA-U 11 160 and PA-U 12 160 ^a	19,0 MPa	
		PA-U 11 180 and PA-U 12 180 ^a	20,0 MPa	
^a For material classification and designation, see ISO 16486-1:2020, 5.4.				
^b Test pressure levels for other SDR are given in Table 5 .				
^c $p_{C,S4,REF}$ is the value of the critical pressure determined in the S4 test on the pipe according to ISO 16486-1:2020, Table 2 from the batch whose full-scale critical pressure, p_c , was determined in ISO 16486-1.				
^d For pipes of $d_n < 90$ mm, the value of critical pressure, $p_{C,S4,REF}$, determined on a pipe of d_n 90 mm or d_n 110 mm according to ISO 16486-1:2020, Table 2, shall be taken as the reference value.				

Table 4 (continued)

Characteristic	Requirement	Test parameters		Test method(s)
		Parameter	Value	
Hydrostatic strength at 80 °C for 165 h	No failure of any test piece during test period	End caps	Type ^a	ISO 1167-1
		Orientation	Free	ISO 1167-2
		Conditioning period	16 h	
		Type of test	Water-in-water	
		Test temperature	80 °C	
		Test period	165 h	
		Circumferential (hoop) stress:		
		PA-U 11 160 and PA-U 12 160 ^a	10,0 MPa	
		PA-U 11 180 and PA-U 12 180 ^a	11,5 MPa	
Elongation at break for $e \leq 12$ mm	≥ 200 %	Test piece shape	Type 1	ISO 6259-1 ISO 6259-3
		Speed of test	25 mm/min	
		Number of test pieces	Shall conform to ISO 6259-1	
Elongation at break for $e > 12$ mm	≥ 200 %	Test piece shape	Type 1	
		Speed of test	25 mm/min	
		Number of test pieces	Shall conform to ISO 6259-1	
		Or		
		Test piece shape	Type 3	
Resistance to slow crack growth for $e > 5$ mm (notch test)	No failure during the test period	Test temperature	80 °C	ISO 13479
		SDR	11	
		Type of test	Water-in-water	
		Test period	500 h	
		Test pressure:		
		PA-U 11 160 and PA-U 12 160 ^a	18 bar ^b	
		PA-U 11 180 and PA-U 12 180 ^a	20 bar ^b	
Resistance to rapid crack propagation (critical pressure, $p_{c,S4}$) (S4 test)	$p_{c,S4} \geq 0,9p_{c,S4,REF}^{c,d}$	Test temperature	0 °C	ISO 13477

^a For material classification and designation, see ISO 16486-1:2020, 5.4.

^b Test pressure levels for other SDR are given in [Table 5](#).

^c $p_{c,S4,REF}$ is the value of the critical pressure determined in the S4 test on the pipe according to ISO 16486-1:2020, Table 2 from the batch whose full-scale critical pressure, p_c , was determined in ISO 16486-1.

^d For pipes of $d_n < 90$ mm, the value of critical pressure, $p_{c,S4,REF}$, determined on a pipe of d_n 90 mm or d_n 110 mm according to ISO 16486-1:2020, Table 2, shall be taken as the reference value.

In [Table 5](#) test pressure levels are given for different SDR classes for information.

Table 5 — Test pressure levels

SDR	Test pressure bar ^a	
	PA-U 11 160 and PA-U 12 160 ^b	PA-U 11 180 and PA-U 12 180 ^b
7,40	28,12	31,25
9,00	22,50	25,00
11,00	18,00	20,00
13,60	14,28	15,87
17,00	11,25	12,50
21,00	9,00	10,00
26,00	7,20	8,00
These pressure levels are calculated to give nominal pipe hydrostatic levels of either 9 MPa (in PA-U 11 160 and PA-U 12 160 materials)^a or 10 MPa (in PA-U 11 180 and PA-U 12 180 materials)^a, using the following formula: $p = \frac{20\sigma}{SDR-1}$ where σ is the hydrostatic stress, in megapascals; SDR is the standard dimension ratio. ^a 1 bar = 0,1 MPa = 10⁵ Pa; 1 MPa = 1 N/mm². ^b For material classification and designation, see ISO 16486-1:2020, 5.4.		

8 Physical characteristics

8.1 Conditioning

Unless otherwise specified in the applicable test method, the test pieces shall be conditioned for at least 16 h at 23 °C and 50 % relative humidity in accordance with ISO 291 before testing in accordance with Table 6.

The test pieces shall not be tested within the period of 48 h after their manufacture.

8.2 Requirements

The test pieces shall be tested in accordance with Table 6. When tested using the test method and parameters specified therein, the pipe shall have physical characteristics conforming to the requirements of Table 6.

Table 6 — Physical characteristics

Characteristic	Requirement	Test parameters		Test method(s)
		Parameter	Value	
Viscosity number	≥ 180 ml/g	Solvent	m-Cresol	ISO 307
^a The water content of the sample shall be <0,1 %. This is essential because PA-U resin is sensitive to hydrolysis. Therefore, the test sample shall be dried prior to testing at 80 °C in a dry air or vacuum dryer for 3 h, or as recommended by the PA-U resin producer. The MVR report shall include the water content of the sample prior testing with the used methodology for its determination. ^b The melt volume-flow rate (MVR) can be measured by the pipe manufacturer for internal QC, as an alternative for the viscosity number, e.g. to test deviations prior to and after working with the material. In practice, the MVR is extremely sensitive to any influence of water content, even if the water content is extremely low (see ISO 1133-2:2011, Table B.1, example for PA 6). It is recommended for PA-U to compare only MVR results from one test device.				

Table 6 (continued)

Characteristic	Requirement	Test parameters		Test method(s)
		Parameter	Value	
Melt vol- ume-flow rate (MVR) ^{a,b}	As recommended by the material supplier	Temperature	235 °C	ISO 1133-2
		Load	10 kg	
Longitudinal reversion	≤ 3 % The pipe shall retain its original appearance	Heating fluid	Air	ISO 2505
		Test temperature	150 °C	
		Length of test piece	200 mm	
		Duration of exposure	According to ISO 2505	

^a The water content of the sample shall be <0,1 %. This is essential because PA-U resin is sensitive to hydrolysis. Therefore, the test sample shall be dried prior to testing at 80 °C in a dry air or vacuum dryer for 3 h, or as recommended by the PA-U resin producer. The MVR report shall include the water content of the sample prior testing with the used methodology for its determination.

^b The melt volume-flow rate (MVR) can be measured by the pipe manufacturer for internal QC, as an alternative for the viscosity number, e.g. to test deviations prior to and after working with the material. In practice, the MVR is extremely sensitive to any influence of water content, even if the water content is extremely low (see ISO 1133-2:2011, Table B.1, example for PA 6). It is recommended for PA-U to compare only MVR results from one test device.

9 Marking

All pipes shall be permanently and legibly marked with the minimum information specified in [Table 7](#) so that the marking does not initiate cracks or other types of failure or weaken the pipe, and so that normal storage, weathering, handling, installation or use does not affect the legibility of the marking.

The length of coiled pipes may be indicated on the coil.

If printing is used, the colour of the printed information shall differ from the basic colour of the product. The frequency of the printing shall be at intervals not greater than 1 m.

The quality and size of the marking shall be so that it is easily legible without magnification.

Table 7 — Minimum information for marking

Information	Marking or symbol
Manufacturer or trademark	Name or symbol
Internal fluid	Gas
Dimensions	e.g. $d_n \times e_n$
SDR (for $d_n \geq 40$ mm)	e.g. SDR 17
Material and designation	e.g. PA-U 11 160 ^a
Production period	Date, code
Reference to this series	ISO 16486
^a For material classification and designation, see ISO 16486-1:2020, 5.4.	

NOTE For marking of traceability information a barcoding system can be used in addition to the minimum required marking in line with ISO 12176-4.

Annex A (normative)

Squeeze-off technique

A.1 General

In certain countries, the squeeze-off technique is used to restrict the flow of gas in PA-U piping systems while effecting maintenance and repair operations^{[5][8][9]}.

The use of hydrogen in natural gas networks requires special consideration^[10].

If the end-user wishes to employ the technique, evidence shall be provided to the end-user that after squeeze-off, in accordance with the method recommended by the manufacturer of the pipes, the requirements for hydrostatic strength of the pipe at 20 °C for 1 000 h or 80 °C for 165 h according to [Table 4](#) are fulfilled. These tests on squeezed-off pipes shall also fulfil the requirements of these hydrostatic tests on pipes in accordance with [Table 4](#).

A.2 Test method

The evidence in accordance with [A.1](#) shall be obtained using a procedure in line with EN 12106.

Annex B (informative)

Examples of the water uptake over time as a function of the sample thickness

[Figures B.1](#) and [B.2](#) show the normalized water uptake at 70 °C of SDR 11 pipes made of PA-U 12 180. Normalized means that 100 % is equal to the water content of fully saturated PA-U.

If the value for full saturation of the specific PA-U grade is known, the figures can be used for a rough estimation for the time for which the sample should be stored in water at 70° in order to reach a certain water content. As specific PA-U grades can behave differently in terms of speed of water content as well as the level for full saturation, [Figure B.1](#) or [Figure B.2](#) can only be used as a very rough guide for sampling followed by measuring the attained water uptake.

A time scale of up to 5 days for [Figure B.1](#) enables a more precise reading of the curves for a short time use. [Figure B.2](#) shows the curves for complete test duration of 70 days.