
**Industrial valves — Lined metal
quarter turn and check valves
for chemical process and related
industries**

Robinetterie industrielle — Robinets quart de tour et clapets de non-retour métalliques revêtus pour les industries de procédé chimique et industries connexes

STANDARDSISO.COM : Click to view the full PDF of ISO 19240:2017



STANDARDSISO.COM : Click to view the full PDF of ISO 19240:2017



COPYRIGHT PROTECTED DOCUMENT

© ISO 2017, Published in Switzerland

All rights reserved. Unless otherwise specified, no part of this publication may be reproduced or utilized otherwise in any form or by any means, electronic or mechanical, including photocopying, or posting on the internet or an intranet, without prior written permission. Permission can be requested from either ISO at the address below or ISO's member body in the country of the requester.

ISO copyright office
Ch. de Blandonnet 8 • CP 401
CH-1214 Vernier, Geneva, Switzerland
Tel. +41 22 749 01 11
Fax +41 22 749 09 47
copyright@iso.org
www.iso.org

Contents

	Page
Foreword	iv
Introduction	v
1 Scope	1
2 Normative references	1
3 Terms and definitions	2
4 Pressure/temperature ratings	3
5 Design	3
5.1 Body wall thickness	3
5.2 Lining and seat materials	4
5.3 Liner anchoring	4
5.4 Minimum lining thickness	4
5.5 Shaft	4
5.6 Dimension and tolerances of body ends	4
5.6.1 Dimensions of flanges	4
5.6.2 Face-to-face dimensions	4
5.6.3 Flange facing type and dimension	4
6 Marking	5
7 Inspection and testing	6
7.1 Lining test	6
7.1.1 Visual inspection	6
7.1.2 Porosity test	6
7.1.3 Anti-static test	6
7.2 Pressure test	6
7.3 Allowable closure test leakage rate	6
7.4 Additional examination	6
Bibliography	7

Foreword

ISO (the International Organization for Standardization) is a worldwide federation of national standards bodies (ISO member bodies). The work of preparing International Standards is normally carried out through ISO technical committees. Each member body interested in a subject for which a technical committee has been established has the right to be represented on that committee. International organizations, governmental and non-governmental, in liaison with ISO, also take part in the work. ISO collaborates closely with the International Electrotechnical Commission (IEC) on all matters of electrotechnical standardization.

The procedures used to develop this document and those intended for its further maintenance are described in the ISO/IEC Directives, Part 1. In particular the different approval criteria needed for the different types of ISO documents should be noted. This document was drafted in accordance with the editorial rules of the ISO/IEC Directives, Part 2 (see www.iso.org/directives).

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. ISO shall not be held responsible for identifying any or all such patent rights. Details of any patent rights identified during the development of the document will be in the Introduction and/or on the ISO list of patent declarations received (see www.iso.org/patents).

Any trade name used in this document is information given for the convenience of users and does not constitute an endorsement.

For an explanation on the voluntary nature of standards, the meaning of ISO specific terms and expressions related to conformity assessment, as well as information about ISO's adherence to the World Trade Organization (WTO) principles in the Technical Barriers to Trade (TBT) see the following URL: www.iso.org/iso/foreword.html.

This document was prepared by Technical Committee ISO/TC 153, *Valves*.

Introduction

The purpose of this document is to establish requirements for lined metal quarter turn valves (butterfly valves, ball valves, plug valves and check valves) in corrosive fluid applications and related industries. It is intended that this document facilitates compatibility with flanged lined fittings and lined pipe.

STANDARDSISO.COM : Click to view the full PDF of ISO 19240:2017

STANDARDSISO.COM : Click to view the full PDF of ISO 19240:2017

Industrial valves — Lined metal quarter turn and check valves for chemical process and related industries

1 Scope

This document specifies requirements for design, dimensions, material, fabrication and production testing of lined metal quarter turns valves (plug valves, butterfly valves, ball valves) and check valves with flanged, wafer and wafer lug body types.

It covers valves of the nominal sizes, DN:

- 15, 20, 25, 32, 40, 50, 65, 80, 100, 125, 150, 200, 250, 300, 350, 400, 450, 500, 600, 700, 750, 800, 900, 1 000, 1 200;

corresponding to nominal pipe sizes, NPS 1/2 to NPS 48, and applies to pressure designations:

- PN 10, 16, 25, 40;
- Class 150, 300.

2 Normative references

The following documents are referred to in the text in such a way that some or all of their content constitutes requirements of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

ISO 5208:2015, *Industrial valves — Pressure testing of metallic valves*

ISO 5209:1977, *General purpose industrial valves — Marking*

ISO 5752, *Metal valves for use in flanged pipe systems — Face-to-face and centre-to-face dimensions*

EN 1092-1:2007+A1:2013, *Flanges and their joints — Circular flanges for pipes, valves, fittings and accessories, PN designated — Part 1: Steel flanges*

EN 1092-2, *Flanges and their joints — Circular flanges for pipes, valves, fittings and accessories, PN designated — Part 2: Cast iron flanges*

EN 12266-2:2012, *Industrial valves — Testing of metallic valves — Part 2: Tests, test procedures and acceptance criteria — Supplementary requirements*

EN 12516-1, *Industrial valves — Shell design strength — Part 1: Tabulation method for steel valve shells*

EN 12516-2, *Industrial valves — Shell design strength — Part 2: Calculation method for steel valve shells*

EN 12516-4, *Industrial valves — Shell design strength — Part 4: Calculation method for valve shells manufactured in metallic materials other than steel*

EN 14879-4:2007, *Organic coating systems and linings for protection of industrial apparatus and plants against corrosion caused by aggressive media — Part 4: Linings on metallic components*

ASME B16.1, *Gray Iron Pipe Flanges and Flanged Fittings: Classes 25, 125, and 250*

ASME B16.5, *Pipe Flanges and Flanged Fittings: NPS 1/2 through NPS 24 Metric/Inch Standard*

ASME B16.34, *Valves Flanged, Threaded and Welding End*

ASME B16.42:2011, *Ductile Iron Pipe Flanges and Flanged Fittings*

ASME B16.47, *Large Diameter Steel Flanges: NPS 26 through NPS 60 Metric/Inch Standard*

ASME BPVC-VIII-1:2015, *Boiler and Pressure Vessel Code — Section VIII: Rules for Construction of Pressure Vessels — Division 1: Design & Fabrication with Inspections, Repairs, and Alterations of Pressure Vessels*

3 Terms and definitions

For the purposes of this document, the following terms and definitions apply.

ISO and IEC maintain terminological databases for use in standardization at the following addresses:

- IEC Electropedia: available at <http://www.electropedia.org/>
- ISO Online browsing platform: available at <http://www.iso.org/obp>

3.1

nominal size

DN

alphanumeric designation of size for components of a pipework system, which is used for reference purposes, comprising the letters DN followed by a dimensionless whole number which is indirectly related to the physical size, in millimetres, of the bore or outside diameter of the end connections

[SOURCE: ISO 6708:1995, 2.1]

3.2

nominal pressure

PN

numerical designation relating to pressure that is a convenient rounded number for reference purposes, and which comprises the letters PN followed by the appropriate reference number

Note 1 to entry: It is intended that all equipment of the same nominal size (DN) designated by the same PN number have compatible mating dimensions.

Note 2 to entry: The maximum allowable pressure depends on materials, design, and working temperature, and is to be selected from the tables of pressure/temperature ratings given in the appropriate standards.

[SOURCE: ISO 7268:1983, Clause 2, modified — the definition and notes to entry have been slightly modified.]

3.3

nominal pipe size

NPS

alphanumeric designation of size for components of a pipework system, which is used for reference purposes, and which comprises the letters NPS followed by a dimensionless number indirectly related to the physical size, in inches, of the bore or outside diameter of the end connections

Note 1 to entry: The number following the letters NPS does not represent a measurable value and is not intended to be used for calculation purposes except where specified in the relevant standard.

3.4

Class

alphanumeric designation used for reference purposes related to a combination of mechanical and dimensional characteristics of a component of a pipework system, which comprises the word “Class” followed by a dimensionless whole number

Note 1 to entry: The number following the word “Class” does not represent a measurable value and is not intended to be used for calculation purposes except where specified in the relevant standard.

3.5**face-to-face dimension**

distance between the body ends of the equipment in accordance with ISO 5752

3.6**differential pressure**

Δp

pressure difference across the upstream and downstream sides of the closure element when the valve is in the closed position

Note 1 to entry: Differential pressure is expressed in bar, where 1 bar = 0,1 MPa = 10⁵ Pa; 1 MPa = 1 N/mm² (bar is a unit deprecated by ISO).

3.7**anti-static design**

design that provides for electrical continuity between the stem and the body parts of the valve

4 Pressure/temperature ratings

The pressure/temperature ratings of the valve shall meet the specification given in the appropriate pressure/temperature tables of the standards listed in [Table 1](#).

Table 1 — Standards for pressure/temperature ratings

Body material	PN-designated valve	Class-designated valve
Steel	EN 12516-1	ASME B16.34
Cast iron	EN 1092-2	ASME B16.1
Ductile iron	EN 1092-2	ASME B16.42

The complete assembly shall comply with differential pressure and pressure/temperature ratings. The maximum allowable temperature and/or the design differential pressure may be limited by restrictions in the pressure/temperature ratings of materials used for certain components like the fluoropolymer lining materials.

Restrictions shall be marked on the valve by the manufacturer (see [Clause 6](#)).

For temperatures below the lowest temperature listed in the pressure/temperature tables, the working pressure shall be no greater than the pressure for the lowest listed temperature. The use of valves at lower temperatures is the responsibility of the user. Consideration should be given to the loss of ductility and impact strength of materials at low temperature.

5 Design**5.1 Body wall thickness**

The minimum body wall thickness shall be determined using the standards indicated in [Table 2](#).

For pressure-temperature ratings of the valve bodies outside the size ranges of the referenced standards of [Table 2](#), design and calculations for pressure-containing elements shall be in accordance with an internationally recognized design code or standards with consideration of pipe loads, operating forces, etc. The choice of standard shall be by agreement.

NOTE An example of internationally recognized design codes or standards is ASME BPVC-VIII, Division 1 or Division 2.

Table 2 — Standards for body wall thickness

Body material	PN-designated valve	Class-designated valve
Steel	EN 12516-1 EN 12516-2	ASME B16.34
Cast iron	EN 12516-4	ASME BPVC-VIII-1:2015, Part UCI
Ductile iron	EN 12516-4	ASME B16.42:2011, Annex A ASME BPVC-VIII-1:2015, Part UCD

5.2 Lining and seat materials

The valve lining shall be made of fluoropolymer or polymer materials.

5.3 Liner anchoring

The liner shall be mechanically anchored to the valve body and closure element to ensure the proper fixation of the liner in both the axial and radial flow directions.

5.4 Minimum lining thickness

The minimum lining thickness shall be 2,5 mm on all media wetted surfaces, as well on the end flange sealing faces.

5.5 Shaft

The shaft lining shall be continued above the primary shaft seal.

The shaft design shall be blow-out proof.

5.6 Dimension and tolerances of body ends

5.6.1 Dimensions of flanges

Body end of PN-designated valves shall be capable of mating with connecting flanges complying with the requirements of EN 1092-1 and EN 1092-2.

Body end of Class-designated valves shall be capable of mating with connecting flanges complying with the requirements of ASME B16.5 for NPS ≤ 24 or ASME B16.47 for NPS > 24.

In case of valve size outside the scope of EN 1092-1, EN 1092-2, ASME B16.5 or ASME B16.47, another flange standard may be used by agreement between the manufacturer and the purchaser.

5.6.2 Face-to-face dimensions

The face-to-face dimensions shall be in accordance with ISO 5752, unless otherwise specified in the purchasing documents. The basic series required shall be specified by the purchaser.

In case of valve configuration outside the ranges covered by ISO 5752, the face-to-face dimensions may be defined by agreement between the manufacturer and the purchaser.


Tolerances on face-to-face dimensions shall be in accordance with ISO 5752.

5.6.3 Flange facing type and dimension

[Figure 1](#) shows two typical flange face lining designs.

Flange facing dimension of PN-designated valves shall be according to EN 1092-1:2007+A1:2013 form B, only shape and dimensions like form B1.

Flange facing dimension of Class-designated valves shall be according to ASME B16.5 or ASME B16.47.



Key

- 1 flange
- 2 lining

Figure 1 — Typical flange face linings

6 Marking

Each PN-designated valve shall be marked in accordance with ISO 5209 as follows.

- a) For valves with $DN < 50$, only markings 1 to 4 are mandatory. They shall be placed on the valve body or on an attached plate.
- b) For all nominal diameters, the following markings are required:
 - design differential pressure;
 - item 5 of ISO 5209:1977 if required by the valve type;
 - item 6 of ISO 5209:1977 if required by the valve type;
 - item 7 of ISO 5209:1977 if the valve application is restricted.

NOTE Markings 8 to 19 of ISO 5209:1977 are optional.

Each Class-designated valve shall be marked in accordance with ASME B16.34.