



Published — 1979-08-15

Commercial refrigerated cabinets — Methods of test Part 2 : General test conditions

AMENDMENT 1

Amendment 1 to International Standard ISO 1992/2 was developed by Technical Committee ISO/TC 86, *Refrigeration*, and was circulated to the member bodies in November 1977

It has been approved by the member bodies of the following countries :

Bulgaria	Israel	Sweden
Czechoslovakia	Italy	Switzerland
Finland	Mexico	Turkey
France	Poland	United Kingdom
Germany, F. R.	Romania	USA
Hungary	South Africa, Rep. of	USSR
Ireland	Spain	Yugoslavia

The member bodies of the following countries expressed disapproval of the document on technical grounds :

Australia
New Zealand

Page 1

Sub-clause 4.1.2, Air movement

Replace the second paragraph by the following :

"For closed cabinets with one door or lid, the direction of air flow shall be such that the air enters the cabinet when the door or lid is open.

For closed cabinets with two or more doors or lids, the direction of air flow shall be such that the air enters at least half the number of the doors or lids when they are open."

Page 3

Sub-clause 5.1

Replace the existing text by the following :

"Before the test is started, the cabinet shall be switched on and allowed to run for at least 24 h (or at least 2 h in the case of cabinets intended to be switched off at night), at the specified climate class, with no packages in the cabinet."

Sub-clause 5.4

Amend the end of the first sentence (lines 5 and 6) to read

"brought to a temperature approximately equal to the average mean temperature expected during the test."

UDC 621.565.9 : 620.16

Ref. No. ISO 1992/2-1973/A1-1979 (E)

Descriptors : refrigerators, tests, testing conditions.

© International Organization for Standardization, 1979 •

Printed in Switzerland

Price based on 1 page