
**Cryogenic vessels — Large
transportable vacuum-insulated
vessels —**

**Part 2:
Operational requirements**

*Réipients cryogéniques — Grands réipients transportables, isolés,
sous vide —*

Partie 2: Exigences de fonctionnement



STANDARDSISO.COM : Click to view the full PDF of ISO 20421-2:2017



COPYRIGHT PROTECTED DOCUMENT

© ISO 2017, Published in Switzerland

All rights reserved. Unless otherwise specified, no part of this publication may be reproduced or utilized otherwise in any form or by any means, electronic or mechanical, including photocopying, or posting on the internet or an intranet, without prior written permission. Permission can be requested from either ISO at the address below or ISO's member body in the country of the requester.

ISO copyright office
Ch. de Blandonnet 8 • CP 401
CH-1214 Vernier, Geneva, Switzerland
Tel. +41 22 749 01 11
Fax +41 22 749 09 47
copyright@iso.org
www.iso.org

Contents

	Page
Foreword	iv
Introduction	v
1 Scope	1
2 Normative references	1
3 Terms and definitions	1
4 Preliminaries before putting into service	2
4.1 General	2
4.2 Marking and labelling	2
4.2.1 Marking	2
4.2.2 Labelling (or placarding)	3
4.3 Handover documents	3
5 Personnel training	3
6 General safety requirements	4
6.1 General	4
6.2 Safety considerations	4
7 Putting into service	5
8 Location	5
9 Transport	6
10 Filling	6
10.1 General	6
10.2 Prefill checks	7
10.3 Preparations	7
10.4 After-fill check	8
11 Product withdrawal	8
12 Change of service	8
13 Taking out service	9
14 Maintenance and repair	9
15 Periodic inspection	10
16 Additional requirements for flammable gases	11
16.1 General safety requirements	11
16.1.1 General	11
16.1.2 Electrical equipment	11
16.1.3 Grounding (earthing) system	11
16.2 Putting into service (see also Clause 7)	12
16.3 Location (see also Clause 8)	12
16.4 Transport (see also Clause 9)	12
16.5 Filling (see also Clause 10)	12
16.6 Change of service (see also Clause 12)	12
16.7 Taking out of service (see also Clause 13)	12
16.8 Maintenance and repair (see also Clause 14)	12
16.9 Emergency equipment and procedures	13
Bibliography	14

Foreword

ISO (the International Organization for Standardization) is a worldwide federation of national standards bodies (ISO member bodies). The work of preparing International Standards is normally carried out through ISO technical committees. Each member body interested in a subject for which a technical committee has been established has the right to be represented on that committee. International organizations, governmental and non-governmental, in liaison with ISO, also take part in the work. ISO collaborates closely with the International Electrotechnical Commission (IEC) on all matters of electrotechnical standardization.

The procedures used to develop this document and those intended for its further maintenance are described in the ISO/IEC Directives, Part 1. In particular the different approval criteria needed for the different types of ISO documents should be noted. This document was drafted in accordance with the editorial rules of the ISO/IEC Directives, Part 2 (see www.iso.org/directives).

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. ISO shall not be held responsible for identifying any or all such patent rights. Details of any patent rights identified during the development of the document will be in the Introduction and/or on the ISO list of patent declarations received (see www.iso.org/patents).

Any trade name used in this document is information given for the convenience of users and does not constitute an endorsement.

For an explanation on the meaning of ISO specific terms and expressions related to conformity assessment, as well as information about ISO's adherence to the World Trade Organization (WTO) principles in the Technical Barriers to Trade (TBT) see the following URL: www.iso.org/iso/foreword.html.

The committee responsible for this document is ISO/TC 220, *Cryogenic vessels*.

This second edition cancels and replaces the first edition (ISO 20421-2:2005), which has been technically revised.

A list of all parts in the ISO 20421 series can be found on the ISO website.

Introduction

Elements of this document support the requirements of the UN-Recommendations on the Transport of Dangerous Goods and other international, national or local requirements.

Large transportable cryogenic vessels are often partly equipped by the manufacturer, but may be completed or re-equipped by another party, such as the operator or owner. For this reason, some of the scope of this document, which includes putting into service, inspection, filling, maintenance and emergency procedures, overlaps with ISO 20421-1.

This document applies to vessels for cryogenic fluids, primarily as specified in ISO 20421-1. It may also be used for vessels for cryogenic fluids manufactured and designed to other standards, e.g. EN 13530-2. In case of conflict between the requirements of this document with applicable regulations, regulations take precedence.

STANDARDSISO.COM : Click to view the full PDF of ISO 20421-2:2017

STANDARDSISO.COM : Click to view the full PDF of ISO 20421-2:2017

Cryogenic vessels — Large transportable vacuum-insulated vessels —

Part 2: Operational requirements

1 Scope

This document specifies operational requirements for large transportable vacuum-insulated cryogenic vessels.

These operational requirements include putting into service, filling, withdrawal, transport within the location, storage, maintenance, periodic inspection and emergency procedures.

For the transport of these vessels by public road, rail, waterway, sea and air, additional requirements can apply; these are defined in specific regulations.

2 Normative references

The following documents are referred to in the text in such a way that some or all of their content constitutes requirements of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

ISO 20421-1, *Cryogenic vessels — Large transportable vacuum-insulated vessels — Part 1: Design, fabrication, inspection and testing*

3 Terms and definitions

For the purposes of this document, the following terms and definitions apply.

ISO and IEC maintain terminological databases for use in standardization at the following addresses:

- IEC Electropedia: available at <http://www.electropedia.org/>
- ISO Online browsing platform: available at <http://www.iso.org/obp>

3.1

putting into service

operation by which a new vessel being used for the first time or an existing vessel being returned to service is prepared for use

Note 1 to entry: Initial inspections and tests are covered in ISO 20421-1 or similar design standards, e.g. EN 13530-2.

3.2

filling

operation by which a transportable vessel undergoes a prefill check, filling with a cryogenic fluid and an after-fill check

3.3

withdrawal

operation by which the product is taken from a vessel connected to the supply system

**3.4
outdoor**

location outside of any building or structure and not enclosed by more than two walls or one wall if a roof is also present

**3.5
underground**

area or room whose ground or floor is on all sides significantly lower than the adjacent ground surfaces

**3.6
large transportable cryogenic vessel**

thermally insulated vessel of more than 450 l intended for the transport of one or more cryogenic fluids, consisting of an inner vessel, an outer jacket, all of the valves and service equipment together with the structural parts

Note 1 to entry: The large transportable cryogenic vessel comprises a complete assembly that is ready for service.

Note 2 to entry: A "large transportable cryogenic vessel" is hereinafter referred to as "vessel"

**3.7
authorized person**

person authorized by the applicable regulations

**3.8
enterprise**

any person or company that has a legal duty of care

**3.9
filler**

any enterprise which loads cryogenic fluids into a cryogenic vessel

**3.10
owner**

enterprise that legally owns the cryogenic vessel

**3.11
operator**

any enterprise for filling, storage, transport and withdrawal of cryogenic product

**3.12
holding time**

time that will elapse from the establishment of the initial filling condition until the pressure has risen due to heat influx to the lowest set pressure of the pressure limiting device(s)

4 Preliminaries before putting into service

4.1 General

Before putting into service, verification shall take place to ensure that the vessel is suitable for the intended service and that the marking, labelling and handover documents are complete.

4.2 Marking and labelling

4.2.1 Marking

Marking shall be in accordance with the applicable design standard and/or regulations, e.g. ISO 20421-1.

4.2.2 Labelling (or placarding)

For labelling, the following shall be affixed:

- a) a flow sheet denoting operation;
- b) danger labels and marks in accordance with transport regulations;
- c) risk and safety phrases associated with the gas content;
- d) name of the owner;
- e) name of the operator;
- f) actual holding time for gases being transported;
- g) maximum permissible gross mass;
- h) unladen (tare) mass;
- i) an unshortened identification of the fluid which is transported in accordance with the transport and substance regulations and its net mass in accordance with the documentation. As an alternative, this information can be included in a transport document.

NOTE 1 Items a) to i) can appear on the vessel, name plate or transport document depending on the requirements of the particular transport mode or operator requirements.

NOTE 2 Items e) to i) can be required by the design standards and do not need to be repeated.

Specific transport regulations shall always be consulted prior to the carriage. The holding time shall be calculated for each journey in accordance with applicable transport regulations.

4.3 Handover documents

In addition to the manufacturer's documentation, where necessary, the cryogenic vessel shall be accompanied by vessel-specific documents and instructions for all items supplied covering the

- operation,
- auxiliary equipment, and
- inspection records.

These documents shall be retained by the owner of the vessel.

The operator shall have appropriate instructions available. Such instructions may be attached to the vessel in a permanent manner, or carried by or available to the operator.

5 Personnel training

Only persons trained for the specific task shall be allowed to put into service, fill, handle, operate or maintain the vessel and its equipment.

The training programme shall include

- normal procedures,
- product and hazard identification,
- safe operating limits,
- emergency procedures,

- physical and chemical properties of the vessel's content and their effects on the human body,
- personal protection, and
- confined spaces entry, if applicable.

Training shall be repeated as necessary to ensure that personnel remain competent. A record should be maintained which details the training personnel have received.

6 General safety requirements

6.1 General

Before any operation, the operator shall ensure that all equipment is free from any obvious damage or defect which could affect its safe operation.

Marking and labelling shall not be removed or defaced.

Consideration shall be given to the product properties and the use of appropriate personal protective equipment.

Parts under pressure shall be disconnected only if they have been previously depressurized.

Leaking valves or connections shall be depressurized before rectification. When this is not possible, leaking valves under pressure shall be tightened using suitable tools and procedures.

Direct flame or direct intense heat shall never be used to raise the pressure or de-ice frozen components.

All surfaces which may come in contact with the product shall be clean for the intended service. For cleanliness requirements, see ISO 23208.

Outlets, seals and transfer hoses shall be checked to be clean, dry and free from contaminants and visible defects before connection.

Vessels and transfer hoses shall not be modified without proper authorization. It is recommended that the couplings be attached to the vessels and/or hoses in a manner that prevents unauthorized removal of the product couplings.

Operating valves should be opened and closed slowly.

6.2 Safety considerations

In all operations and training, the following safety considerations shall be taken into account.

- Small amounts of cryogenic fluids will produce large volumes of vaporized gas. Spillage of oxygen can result in an oxygen-enriched atmosphere; spillage of other cryogenic fluids can result in an oxygen-deficient atmosphere. Appropriate measures shall be taken for all these cases, e.g. ventilation.
- Because of the possibility of cold embrittlement, cryogenic fluids shall only be used in product systems with components which are suitable for low temperatures.
- Vaporizing cryogenic fluids produce gases that are heavier than air and can accumulate in lower areas (e.g. pits, trenches).
- Because of their extremely low temperatures, cryogenic fluids will produce cold burns when coming into contact with the skin. Cold burns can also be produced from contact with uninsulated equipment and piping.
- Oxygen enrichment due to liquefaction of ambient air can occur on the cold surfaces of uninsulated equipment which contains a fluid with a boiling point lower than that of oxygen.

- Consideration should be given to establishing proper safety distances during parking or product transfer.

7 Putting into service

This operation shall follow a written procedure and the results of the steps involved should be recorded (e.g. in a check list). Such lists should be retained by the operating company.

Vessels and accessories shall be visually checked for damage.

The following shall be verified.

- The vessel and accessories are appropriate for the intended service, comply with the flow sheet and are appropriately marked and labelled; all labels shall be clearly displayed and appropriate for the product.
- A relief device with a set pressure not higher than the maximum allowable working pressure of the vessel is fitted. Pressure, size and installation shall comply with the documentation. Devices requiring approval shall be correctly stamped and matching certificates shall be available.
- All valves are operable.
- All required checks and tests have been carried out.

Ensure that the vessel and accessories are clean and compatible for the intended service; see ISO 23208 and ISO 21010.

The vessel should be purged with an appropriate gas until the gas emerging from the vessel is sufficiently dry and pure for the intended service.

The vessel shall be cooled down according to the manufacturer's recommendations. Steps shall be taken to avoid uncontrolled pressure rise due to rapid liquid vaporization. The cool-down gas chosen shall take into account the risk of solidification.

Measuring and controlling devices (level gauge, pressure gauge, etc.) shall be checked for correct operation and setting.

8 Location

The requirements listed in this clause are valid for storage and parking, as well as for other activities such as filling and withdrawal.

- Vessels shall be located in a suitable area such as in the open air or in a sufficiently ventilated enclosed area, away from sources of heat (welding source, open fire, etc.). Hot work shall be subject to appropriate safety measures. The area shall be kept appropriately clean and suitable access shall be provided.
- Adequate ventilation shall be provided. In locations at or above ground level, natural ventilation is generally sufficient, provided that the room is large enough or that the outdoor area is not closely surrounded by walls. In other circumstances, forced ventilation or other precautions shall be provided.
- Vessels should not be located underground. However, where this is unavoidable, relief device outlet(s) should be piped to a safe external venting point. As an alternative, appropriate marking (e.g. indicating the risk of asphyxiation) and sufficient continuous ventilation to deal with product releases should be provided. The vent pipework shall be designed in such a way as to ensure proper pressure relief from the vessel and to prevent the accumulation or blockage of rainwater by airborne material. The same measures shall be taken if vessels are indoors for extended periods (i.e. overnight or weekends).

- The floor of the designated trans-shipment area shall be level and strong enough to take the mass of the full transport unit. The vessel shall be located at a sufficient distance from the normal paths used by people or vehicles. Water accumulation in the vicinity of the vessel shall be avoided.
- For filling and withdrawing oxidizing liquids and cryogenic liquids colder than liquid nitrogen, the connections shall be located over a non-combustible surface, like concrete.
- Vessels and their components shall be protected against mechanical damage.
- In case of emergency, adequate means of escape shall be provided. Emergency exits shall be kept clear at all times.
- All doors/gates should be preferably outward opening and wide enough to provide an easy access and exit route for personnel.
- A vessel should only be left parked unattended in a location such that operation of the vessel relief devices will not constitute a hazard.
- The operating area should be clearly marked with appropriate warning signs. These may be displayed on the vessel.
- Operation by unauthorized persons shall be prevented, e.g. by locking the valve cabinet.

When large transportable vessels are temporarily used as static vessels, the requirements defined for static vessels shall be considered.

9 Transport

This clause refers to the transport of filled vessels. Additional requirements can apply for transport by public road, rail, waterway, sea and air.

Before transport, the vessels shall be examined for signs of damage or leaks, and valves shall be checked to ensure that they are operational and in the correct position.

Cryogenic vessels shall never be subjected to impacts or falls; these could damage the outer jacket or the suspension system of the inner vessel, causing loss of insulating properties. If any vessel is known to have been subjected to accidental impact or fall, this shall be reported to an appropriate authorized person before further use.

Vehicles used for transport shall have well-ventilated cargo areas and shall have separate cargo and passenger compartments. Vessels shall be transported in their correct position and shall be securely fixed by appropriate means.

The vessels shall be handled only by those means for which they are designed and equipped.

Carriage of empty and uncleaned tank is adequately safe if suitable measures have been taken to ensure equivalent safety commensurate with the provisions of the applicable regulation to prevent the uncontrolled release of the dangerous goods.

10 Filling

10.1 General

The following operations shall be carried out in accordance with a written procedure following the applicable regulation for filling limits (pressure, weight, temperature, etc.).

Holding times should be calculated and recorded as required by particular regulations.

10.2 Prefill checks

Prior to filling, the filler shall examine the condition of the vessel as indicated in [Table 1](#).

Table 1 — Prefill checks

	Acceptance criteria for filling
Labelling and marking	
Data plate	Present, legible and in accordance with 4.2
Inspection date	Within required period
Product identification labels	Fitted, legible and for the correct product
Vessel	
	No obvious signs of damage, corrosion, contamination, oil or grease No unusual ice No loss of vacuum No damage to its lifting or securing arrangements
Accessories	
All accessories (valves, PRD, connections, etc.)	No obvious signs of damage or corrosion Free from dirt, oil or grease No unusual ice
Valves	Operable
Pressure relief devices	In place, free from ice and other visible obstructions
Filling couplings and transfer hoses	Appropriate connection fitted for product, identified by the product identification label, and cap-fitted if required Check for leakage and damage of hoses
Pressure gauge	Positive pressure in vessel

An external visual inspection of the vessel and equipment shall be performed to ensure that the vacuum between inner vessel and outer jacket remains intact (checking of abnormal frosting on tank surface; gas venting from a vacuum protection device; relief valves are continually venting). If the vessel has lost vacuum, the owner of the cryogenic vessel shall immediately investigate the cause of the vacuum loss. Where a vacuum loss is believed to be associated with an internal pipe failure, for example, vapour escaping from the vacuum relief device(s), then the cryogenic vessel shall be made safe by immediately reducing the pressure to atmospheric and emptying all cryogenic liquid in a safe manner. The reduction of pressure is the most significant action to reduce the level of hazard. For more information, in particular to differentiate between loss of vacuum and vacuum decay, see EIGA IGC doc 115/12, Appendix E or CGA SB-45.

10.3 Preparations

The vehicle carrying the vessel shall be immobilized by an appropriate device.

Depending on the type of the cryogenic vessel, and product, it may be filled to nominated capacity either by volume or by mass, taking into account product density to the level for which the vessel is designed. The necessary measuring equipment shall be in good working order and within the calibration period, where required.

If there is no residual pressure in the vessel prior to filling, it should be purged to remove possible contaminants. For carbon dioxide vessels, only gaseous carbon dioxide should be used for purging.

If the vessel is warm, it should be cooled down according to the manufacturer's recommendations. Carbon dioxide vessels shall be pressurized to at least 0,7 MPa (7 bar) with gaseous carbon dioxide before introducing liquid CO₂.

The purity of the residual product in the vessel shall be analysed and recorded where required by specification. Where the purity of the residual product is outside specification, the vessel should be purged until it meets specification.

The fill hose shall be securely connected, purged and cooled down.

Where it is necessary, the pressure shall be reduced by venting to facilitate safe filling. For carbon dioxide, the pressure shall not drop below 0,7 MPa (7 bar) to avoid forming of dry ice. Measures shall be taken to ensure that there is no unwanted backflow between the vessel and supply vessel.

Appropriate measures shall be taken to prevent the release of dangerous quantities of gases and vapours during filling and discharge of the tanks.

10.4 After-fill check

The vessel mass or level of contents and pressure shall be checked and, where necessary, the vessel should be vented or drained to reach the values required by specification.

Where required by specification, the vessel contents shall be analysed and recorded and any particular mode requirements are adhered to.

The filler shall check that all valves are in the correct position (open or closed) according to the instructions that no unusual cold spots have developed and that valves, piping and fittings are free from leaks.

Where required (e.g. for portable tanks), the vessel shall be labelled with the holding time.

Some regulations require that forklift pockets (if provided) of portable tanks shall be closed off when the tank is filled.

11 Product withdrawal

The operator shall ensure that the product and the pressure in the vessel are compatible with the supply system, that the correct hose couplings are fitted and that the nominal pressure of the withdrawal line is greater than the pressure developed by the withdrawal system, e.g. pumping system.

Before connecting the vessel for withdrawal, the operator shall ensure that no unwanted backflow from the vessel is possible and also that the liquid cannot become trapped without adequate pressure relief.

The vehicle carrying the vessel shall be immobilized by an appropriate device before connecting the hose.

Operating valves shall be returned to the appropriate position for transport unless otherwise instructed.

12 Change of service

Change of service shall only be authorized by the owner. This operation shall follow a written procedure and the results of the steps involved should be recorded. Such records should be retained.

The procedure shall include the following.

- Check that the vessel, the pump, soft goods (e.g. seals, gaskets, etc.) and the accessories are designed for the intended service. Special attention shall be given to this point if the vessel is intended for oxidizing fluids.
- Depressurization, emptying and disconnecting the vessel shall be performed in accordance with [Clause 13](#).

- Where it is suspected that the vessel may have been contaminated, it shall be cleaned by using a suitable cleaning procedure. Special attention shall be given to this point if the vessel is intended for oxidizing fluids.
- The vessel labelling, couplings and transfer hoses shall be changed appropriate to the new product.

If the vessel is intended for oxidizing fluids, the following additional requirements shall be considered.

- The vessel and all piping and accessories shall be purged with inert gas until the outlet temperature is at least close to ambient temperature. The purge gas inlet temperature shall never exceed the maximum operating temperature of 50 °C.
- It shall be ensured that the vessel and all piping and accessories are clean for the intended service; see ISO 23208.
- Before the vessel is filled with an oxidizing fluid, the person responsible for filling shall verify that the procedure has been carried out correctly.

Thereafter, follow the procedure in [Clause 7](#) before filling the vessel.

13 Taking out service

This operation shall follow a written procedure and the results of the steps involved shall be recorded. If the vessel is intended for further service, such records shall be retained by the owner company.

The procedure shall include the following:

- emptying of the vessel and depressurizing to a positive pressure no greater than 0,2 MPa (2 bar);
- monitoring pressure and level gauge/mass, if necessary; verifying that no line is obstructed;
- taking into account the properties of the product involved (e.g. solidification of CO₂; see [10.3](#)).

If the vessel is intended to be taken into service again later, the following additional requirements shall be considered:

- purging of the vessel and accessories with inert gas;
- if the vessel may be used for oxidizing fluids at a later time, the cleaning and hydrocarbon checking steps outlined in [Clause 12](#) (necessary) shall be applied when the vessel is taken out of service;
- if the vessel is to be transported or stored/parked, protective caps shall be fitted on all transfer couplings;
- when in store, a slight positive pressure of dry inert gas shall be maintained in the vessel and the vessel shall be labelled accordingly.

If the vessel is to be scrapped, it shall be purged necessarily with inert gas and labelled accordingly.

EXAMPLE "Purged with nitrogen — To be scrapped".

Product identification labels shall be removed and nameplates rendered unusable.

14 Maintenance and repair

Maintenance is required to ensure that the vessel remains in a safe, serviceable condition. The responsibility for its maintenance and repair shall be established between the contracting parties (e.g. owner and filler). Following maintenance, the vessel shall comply with the current approval documentation.

Maintenance generally comprises the following:

- checking the condition of the vessel, accessories and the external supporting structure;
- checking the operability of valves;
- minor repairs, e.g. changing of seals;
- cleaning external surfaces.

IMPORTANT — Before entering the inner vessel, all hazards related to confined spaces (e.g. oxygen enrichment/deficiency or flammability) shall have been considered and documented.

Equipment shall not be removed until the directly connected system has been depressurized or adequately isolated and depressurized.

Modifications in design, materials and equipment or repairs shall be approved by an authorized person and the documentation updated accordingly (see ISO 20421-1).

Any leakage shall be rectified promptly and in a safe manner. Original approved spare parts should preferably be used. The suitability of the spare part shall be approved by an authorized person. Repairs shall be consistent with the fabrication and testing requirements of the applicable design and construction standards.

Hot work (welding, soldering, heating, etc.) shall be carried out to an equivalent procedure (fabrication, qualification of personnel, testing, certification, etc.) as during manufacture.

If at any time it is necessary to break the seal for adjustment of a pressure-relief valve, the valve shall be removed from service until it has been reset and sealed. Any adjustment of spring-loaded pressure-relief devices shall be made by the manufacturer or another company qualified by the manufacturer for the repair, adjustment, replacement and testing of such devices. Replacement of pressure-relief devices shall be carried out by trained personnel.

The organization making such adjustment shall attach a permanent tag with the setting, capacity and date to the pressure-relief valve.

Vessels shall be internally clean, dry and free from particulate matter, and vessels for oxidizing fluids shall be free from oil and grease (see ISO 20421-1).

CO₂ vessels shall be depressurized using a written procedure. Liquid carbon dioxide vessels that have lost pressure shall be repressurized using a written procedure. The material properties of the vessel have to be considered

NOTE For guidance, see IGC Doc. 164/10/E or CGA G-6.7.

15 Periodic inspection

The inspection shall be performed at intervals defined by the relevant regulation for transport by public road, rail, waterway, sea or air.

If, at the time of periodic inspections, openings have been made in shells, the method by which they are hermetically closed before the shells are returned to service shall be approved as required by the applicable regulation and shall ensure the integrity of the shell.

The following activities shall be performed.

- a) Equipment and safety device check:
 - Reclosable pressure-relief devices shall either be replaced or undergo a functional test (lift or set pressure test) either in situ or off the vessel.

- Non-reclosable pressure-relief devices, where fitted, shall be replaced.
- b) Visual internal inspection. The visual internal inspection is not required. The vessel integrity may be checked by a leak test [(see d)] and measurement of the vacuum, if appropriate. Vacuum measurement should only be performed when the thermal performance is deficient as noted by vessel operation.
- c) Visual external inspection. Check for signs of damage or corrosion which may affect the integrity. Check content and legibility of data plate (see 4.2) and other markings.
- d) Leak test. A gas-leak test using an inert gas or the working medium at minimum of 90 % of the allowable working pressure shall be carried out. However lower pressures may be used with the agreement of the competent person and in combination with a check of the vacuum, see b).
- e) All other equipment shall be checked for satisfactory functioning.
- f) Traceability of inspection shall be ensured (see ISO 20421-1).

NOTE 1 For periodic inspection of cryogenic flexible hoses, see applicable regulations.

NOTE 2 Some regulations make the difference between intermediate (limited inspection), periodic inspection (full inspection) and exceptional inspection (e.g. after repair).

16 Additional requirements for flammable gases

16.1 General safety requirements

16.1.1 General

Precautions shall be taken when approaching a leak as the product may ignite and produce a flame. Products such as hydrogen require specific care as the flame is invisible.

Care shall be taken in the choice of personnel clothing, to protect as much as practical against static charges and flames. Electrically conductive footwear should be worn.

Fill/withdrawal connections shall be capped when not in use.

Spillage of flammable fluids can result in the risk of fire or explosion.

16.1.2 Electrical equipment

All product system and ancillary electrical equipment shall be in accordance with the requirements of the hazardous area classification in which it is being used.

In the classified area, personnel shall not be permitted to carry sources of flame, or non-approved electrical equipment. Consideration shall be given to all electrical equipment, e.g. mobile phones and radio transmitters.

16.1.3 Grounding (earthing) system

All parts of the installation shall be bonded to ensure electrical continuity.

Major items of equipment such as the tank and vent stack shall be bonded directly to the earth point and not rely on the piping as a means to earth.

Installations shall be earthed in accordance with national regulations. Consideration shall be given to the need for lightning protection.

For transferring processes between several installations or between static vessels and transportable vessels, equalizing of the electrical potentials is necessary.