
**Cryogenic vessels — Transportable
vacuum insulated vessels of not more
than 1 000 litres volume —**

**Part 2:
Operational requirements**

*Réipients cryogéniques — Réipients transportables, isolés, sous vide,
d'un volume n'excédant pas 1 000 litres —*

Partie 2: Prescriptions de fonctionnement



PDF disclaimer

This PDF file may contain embedded typefaces. In accordance with Adobe's licensing policy, this file may be printed or viewed but shall not be edited unless the typefaces which are embedded are licensed to and installed on the computer performing the editing. In downloading this file, parties accept therein the responsibility of not infringing Adobe's licensing policy. The ISO Central Secretariat accepts no liability in this area.

Adobe is a trademark of Adobe Systems Incorporated.

Details of the software products used to create this PDF file can be found in the General Info relative to the file; the PDF-creation parameters were optimized for printing. Every care has been taken to ensure that the file is suitable for use by ISO member bodies. In the unlikely event that a problem relating to it is found, please inform the Central Secretariat at the address given below.

STANDARDSISO.COM : Click to view the full PDF of ISO 21029-2:2004

© ISO 2004

All rights reserved. Unless otherwise specified, no part of this publication may be reproduced or utilized in any form or by any means, electronic or mechanical, including photocopying and microfilm, without permission in writing from either ISO at the address below or ISO's member body in the country of the requester.

ISO copyright office
Case postale 56 • CH-1211 Geneva 20
Tel. + 41 22 749 01 11
Fax + 41 22 749 09 47
E-mail copyright@iso.org
Web www.iso.org

Published in Switzerland

Contents

Page

1	Scope	1
2	Normative references	1
3	Terms and definitions	1
4	Preliminaries before putting into service	2
4.1	General	2
4.2	Marking and labelling	3
4.3	Handover documents	3
5	Personnel training	3
6	Safety requirements	4
6.1	General	4
6.2	Safety considerations	4
6.3	Safety distances	4
7	Putting into service	5
8	Location	5
9	Transport	6
10	Filling	6
10.1	General	6
10.2	Prefill checks	6
10.3	Preparations	7
10.4	After fill check	7
11	Product withdrawal	7
12	Change of service	8
13	Taking out of service	8
14	Maintenance and repair	9
15	Periodic inspection	9
16	Additional requirements for flammable gases	10
16.1	General safety requirements (see also Clause 6)	10
16.2	Putting into service (see also Clause 7)	10
16.3	Location (see also Clause 8)	11
16.4	Transport (see also Clause 9)	11
16.5	Filling (see also Clause 10)	11
16.6	Change of service (see also Clause 12)	11
16.7	Taking out of service (see also Clause 13)	11
16.8	Maintenance and repair (see also Clause 14)	11
17	Emergency equipment/procedures	12
Annex A	(informative) Safety distances	13
Bibliography		14

Foreword

ISO (the International Organization for Standardization) is a worldwide federation of national standards bodies (ISO member bodies). The work of preparing International Standards is normally carried out through ISO technical committees. Each member body interested in a subject for which a technical committee has been established has the right to be represented on that committee. International organizations, governmental and non-governmental, in liaison with ISO, also take part in the work. ISO collaborates closely with the International Electrotechnical Commission (IEC) on all matters of electrotechnical standardization.

International Standards are drafted in accordance with the rules given in the ISO/IEC Directives, Part 2.

The main task of technical committees is to prepare International Standards. Draft International Standards adopted by the technical committees are circulated to the member bodies for voting. Publication as an International Standard requires approval by at least 75 % of the member bodies casting a vote.

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. ISO shall not be held responsible for identifying any or all such patent rights.

ISO 21029-2 was prepared by Technical Committee ISO/TC 220, *Cryogenic vessels*.

ISO 21029 consists of the following parts, under the general title *Cryogenic vessels — Transportable vacuum insulated vessels of not more than 1 000 litres volume*:

- *Part 1: Design, fabrication, inspection and tests*
- *Part 2: Operational requirements*

Introduction

Elements of this part of ISO 21029 support the requirements of the UN Recommendations on the Transport of Dangerous Goods and other international, national or local requirements.

STANDARDSISO.COM : Click to view the full PDF of ISO 21029-2:2004

STANDARDSISO.COM : Click to view the full PDF of ISO 21029-2:2004

Cryogenic vessels — Transportable vacuum insulated vessels of not more than 1 000 litres volume —

Part 2: Operational requirements

1 Scope

This part of ISO 21029 specifies operational requirements for transportable vacuum insulated cryogenic vessels of not more than 1 000 l volume designed to operate above atmospheric pressure. Appropriate parts may be used as a guidance for a vessel design to operate open to the atmosphere.

For cryogenic vessels designed for personal medical use, other requirements may apply.

The scope includes putting into service, filling, withdrawal, transport within the location, storage, maintenance, periodic inspection and emergency procedures.

For the transportation of these vessels by public road, rail, sea and air, other additional requirements may apply; these are defined in specific regulations.

This part of ISO 21029 applies to vessels for cryogenic fluids as specified in ISO 21029-1. The additional requirements for flammable fluids are detailed in Clause 16.

Transportable cryogenic vessels of not more than 1 000 l volume are often partly equipped by the manufacturer, but may be installed or re-installed by another party, such as the operator or owner. For this reason some of the scope of this part of ISO 21029, which includes putting into service, inspection, filling, maintenance and emergency procedure, overlaps with ISO 21029-1.

2 Normative references

The following referenced documents are indispensable for the application of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

ISO 21029-1, *Cryogenic vessels — Transportable vacuum insulated vessels of not more than 1000 l volume — Part 1: Design, fabrication, inspection and tests*

ISO 21010, *Cryogenic vessels — Gas/materials compatibility*

ISO 23208, *Cryogenic vessels — Cleanliness for cryogenic service*

3 Terms and definitions

For the purposes of this document, the following terms and definitions apply.

3.1

putting into service

operation by which a vessel is prepared to be used, applying to either a new vessel being used for the first time or an existing vessel being returned to service

3.2

filling

operation by which a transportable vessel undergoes a prefill check, filling with a cryogenic fluid and an after fill check

3.3

withdrawal

operation by which the product is taken from a vessel connected to the supply system

3.4

outdoor location

location outside of any building or structure and not enclosed by more than two walls

3.5

underground location

area or room whose ground or floor is, on all sides, significantly lower than the adjacent ground surfaces

3.6

safety distance

distance from a piece of equipment with inherent hazard being the minimum separation that will mitigate the effect of a likely foreseeable incident and prevent a minor incident escalating into a larger incident

NOTE The safety distance is determined in order to provide protection from foreseeable external impact (e.g. roadway, flare) or activities outside the control of the operation (e.g. plant or customer station boundary).

3.7

vessel

large transportable cryogenic vessel

[ISO 21029-1]

3.8

competent person

trained and qualified person for the purpose mentioned in this document

3.9

enterprise

any person or company that has a legal duty of care

3.10

filler

any enterprise that loads cryogenic fluids into a cryogenic vessel

3.11

owner

enterprise that legally owns the cryogenic vessel

3.12

operator

any enterprise for filling, storage, transport and withdrawal of cryogenic product

4 Preliminaries before putting into service

4.1 General

Before putting into service, verification shall take place to ensure that the vessel is suitable for the intended service and that the marking, labelling and handover documents are complete.

4.2 Marking and labelling

4.2.1 Marking

Marking shall be in accordance with ISO 21029-1.

4.2.2 Labelling

For labelling the following shall be affixed:

- a) a flow sheet denoting operation;
- b) an unshortened identification of the fluid that is being transported in accordance with the transport and substance regulations and its net mass in accordance with the documentation;
- c) danger labels in accordance with transport regulations;
- d) risk and safety phrases associated with the gas content;
- e) name and address of the fluid producer or supplier.

All vessels shall include a product identification label visible from all directions (e.g. 360 degree wrap-around tape), which can be easily read from a distance of 2 m, and securely affixed product labels at the inlet and outlet connections. Additionally, warning labels reading "Never use adapters or try to change gas connections on the vessel when trying to attach a product distribution connection" shall be affixed at outlet connections.

4.3 Handover documents

In addition to the manufacturer's documentation, where necessary the cryogenic vessel shall be accompanied by vessel specific documents and instructions for all items:

- operations;
- auxiliary equipment;
- inspection records.

These documents shall be retained by the owner of the vessel.

The operator shall have appropriate instructions available. Such instructions may be attached to the vessel in a permanent manner.

5 Personnel training

Only persons trained for the specific task shall be allowed to put into service, fill, handle, operate or maintain the vessel.

The training programme shall include:

- normal procedures;
- product and hazard identification;
- safe operating limits;
- emergency procedures;
- physical and chemical properties of the vessel's contents and their effects on the human body;
- personnel protective equipment (e.g. safety boots/goggles/gloves).

Training shall be repeated as necessary to ensure that personnel remain competent. A training record shall be maintained which details the information that the personnel have received.

6 Safety requirements

6.1 General

Marking and labelling shall not be removed or defaced.

Appropriate warning signs, regarding product hazards and personnel protective equipment requirements, shall be displayed.

Parts under pressure shall be disconnected only if they have been previously depressurized.

Leaking valves or connections shall be depressurized before rectification. When this is not possible, leaking valves under pressure shall be tightened using suitable tools and procedures.

Direct flame or intense heat shall never be used to raise the pressure or de-ice frozen components.

All surfaces which may come into contact with the product shall be cleaned for the intended service. For cleanliness requirements, see ISO 23208. Valve outlets shall be kept clean, dry and free from contaminants.

Vessels and their accessories shall not be modified without proper authorization. It is recommended, that the couplings be attached to the vessels and/or hoses in a manner that prevents unauthorized removal of the product couplings.

6.2 Safety considerations

In all operations and training the following safety considerations shall be taken into account.

- Small amounts of cryogenic fluids produce large volumes of vaporized gas. Spillage of oxygen can result in an oxygen enriched atmosphere, spillage of other cryogenic fluids can result in an oxygen deficient atmosphere. Provision shall be made for appropriate measures for this, e.g. ventilation.
- Due to the possibility of cold embrittlement, cryogenic fluids shall not come in contact with materials (metals or plastics) which are not suitable for low temperatures.
- Vaporizing cryogenic fluids produce gases that are always heavier than air and can accumulate in lower areas (e.g. pits, trenches).
- Because of their extremely low temperatures, cryogenic fluids produce cold burns when coming into contact with the skin. Cold burns can also be produced from contact with uninsulated equipment.
- Oxygen enrichment due to liquefaction of ambient air can occur on the cold surfaces of uninsulated equipment that contains fluids with a boiling point lower than oxygen.

6.3 Safety distances

Minimum safety distances are not intended to provide protection against catastrophic events or major releases and these should be addressed by other means to reduce the frequency and/or consequences to an acceptable level.

Included in safety distances are:

- distances between vessels and neighbouring installations, buildings or public roads, the purpose of which is to protect the vessel from any damage, such as heating as a result of fire or mechanical damage;
- distance between the vessel and an object outside the installation, which must be protected from the effects of a gas release arising from normal operation.

These distances are measured from those points on a vessel from which in the normal course of operation a release of product may occur, e.g. vent point, fill connection, flanges or other mechanical joints.

The safety distance is the distance, outside of which:

- in the case of flammable gases, dangers through formation of an explosive atmosphere is eliminated, i.e. the lower explosive limit (LEL) is not exceeded;
- in the case of inert and oxidizing gases, dangers from a lack of oxygen or enrichment are eliminated.

The minimum safety distances defined in Annex A are based on experience and calculation of minor releases.

The safety distances may be reduced if the suitable sufficient risk assessment is completed and documented by the owner/operator.

7 Putting into service

This operation shall follow a written procedure and the results of the steps involved shall be recorded (e.g. in a check list). Such lists shall be retained by the operating company.

Vessel and accessories shall be visually checked for damage.

It shall be verified that:

- vessel and accessories are appropriate for the intended service, comply with the flow-sheet and are appropriately marked;
- relief devices with a set pressure no higher than the maximum permissible working pressure of the vessel are fitted. Pressure, size and installation shall comply with the documentation. Devices requiring approval shall be correctly stamped and matching certificates shall be available;
- all valves are easy to operate;
- all labels are clearly displayed and appropriate for the product;
- all required tests have been carried out;
- the vessel and accessories are clean and compatible for the intended service, see ISO 23208 and ISO 21010.

The vessel shall be purged with an appropriate gas until the gas emerging from the vessel is sufficiently dry and pure for the intended service.

The vessel shall be cooled in accordance with the manufacturer's recommendations. Steps shall be taken to avoid any uncontrolled pressure rise due to rapid liquid evaporation. The cooling gas chosen shall take into account the risk of solidification.

Measuring and controlling devices (e.g. level gauge, pressure regulator, etc.) shall be checked for correct operation and setting.

8 Location

The requirements listed in this clause are valid for storage as well as other activities such as filling, withdrawal, etc.

- Vessels shall be located in a suitable area such as in the open air or in a sufficiently ventilated enclosed area, away from sources of heat (e.g. welding source, open fire, etc.). Hot work shall be subjected to appropriate safety measures. The area shall be kept clear and suitable access shall be provided.
- Adequate ventilation shall be provided. In locations over ground level, natural ventilation is generally sufficient, provided that the room is large enough or that the outdoor area is not enclosed by walls. In other circumstances, forced ventilation or other precautions shall be provided.
- Vessels shall not be located underground. However, where this is unavoidable, relief device outlet(s) shall be piped to a safe external venting point and the underground location shall have sufficient continuous ventilation to deal with product releases arising from normal operation.

- The floor of the designated area shall be level and strong enough to take the mass of the full vessel. The vessel shall be located at a sufficient distance from the normal paths used by people or vehicles. Water accumulation in the vicinity of the vessel shall be avoided.
- For filling and withdrawing oxidizing liquids and cryogenic liquids colder than liquid nitrogen, the connections shall be located over a non-combustible surface, such as concrete.
- Vessels and their components shall be protected against mechanical damage.
- In case of emergency, adequate means of escape shall be provided. Emergency exits shall be kept clear at all times.
- All doors/gates should preferably be outward opening and wide enough to provide easy access and exit routes for personnel.
- Vessels which exhibit a risk of toppling over shall be firmly secured in the upright position.
- The operating area shall be clearly marked with appropriate warning signs. These can be displayed on the vessel.
- If vessels are indoors for extended periods (i.e. overnight or weekends) appropriate ventilation or pressure relief valve outlets shall be piped to a safe place. The vent pipe-work shall be designed in such a way as to ensure proper pressure relief from the vessel. The vent will also prevent the accumulation or blockage of rainwater by airborne material.
- Access by unauthorized persons shall be prevented. On sites without sufficient supervision, fencing shall be provided.

9 Transport

This clause refers to the transport of filled vessels. Additional requirements may apply for transport on public roads, rail, waterways, sea and air. Before transport, the vessels shall be examined for signs or damage or leaks and valves shall be checked to ensure that they are operational and in the correct position.

Cryogenic vessels should never be subjected to impacts or falls; these could damage the outer jacket or the suspension system of the inner vessel causing loss of insulating properties. Where vehicles are used (either powered or unpowered) the vessels shall be secured against toppling over.

The vessels shall be handled only by those means for which they are designed and equipped.

Because of the potential hazard of oxygen deficiency or enrichment where a lift is stopped for a certain period between floors, vessels shall not be transported together with persons, unless adequate safety precautions have been taken.

Vehicles used for transport, shall have well-ventilated cargo areas and wherever possible separate cargo and passenger compartments. Where this is not possible, or in cases of doubt as to the effectiveness of the ventilation, an atmosphere monitor shall accompany the personnel travelling with the vessel. Vessels should be transported in their correct position and shall be securely fixed by appropriate means.

10 Filling

10.1 General

The following operations shall be carried out in accordance with a written procedure.

10.2 Prefill checks

Prior to filling, the filler shall examine the condition of the vessel as indicated in Table 1.

The vessel shall not be filled if any of these acceptance criteria cannot be met. Prior to filling all non-compliances shall be corrected.

Table 1 — Prefill checks

Item	Acceptance criteria for filling
Data plate	Present, legible and in accordance with 4.2
Inspection date	Within required period
Product identification labels	Legible and fitted to the correct product
Vessel and accessories	No obvious signs of damage, corrosion, dirt, oil or grease; no unusual ice
Valves	Operable
Pressure relief devices	In place, free from ice or other obstructions
Filling connection	Correct connection fitted for product identified by the product identification label and cap-fitted if required
Pressure gauge	Positive pressure in vessel
Connections	Free from dirt, oil or grease and free from water or excessive ice

10.3 Preparations

Depending on the type of the cryogenic vessel, it may be filled by volume or by mass, taking into account product density. The necessary measuring equipment shall be in good working order and within the calibration period, where required.

If there is no residual pressure in the vessel prior to filling, it shall be purged to remove possible contaminants. For carbon dioxide vessels, only gaseous carbon dioxide shall be used for purging.

If the vessel is warm, it shall be cooled in accordance with the manufacturer's recommendations. Carbon dioxide vessels shall be pressurized to at least 5 bar with gaseous carbon dioxide before introducing liquid CO₂. The purity of the residual product in the vessel shall be analysed and recorded where required by specification. Where the residual purity is outside specification, the vessel shall be purged until it meets specification.

The fill hose shall be securely connected, purged and cooled.

Where necessary, the pressure shall be reduced by venting to facilitate filling. For carbon dioxide the pressure shall not drop below 5 bar.

10.4 After fill check

The vessel mass or level of contents and pressure shall be checked and, where necessary, the vessel shall be vented to reach the level required by specification.

Where required by specification, the vessel contents shall be analysed and recorded.

The filler shall check that all valves are closed, that no cold spots have developed and that valves, piping and fittings are free from leaks.

11 Product withdrawal

The operator shall check that the product and the pressure in the vessel are compatible with the supply system, that the correct hose connection is fitted and that the vessel is positioned in accordance with manufacturer's recommendations.

Before connecting the vessel for use, the operator shall check that backflow from the system into the vessel is not possible and also that the liquid cannot become trapped without adequate pressure relief.

For de-icing frozen valves, use hot air but never flames.

12 Change of service

This operation shall follow a written procedure and the results of the steps involved shall be recorded. Such records shall be retained by the company who made or ordered the change of service of the cryogenic vessel.

The procedure shall include the following.

- Check that the vessel is designed for its intended service. Special attention shall be given to this point if the vessel is intended for oxidizing fluids.
- Depressurization, emptying and disconnecting the vessel shall be performed in accordance with Clause 13.
- Where it is suspected that the vessel may have been contaminated, it shall be cleaned by using a suitable cleaning procedure.
- The vessel's fill- and withdraw-couplings, where necessary, shall be removed and replaced with the proper connection for the new product. The vessel's labelling shall be removed and replaced with the proper labelling. Relabelling over existing labelling is strictly prohibited.

If the vessel is intended for oxidizing fluids, the following additional requirements shall be considered.

- The vessel and all piping and accessories shall be purged with inert gas until the outlet temperature is at least close to ambient temperature. The purge gas inlet temperature shall never exceed the maximum operating temperature of 50 °C.
- It shall be verified by suitable methods that the vessel and all piping and accessories are not contaminated by hydrocarbons.
- Before the vessel is filled with an oxidizing fluid, a competent person shall verify that the procedure has been carried out correctly.

13 Taking out of service

This operation shall follow a written procedure and the results of the steps involved shall be recorded. If the vessel is intended for further service, such records shall be retained by the owner company.

The procedure shall include the following:

- emptying of the vessel and depressurizing to a positive pressure no greater than 2 bar;
- monitoring pressure and mass, if necessary; verifying that no line is obstructed;
- taking into account the properties of the product involved (e.g. solidification of CO₂).

If the equipment is intended to be taken into service again later, the following additional points shall be considered.

- Purging of the vessel and all piping and accessories with inert gas.
- If there is a possibility that the vessel could be used for oxidizing fluids at a later time, then the cleaning and hydrocarbon checking steps outlined in Clause 12 shall be applied when the vessel is taken out of service.
- If the vessel is to be transported or stored, protective caps shall be fitted on all open connections.
- When in storage, a slight positive pressure of dry inert gas shall be maintained in the vessel and the vessel shall be labelled accordingly.

If the vessel is to be scrapped, it shall be purged with inert gas and labelled accordingly. Product identification labels shall be removed and nameplates rendered unusable.

14 Maintenance and repair

Maintenance is required to ensure that equipment remains in a safe condition. The responsibility for the maintenance and repair shall be established between the contracting parties (e.g. owner, filler). Following maintenance, the vessel shall comply with the current approval documentation.

Maintenance generally comprises:

- checking the condition of the vessel, piping and accessories;
- checking the operability of valves;
- minor repairs, e.g. changing of seals;
- cleaning external surfaces.

Maintenance operations shall only be carried out by personnel trained for the task.

Equipment shall not be removed until pressure has been released or adequately isolated or depressurized.

Any leakage shall be rectified promptly and in a safe manner. Original spare parts should preferably be used. If this is not possible, the suitability of the spare part shall be approved by a competent person.

Modifications in design, materials and equipment or repairs shall be approved by a competent person and documentation updated accordingly (see also ISO 21029-1).

Hot work (welding, soldering, and heating, etc.) shall be carried out to the same standard (fabrication, qualification of personnel, testing, certification, etc.) as during manufacture.

If at any time it is necessary to break the seal for adjustment of a pressure-relief valve, the valve shall be removed from service until it has been reset and sealed. Any adjustment necessary shall be made by the manufacturer or other companies having competent personnel and adequate facilities for the repair, adjustment, and testing of such valves. The organisation making such adjustment shall attach a permanent tag with the setting, capacity and date to the pressure-relief valve. Replacement of pressure relief devices shall be carried out by trained personnel.

Vessels shall be internally clean, dry and free from particulate matter and contaminants; vessels for oxidizing fluids shall be free from oil and grease.

15 Periodic inspection

15.1 The inspection shall be performed at intervals not exceeding 10 years.

a) Equipment and pressure-relief device check.

Reclosable pressure-relief devices shall be lift-tested either *in situ* or off the vessel.

Non reclosable pressure-relief devices, where fitted, shall be replaced.

b) All other equipment shall be checked for satisfactory functioning.

Visual external examination:

- check for signs of damage;
- check content and legibility of data plate (see 4.2) and other markings.

c) Leak test

A gas test using an inert gas or the working medium at a minimum of 25 % of the permissible working pressure shall be carried out.

The vessel integrity may be checked by a leak test (see above) and measurement of vacuum if appropriate. Vacuum measurement shall only be performed when the thermal performance is deficient as noted by vessel operation.

15.2 In addition, at intervals not exceeding 5 years.

a) The reclosable pressure-relief devices shall be lift-tested.

NOTE Inspection intervals may exceed 5 years if system and equipment performance tests demonstrate proper functionality.

b) Non reclosable pressure-relief devices shall be visually inspected.

Satisfactory examination shall be confirmed in accordance with ISO 21029-1.

16 Additional requirements for flammable gases

16.1 General safety requirements (see also Clause 6)

16.1.1 General

Open vessels/dewars shall not be used.

Precautions shall be taken when approaching a leak as the product may ignite and produce a flame. Products such as hydrogen require specific care as the flame is invisible.

Care shall be taken in the choice of personnel clothing, to protect as much as is practicable against static charges and flames. Electrically-conductive footwear shall be worn.

Fill/withdrawal connections shall be capped when not in use.

Spillage of flammable fluids can result in the risk of fire or explosion.

16.1.2 Electrical equipment

All equipment shall be in accordance with the requirements of the hazardous area classification.

In the classified area, personnel shall not be permitted to carry sources of flame, or non-approved electrical equipment. Consideration shall be given to all electric equipment, e.g. mobile 'phones and radio transmitters.

16.1.3 Earthing system

All parts of the installation shall be bonded to ensure electrical continuity.

Installations shall be earthed, resistance $\leq 10 \Omega$.

Major items of equipment (e.g. the vessel) shall be bonded directly to the earth point and shall not rely upon the piping as a means to earth.

For transfilling processes, equalization of the electrical potentials is necessary.

16.2 Putting into service (see also Clause 7)

Prior to filling, a vessel that is empty or depressurized shall be purged with an inert gas. Purging shall be continued until the gas within the vessel will not result in an explosive mixture forming during filling with the flammable fluid.

The purge gas shall be warm and dry in order to expel moisture from the vessel.

16.3 Location (see also Clause 8)

Vessels shall not be located underground.

Vessels shall not be filled or stored indoors.

Vessels that are connected to product withdrawal systems shall be located outdoors. However, they may be located indoors providing the following requirements are met.

- The maximum quantity of flammable fluid within the vessel is less than 200 l, or between 200 l and 1 000 l providing the vessel is located in a room that has been specifically designed, for this purpose, e.g. one with ventilation control by gas monitoring devices.
- Where forced ventilation is provided, appropriate classified equipment shall be used.
- All relief valve outlets and vent valve outlets shall be piped to a safe external venting point. The fire resistance of the materials in the vicinity of the vent discharge shall be considered.
- Gas detectors shall be fitted within the room, set to alarm when 25 % of the lower explosive limit is reached.

For vessels which are located outdoors, safety distances are given in Annex A. For vessels which are located indoors, the entire room in which the vessel is located shall be considered a potentially hazardous area and be subject to individual assessment.

16.4 Transport (see also Clause 9)

Vessels shall not be transported unless the vessel's pressure at the start of the journey is less than 50 % of the vessel's maximum permissible working pressure, and fill connections are capped.

Vessels shall not be transported in elevators or lifts.

Vessels shall not be transported in enclosed passenger or cargo compartments of vehicles.

16.5 Filling (see also Clause 10)

Before starting the transfilling, the earthing conductor shall be connected, the integrity of the earthing system shall be checked against obvious damage and the filling hose(s) purged free of air and impurities.

Filling shall only be undertaken outdoors.

16.6 Change of service (see also Clause 12)

Vessels designed and used for flammable fluid service shall not be transferred to oxidizing, or inert gas service, without appropriate purging, cleaning and design parameter verification.

16.7 Taking out of service (see also Clause 13)

The vessel shall be purged with inert gas until the flammable gas concentration in the inert gas is below 50 % of the lower explosive limit of flammable gas in air.

16.8 Maintenance and repair (see also Clause 14)

Where maintenance and repair work requires the vessels to be rendered inert, they shall be emptied using a safe procedure and purged with inert gas until the concentration of flammable gas in the inert gas is below 50 % of the lower explosive limit of the flammable gas in air.