
**Plastics piping systems for
the trenchless replacement of
underground pipeline networks —**

**Part 1:
Replacement on the line by pipe
bursting and pipe extraction**

*Systèmes de canalisations en plastique pour le remplacement sans
tranchée des réseaux de canalisations enterrés —*

*Partie 1: Remplacement sur ligne par éclatement de tuyau et
extraction de tuyau*



STANDARDSISO.COM : Click to view the full PDF of ISO 21225-1:2018



COPYRIGHT PROTECTED DOCUMENT

© ISO 2018

All rights reserved. Unless otherwise specified, or required in the context of its implementation, no part of this publication may be reproduced or utilized otherwise in any form or by any means, electronic or mechanical, including photocopying, or posting on the internet or an intranet, without prior written permission. Permission can be requested from either ISO at the address below or ISO's member body in the country of the requester.

ISO copyright office
CP 401 • Ch. de Blandonnet 8
CH-1214 Vernier, Geneva
Phone: +41 22 749 01 11
Fax: +41 22 749 09 47
Email: copyright@iso.org
Website: www.iso.org

Published in Switzerland

Contents

	Page
Foreword	iv
Introduction	v
1 Scope	1
2 Normative references	1
3 Terms and definitions	2
4 Symbols and abbreviated terms	7
4.1 Symbols	7
4.2 Abbreviated terms	8
5 Design aspects	8
6 Material selection	8
6.1 Pipes and fittings	8
6.2 Regional requirements for pipes and fittings	8
6.3 Ancillary components	9
7 Installation practice	9
7.1 Preparatory work	9
7.2 Storage, handling and transport	9
7.3 Equipment	10
7.3.1 General	10
7.3.2 Inspection equipment	10
7.3.3 Lifting equipment	10
7.3.4 Butt fusion equipment and debearing equipment	10
7.3.5 Pipe skids/rollers	10
7.3.6 Winching and rod-pulling equipment	10
7.3.7 Pipe bursting equipment	11
7.3.8 Pipe extraction equipment	11
7.3.9 Electrofusion equipment	12
7.4 Installation	12
7.4.1 General	12
7.4.2 Disconnection from the existing pipeline	13
7.5 Process-related inspection and testing	13
7.6 Finishing off	13
7.7 Reconnection to the existing pipeline system	13
8 Fitness for purpose	13
8.1 General	13
8.2 Final inspection	14
8.3 Pressure testing	14
8.4 Disinfection	14
8.5 Documentation	14
Annex A (normative) Layered pipes	15
Annex B (informative) Pipe design considerations particular to pipe bursting and pipe extraction	16
Bibliography	18

Foreword

ISO (the International Organization for Standardization) is a worldwide federation of national standards bodies (ISO member bodies). The work of preparing International Standards is normally carried out through ISO technical committees. Each member body interested in a subject for which a technical committee has been established has the right to be represented on that committee. International organizations, governmental and non-governmental, in liaison with ISO, also take part in the work. ISO collaborates closely with the International Electrotechnical Commission (IEC) on all matters of electrotechnical standardization.

The procedures used to develop this document and those intended for its further maintenance are described in the ISO/IEC Directives, Part 1. In particular the different approval criteria needed for the different types of ISO documents should be noted. This document was drafted in accordance with the editorial rules of the ISO/IEC Directives, Part 2 (see www.iso.org/directives).

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. ISO shall not be held responsible for identifying any or all such patent rights. Details of any patent rights identified during the development of the document will be in the Introduction and/or on the ISO list of patent declarations received (see www.iso.org/patents).

Any trade name used in this document is information given for the convenience of users and does not constitute an endorsement.

For an explanation on the voluntary nature of standards, the meaning of ISO specific terms and expressions related to conformity assessment, as well as information about ISO's adherence to the World Trade Organization (WTO) principles in the Technical Barriers to Trade (TBT) see the following URL: www.iso.org/iso/foreword.html.

This document was prepared by Technical Committee ISO/TC 138, *Plastics pipes, fittings and valves for the transport of fluids*, Subcommittee SC 8, *Rehabilitation of pipeline systems*.

A list of all the parts in the ISO 21225 series can be found on the ISO website.

Introduction

System standards dealing with the following applications are either available or in preparation for pipeline renovation:

- The ISO 11296 series: *Plastics piping systems for renovation of underground non-pressure drainage and sewerage networks*;
- The ISO 11297 series: *Plastics piping systems for renovation of underground drainage and sewerage networks under pressure*;
- The ISO 11298 series: *Plastics piping systems for renovation of underground water supply networks*;
- The ISO 11299 series: *Plastics piping systems for renovation of underground gas supply networks*.

System standards dealing with all application areas are either available or in preparation for trenchless pipeline replacement:

- The ISO 21225 series: *Plastics piping systems for the trenchless replacement of underground pipeline networks*.

The system standard ISO 21225 comprises:

- *Part 1: Replacement on the line by pipe bursting and pipe extraction* (this document);
- *Part 2: Replacement off the line by horizontal directional drilling and impact moling*.

The requirements for technique families are given in ISO 21225-1 and ISO 21225-2 respectively. For complimentary information, see ISO 11295^[1].

A consistent structure of clause headings has been adopted for all parts to facilitate direct comparisons across replacement standards.

[Figure 1](#) shows the common part and clause structure and the relationship between ISO 21255 and the system standards for the renovation application areas.




Figure 1 — Technique families and clause structure

Plastics piping systems for the trenchless replacement of underground pipeline networks —

Part 1:

Replacement on the line by pipe bursting and pipe extraction

1 Scope

This document specifies requirements and test methods for pipes and fittings which are part of plastics piping systems for the trenchless replacement of underground non-pressure and pressure drainage and sewerage networks and underground water and gas supply networks, by means of pipe bursting and pipe extraction.

It is applicable to polyethylene (PE) pipes and fittings, as manufactured, as well as to the installed replacement system.

This document is intended to be used in conjunction with standards applicable for the construction of PE pipeline systems where available.

Regarding manufactured pipes it is applicable to three different PE pipe types:

- PE solid wall single layered pipes (nominal outside diameter, d_n), including any identification stripes;
- PE pipes with co-extruded layers on either or both the outside and inside of the pipe (total outside diameter, d_n), as specified in [Annex A](#), where all layers have the same MRS rating;
- PE pipes (outside diameter, d_n) having a peelable, contiguous, thermoplastics additional layer on the outside of the pipe ("coated pipe"), see [Annex A](#).

In addition it is applicable to:

- jointing of pipe lengths by means of butt fusion joint;
- jointing of pipe lengths by means of electrofusion joint;
- fabricated and injection-moulded fittings made of PE.

Pipes made from other plastics, e.g. glass reinforced plastics (GRP), are outside the scope of this document.

2 Normative references

The following documents are referred to in the text in such a way that some or all of their content constitutes requirements of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

ISO 4427 (all parts), *Plastics piping systems — Polyethylene (PE) pipes and fittings for water supply*

ISO 4437 (all parts), *Plastics piping systems for the supply of gaseous fuels — Polyethylene (PE)*

ISO 4633, *Rubber seals — Joint rings for water supply, drainage and sewerage pipelines — Specification for materials*

ISO 8772, *Plastics piping systems for non-pressure underground drainage and sewerage — Polyethylene (PE)*

ISO 12176-1, *Plastics pipes and fittings — Equipment for fusion jointing polyethylene systems — Part 1: Butt fusion*

ISO 12176-2, *Plastics pipes and fittings — Equipment for fusion jointing polyethylene systems — Part 2: Electrofusion*

ISO 16010, *Elastomeric seals — Material requirements for seals used in pipes and fittings carrying gaseous fuels and hydrocarbon fluids*

EN 681-1, *Elastomeric seals — Material requirements for pipe joint seals used in water and drainage applications — Part 1: Vulcanized rubber*

EN 681-2, *Elastomeric seals — Material requirements for pipe joint seals used in water and drainage applications — Part 2: Thermoplastic elastomers*

EN 681-3, *Elastomeric seals — Material requirements for pipe joint seals used in water and drainage applications — Part 3: Cellular materials of vulcanized rubber*

EN 681-4, *Elastomeric seals — Material requirements for pipe joint seals used in water and drainage applications — Part 4: Cast polyurethane sealing elements*

EN 682, *Elastomeric seals — Material requirements for seals used in pipes and fittings carrying gas and hydrocarbon fluids*

EN 1555-1, *Plastics piping systems for the supply of gaseous fuels — Polyethylene (PE) — Part 1: General*

EN 1555-2, *Plastics piping systems for the supply of gaseous fuels — Polyethylene (PE) — Part 2: Pipes*

EN 1555-3, *Plastics piping systems for the supply of gaseous fuels — Polyethylene (PE) — Part 3: Fittings*

EN 1555-5, *Plastics piping systems for the supply of gaseous fuels — Polyethylene (PE) — Part 5: Fitness for purpose of the system*

EN 12201-1, *Plastics piping systems for water supply, and for drainage and sewerage under pressure — Polyethylene (PE) — Part 1: General*

EN 12201-2, *Plastics piping systems for water supply, and for drainage and sewerage under pressure — Polyethylene (PE) — Part 2: Pipes*

EN 12201-3, *Plastics piping systems for water supply, and for drainage and sewerage under pressure — Polyethylene (PE) — Part 3: Fittings*

EN 12201-5, *Plastics piping systems for water supply, and for drainage and sewerage under pressure — Polyethylene (PE) — Part 5: Fitness for purpose of the system*

EN 12666-1, *Plastics piping systems for non-pressure underground drainage and sewerage — Polyethylene (PE) — Part 1: Specifications for pipes, fittings and the system*

3 Terms and definitions

For the purposes of this document the following terms and definitions apply.

ISO and IEC maintain terminological databases for use in standardization at the following addresses:

- IEC Electropedia: available at <http://www.electropedia.org/>
- ISO Online browsing platform: available at <http://www.iso.org/obp>

3.1 General

3.1.1**CCTV system**

system comprised of cameras, recorders, interconnections and displays that are used to inspect pipelines

3.1.2**characteristic**

property, dimension or other feature of a material or component

3.1.3**coated pipe**

pipe with a peelable, contiguous thermoplastic additional layer on the outside of the pipe

3.1.4**installed pipe**

replacement pipe after installation

3.1.5**maintenance**

routine work undertaken to ensure the continuing performance of an asset

3.1.6**pipe with co-extruded layers**

pipe with smooth internal and external surface, having co-extruded layers on either or both the outside and inside of the pipe, where all layers have the same MRS rating

3.1.7**pipeline system**

interconnecting pipe network for the conveyance of fluids

3.1.8**rehabilitation**

measures for restoring or upgrading the performance of existing pipeline systems, including renovation, repair and replacement

3.1.9**renovation**

work incorporating all or part of the original fabric of the pipeline, by means of which its current performance is improved

3.1.10**repair**

rectification of local damage

3.1.11**replacement**

construction of a new pipeline, on or off the line of an existing pipeline, where the function of the new pipeline system incorporates that of the old

3.1.12**replacement pipe**

new pipe installed for rehabilitation purposes

3.1.13**replacement system**

replacement pipe and all relevant fittings for trenchless replacement on or off an existing pipeline for the purposes of rehabilitation

3.1.14

solid wall single layered pipe

pipe with smooth internal and external surface, extruded from the same compound/formulation throughout the wall

3.1.15

system test pressure

STP

pressure applied to the installed pipeline system in order to ensure its integrity and leaktightness

3.1.16

technique family

group of renovation or trenchless replacement techniques which are considered to have common characteristics for standardization purposes

3.1.17

trenchless replacement

replacement without opening trenches other than small excavations to provide access for the particular technique

3.2 Techniques

The various techniques for trenchless replacement of underground networks, within the scope of pipeline rehabilitation techniques generally, are shown schematically in [Figure 2](#).

Definitions of technique families outside the scope of this document are given in ISO 11295.

The technique families within the scope of this document are defined as follows.

3.2.1

bursting head

tool that can crack or split the existing pipe material

Note 1 to entry: Brittle pipe materials such as clay or grey cast iron crack. Ductile pipe materials such as ductile iron, steel or PVC-U split.

3.2.2


pipe bursting

on the line replacement method in which an existing pipe is broken by longitudinal splitting or brittle fracture, using a mechanically applied force from within, where the pipe fragments are forced into the surrounding ground and a new pipe of the same, smaller or larger diameter, is simultaneously pulled in

3.2.3

pipe extraction

on the line replacement method in which an existing pipeline is extracted by pulling or pushing and replaced with a new pipe of the same, smaller or larger diameter, is simultaneously pulled or pushed in



^a This document is applicable.

^b In scope of ISO 21225-2.

^c Outside scope of ISO 21225, see ISO 11295[1].

Figure 2 — Technique families for trenchless replacement of underground pipeline networks using plastics pipes, within the scope of pipeline rehabilitation techniques

3.3 Geometrics

3.3.1

minimum bending radius

minimum radius at any point throughout the length of the pipeline, measured to the longitudinal axis of the pipe

Note 1 to entry: This is usually expressed as a multiple of the pipe diameter.

3.3.2

minimum mean outside diameter

$d_{em,min}$

minimum value of the mean outside diameter as specified for a given nominal size

[SOURCE: ISO 4427-1:2007, 3.1.1.6]

3.3.3

minimum wall thickness at any point

$e_{\min}$

minimum value of the wall thickness at any point around the circumference of a component as specified

[SOURCE: ISO 4427-1:2007, 3.1.1.11]

3.3.4

nominal outside diameter

d_n

specified outside diameter, in millimetres, assigned to a nominal size DN/OD

Note 1 to entry: For thermoplastics solid-wall components, the value of nominal outside diameter is identical to the minimum mean outside diameter, $d_{em,\min}$.

[SOURCE: ISO 4427-1:2007, 3.1.1.3, modified by addition of Note 1 to entry.]

3.3.5

nominal thickness of the coating

e_{coating}

arithmetic mean of a number of measurements of the coating thickness around the circumference and in the same cross-section of a component

3.3.6

nominal wall thickness

e_n

numerical designation of the wall thickness of a component, which is a convenient round number, approximately equal to the manufacturing dimension in millimetres

Note 1 to entry: For thermoplastics solid-wall components, the value of nominal wall thickness, e_n , is identical to the specified minimum wall thickness at any point, $e_{\min}$.

[SOURCE: ISO 4427-1:2007, 3.1.1.9, modified by addition of Note 1 to entry.]

3.3.7

out-of-roundness

difference between the measured maximum and the measured minimum outside diameter in the same cross-sectional plane of the pipe

3.3.8

standard dimension ratio

SDR

ratio of the nominal outside diameter, d_n , to its nominal wall thickness, e_n

3.3.9

wall thickness

e

value of the measurement of the wall thickness at any point around the circumference of a component

3.4 Materials

3.4.1

compound/formulation

clearly defined homogenous mixture of base polymer with additives, e.g. anti-oxidants, pigments, stabilisers and others, at a dosage level necessary for the processing and intended use of the final product

3.4.2**lower confidence limit of the predicted hydrostatic strength** σ_{LPL}

quantity, with the dimensions of stress, which represents the 97,5 % lower confidence limit of the predicted hydrostatic strength at a temperature θ and time t

Note 1 to entry: It is expressed in megapascals.

3.4.3**melt mass-flow rate****MFR**

value relating to the viscosity of the molten material at a specified temperature and load

Note 1 to entry: It is expressed in grams per 10 min (g/10 min).

3.4.4**minimum required strength****MRS**

value of σ_{LPL} , rounded down to the next smaller value of the R10 series or R20 series, depending on the value of σ_{LPL}

Note 1 to entry: R10 and R20 series are the Renard number series according to ISO 3 and ISO 497.

3.4.5**oxidation induction time****OIT**

relative measure of a stabilized material's resistance to oxidative decomposition, determined by the calorimetric measurement of the time interval to the onset of exothermic oxidation of the material at a specified temperature in an oxygen or air atmosphere, under atmospheric pressure

3.5 Joints**3.5.1****butt fusion joint**

joint made by heating the planed ends of matching surfaces by holding them against a flat heating plate until the PE material reaches fusion temperature, quickly removing the heating plate and pushing the two softened ends against one another

3.5.2**electrofusion joint**

joint between a PE socket or saddle electrofusion fitting and a pipe or fitting with spigotted ends, made by heating the electrofusion fittings by the Joule effect of the heating element incorporated at their jointing surfaces, causing the material adjacent to them to melt and pipe and fitting surfaces to fuse

Note 1 to entry: A support sleeve inserted into the pipe bore can be used to provide a permanent support for the PE pipe to prevent creep in the pipe wall under radial compressive forces.

4 Symbols and abbreviated terms**4.1 Symbols**

For the purposes of this document the following symbols apply:

$d_{em,min}$ minimum mean outside diameter

d_n nominal outside diameter

e wall thickness

$e_{\min}$	minimum wall thickness at any point
e_n	nominal wall thickness
e_{coating}	nominal thickness of the coating

4.2 Abbreviated terms

CCTV	closed-circuit television
DN/OD	nominal size, related to the outside diameter
MFR	melt mass-flow rate
MRS	minimum required strength
OIT	oxidation induction time
SDR	standard dimension ratio
STP	system test pressure

5 Design aspects

For general information on design, including specific design parameters relevant to the technique families covered by this document refer to ISO 11295^[1].

Further information particular to pipe bursting and pipe extraction is provided in [Annex B](#).

6 Material selection

6.1 Pipes and fittings

The characteristics of pipes and fittings shall conform to the requirements of all parts of the relevant application area standard from the following list:

- ISO 8772, for non-pressure drainage and sewerage networks;
- EN 12201 (Parts 1, 2, 3 and 5), for drainage and sewerage networks under pressure;
- ISO 4427 (all parts), for water supply under pressure;
- ISO 4437 (all parts), for networks supplying gaseous fuels.

In addition, any nominal diameter shall be permitted.

NOTE Developments are ongoing to amend these standards to include PE100 materials with a significantly enhanced resistance to slow crack growth.

Elastomeric sealing rings shall conform to the performance requirements in:

- ISO 4633, for water and drainage;
- ISO 16010, for gas.

6.2 Regional requirements for pipes and fittings

In countries of the Single European Market, the applicable normative references indicated in [6.1](#) are replaced by the following.

For the characteristics of pipes and fittings:

- EN 12666-1 for non-pressure drainage and sewerage networks;
- EN 12201 (Parts 1, 2, 3 and 5) for drainage and sewerage networks under pressure;
- EN 12201 (Parts 1, 2, 3 and 5) for water supply under pressure;
- EN 1555 (Parts 1, 2, 3 and 5) for networks supplying gaseous fuels.

For the performance requirements of elastomeric sealing rings:

- EN 681 (Part 1, 2, 3 or 4, as applicable) for water and drainage;
- EN 682 for gas.

6.3 Ancillary components

All materials used for ancillary components intended for water supply systems shall be suitable for such an application. They shall not cause any unacceptable deterioration of the quality of water with which they come into contact.

For valves including hydrants, the relevant pressure capability shall be specified in the open position and in the closed position so that the valve function and its tightness are assured under this pressure.

Certain replacement systems require mechanical, end-load-bearing fittings for service connections and pipe terminations. If applicable, full details of these shall be included in the installation manual.

7 Installation practice

7.1 Preparatory work

Prior to starting the process, any connections to the existing pipeline that are due to be remade to the new pipe shall be exposed and disconnected, and any obstacles or severe encrustations that could prevent the operation from being carried out (e.g. insertion of pulling rods) shall be removed.

Prior to commencing installation the installer shall inspect the site for any underground installations or other buried utilities that may be affected by the work.

7.2 Storage, handling and transport

The manufacturer's prescribed procedures for storage, handling and transport of all replacement system components shall be adhered to.

Precautions shall be taken to ensure that no excessive damage is caused to the replacement pipe during unloading, site handling, storage and installation. In this context, excessive damage shall mean any scratch which is more than 10 % of the wall thickness in depth or the imposition of any severe bending operation, which results in a permanent kink, crease or fold.

The replacement pipe shall be stored on reasonably level ground, free of large sharp stones, debris or litter, to avoid potentially damaging point-loading.

In general, and in the absence of any specific handling requirements, these precautions shall include the use of webbing slings in place of wire rope or chains, and the use of spreader beams for pipe lengths in excess of 12 m. Where the system designer specifies handling requirements, these shall prevail.

The replacement pipe shall be transported on a flat-bed vehicle, free of nails or other projections or on a purpose-built trailer designed to carry the rehabilitation pipe as a free-standing coil or wound on to a drum. Before being loaded, the replacement pipe shall be visually checked for any damage.

Pipe ends shall be securely sealed to prevent contamination of the pipe by moisture and/or dirt under storage, handling and transport.

For pipes of 600 mm diameter or larger, a suitable plug or other closure, which also prevents ovality or other deformation, is recommended.

7.3 Equipment

7.3.1 General

All equipment shall be as specified by the system designer and/or installer.

All equipment introduced into the installed pipe shall be constructed and maintained so as to prevent any damage or contamination to the installed pipe.

Schematic representations of the equipment used for the techniques described in this document are provided in ISO 11295.

7.3.2 Inspection equipment

Inspection equipment (CCTV system) shall provide a clear picture of all parts of the installed pipe. This shall include a full colour picture and recording/replay facilities complete with slow motion and frame by frame replay. The recording shall be labelled on screen with full location, metreage, pipe type and size and date information.

7.3.3 Lifting equipment

All lifting equipment shall be covered by current test certification.

7.3.4 Butt fusion equipment and debearing equipment

Butt fusion equipment shall be capable of producing joints between PE pipes or PE pipes and fittings under site conditions and shall comply with ISO 12176-1. In addition to the heater plate, the equipment shall include such clamping, re-rounding and trimming systems as to ensure alignment and matching of the pipe ends.

If an external debearer is used, this shall be capable of removing the bead cleanly in one continuous strip without damage to the pipe surface. If an internal debearer is used, this shall not cause damage to the internal pipe surface.

A shelter shall be provided to avoid fusion joint contamination from water and dust and to generally maintain a clean and warm working environment. The ends of the pipe string shall be plugged to prevent cold air blowing through, which could otherwise adversely affect the fusion joint.

7.3.5 Pipe skids/rollers

Depending on the technique, pipe skids or rollers shall be used. These shall minimize frictional loads and prevent damage to the pipe as it is moved during the butt fusion and installation processes.

7.3.6 Winching and rod-pulling equipment

Winching equipment consists of a winch connected to the replacement pipe by a winch cable and appropriate nose cone connection.

Rod pulling equipment consists of a hydraulic ram driven carriage, connected to the replacement pipe by a string of rods which screw or hook together, and an appropriate nose cone connection.

The pulling force applied to the replacement pipe shall be measured by a load cell inserted directly in front of the nose cone. This force shall be continuously monitored, and shall be recorded, either

graphically or numerically. The sampling rate for recording shall be sufficiently high to capture short load peaks due to snagging, which may result in pipe scoring.

7.3.7 Pipe bursting equipment

Two distinct bursting procedures are possible:

- Static pipe bursting (using bursting head);
- Dynamic pipe bursting.

Static pipe bursting involves pulling a bursting head through the existing pipeline with sufficient force to both break the pipe and expand the bore by pushing the resulting pipe fragments into the surrounding ground. Use of rod pulling equipment rather than cable winching is generally necessary to apply the required force. The equipment is positioned at one end of the section of pipeline to be replaced (receiving end) and the rods then linked together and pushed towards the other end (insertion end) where the bursting head is attached. The selection of bursting head depends on the material of the existing pipeline.

For brittle pipe materials, such as grey cast iron and asbestos cement, a bursting head with one or more blades designed to crack and expand the existing pipeline shall be used.

For non-brittle pipe materials, such as steel or ductile iron, the bursting head shall comprise hardened blades or splitter wheels to make longitudinal cuts in the existing pipeline, in either case followed by a conical expander to increase the size of the cavity.

Measurement of the pulling force applied to the replacement pipe during installation using static pipe bursting shall be by means of a load link inserted directly in front of the nose cone.

Dynamic pipe bursting uses winching equipment to guide a pneumatically driven cracking and displacement bursting head to break the existing pipeline and then push the fragments into the surrounding soil.

The bursting head, incorporating a pneumatic hammer, is positioned at the pipe entry end, directly followed by the displacement part, usually a conical expander. The rear of the cracking and displacement bursting head is connected to the replacement pipe and also to the pneumatic supply hoses, which are fed through the replacement pipe.

The pulling force of the winch shall be used to maintain the correct alignment of the dynamic bursting head and its continuous contact with the pipe being broken only, and not as the principal method of advancing it.

The pulling force monitoring equipment shall be calibrated in line with the manufacturer's instructions.

Appropriate measures shall be taken to avoid compressed air contaminating internal surfaces drinking water pipes.

7.3.8 Pipe extraction equipment

Pipe extraction uses a winching or rod pulling equipment (similar to the equipment used with static pipe bursting) positioned at the receiving end of the pipeline section. The winch cable or pulling rods are first fed through the existing pipe to the insertion end, where the pipe extraction adapter (a push plate) is attached. As a next step, the winching or rod pulling equipment pushes the existing pipe through the ground, while pulling in the new pipe simultaneously, removing or bursting existing pipe sections as they arrive at the receiving end.

Pipe extraction would typically be used for pressure pipes as it allows installation of continuous pipe. Due to the high friction forces only a short length of pipe can be extracted between pits.

7.3.9 Electrofusion equipment

The electrofusion control box shall conform to ISO 12176-2. In addition:

- Pipe preparation shall be carried out using a mechanical scraper, wherever possible.
- Robust alignment and re-rounding clamps shall be used.
- Where requested by the client, fusion parameters and joint location details shall be recorded by a data logging system.

7.4 Installation

7.4.1 General

The installer shall ensure that the rehabilitation process shall not damage any adjacent infrastructure.

NOTE 1 A safe distance from adjacent structure will be a function of both upsize ratio and vibration characteristics of the technique applied (See [Annex B](#)).

The installer shall employ competent, trained staff with appropriate certification, where applicable, to carry out the work.

The installer shall prepare an installation manual detailing all of the procedures required to carry out the work.

The installation manual shall specify the method of installation, including the equipment, new pipe termination and reconnection to existing network and customer service pipes, inspection and testing, and all necessary parameters according to the requirements of the method described.

This manual shall also include:

- a) Calculation of pulling forces required to advance a bursting head or extract an existing pipe, as a function of pipe diameter, material and temperature, and of soil type and depth of burial, also of upsize ratio;
- b) Maximum allowable pulling force on the replacement pipe as declared by the pipe manufacturer as a function of temperature;

NOTE 2 The maximum pulling force is usually calculated to limit the maximum stress to not more than 50 % of the tensile yield stress of the material.

- c) Maximum outside diameter of replacement pipe relative to diameter of conical expander or, in the case of extraction technique, of the existing pipe;
- d) Minimum bending radius during installation, as declared by the pipe manufacturer as a function of SDR and temperature, and the associated minimum length of insertion pit as a function of excavation depth;
- e) details of the type of fittings to be used.

Where pipes are jointed to form one pipe string on site using butt-fusion, a method statement for internal de-beading, where required, and for external de-beading shall be provided and shall specify at least:

- 1) how the bead is removed;
- 2) how the bead and related joint are identified;
- 3) how the bead is to be examined for quality control purposes, and stored for future reference.

NOTE 3 The composition or condition of certain types of existing pipe can be considered to represent an environmental hazard and can restrict bursting or require that the material or former contents of the pipe remain on record after bursting for the advice of future excavators. Examples include asbestos cement pipes and chemical residues in old iron gas pipes.

WARNING — All pulling operations are potentially dangerous and any exposed winch cable or puller rods should be guarded.

7.4.2 Disconnection from the existing pipeline

The pipeline section to be replaced shall be isolated and all service connections, branches and laterals shall be located and disconnected prior to the process. Bends and valves shall be removed. The installation manual shall contain instructions on the procedure to be followed with any repair collars or clamps present.

7.5 Process-related inspection and testing

The required measurements and tests relating to the installation process and the methods by which the measurements shall be taken or the tests conducted, shall be documented in the installation manual.

7.6 Finishing off

On completion of the rehabilitation process, the installation equipment shall be dismantled, and the ends of the installed replacement pipe prepared for subsequent reconnection.

7.7 Reconnection to the existing pipeline system

In the case of pressure applications, where applicable, the ends of the replacement pipe shall be anchored and sealed in such a way as to provide a leaktight connection to the existing pipeline. The method of anchoring the replacement pipe ends shall be such that no longitudinal forces are transmitted onto the existing network pipes either during installation or subsequently when in service. Any service connections, bends, valves, branches and laterals shall be restored via local excavations.

The methods of connecting the installed replacement system to existing connections and the recommended method of making subsequent connections and repairs, including fittings to be used, temperature variations and any special equipment required, shall be documented in the installation manual.

8 Fitness for purpose

8.1 General

All elements of the installed replacement system shall be able to withstand without leakage, and for the full design life, all stresses arising from operation within the system parameters, and any residual stresses caused by the installation or thermal effects.

The system supplier shall document compliance with all relevant mechanical requirements.

The installed replacement system shall have a minimum free bore in accordance with the design requirements (e.g. flow capacity and routine maintenance).

NOTE Free bore has two aspects. The first (cross-sectional) free bore is to ensure that adequate cross-section is retained for flow capacity. The second (dimensional) free bore is to ensure that adequate clearance is retained for routine maintenance equipment to be used or for access to be maintained in the installed pipeline system.

Out-of-roundness of the replacement system after installation (including any caused by the installation of the replacement pipe) shall not exceed any maximum value specified by design or otherwise agreed between the client and installer.

For drinking water applications, the installed system shall ensure that there is no unacceptable deterioration of water quality.

IMPORTANT — Attention is drawn to the need for care in respect of the potential for any residues of materials, lubricants or other chemical agents from the installation process to damage the surrounding environment.

8.2 Final inspection

If specified by the client, the finished replacement pipe shall be inspected internally.

NOTE Where specified, testing to verify leaktightness of the installed replacement system in accordance with 8.4 can take place in stages. For example, in order to verify leaktightness of the installed pipe, including any integral joints only, testing of leaktightness can be carried out before the reconnection of any service or lateral connections.

External inspection shall be carried out of the leading replacement pipe end, and where possible, at other places along the installed lengths where the pipe is exposed (e.g. service connection windows), to verify that the external surface of the pipe is not scratched to a depth greater than 10 % of the wall thickness. Where the pipe wall has scratches greater than 10 % of the wall thickness, the installed length affected shall be replaced.

8.3 Pressure testing

In the case of pressurized applications, the installed replacement system shall meet the STP to ensure the integrity of pipes, joints, fittings and other components, such as anchor blocks.

The STP methodology and the pass/fail criteria shall be agreed on between the client and the system installer and documented in the installation manual.

8.4 Disinfection

In the case of water supply pipelines, the measures taken to disinfect the installed replacement system after final inspection shall be specified by the client and documented in the installation manual.

8.5 Documentation

The values of the installation parameters achieved, including ambient temperature and the maximum recorded pulling force on the pipe, shall be documented, together with all written, photographic and/or electronic records of the replacement required by the installation manual (see 7.4).