



**International
Standard**

ISO 21452

**Specification and requirements of
thermal spray coatings for power
plant boiler tubes**

*Spécification et exigences des revêtements de projection
thermiques pour les tubes de chaudière des centrales électriques*

**First edition
2025-03**

STANDARDSISO.COM : Click to view the full PDF of ISO 21452:2025

STANDARDSISO.COM : Click to view the full PDF of ISO 21452:2025



COPYRIGHT PROTECTED DOCUMENT

© ISO 2025

All rights reserved. Unless otherwise specified, or required in the context of its implementation, no part of this publication may be reproduced or utilized otherwise in any form or by any means, electronic or mechanical, including photocopying, or posting on the internet or an intranet, without prior written permission. Permission can be requested from either ISO at the address below or ISO's member body in the country of the requester.

ISO copyright office
CP 401 • Ch. de Blandonnet 8
CH-1214 Vernier, Geneva
Phone: +41 22 749 01 11
Email: copyright@iso.org
Website: www.iso.org

Published in Switzerland

Contents

Page

Foreword	iv
Introduction	v
1 Scope	1
2 Normative references	1
3 Terms and definitions	1
4 Recommended thermal spray coating materials for boiler tubes	2
5 Preparation of thermal spray coatings for variable boiler tubes	2
5.1 Pre-treatment of variable boiler tubes	2
5.2 Thermal spraying	3
5.3 Post-process of thermal sprayed coatings	3
6 Coating quality and performance evaluation	4
6.1 Coating quality	4
6.2 Performance evaluation of coatings	4
6.2.1 Microhardness	4
6.2.2 Bonding strength	4
6.2.3 Porosity	5
6.2.4 Thermal conductivity	5
6.2.5 High-temperature corrosion test	5
6.2.6 High-temperature erosion wear test	7
Annex A (informative) An example of thermogravimetric plot as a function of the number of hot corrosion cycles	9
Bibliography	11

Foreword

ISO (the International Organization for Standardization) is a worldwide federation of national standards bodies (ISO member bodies). The work of preparing International Standards is normally carried out through ISO technical committees. Each member body interested in a subject for which a technical committee has been established has the right to be represented on that committee. International organizations, governmental and non-governmental, in liaison with ISO, also take part in the work. ISO collaborates closely with the International Electrotechnical Commission (IEC) on all matters of electrotechnical standardization.

The procedures used to develop this document and those intended for its further maintenance are described in the ISO/IEC Directives, Part 1. In particular, the different approval criteria needed for the different types of ISO document should be noted. This document was drafted in accordance with the editorial rules of the ISO/IEC Directives, Part 2 (see www.iso.org/directives).

ISO draws attention to the possibility that the implementation of this document may involve the use of (a) patent(s). ISO takes no position concerning the evidence, validity or applicability of any claimed patent rights in respect thereof. As of the date of publication of this document, ISO had not received notice of (a) patent(s) which may be required to implement this document. However, implementers are cautioned that this may not represent the latest information, which may be obtained from the patent database available at www.iso.org/patents. ISO shall not be held responsible for identifying any or all such patent rights.

Any trade name used in this document is information given for the convenience of users and does not constitute an endorsement.

For an explanation of the voluntary nature of standards, the meaning of ISO specific terms and expressions related to conformity assessment, as well as information about ISO's adherence to the World Trade Organization (WTO) principles in the Technical Barriers to Trade (TBT), see www.iso.org/iso/foreword.html.

This document was prepared by Technical Committee TC 107, *Metallic and other inorganic coatings*.

Any feedback or questions on this document should be directed to the user's national standards body. A complete listing of these bodies can be found at www.iso.org/members.html.

Introduction

Thermal power generation is the main form of power generation in the world. As an important part of the thermal power plant, the safe and stable operation of the boiler is very important for the thermal power plant. However, the four tubes of the boiler (water wall, superheater, reheater and economizer) are in contact with the flame or high-temperature flue gas for a long time, and the working environment is harsh. During operation, the tubes are affected by wear, high-temperature oxidative corrosion, high-temperature operation and other factors, which lead to leakage and directly threaten the safe operation of the thermal power plant. Thermally sprayed technology is an effective technology to improve the surface quality and prolong the service life of boiler tubes. So far, thermal spraying technology and metal and metal ceramic coatings have been widely used in the protection of various boilers (such as circulating fluidized bed boilers and biomass boilers) in the global energy industry. In the process of power plant operation, the type of coating is determined by the specific working conditions of various boiler tubes.

This document provides guidance for the application of thermal sprayed coatings on four boiler tubes and promotes technical progress in the energy industry.

STANDARDSISO.COM : Click to view the full PDF of ISO 21452:2025

STANDARDSISO.COM : Click to view the full PDF of ISO 21452:2025

Specification and requirements of thermal spray coatings for power plant boiler tubes

1 Scope

This document specifies the procedure and requirements of thermal sprayed coatings for water walls and superheaters of coal-fired and biomass boilers involving the selection of coating materials, pre-treatment, 12/15CrMoV steel substrate preparation and post-treatment as well as the quality and performance evaluation of the coatings.

2 Normative references

The following documents are referred to in the text in such a way that some or all of their content constitutes requirements of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

ISO 3233-1, *Paints and varnishes — Determination of percentage volume of non-volatile matter — Part 1: Method using a coated test panel to determine non-volatile matter and to determine dry-film density by the Archimedes' principle*

ISO 11357-4, *Plastics — Differential scanning calorimetry (DSC) — Part 4: Determination of specific heat capacity*

ISO 13826, *Metallic and other inorganic coatings — Determination of thermal diffusivity of thermally sprayed ceramic coatings by laser flash method*

ISO 14918, *Thermal spraying — Qualification testing of thermal sprayers*

3 Terms and definitions

For the purpose of this document, the following terms and definitions shall apply.

ISO and IEC maintain terminology databases for use in standardization at the following addresses:

- ISO Online browsing platform: available at <https://www.iso.org/obp>
- IEC Electropedia: available at <https://www.electropedia.org/>

3.1 coal-fired boiler

equipment that produces steam or hot water through heat exchange between the heat energy released by the combustion of coal

3.2 biomass boiler

equipment that produces steam or hot water through heat exchange between the heat energy released by the combustion of biomass

3.3 water wall

wall mainly used to absorb the radiant heat emitted by the flame and high-temperature flue gas in the furnace

Note 1 to entry: Usually laid on the inner wall of the furnace, the water wall has the role of cooling and protecting the furnace wall.

3.4

superheater

component of a boiler system that heats the steam above its saturation temperature, also known as a steam superheater

4 Recommended thermal spray coating materials for boiler tubes

This document recommends the appropriate coatings for the following boiler tubes:

- a) water wall of a coal-fired boiler;
- b) superheater of a coal-fired boiler;
- c) water wall of a biomass boiler;
- d) superheater of a biomass boiler.

Generally, damage to tubes includes corrosion, wear, coking and so on. Therefore, on the basis of the failure type, the coating materials outlined in [Table 1](#) are recommended.

Table 1 — Failures and recommended coating materials for variable boiler tubes

Rollers	Failures				Tube materials	Recommended coating materials
	Corrosion	Wear	Fatigue	Coking		
Water wall of a coal-fired boiler	/	√	√	√	12/15 Cr1MoV steel	NiCrTi NiCr-B ₄ C NiCr-Cr ₃ C ₂
Superheater of a coal-fired boiler	/	√	/	√	12Cr1MoV steel	FeCrBMoC NiCr-Cr ₃ C ₂
Water wall of a biomass boiler	√	√	√	√	15 Cr1MoV steel	NiCrBSi NiCrMoNb
Superheater of a biomass boiler	√	√	/	√	12/15 Cr1MoV steel	NiCrMoNb

NOTE In this table, "√" means "possessing this failure form" and "/" means "there is no such failure form".

5 Preparation of thermal spray coatings for variable boiler tubes

5.1 Pre-treatment of variable boiler tubes

The surface of the tubes shall be inspected and reviewed to ensure their suitability before spraying. The following surface preparation procedure is recommended:


- a) Surface cleaning: Remove all kinds of impurities on the surface of the object, such as grease, dirt, oxide scale and rust, especially the welding part at the root of the pipe. No oxide scale and other impurities that hinder the coating or coating adhesion are allowed. The suggested steps are as follows:
 - 1) Alkali washing: The boiler tube is cleaned with alkaline solution and the temperature is heated to 70 °C to 80 °C for 48 h. Among them, the mass concentration of Na₂CO₃ is 0,5 % to 1 % and the mass concentration of NaOH is 0,3 % to 0,5 %.
 - 2) After alkali washing, clean the boiler tube with water until the pH value is 7 to 8.
 - 3) Acid pickling: The boiler tube is cleaned with acid solution and the temperature is heated to 70 °C to 80 °C for 48 h. Among them, the mass concentration of hydrochloric acid is 6 % and the mass concentration of corrosion inhibitor is 0,3 %.

- 4) After pickling, rinse boiler tube surface with water to neutral.
- b) Surface roughening: Dry sandblasting is recommended. Quartz sand with nominal grain size 1,00 mm to 1,40 mm or corundum sand shall be used as an abrasive for sandblasting, and 0,83 to 1,00 mm quartz sand, nominal grain size 0,85 mm to 1,18 mm, is preferred for sandblasting in the furnace. The compressed air pressure used while sandblasting should be greater than 0,4 MPa and 0,1 MPa for a suction blast system and a pressure blast system, respectively. Compressed air shall be free of oil and water. The sandblasting distance is 100 mm to 200 mm and the included angle is 45° to 70°. The final surface roughness, Ra, shall be 5,4 µm to 6,0 µm after sandblasting. After sandblasting, the surface of the pipe that passes the inspection shall be protected from secondary oil contamination. The workpiece storage time shall not exceed 4 h before thermal spraying. When the humidity is greater than 85 %, the storage time shall be reduced to 2 h.

5.2 Thermal spraying

Thermal spraying should be operated according to ISO 14918 and ISO 14921. For the spraying of boiler tubes, the following points shall be taken into consideration:

- a) Spray the edge chamfer or arc part (see [Figure 1](#)) first, then spray the middle part.



Key

- 1 edge chamfer
- 2 arc part
- 3 middle part

Figure 1 — Schematic diagram of boiler tubes

- b) When spraying, the spray gun should swing back and forth to ensure uniform spraying. The number of each swing is determined by the temperature of the matrix.
- c) The temperature of the substrate in the spraying process should not exceed 200 °C. If the temperature is likely to exceed this figure, the substrate should be cooled to a maximum of 80 °C before spraying.
- d) In the cooling process, dust or other debris on the surface is brushed clean with an air gun or wire brush to ensure a good combination between layers.

5.3 Post-process of thermal sprayed coatings

The post-process of thermal sprayed coatings in boiler tubes includes sealing of pores and heat treatment.

- a) Coating inspection: After thermal spraying, the coating inspection should be performed by measuring coating thickness, roughness, microhardness and bonding strength.
- b) Sealing: Thermal sprayed coatings for all boiler tube types should undergo a sealing process. Once the spraying is finished, sealing the pores as soon as possible is recommended. For sealing, a range of different sealants and procedures are available, which should follow the supplier's instructions. The sealing agent shall withstand the high temperature of 400 °C to 600 °C.

6 Coating quality and performance evaluation

The performance of a coating determines its service life; therefore, it is required to evaluate the coating quality and performance.

6.1 Coating quality

Coating quality shall be inspected in accordance with ISO 14918. However, thermal spray coating on different boiler tubes shall possess the qualities outlined in [Table 2](#).

Table 2 — Recommended performance indicators for variable boiler tubes

	Performance indicators				
	Microhardness HV _{0.3}	Thermal conductivity W/(m·K)	Porosity	Hot corrosion kinetic constant mg ² /(cm ⁴ ·h)	Erosive wear rate mg/(cm ² ·h)
Water wall of a coal-fired boiler	600-800	≥25	≤5 % for as-sprayed; ≤1 % after sealing	≤1,5	20-35
Superheater of a coal-fired boiler	400-700	≥15	<1 %	≤1,5	15-30
Water wall of a biomass boiler	300-500	≥20	<1 %	≤1	20-30
Superheater of a biomass boiler	>300	≥15	<1 %	≤1	10-20

6.2 Performance evaluation of coatings

6.2.1 Microhardness

The hardness of the coating is related not only to the hardness of the material itself but also to the coating structure, pore distribution and oxide content. The difference in spraying methods or conditions often leads to the difference in the above factors, resulting in the difference in the coating hardness of the same material. Vickers indentation is deeper than the Knoop's under the same load; therefore, the Vickers microhardness test is more suitable for the thermal sprayed coatings, which can be tested according to ISO 6507-1.

The following should be considered for the hardness measurement for thermal sprayed coatings on boiler tubes:

- The load selection for the test depends on the thickness and hardness range of the test piece. The highest load shall be used within the allowable range of the thickness of the test piece to obtain the largest size indentation, thus reducing the relative error of measurement. It is therefore recommended to select the load for which the diagonal of the obtained indentation shall not be less than 10 micrometres.
- The dwell holding time shall be between 10 s and 30 s.
- At least ten points shall be measured on the same test piece, and the average value of the ten points shall be taken as the hardness value of the tested piece. The distance between the indentation centre and the edge of the test piece and between the two adjacent indentation centres shall not be less than 2,5 times the diagonal indentation length. For metallic coatings, the distance shall not be less than five times the diagonal length of the indentation.

6.2.2 Bonding strength

The bonding strength of the coating should be measured according to ISO 14916.

6.2.3 Porosity

The evaluation of the porosity of coatings is covered by should follow the steps given in ISO/TR 26946.

6.2.4 Thermal conductivity

The laser flash method uses a pulsed laser to irradiate one surface of the sample and then monitors the temperature change of the other surface through an infrared thermometer. The thermal conductivity of the material can be calculated by measuring the thermal diffusivity of the coating by laser flash method and then combining the specific heat capacity and bulk density of the material. The specific calculation is given in [Formula \(1\)](#):

$$\lambda = \alpha \cdot \rho \cdot C_p \quad (1)$$

where

λ is the thermal conductivity, expressed in W/(m·K);

α is the thermal diffusivity, expressed in m²/s;

ρ is the bulk density of the coating, expressed in Kg/m³;


C_p is the specific heat capacity, expressed in J/(Kg·K).

For the measurement of the thermal conductivity of thermal sprayed coatings on boiler tubes, the following recommendations should be considered:

- a) The thermal conductivity of the coating shall be tested in accordance with ISO 13826 and the dimension of the sample shall be Φ 10 mm × 1,5 mm.
- b) The density of the coating shall be obtained by Archimedes drainage method in accordance with ISO 3233-1.
- c) The specific heat capacity shall be measured by the specific heat tester in accordance with ISO 11357-4. The sample diameter shall be $(5,5 \pm 0,1)$ mm, and the coating thickness shall be 0,4 mm to 0,7 mm.

6.2.5 High-temperature corrosion test

- Specimen preparation: Substrate materials were prepared with square matrix samples having dimensions of (15 to 20) mm × (15 to 20) mm × (5 to 10) mm by electric discharge wire cutting method. The samples shall be chamfered. Specimens shall be subjected to oil removal treatment, cleaning with alcohol and then drying. All six surfaces of the specimen shall be roughened by sandblasting with a suction blast system. The sandblasting pressure shall be 0,6 MPa to 0,7 MPa, the sandblasting angle 50° to 60°, and the sandblasting distance 100 mm to 120 mm. The final surface roughness, Ra, shall be 5,4 µm to 6,0 µm after the sandblasting.
- High-temperature corrosion: Grind the mixed or single salt (salt: NaCl, KCl or Na₂SO₄, analytically pure, white crystalline powder) and configure it into a fine salt powder according to the working conditions. The salt shall be evenly coated on the upper surface of the specimen with a brush. The total amount of salt coated shall be controlled within 5 mg/cm² to 6 mg/cm² and the salt coating error shall be controlled within $\pm 0,3$ mg/cm². Measure the mass of the coated specimen and crucible separately before the experiment. Place the salt-coated specimen in an alumina crucible. The hot corrosion test shall be carried out in a tubular furnace at 500 °C to 700 °C with an accuracy of ± 5 °C (see [Figure 2](#)). Put the salt-coated specimen into the tubular furnace together with the alumina crucible. Take the crucible and specimen out from the furnace every 10 h, measure the mass and then put it back into the furnace to continue the hot corrosion test. Repeat the cumulative hot corrosion cycle (10 to 20) times.



Key

1	air	6	condensate
2	cotton insulation brick	7	scrubbers
3	hot area of a tubular furnace	8	quartz tube
4	alumina crucibles	9	ground salt powder upon the surface
5	vent	10	fully coated specimen

Figure 2 — Diagram of a high-temperature corrosion test device

For the hot corrosion test, the following points should be considered:

- Specimen requirement: The size of the specimen shall be (15 to 20) mm × (15 to 20) mm × (5 to 10) mm, and the specimens shall be chamfered.
- In the process of spraying, six surfaces of square samples shall be treated with full coating spraying.
- The hot corrosive medium: A mixture of NaCl, KCl, and Na₂SO₄, and the molar ratio is 1:1:1.
- Temperature: 600 °C to 800 °C.
- Corrosion kinetics: Since the corrosion is not uniform on the surface, the corrosion kinetics is analysed by the following two methods:
 - Microscopic inspection: The corrosion degree of the coating is evaluated by observing the cross section of the sample. In order to test the thickness of corrosion layer and inner oxidation layer of the coating accurately, the specimens should be cut, cleaned, mounted and polished. A scanning electron microscope is used to measure the corrosion depth.
 - Mass method: The corrosion dynamics are understood by plotting thermogravimetric measurements of mass change per unit surface area as a function of the number of cycles. In addition, plot the mass change per unit surface area squared with the number of cycles to obtain the thermal corrosion mass gain kinetic constant (see [Annex A](#)). The fitting formula is given in [Formula \(2\)](#):

$$\left(\frac{\Delta w}{A} \right)^2 = k_p \cdot t \quad (2)$$

where

Δw is the mass increment, expressed in mg;

A is the coating area, expressed in cm^2 ;

k_p is the kinetic constant of mass gain in hot corrosion, expressed in $\text{mg}^2/(\text{cm}^4 \cdot \text{h})$;

t is the corrosion time, expressed in h.

6.2.6 High-temperature erosion wear test

High-temperature erosion wear properties of thermal-sprayed coatings determine their performances on boiler tubes. Referring to the ASTM G211, it is possible to test the erosion experiment of the coating hit by solid particles at high temperatures. However, for the thermal sprayed coating on boiler tubes, the following special requirements shall be followed:

- a) Specimen preparation (see 6.2.5).
- b) High-temperature erosion system: As shown in Figure 3, the sample is heated directly by the power supply and the rotary plate is driven by a high-speed motor for high-speed rotation movement to provide the power required for erosion. Sand particles fall from the drop bucket above the rotary plate to the sand separator. The sand particles are thrown out at high speed and hit the sample surface around the rotary plate under the action of centrifugal force.
- c) In the process of spraying, six surfaces of square samples shall be treated with full coating spraying. The final surface roughness, Ra , shall be $1 \mu\text{m}$ to $2 \mu\text{m}$ after polishing.
- d) Sand particles: The sand particles should be sharp-edged brown corundum sand with a $0,5 \text{ mm}$ to 1 mm diameter.
- e) Test temperature: The test temperature should be selected in accordance with the specific working conditions of the tubes. The recommended test temperatures are $400 \text{ }^\circ\text{C}$ to $700 \text{ }^\circ\text{C}$ for tubes of biomass boiler and $600 \text{ }^\circ\text{C}$ to $800 \text{ }^\circ\text{C}$ for tubes of a coal-fired boiler.
- f) Impact angle: $0 < \theta \leq 90^\circ$
- g) Impact speed: $10 \leq v \leq 100 \text{ m/s}$
- h) Erosion distance: $40 \leq L \leq 60 \text{ mm}$
- i) Wear rate measurement, is given in Formula (3):

$$W = (m_1 - m_0) / (S \cdot h) \quad (3)$$

where


W is the wear rate, expressed in mg/cm^2 ;

m_1 is the mass after wear, expressed in mg;

m_0 is the mass before wear, expressed in mg;

S is the surface area, expressed in cm^2 ;

h is the erosion time, expressed in h.



Key

- | | | |
|--------------------------|--------------------|-------------------------|
| 1 control cabinet | 7 funnel | 13 erosion box |
| 2 heating electric power | 8 sand separator | 14 motor |
| 3 bracket | 9 turnplate | 15 slip board |
| 4 sand feeder | 10 enclosure cover | 16 water cooling system |
| 5 sand grains | 11 specimen | 17 sand outlet |
| 6 shakeout tank | 12 electrode | |

Figure 3 — Schematic diagram of a high-temperature erosion wear test device