
**A method to calculate and express
energy consumption of industrial
wastewater treatment for the purpose
of water reuse —**

**Part 1:
Biological processes**

STANDARDSISO.COM : Click to view the full PDF of ISO 21939-1:2019



STANDARDSISO.COM : Click to view the full PDF of ISO 21939-1:2019



COPYRIGHT PROTECTED DOCUMENT

© ISO 2019

All rights reserved. Unless otherwise specified, or required in the context of its implementation, no part of this publication may be reproduced or utilized otherwise in any form or by any means, electronic or mechanical, including photocopying, or posting on the internet or an intranet, without prior written permission. Permission can be requested from either ISO at the address below or ISO's member body in the country of the requester.

ISO copyright office
CP 401 • Ch. de Blandonnet 8
CH-1214 Vernier, Geneva
Phone: +41 22 749 01 11
Fax: +41 22 749 09 47
Email: copyright@iso.org
Website: www.iso.org

Published in Switzerland

Contents

Page

Foreword	iv
Introduction	v
1 Scope	1
2 Normative references	1
3 Terms and definitions, symbols and abbreviated terms	2
3.1 Terms and definitions	2
3.2 Symbols and abbreviated terms	2
4 Expression and normalization of energy consumption	2
4.1 Energy consumption indicator	2
4.2 Calculation	4
5 Components contribution to the energy consumption	4
5.1 General	4
5.1.1 Steady state conditions	4
5.1.2 Consideration of flow rate	5
5.1.3 Calculation of variable consumptions	5
5.1.4 Accounting for addition of oxidizing chemicals	5
5.1.5 Physico-chemical separation pre-treatment processes	5
5.2 List of system components	6
5.2.1 General	6
5.2.2 Aeration and combined mixing and aeration equipment	6
5.2.3 Mixing	6
5.2.4 Solid-liquid separation	6
5.2.5 Internal circulation pumping	6
5.2.6 Circulation of settled sludge	6
5.2.7 Other pumping	6
5.2.8 Air driven pumping and/or mixing	6
6 Factoring of different process conditions	7
6.1 General	7
6.2 Temperature adjustments	7
6.3 Barometric pressure adjustment	7
6.4 Type of wastewater	7
Annex A (informative) References to formulae and calculations	8
Annex B (informative) Example calculations	9
Bibliography	12

Foreword

ISO (the International Organization for Standardization) is a worldwide federation of national standards bodies (ISO member bodies). The work of preparing International Standards is normally carried out through ISO technical committees. Each member body interested in a subject for which a technical committee has been established has the right to be represented on that committee. International organizations, governmental and non-governmental, in liaison with ISO, also take part in the work. ISO collaborates closely with the International Electrotechnical Commission (IEC) on all matters of electrotechnical standardization.

The procedures used to develop this document and those intended for its further maintenance are described in the ISO/IEC Directives, Part 1. In particular, the different approval criteria needed for the different types of ISO documents should be noted. This document was drafted in accordance with the editorial rules of the ISO/IEC Directives, Part 2 (see www.iso.org/directives).

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. ISO shall not be held responsible for identifying any or all such patent rights. Details of any patent rights identified during the development of the document will be in the Introduction and/or on the ISO list of patent declarations received (see www.iso.org/patents).

Any trade name used in this document is information given for the convenience of users and does not constitute an endorsement.

For an explanation of the voluntary nature of standards, the meaning of ISO specific terms and expressions related to conformity assessment, as well as information about ISO's adherence to the World Trade Organization (WTO) principles in the Technical Barriers to Trade (TBT) see www.iso.org/iso/foreword.html.

This document was prepared by Technical Committee ISO/TC 282, *Water reuse*, Subcommittee SC 4, *Industrial water reuse*.

Any feedback or questions on this document should be directed to the user's national standards body. A complete listing of these bodies can be found at www.iso.org/members.html.

Introduction

Biological wastewater treatment is a major process step in many cases of industrial wastewater treatment for reuse.

In the field of biological wastewater treatment, the energy consumption of the process is commonly normalized in order to account for difference in flow and concentration when comparing different treatment options. For example, energy consumption is reported per unit volume of wastewater treated (e.g. kWh/m³) or per unit of pollutant removed BOD₅ (e.g. kWh/kg BOD₅), TN (e.g. kWh/kg TN).

The disadvantages and limitations of these indicators include:

- Neither of the existing indicators are agreed to and accepted as a standard in the industry;
- They do not provide means to compare nitrifying processes to non-nitrifying processes;
- There is no differentiation between design values and measured values, and there are no standard methods to obtain the indicator for each case.

Another approach is to report on the results from standard tests in water as oxygen transfer capacity per unit energy consumed (e.g. kg O₂/kWh).

The disadvantages and limitations of this type of indicator include:

- It is less convenient for the market to apply to its cases, (for example because not all removal is by oxidation, some is by metabolic consumption);
- It only considers oxygen transfer equipment or processes able to dissolve oxygen in water, which does not apply to all biological treatment processes (such as rotating biological contactor (RBC) and trickling filter (TF)).

These issues are discussed in the literature, which compares results expressed in different ways and correspondingly provides contradicting indications (see References [4], [5] and [10]).

Therefore this document aims to create a quantitative measure for universal characterization of the energy consumption for aerobic biological wastewater treatment systems. Such standardization will benefit engineers in specification of systems and comparison of systems. The need arises especially in consideration of life cycle cost of a wastewater treatment system.

NOTE 1 Normalized energy consumption of wastewater treatment systems typically decreases with increasing size of the system, mainly due to higher efficiency of larger electromechanical equipment such as pumps and blowers. Thus, large wastewater treatment plants will have lower normalized energy consumption than small wastewater treatment systems. In order to neutralize the influence of plant size in comparison of energy consumption, a correlation such as published by Silva, C., et al. (see Reference [11]) can be used, regardless of this document.

NOTE 2 Higher effluent quality requirements are generally associated with higher normalized energy consumption. Typically, normalized energy consumption will be compared for similarly performing systems. However, it is possible, for example, to present the normalized energy consumption for different treatment qualities as such.

NOTE 3 This document quantifies the energy consumption, regardless of treatment efficiency that can vary for different types of wastewater. Treatment efficiency might typically be characterized by retention time and/or volumetric loading rate and/or volumetric removal rate or other indicators which are not part of this document.

STANDARDSISO.COM : Click to view the full PDF of ISO 21939-1:2019

A method to calculate and express energy consumption of industrial wastewater treatment for the purpose of water reuse —

Part 1: Biological processes

1 Scope

This document sets out the general principles for, and provides guidance on, the quantitative characterization of the energy consumed by industrial biological wastewater treatment systems. It does not aim to characterize the treatment pollutants removal performance or process reliability or any other consideration in the selection of a wastewater treatment system.

This document includes the following sub-systems of biological treatment system:

- Biological reactors, which might be suspended growth or fixed film processes or a combination thereof, and can include anaerobic, anoxic and/or aerobic tanks and/or zones.
- Solid-liquid separation processes such as sedimentation, flotation, or membrane filtration, used for clarification of the water before discharge to downstream processes, which can also involve the return of a the separated solids as sludge back to the biological reactor.
- Any pumps, blowers and mixers for water circulation, mixing and air supply in and between the sub-systems listed herein.
- Heating or cooling of the water for treatment.

This document does not include the following subsystems of the biological treatment system:

- Wastewater feed pumps.
- Pre-treatment systems, which for the purposes of this document also include preliminary and primary treatment processes, such as but not limited to, screening, sedimentation, dissolved air flotation, chemical oxidation, oil separation.
- Post-treatment processes, such as but not limited to, disinfection, desalination, ion exchange, sludge treatment and handling systems.
- Site lighting or any energy consumption involved in office operation.
- Energy recovery from processes such as anaerobic reactors producing biogas.

Filtration processes, which are sometimes part of the biological treatment process and at other times part of the post treatment, are referred to separately within this document.

2 Normative references

The following documents are referred to in the text in such a way that some or all of their content constitutes requirements of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

ISO 20670, *Water reuse — Vocabulary*

3 Terms and definitions, symbols and abbreviated terms

3.1 Terms and definitions

For the purposes of this document, the terms and definitions given in ISO 20670 and the following apply.

ISO and IEC maintain terminological databases for use in standardization at the following addresses:

- ISO Online browsing platform: available at <https://www.iso.org/obp>
- IEC Electropedia: available at <http://www.electropedia.org/>

3.2 Symbols and abbreviated terms

A ² O	anaerobic-anoxic-oxic wastewater treatment process
Bardenpho	a process for biological nutrient removal developed by James Barnard of South Africa in the 1970's
BOD ₅	bio-chemical oxygen demand (5 days) concentration or load, mg/l or kg/d, respectively
COD	chemical oxygen demand concentration or load, mg/l or kg/d, respectively
DAF	dissolved air flotation
DO	dissolved oxygen
DGF	dissolved gas flotation
MBR	membrane bio-reactor
MLE	modified Ludzack Ettinger process of wastewater treatment
NEC	normalized energy consumption, kWh/kg
NO ₃ -N	net oxidizable mass removed
TN	total nitrogen concentration or load, mg/l or kg/d, respectively
UCT	University of Cape Town process of wastewater treatment
VIP	Virginia Initiative Plant process of wastewater treatment
VFD	variable frequency drive
RBC	rotating biological contactor
TF	trickling filter
TKN	total Kjeldahl nitrogen concentration or load, mg/l or kg/d, respectively
VSS	volatile suspended solids

4 Expression and normalization of energy consumption

4.1 Energy consumption indicator

Following are details and explanations of values needed for later calculations in 4.2.

4.1.1 Normalized energy consumption shall be expressed in terms of energy per net oxidizable mass removed.

4.1.2 The net oxidizable mass removed (NOR) shall comprise of

- COD removed,
- TKN removed,
- Nitrate created (or subtraction of nitrate removed).

4.1.3 Constituents included in the indicator shall be factored for their oxygen demand value. Specifically the following factoring principles shall be applied, based on the references indicated in [Annex A](#) and in References [\[1\]](#), [\[2\]](#) and [\[5\]](#).

- COD removed shall be multiplied by +1,0.
- In design, COD concentration in the sludge shall be calculated on the basis of VSS concentration multiplied by 1,42 (References [\[8\]](#), [\[12\]](#), [Annex A](#)); the VSS concentration in the sludge, taken for calculations in this document, shall be the same as the value for VSS concentration in the sludge taken in process design. Process design values for sludge composition can be calculated according to conventional design procedures (Reference [\[8\]](#), [Annex A](#)).
- TKN removed shall be multiplied by +1,71 (corresponding to oxidation to nitrogen gas regardless of the chemical pathway).

NOTE The fraction of TKN which was not reduced to zero-valence nitrogen is accounted for as nitrate and nitrite, with the multipliers as specified below.

- In design, TKN concentration in the sludge shall be calculated as 12 % of the VSS, on the basis described above for COD calculation.
- Nitrate nitrogen removed or produced shall be multiplied by -2,86 or +2,86, respectively.
- Nitrite nitrogen removed or produced shall be multiplied by -1,71 or +1,71, respectively.

4.1.4 Removed mass for each constituent in the NOR shall be calculated as: constituent load in the inlet subtracted by constituent load in the outlet of the system as shown in [Formula \(1\)](#), wherein load is defined as the concentration multiplied by the flow rate.

4.1.5 Concentration and flow used for load calculation shall be representative samples, and flow shall be average daily flow. Attention should be paid to use results which do not significantly deviate from typical values, see for example existing wastewater sampling standard ISO 5667-10.

4.1.6 The indicator shall be expressed in metric units as follows: kWh/kg NOR.

4.1.7 All calculations and factors shall refer to metric units, and specifically concentrations in g/m³ and flow in m³/d.

4.1.8 Actual average daily power consumption in kW shall be used for the calculation of the normalized energy consumption. The power consumption should be measured by electricity power meters as required, installed on the mains of all the components included in the biological treatment system as defined in [5.2](#).

4.1.9 It shall be noted if all values are measured in an actual operating plant or calculated theoretically according to design.

4.1.10 It should be noted in addition, what type of wastewater the result is associated with, referring to ISO 22447.

4.1.11 The energy consumption in terms of NEC may be calculated for any of average/typical or peak conditions. It shall be noted alongside the result when energy consumption is calculated for peak conditions.

4.2 Calculation

The basic formulae for calculating energy consumption of a biological wastewater treatment system process shall be as follows:

$$LR_i = (Q_{\text{influent}} \cdot C_{i,\text{influent}} - Q_{\text{effluent}} \cdot C_{i,\text{effluent}} - Q_{\text{sludge}} \cdot C_{i,\text{sludge}}) / 1\,000 \quad (1)$$

where

- Q is the average daily flow through the biological treatment, m³/d;
- Q_{influent} is the influent average daily flow through the biological treatment, m³/d;
- Q_{effluent} is the effluent average daily flow through the biological treatment, m³/d;
- Q_{sludge} is the sludge average daily flow through the biological treatment, m³/d;
- C_i is the concentration of constituent i , and specifically:
COD or TKN or NO₃-N or NO₂-N or DO, all in mg/l;
- LR_i is the daily load of constituent i , removed, kg/d.

NOTE Regarding average daily flow through the biological treatment — flow and all concentrations are without (excluding) any circulations but with (including) return streams such as filter backwash and reject water from sludge handling operations. In other words: the flow and concentrations taken for calculation of LR_i need to include return streams from backwash of filters and sludge handling.

$$NOR = LR_{\text{COD}} \cdot 1,0 + LR_{\text{TKN}} \cdot 1,71 - LR_{\text{NO}_3\text{-N}} \cdot 2,86 - LR_{\text{NO}_2\text{-N}} \cdot 1,71 - LR_{\text{DO}} \cdot 1,0 \quad (2)$$

where NOR is the net oxidizable mass removed, kg/d.

$$NEC = \frac{W \cdot 24}{NOR} \quad (3)$$

Example calculations of [Formulae \(1\), \(2\) and \(3\)](#) are shown in [Table B.1](#), [Table B.2](#) and [Table B.3](#).

5 Components contribution to the energy consumption

5.1 General

It is common in engineering design calculations to take different safety factors according to experience or recommendations from the literature. In all design calculations of NEC as part of this document, a safety factor of 1.0 shall be taken (i.e. no safety factor).

5.1.1 Steady state conditions

Measurements shall be performed at conditions where there is no positive or negative accumulation in the system. In order to avoid erroneous reporting of transition phase results as representative, the general conditions of the system should not be monotonously changing over the period of measurement,

but rather constant or fluctuating around an average value. Generally, the fluctuations of the system over the period of measurement should also be normal and not reflect irregular instability.

5.1.2 Consideration of flow rate

A representative flowrate shall be taken for daily load removed (LR_i) calculations, corresponding to the average pollutant concentrations taken for the same calculation. The representative flowrate shall be one of the following:

- Actual quantity (water volume fed to the system) per relevant unit of time;
- Design quantity (water volume fed to the system) per relevant unit of time;

The relevant time for a system shall be the most suitable for the system of the following:

- One day;
- The hydraulic retention time;
- One full cycle of operation.

The above is suitable for calculation of both continuous and batch processes.

Flow data shall be collected or considered for the same time period as pollutants concentrations data in calculation of the daily load removed (LR_i).

Fluctuating and variable conditions in measurement of an operating system should be considered in selection of averaging periods. See also remarks in 5.1.1 regarding fluctuating conditions.

5.1.3 Calculation of variable consumptions

Calculation of the energy consumption of variable frequency drives (VFD) or intermittently operated equipment e.g. in the design of a system should be based on average values.

5.1.4 Accounting for addition of oxidizing chemicals

Addition of oxidizing chemicals such as pure oxygen or nitrate shall be reported alongside the result. Ideally, the oxidation capacity of added chemicals needs to be deducted from the NOR because the oxidation is performed chemically.

NOTE Inclusion of the added oxidizing chemicals load to the NOR will be considered in future parts in the ISO 21939 series.

5.1.5 Physico-chemical separation pre-treatment processes

Physico-chemical separation pre-treatment processes are not included in the system, therefore concentration of all constituents included in the NOR should be taken after such pre-treatment. For example: screens, dissolved air flotation and primary clarifiers are not included in the system for the purposes of this document. The rationale for this exclusion is that the pre-treatment operations do not remove any oxidation requirement, they only separate and discharge part of it. Inclusion of these operations will be an unnecessary complication, requiring subtraction of the load discharged as screenings from the NOR.

The same applies to solids accumulating pre-treatment systems such as settling ponds or chambers that are periodically emptied. However, in this case special attention should be given to water composition at the outlet of such systems, which might be different than at the inlet due to digestion and hydrolysis processes.

5.2 List of system components

5.2.1 General

The energy consumption of the components of a wastewater treatment system listed in 5.2.2 to 5.2.8 shall be included in the calculation or measurement of the normalized energy consumption.

5.2.2 Aeration and combined mixing and aeration equipment

All electrically driven blowers, compressors, surface aerators, aspirators, etc., including RBC drives, serving the biological treatment system as defined in the scope of this document.

5.2.3 Mixing

Any type of mixers and agitators drives, as used in anaerobic and anoxic sections or in aeration sections of the biological treatment system as defined in the scope of this document.

5.2.4 Solid-liquid separation

The sludge raking and scum skimming system drive of all biological treatment and intermediate clarifiers, such as in contact stabilization processes. The compressors, circulation pumps and skimming systems of DAF or DGF processes. Any other such electromechanical units serving solid-liquid separation serving the biological treatment system as defined in the scope of this document.

Electro-mechanical systems directly associated with the operation of the membranes in membrane bioreactor (MBR), such as suction pump, backwash pump or chemicals pump. The value obtained for MBR shall be reported as "including tertiary filtration".

Tertiary filtration post a solid-liquid separation unit may be reported as part of the total process energy consumption. In that case,

- the feed pumps, backwash pumps and air scouring compressors of media filters shall be included in the calculation,
- the result shall be reported as "including tertiary filtration".

5.2.5 Internal circulation pumping

All pumps for circulation of mixed liquor within the biological treatment system, such as in the A²O, MLE, BARDENPHO, UCT, VIP and other processes circulating mixed-liquor in order to perform mixing or/and denitrification.

5.2.6 Circulation of settled sludge

All pumping of sludge from any clarifiers or membrane separation processes that are included in the scope of this document.

5.2.7 Other pumping

For example, trickling filters recirculation.

5.2.8 Air driven pumping and/or mixing

Air driven pumping and/or mixing of any of the above components, by means such as airlifts, is included in aeration i.e. accounted for as part of aeration energy.

6 Factoring of different process conditions

6.1 General

The following adjustment formulas are based on the references indicated in [Annex A](#).

6.2 Temperature adjustments

NEC shall be reported at the temperature of the design or measurement used for its calculation.

For the comparison of aerobic processes, where aeration is the foremost energy consumption, NEC should be corrected to any other temperature using the following common oxygen transfer temperature correction formula:

$$NEC_{T_2} = NEC_{T_1} \cdot 1,024^{(T_2 - T_1)} \quad (4)$$

where T_1 is the design or measured water temperature and T_2 is the corrected temperature, all in °C.

NOTE The temperature correction is applied to the entire NEC rather than just the aeration part for the sake of simplicity and because most of the energy is consumed for aeration.

Example calculation to [Formula \(4\)](#) is shown in [Table B.2](#).

6.3 Barometric pressure adjustment

NEC shall be corrected to 1,0 atm (760 mmHg) by using the following common oxygen transfer pressure correction formula:

$$NEC_{1atm} = NEC_P \cdot \frac{P}{P_0} \quad (5)$$

where P is the design or measurement barometric pressure at the site, atm.

Example calculation to [Formula \(5\)](#) is shown in [Table B.2](#).

6.4 Type of wastewater

Accounting for different wastewater sources shall be by disclosing the type of wastewater treated by the system. For example, a NEC result for food and beverage wastewater. For the classification, ISO 22447 should be used.

Annex A (informative)

References to formulae and calculations

A.1 Calculations of VSS concentration in the sludge in [4.1.3](#) are taken from:

Metcalf and Eddy (2014) Wastewater Engineering: Treatment and Resource Recovery, 5th Edition, McGraw-Hill, New York, pp. 720-722

Takács, I., and P. A. Vanrolleghem, "Elemental balances in activated sludge modelling" Proceedings of IWA World Water Congress

A.2 Calculations of COD and TKN content of VSS in [4.1.3](#) are taken from:

Metcalf & Eddy (2014) Wastewater Engineering: Treatment and Resource Recovery, 5th Edition, McGraw-Hill, New York, p. 587

Takács, I., and P. A. Vanrolleghem, "Elemental balances in activated sludge modelling" Proceedings of IWA World Water Congress

A.3 Calculations of nitrification and denitrification oxygen and organic substrate requirements in section [4.1.3](#) are taken from:

Metcalf and Eddy (2014) Wastewater Engineering: Treatment and Resource Recovery, 5th Edition, McGraw-Hill, New York, pp. 622-623, 635-638

A.4 Calculations of temperature adjustment factoring for [Clause 6](#) are taken from:

Metcalf and Eddy (2014) Wastewater Engineering: Treatment and Resource Recovery, 5th Edition, McGraw-Hill, New York, p. 422

A.5 Calculations of barometric pressure factoring for [Clause 6](#) are taken from:

Metcalf and Eddy (2014) Wastewater Engineering: Treatment and Resource Recovery, 5th Edition, McGraw-Hill, New York, p. 420

Annex B (informative)

Example calculations

Table B.1 — Numerical example for NEC calculation from measured plant data, including factoring for temperature and pressure

No.	Parameter	Value	Units	Source
Flows				
1	Q_{influent}	52,5	m ³ /d	daily totalizer reading, average 5 days
2	Q_{sludge}	1,3	m ³ /d	daily totalizer reading, average 5 days
3	Q_{effluent}	51,2	m ³ /d	calculation $Q_{\text{influent}} - Q_{\text{sludge}}$
COD concentrations				
4	$C_{\text{influent, COD}}$	480	mg/l	Average of 5 daily analyses
5	$C_{\text{effluent, COD}}$	25	mg/l	Average of 5 daily analyses
6	$C_{\text{sludge, VSS}}$	7,450	mg/l	Average of 5 daily analyses
7	$C_{\text{sludge, COD}}$	10,590	mg/l	Calculated as $1,42 \cdot C_{\text{sludge, VSS}}$
TKN concentrations				
9	$C_{\text{influent, TKN}}$	58	mg/l	Average of 5 daily analyses
10	$C_{\text{effluent, TKN}}$	7,0	mg/l	Average of 5 daily analyses
11	$C_{\text{sludge, TKN}}$	632	mg/l	Average of 5 daily analyses
NO ₃ -N concentrations				
12	$C_{\text{influent, NO}_3\text{-N}}$	1,0	mg/l	Average of 5 daily analyses
13	$C_{\text{effluent, NO}_3\text{-N}}$	2,0	mg/l	Average of 5 daily analyses
14	$C_{\text{sludge, NO}_3\text{-N}}$	2,0	mg/l	Assumed same as effluent
DO concentrations				
15	$C_{\text{influent, DO}}$	0,0	mg/l	Assume zero
16	$C_{\text{effluent, DO}}$	1,5	mg/l	Online DO probe, average
17	$C_{\text{sludge, DO}}$	0,0	mg/l	Assume zero
Power				
18	P	0,6	kW	calculated from dedicated electricity counter over 5 days
Conditions				
19	Temperature	23	°C	online sensor 5 days average
20	Barometric pressure	1,015	atm	online sensor 5 days average
21	LR COD	10,2	kg/d	from Formula (1)
22	LR TKN	1,86	kg/d	from Formula (1)
23	LR NO ₃ -N	-0,05	kg/d	from Formula (1)
24	LR DO	-0,08	kg/d	from Formula (1)

Table B.1 (continued)

No.	Parameter	Value	Units	Source
25	NOR	13,6	kg/d	from Formula (2)
26	NEC T,P	1,06	kWh/kg NOR	at 23 °C and 1,015 atm, Formula (3)
27	NEC	0,97	kWh/kg NOR	corrected to standard conditions [Formulae (4) and (5)]

Table B.2 — Numerical Example for NEC calculation from design data, including factoring for temperature and pressure

	Parameter	Value	Units	Source
1	Design Flow			
2	Q_{influent}	60	m ³ /d	Design data
3	Q_{sludge}	1,3	m ³ /d	Calculated from mass balance
4	Q_{effluent}	58,7	m ³ /d	Calculated from mass balance
5	COD concentrations			
6	$C_{\text{influent, COD}}$	500	mg/l	Design data
7	$C_{\text{effluent, COD}}$	25	mg/l	Calculated from effluent requirements
8	$C_{\text{sludge, COD}}$	11 000	mg/l	Calculated from VSS as shown in Table B.3
9	TKN concentrations			
10	$C_{\text{influent, TKN}}$	58	mg/l	Design data
11	$C_{\text{effluent, TKN}}$	7,0	mg/l	Calculated from effluent requirements
	$C_{\text{sludge, TKN}}$	632	mg/l	Calculated from mass balance
12	NO ₃ -N concentrations			
13	$C_{\text{influent, NO}_3\text{-N}}$	0,0	mg/l	Assume zero
14	$C_{\text{effluent, NO}_3\text{-N}}$	2,0	mg/l	Effluent requirements
	$C_{\text{sludge, NO}_3\text{-N}}$	2,0	mg/l	Assumed same as effluent
15	DO concentrations			
16	$C_{\text{influent, DO}}$	0,0	mg/l	Assume zero
17	$C_{\text{effluent, DO}}$	1,5	mg/l	Design last treatment stage conditions
	$C_{\text{sludge, DO}}$	0,0	mg/l	Assume zero
18	Power			
	Aeration blower	W	1 350	from blower selection at working point
19	Mechanical agitator	W	100	mixer selection
20	Clarifier raking system	W	250	rake motor duty
21	Internal circulation pump	W	150	wall pump selection at working point
22	Sludge circulation pump	W	300	progressive cavity pump selection at working point
23	Total	kW	2,15	
24	Conditions			
25	Temperature	°C	23	design temperature
26	Barometric pressure	atm	1,015	average for site elevation of 150 meter
27	LR COD	14,2	kg/d	from Formula (1)
28	LR TKN	2,25	kg/d	from Formula (1)
29	LR NO ₃ -N	-0,12	kg/d	from Formula (1)