
Gas turbines — Procurement —
Part 2:
Standard reference conditions and
ratings

Turbines à gaz — Spécifications pour l'acquisition —
Partie 2: Conditions normales de référence et caractéristiques

STANDARDSISO.COM : Click to view the full PDF of ISO 3977-2:2023



STANDARDSISO.COM : Click to view the full PDF of ISO 3977-2:2023



COPYRIGHT PROTECTED DOCUMENT

© ISO 2023

All rights reserved. Unless otherwise specified, or required in the context of its implementation, no part of this publication may be reproduced or utilized otherwise in any form or by any means, electronic or mechanical, including photocopying, or posting on the internet or an intranet, without prior written permission. Permission can be requested from either ISO at the address below or ISO's member body in the country of the requester.

ISO copyright office
CP 401 • Ch. de Blandonnet 8
CH-1214 Vernier, Geneva
Phone: +41 22 749 01 11
Email: copyright@iso.org
Website: www.iso.org

Published in Switzerland

Contents

Page

Foreword	iv
Introduction	v
1 Scope	1
2 Normative references	1
3 Terms and definitions	1
4 Standard reference conditions	1
4.1 General.....	1
4.2 Air intake conditions.....	1
4.3 Exhaust conditions.....	1
4.4 Cooling water conditions (if applicable).....	2
4.5 Working fluid heater or cooler.....	2
5 Ratings	2
5.1 General.....	2
5.1.1 Output power.....	2
5.1.2 Performance ratings.....	2
5.1.3 Fuel.....	2
5.2 Power ratings.....	2
5.3 ISO standard ratings.....	3
5.4 Site ratings.....	3

Foreword

ISO (the International Organization for Standardization) is a worldwide federation of national standards bodies (ISO member bodies). The work of preparing International Standards is normally carried out through ISO technical committees. Each member body interested in a subject for which a technical committee has been established has the right to be represented on that committee. International organizations, governmental and non-governmental, in liaison with ISO, also take part in the work. ISO collaborates closely with the International Electrotechnical Commission (IEC) on all matters of electrotechnical standardization.

The procedures used to develop this document and those intended for its further maintenance are described in the ISO/IEC Directives, Part 1. In particular, the different approval criteria needed for the different types of ISO documents should be noted. This document was drafted in accordance with the editorial rules of the ISO/IEC Directives, Part 2 (see www.iso.org/directives).

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. ISO shall not be held responsible for identifying any or all such patent rights. Details of any patent rights identified during the development of the document will be in the Introduction and/or on the ISO list of patent declarations received (see www.iso.org/patents).

Any trade name used in this document is information given for the convenience of users and does not constitute an endorsement.

For an explanation of the voluntary nature of standards, the meaning of ISO specific terms and expressions related to conformity assessment, as well as information about ISO's adherence to the World Trade Organization (WTO) principles in the Technical Barriers to Trade (TBT), see www.iso.org/iso/foreword.html.

This document was prepared by Technical Committee ISO/TC 192, *Gas turbines*.

This second edition cancels and replaces the first edition (ISO 3977-2:1997), which has been technically revised.

The main changes are as follows:

- revisions to text (clarifications).

A list of all parts in the ISO 3977 series can be found on the ISO website.

Any feedback or questions on this document should be directed to the user's national standards body. A complete listing of these bodies can be found at www.iso.org/members.html.

Introduction

This is a procurement International Standard developed for gas turbines reference conditions and ratings.

STANDARDSISO.COM : Click to view the full PDF of ISO 3977-2:2023

STANDARDSISO.COM : Click to view the full PDF of ISO 3977-2:2023

Gas turbines — Procurement —

Part 2: Standard reference conditions and ratings

1 Scope

This document specifies the standard reference conditions and ISO standard ratings for gas turbines.

2 Normative references

The following documents are referred to in the text in such a way that some or all of their content constitutes requirements of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

ISO 2314:2009, *Gas turbines — Acceptance tests*

3 Terms and definitions

No terms and definitions are listed in this document.

ISO and IEC maintain terminological databases for use in standardization at the following addresses:

- ISO Online browsing platform: available at <https://www.iso.org/obp>
- IEC Electropedia: available at <https://www.electropedia.org/>

4 Standard reference conditions

4.1 General

The standard reference conditions on ISO power, efficiency, heat rate and specific fuel consumption are as specified in 4.2 to 4.5.

The conditions shall be as described in ISO 2314:2009, 3.9.

4.2 Air intake conditions

Air intake conditions shall be defined at the gas turbine compressor flange (alternatively, the compressor intake flare) with:

- a total pressure of 101,325 kPa;
- a total temperature of 15 °C;
- a relative humidity of 60 %.

4.3 Exhaust conditions

For the exhaust at the turbine exhaust flange (or regenerator outlet, if a regenerative cycle is used), the static pressure shall be 101,325 kPa.

4.4 Cooling water conditions (if applicable)

The inlet water temperature shall be 15 °C if cooling of the working fluid is used.

4.5 Working fluid heater or cooler

Where a heater or a cooler is used that uses ambient air, the standard reference conditions of the ambient air shall be 15 °C and 101,325 kPa.

5 Ratings

5.1 General

Output power, performance rating and fuel are defined as through [5.1.1](#) to [5.1.3](#).

5.1.1 Output power

The output power of a given gas turbine at a given reference turbine inlet temperature is, in general, proportional to the absolute ambient pressure and is also greatly dependent on the air intake temperature (normally outside dry bulb temperature). Likewise, the output at a given air intake temperature is dependent on the reference turbine inlet temperature as published value or alternatively the ISO 2314 turbine inlet temperature. To achieve a rating, it is necessary to adopt standard conditions of ambient temperature and pressure, but gas turbine ratings will nevertheless vary considerably owing to the differing operational modes demanded of them as well as the varying criteria used in the design of the basic elements. ISO standard ratings neglect pressure drop at the inlet and exhaust, but site ratings allow for these losses.

NOTE Steam or water injection can be used to increase the power output and to reduce the NO_x emissions.

5.1.2 Performance ratings

The performance ratings of gas turbines shall be assessed on the net specific energy, or lower heating value (LHV), of the fuel used, as follows:

- a) turbines intended for use on liquid fuel: 42 000 kJ/kg;
- b) turbines intended for use on gaseous fuel (100 % methane): 50 033 kJ/kg;
- c) turbine intended for use on hydrogen (100 % H₂): 119 907,4 kJ/kg;
- d) any site specific fuel agreed with the manufacturer.

The specific energy at constant pressure of the fuel, whether liquid, gaseous or solid, is based on a pressure of 101,325 kPa and a temperature of 15 °C.

5.1.3 Fuel

If the fuel to be used for testing the gas turbine is different from that agreed between the purchaser and the manufacturer for service operation, a test fuel of a mutually agreed specification shall be used.

5.2 Power ratings

Net power rating shall be defined taking into consideration the life requirements of the turbine and all operational conditions affecting this life.

NOTE 1 A higher power can be achieved if life is reduced, generally. It is important that the operational conditions (which can be described as “peak”, “baseload”, max. number of starts, etc.) are understood to allow the life to be stated adequately.