

First edition
2014-04-15

AMENDMENT 1
2015-10-01

**Refrigerating systems and heat
pumps — Safety and environmental
requirements —**

**Part 1:
Definitions, classification and
selection criteria**

**AMENDMENT 1: Correction of QLAV,
QLMV**

*Systèmes frigorifiques et pompes à chaleur — Exigences de sécurité et
d'environnement —*

Partie 1: Définitions, classification et critères de choix

AMENDEMENT 1: Correction de QLAV, QLMV



Reference number
ISO 5149-1:2014/Amd.1:2015(E)

© ISO 2015



COPYRIGHT PROTECTED DOCUMENT

© ISO 2015, Published in Switzerland

All rights reserved. Unless otherwise specified, no part of this publication may be reproduced or utilized otherwise in any form or by any means, electronic or mechanical, including photocopying, or posting on the internet or an intranet, without prior written permission. Permission can be requested from either ISO at the address below or ISO's member body in the country of the requester.

ISO copyright office
Ch. de Blandonnet 8 • CP 401
CH-1214 Vernier, Geneva, Switzerland
Tel. +41 22 749 01 11
Fax +41 22 749 09 47
copyright@iso.org
www.iso.org

Foreword

ISO (the International Organization for Standardization) is a worldwide federation of national standards bodies (ISO member bodies). The work of preparing International Standards is normally carried out through ISO technical committees. Each member body interested in a subject for which a technical committee has been established has the right to be represented on that committee. International organizations, governmental and non-governmental, in liaison with ISO, also take part in the work. ISO collaborates closely with the International Electrotechnical Commission (IEC) on all matters of electrotechnical standardization.

The procedures used to develop this document and those intended for its further maintenance are described in the ISO/IEC Directives, Part 1. In particular the different approval criteria needed for the different types of ISO documents should be noted. This document was drafted in accordance with the editorial rules of the ISO/IEC Directives, Part 2 (see www.iso.org/directives).

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. ISO shall not be held responsible for identifying any or all such patent rights. Details of any patent rights identified during the development of the document will be in the Introduction and/or on the ISO list of patent declarations received (see www.iso.org/patents).

Any trade name used in this document is information given for the convenience of users and does not constitute an endorsement.

For an explanation on the meaning of ISO specific terms and expressions related to conformity assessment, as well as information about ISO's adherence to the WTO principles in the Technical Barriers to Trade (TBT) see the following URL: [Foreword - Supplementary information](#)

The committee responsible for this document is ISO/TC 86, *Refrigeration and air-conditioning*, Subcommittee SC 1, *Safety and environmental requirements for refrigerating systems*.

STANDARDSISO.COM : Click to view the full PDF of ISO 5149-1:2014/Amd 1:2015

Refrigerating systems and heat pumps — Safety and environmental requirements —

Part 1:

Definitions, classification and selection criteria

AMENDMENT 1: Correction of QLAV, QLMV

Page 11, 3.10.3 and 3.10.4

Replace definitions 3.10.3 and 3.10.4 with the following:

3.10.3

quantity limit with additional ventilation

charge density of refrigerant that when exceeded creates an instantaneous dangerous situation, if the total charge leaked within the occupied space

Note 1 to entry See A.5 for the use of Quantity Limit with Additional Ventilation (QLAV) to manage risk for systems in occupied spaces where the level of ventilation is sufficient to disperse the leaked refrigerant within 15 min.

3.10.4

quantity limit with minimum ventilation

charge density of refrigerant that results in a concentration equal to the RCL in a room of non-airtight construction with a moderately severe refrigerant leak

Note 1 to entry See A.5 for the use of Quantity Limit with Minimum Ventilation (QLMV) to manage risk for systems in occupied spaces not below ground level where the level of ventilation is not sufficient to disperse the leaked refrigerant within 15 min. The calculation is based on an opening of 0,003 2 m² and a leak rate of 2,78 g s⁻¹.

Page 27, A.5.2.1

Replace the entire subclause with the following:

A.5.2.1 General

For occupied spaces exceeding 250 m², the charge limits calculation shall use 250 m² as the room floor area for determination of the room volume.

The total charge of the system divided by the room volume shall not exceed the QLMV value specified in [Table A.3](#) (or if the lowest floor is underground, the RCL value in [Table A.3](#)) unless appropriate measures are taken. If the value exceeds the QLMV or RCL, appropriate measures shall be taken in accordance with A.5.2.2 or A.5.2.3. The appropriate measure shall be ventilation (natural or mechanical), safety shut-off valves and safety alarm, in conjunction with a gas detection device. See ISO 5149-3:2014, Clauses 6, 8, 9 and 10. A safety alarm alone shall not be considered as an appropriate measure where occupants are restricted in their movement (see ISO 5149-3:2014, 8.1).

NOTE 1 For systems that are installed and operated within the constraints of A.5.1 the risk of rapid release of refrigerant through a major leak has been minimized. The calculation of ventilation rate in Annex A has therefore been based on a maximum leakage rate of 10 kg/h.

NOTE 2 QLMV is based on a room height of 2,2 m and an opening of 0,003 2 m² (0,8 m width door and 4 mm gap) that can be expected in rooms without designed ventilation.

Table A.3 — Allowable refrigerant charge density

Refrigerant	Allowable concentration (kg m ⁻³) RCL	QLMV (kg m ⁻³)	QLAV (kg m ⁻³)
R22	0,21	0,28	0,50 ^a
R134a	0,21	0,28	0,58 ^a
R407C	0,27	0,44	0,49 ^a
R410A	0,39	0,42	0,42 ^a
R744	0,072	0,074	0,18 ^b
R32	0,061	0,063	0,15 ^c
R1234yf	0,058	0,060	0,14 ^c
R1234ze	0,061	0,063	0,15 ^c
^a Based on ODL			
^b Based on 10 % v/v			
^c Based on 50 % LFL			

For refrigerants not listed in [Table A.3](#), QLAV shall be the lower of:

- For R-744 10 %v/v (due to acute anaesthetic effect);
- ODL;
- 50 % of LFL for class 2L refrigerants.

For refrigerants not listed in [Table A.3](#), Formula (A.6) shall be used for the calculation of QLMV:

$$QLMV = s \Big|_{x=RCL} \times \dot{m} \quad (A.6)$$

where $s \Big|_{x=RCL}$ is the point in normalized time s , when the concentration $x = RCL$, and is found by solving

$$\frac{dx}{ds} = \dot{m} - x \times A \times c \times \sqrt{2 \times \left(1 - \frac{\rho_a}{\rho}\right)} \times h \times g$$

where

x is the refrigerant concentration in the room (kg m⁻³);

s is the time since the leak started divided by the room volume (s m⁻³);

$\dot{m}$ is the leak rate from refrigerating system (0,002 78 kg s⁻¹);

A is the opening area (m²) to give the minimum ventilation rate typical of rooms without designed ventilation, 0,004 m × 0,8 m = 0,003 2 m²;

c is the flow coefficient equal to 1;

ρ is the density of refrigerant air mixture (kg m⁻³); where $\rho = x + \rho_a - x \frac{\rho_a}{\rho_r}$

ρ_a is the air density (kg m⁻³) (calculated based on molar mass of air = 29 and ISO 817);