

INTERNATIONAL STANDARD

**ISO
6874**

Second edition
2005-08-15

Dentistry — Polymer-based pit and fissure sealants

*Art dentaire — Produits dentaires à base de polymères pour
comblement des puits et fissures*

STANDARDSISO.COM : Click to view the full PDF of ISO 6874:2005



Reference number
ISO 6874:2005(E)

© ISO 2005

PDF disclaimer

This PDF file may contain embedded typefaces. In accordance with Adobe's licensing policy, this file may be printed or viewed but shall not be edited unless the typefaces which are embedded are licensed to and installed on the computer performing the editing. In downloading this file, parties accept therein the responsibility of not infringing Adobe's licensing policy. The ISO Central Secretariat accepts no liability in this area.

Adobe is a trademark of Adobe Systems Incorporated.

Details of the software products used to create this PDF file can be found in the General Info relative to the file; the PDF-creation parameters were optimized for printing. Every care has been taken to ensure that the file is suitable for use by ISO member bodies. In the unlikely event that a problem relating to it is found, please inform the Central Secretariat at the address given below.

STANDARDSISO.COM : Click to view the full PDF of ISO 6874:2005

© ISO 2005

All rights reserved. Unless otherwise specified, no part of this publication may be reproduced or utilized in any form or by any means, electronic or mechanical, including photocopying and microfilm, without permission in writing from either ISO at the address below or ISO's member body in the country of the requester.

ISO copyright office
Case postale 56 • CH-1211 Geneva 20
Tel. + 41 22 749 01 11
Fax + 41 22 749 09 47
E-mail copyright@iso.org
Web www.iso.org

Published in Switzerland

Foreword

ISO (the International Organization for Standardization) is a worldwide federation of national standards bodies (ISO member bodies). The work of preparing International Standards is normally carried out through ISO technical committees. Each member body interested in a subject for which a technical committee has been established has the right to be represented on that committee. International organizations, governmental and non-governmental, in liaison with ISO, also take part in the work. ISO collaborates closely with the International Electrotechnical Commission (IEC) on all matters of electrotechnical standardization.

International Standards are drafted in accordance with the rules given in the ISO/IEC Directives, Part 2.

The main task of technical committees is to prepare International Standards. Draft International Standards adopted by the technical committees are circulated to the member bodies for voting. Publication as an International Standard requires approval by at least 75 % of the member bodies casting a vote.

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. ISO shall not be held responsible for identifying any or all such patent rights.

ISO 6874 was prepared by Technical Committee ISO/TC 106, *Dentistry*, Subcommittee SC 1, *Filling and restorative materials*.

This second edition cancels and replaces the first edition (ISO 6874:1988), and in comparison with the first edition the classification and the test for depth of cure have been aligned with ISO 4049:2000. It is intended to include sealant materials within the scope of ISO 4049 at its the next revision. The requirements and tests for uncured film thickness, sensitivity to ambient light and curing time for Type 2 sealants have been deleted from this edition of ISO 6874.

Introduction

The efficacy of pit and fissure sealants for the prevention of dental caries is widely accepted. The polymer-based materials intended for this purpose and covered by this International Standard harden by a free-radical polymerization reaction that is either initiated by mixing components or by external energy, e.g. visible light.

Specific qualitative and quantitative requirements for freedom from biological hazard are not included in this International Standard. However, when assessing possible biological or toxicological hazards, it is recommended to refer to ISO 10993-1 and ISO 7405.

STANDARDSISO.COM : Click to view the full PDF of ISO 6874:2005

Dentistry — Polymer-based pit and fissure sealants

1 Scope

This International Standard specifies requirements and test methods for polymer-based materials intended for sealing pits and fissures in teeth.

This International Standard covers both self-cured and external-energy-activated materials.

2 Normative references

The following referenced documents are indispensable for the application of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

ISO 8601, *Data elements and interchange formats — Information interchange — Representation of dates and times*

3 Classification

For the purposes of this International Standard, polymer-based pit and fissure sealants are classified, according to the method of curing, as follows.

- **Class 1:** Materials whose setting is effected by mixing an initiator and activator (“self-curing” materials).
- **Class 2:** Materials whose setting is effected by the application of energy from an external source, such as visible light (“external-energy-activated” materials).

4 Requirements

4.1 Biocompatibility

See ISO 7405 and ISO 10993-1 for guidance on biocompatibility.

4.2 Physical properties

4.2.1 Working time, Class 1 sealant

The working time for Class 1 sealants, determined in accordance with 6.4, shall not be less than 40 s.

4.2.2 Setting time, Class 1 sealant

The setting time for Class 1 sealants, determined in accordance with 6.5, shall not be greater than 5 min.

4.2.3 Depth of cure, Class 2 sealant

The depth of cure for Class 2 sealants, determined in accordance with 6.6, shall not be less than 1,5 mm. If the material is supplied in more than one shade, each shade shall comply with this requirement.

5 Sampling

The test sample shall consist of a retail package, or packages, from the same batch containing sufficient material (a minimum of 20 g) to carry out the specified tests and repeat tests, if necessary.

6 Test methods

6.1 Inspection

Inspect visually to check that requirements specified in Clause 7 have been met.

6.2 Test conditions

Unless specified otherwise by the manufacturer, prepare and test all specimens at $(23 \pm 1) ^\circ\text{C}$. Control the relative humidity to ensure that it remains greater than 30 % at all times. If the material was refrigerated for storage, allow it to attain $(23 \pm 1) ^\circ\text{C}$ before use.

For the preparation of Class 2 materials, reference should be made to the manufacturer's instructions [see 7.3 e) and h)] that state the external energy source or sources recommended for the materials to be tested. Care shall be taken to ensure that the source is in a satisfactory operating condition.

Reference may also be made to ISO 10650 (all parts).

6.3 Preparation of test specimens

Mix or otherwise prepare the material in accordance with the manufacturer's instructions and the test conditions specified in 6.2.

6.4 Working time, Class 1 sealant

6.4.1 Apparatus


6.4.1.1 Thermometry apparatus, as shown in Figure 1, consisting of a piece of polyethylene (or similar material) tubing (1), located on a block of polyamide or similar material (2), which has a hole into which is inserted a stainless steel tube (3), containing a stabilized thermocouple (4).

The polyethylene tube (1) is 6 mm long, 4 mm in internal diameter and has a wall thickness of 1 mm. The locating part of block (2) is 4 mm in diameter and 2 mm high. When assembled the two components form a specimen well 4 mm high $\times$ 4 mm in diameter. In order to facilitate removal of the specimen after testing, the thermocouple (4) has a conical tip consisting of silver soldering (5) that protrudes 1 mm into the base of the specimen well. The tolerances on the above-mentioned dimensions are $\pm 0,1$ mm.

The thermocouple consists of wires $(0,25 \pm 0,05)$ mm in diameter, made of a material (e.g. copper/constantan) capable of registering rapid temperature changes in a specimen of setting material to an accuracy of $0,1 ^\circ\text{C}$. The thermocouple is connected to an instrument (e.g. voltmeter or chart recorder) capable of recording the temperature to that accuracy.

A prefabricated thermocouple of similar size and performance may be substituted.

Dimensions in millimetres



Key

- 1 polyethylene tubing
- 2 polyamide block
- 3 stainless steel tube
- 4 thermocouple
- 5 silver soldering

Figure 1 — Apparatus for determination of working and setting times


6.4.2 Procedure

Prepare the sealant in accordance with the manufacturer's instructions (see 7.3) and start timing from the moment mixing is begun. Maintain the mould at $(23 \pm 1) ^\circ\text{C}$. Thirty seconds after the start of mixing, place the mixed sealant in the mould and record the temperature, T_0 , of the sealant. Maintain the apparatus at $(23 \pm 1) ^\circ\text{C}$ and continuously record the temperature of the sealant until the peak temperature is reached.

A typical recording trace is shown in Figure 2. As soon as the sealant is inserted into the mould, the temperature may fall slightly until it becomes steady at T_1 and then starts to increase. The point at which the temperature begins to increase denotes the start of the setting reaction and, therefore, the end of the working time. The results are extremely temperature-dependent and slight variations within the permitted temperature range will cause variations of several seconds.

Record the working time, t_w , from the start of mixing until the temperature starts to increase.

Carry out five determinations.



Key

- X time, in seconds
- Y temperature
- T_0 temperature at time of insertion
- T_1 temperature after a slight drop immediately after time of insertion
- T_2 peak temperature
- t_w time of insertion to the start of the setting reaction at T_1 , denoted as the working time
- t_s time of insertion to the time of the peak temperature, denoted as the setting time

Figure 2 — Typical recording trace showing temperature changes in time for determination of working and setting times

6.4.3 Treatment of results

Record the working times and report the following.

- a) If at least four of the times obtained are equal to or longer than 40 s, the material is deemed to have complied with the requirement specified in 4.2.1.
- b) If three or more of the times are shorter than 40 s, the material is deemed to have failed.
- c) If only three of the times are equal to or longer than 40 s, repeat the whole test. All the specimens in the second series shall comply with the requirement, otherwise the material is deemed to have failed the whole test.

6.5 Setting time, Class 1 sealant

6.5.1 Apparatus

6.5.1.1 Thermometry apparatus, as specified in 6.4.1.1.

6.5.2 Procedure

Repeat the procedure described in 6.4.2, but maintain the apparatus at $(37 \pm 1) ^\circ\text{C}$ in air.

Record the time elapsed between the start of mixing and the peak temperature, T_2 , as the setting time, t_s .

Carry out five determinations.

6.5.3 Treatment of results

Record the setting times and report the following.

- a) If at least four of the times obtained are equal to or shorter than 5 min, the material is deemed to have complied with the requirement specified in 4.2.2.
- b) If three or more of the times are longer than 5 min, the material is deemed to have failed.
- c) If only three of the times are equal to or shorter than 5 min, repeat the whole test. All the specimens in the second series shall comply with the requirement, otherwise the material is deemed to have failed the whole test.

6.6 Depth of cure, Class 2 sealant

6.6.1 Apparatus

6.6.1.1 Stainless steel mould, for the preparation of a cylindrical specimen, 6 mm long and 4 mm in diameter.

A mould release agent that does not interfere with the setting reaction, for example a 3 % solution of polyvinyl ether wax in hexane, may be used to facilitate removal of the specimen.

6.6.1.2 Two glass slides/plates, each of sufficient area to cover one side of the mould.

A standard glass microscope slides may be used.

6.6.1.3 White filter paper.

6.6.1.4 Film, transparent to the activating radiation, $(50 \pm 30) \mu\text{m}$ thick, e.g. polyester.

6.6.1.5 External energy source, as recommended by the manufacturer for use with the test material [see 7.3 e)].

6.6.1.6 Micrometer, accurate to 0,01 mm.

6.6.1.7 Plastics spatula.

6.6.2 Procedure

Place the mould (6.6.1.1) onto a strip of the transparent film (6.6.1.4) on one of the glass slides (6.6.1.2). Fill the mould with the test material, prepared in accordance with the manufacturer's instructions, taking care to exclude air bubbles. Slightly overfill the mould and place a second strip of the transparent film on top followed by the second microscope slide. Press the mould and strips of film between the glass slides (6.6.1.2) to displace excess material. Place the mould onto the filter paper (6.6.1.3), remove the microscope slide covering the upper strip of film and gently place the exit window of the external energy source (6.6.1.5) against the strip of film. Irradiate the material for the time recommended by the manufacturer to achieve a depth of cure of at least 1,5 mm.

Immediately after completion of irradiation, remove the specimen from the mould and remove the uncured material with the plastics spatula (6.6.1.7). Measure the height of the cylinder of cured material with the micrometer (6.6.1.6) to an accuracy of 0,1 mm.

Record this value as the depth of cure.

Carry out three determinations.

6.6.3 Treatment of results

If all three values are greater than 1,5 mm, the material has complied with the requirement of 4.2.3. If one or more values is less than 1,5 mm, the material has failed the requirement.

7 Packaging, marking and instructions and information to be supplied by the manufacturer

7.1 Packaging

The materials shall be supplied in containers or capsules (for the purposes of this International Standard, the container or capsule shall be considered to be the immediate wrapping of the material) that afford adequate protection and have no adverse effect on the quality of the contents.

An outer pack may also be used to present the containers or capsules as a single unit that provides protection for them.

Additional information may be included at the discretion of the manufacturer or as required by legislation.

7.2 Marking

7.2.1 Capsule or single dose container

If the material is supplied in different shades, then the capsule or single dose container shall be marked to indicate the shade of the contained material. The capsule or single dose container shall also be marked so that the product can be identified clearly. The capsules or single dose containers shall be presented as a single unit in an outer pack.

NOTE The single dose container is a small syringe containing no more than 0,5 ml of material.

7.2.2 Outer pack

The outer pack shall be marked with the following information:

- a) the trade- or brand-name of the material;
- b) the manufacturer's name and address and/or agent in country of sale;
- c) the Class of sealant (see Clause 3) and its application given in clear language.

In addition, the following information shall be clearly visible either on the outer pack or in the manufacturer's instructions (see 7.3) or both:

- d) the manufacturer's lot number;
- e) the expiry date, expressed in accordance with ISO 8601, for the material if stored under the manufacturer's recommended conditions [see 7.3 k)];
- f) recommended storage conditions [see 7.3 k)];
- g) the mass and/or volume or number of dose units, etc.

7.3 Manufacturer's instructions and information for the user

Instructions and information shall accompany each individual outer pack of components and shall include the following details:

- a) the principal component of the polymer base;
- b) special indications or warnings, when necessary;
- c) any pharmaceutically active ingredients, when present and referred to, in the claim or use of the material;
- d) a description of the appearance of the components and the set sealant;
- e) the instructions for the pre-preparation of the sealant and information about those ambient conditions, such as temperature, humidity or light, that are likely to affect the sealant adversely;
- f) the instructions for manipulating the sealant;
- g) the working and setting times of the sealant, determined in accordance with Clause 6;
- h) the external energy source(s) suitable for curing Class 2 sealants and the irradiation time to be used;
- i) the detailed procedures for conditioning the tooth surfaces;
- j) any limitation on the time of use of the sealant after preparation, particularly stating the effects of ambient light on external energy cured materials;
- k) the recommended storage conditions (e.g. need for refrigeration) making reference to the expiry date [see 7.2.2 e)];
- l) any precautions for use and information on any adverse reactions that may be associated with the components or set sealant, particularly with regard to any uncured layer on the surface of the set sealant;
- m) a description of the shade or shades of the material.