
Medical gas pipeline systems —

Part 2:

**Anaesthetic gas scavenging disposal
systems**

Réseaux de distribution de gaz médicaux —

Partie 2: Réseaux d'évacuation de gaz d'anesthésie non réutilisables



PDF disclaimer

This PDF file may contain embedded typefaces. In accordance with Adobe's licensing policy, this file may be printed or viewed but shall not be edited unless the typefaces which are embedded are licensed to and installed on the computer performing the editing. In downloading this file, parties accept therein the responsibility of not infringing Adobe's licensing policy. The ISO Central Secretariat accepts no liability in this area.

Adobe is a trademark of Adobe Systems Incorporated.

Details of the software products used to create this PDF file can be found in the General Info relative to the file; the PDF-creation parameters were optimized for printing. Every care has been taken to ensure that the file is suitable for use by ISO member bodies. In the unlikely event that a problem relating to it is found, please inform the Central Secretariat at the address given below.

STANDARDSISO.COM : Click to view the full PDF of ISO 7396-2:2007



COPYRIGHT PROTECTED DOCUMENT

© ISO 2007

All rights reserved. Unless otherwise specified, no part of this publication may be reproduced or utilized in any form or by any means, electronic or mechanical, including photocopying and microfilm, without permission in writing from either ISO at the address below or ISO's member body in the country of the requester.

ISO copyright office
Case postale 56 • CH-1211 Geneva 20
Tel. + 41 22 749 01 11
Fax + 41 22 749 09 47
E-mail copyright@iso.org
Web www.iso.org

Published in Switzerland

Contents

Page

Foreword.....	iv
Introduction	v
1 Scope	1
2 Normative references	1
3 Terms and definitions.....	2
4 General requirements.....	6
4.1 Safety	6
4.2 Alternative construction	6
4.3 Materials	6
4.4 Continuity of operation	7
5 Power device	7
6 Indicating systems.....	8
7 Pipelines, connecting assemblies and disposal hoses.....	8
8 Disposal system characteristics and test methods for pressure and flow	9
8.1 Requirements	9
8.2 Test methods for pressure and flow.....	10
8.3 Means to prevent backflow.....	12
9 Terminal units	12
10 Marking and colour coding.....	12
10.1 Marking	12
10.2 Colour coding.....	13
10.3 Test for durability.....	13
11 Pipeline installation	13
12 Testing, commissioning and certification.....	15
12.1 General.....	15
12.2 General requirements for tests	15
12.3 Tests, inspections and checks.....	15
12.4 Requirements for tests, inspections and checks listed in 12.3	15
12.5 Certification of the system.....	16
12.6 Extensions or modifications.....	17
13 Information to be supplied by the manufacturer.....	17
13.1 General.....	17
13.2 Instructions for use	17
13.3 Operational management information.....	18
13.4 "As-installed" drawings	18
13.5 Electrical diagrams	18
Annex A (informative) Guidelines for power devices consisting of fans, blowers or dedicated vacuum pumps.....	19
Annex B (informative) Example of procedure for testing and commissioning.....	20
Annex C (informative) Typical forms for certification of AGS disposal systems	23
Annex D (informative) Risk management checklist.....	36
Annex E (informative) Rationale	44
Bibliography	45

Foreword

ISO (the International Organization for Standardization) is a worldwide federation of national standards bodies (ISO member bodies). The work of preparing International Standards is normally carried out through ISO technical committees. Each member body interested in a subject for which a technical committee has been established has the right to be represented on that committee. International organizations, governmental and non-governmental, in liaison with ISO, also take part in the work. ISO collaborates closely with the International Electrotechnical Commission (IEC) on all matters of electrotechnical standardization.

International Standards are drafted in accordance with the rules given in the ISO/IEC Directives, Part 2.

The main task of technical committees is to prepare International Standards. Draft International Standards adopted by the technical committees are circulated to the member bodies for voting. Publication as an International Standard requires approval by at least 75 % of the member bodies casting a vote.

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. ISO shall not be held responsible for identifying any or all such patent rights.

ISO 7396-2 was prepared by the European Committee for Standardization (CEN) Technical Committee CEN/TC 215, *Respiratory and anaesthetic equipment*, in collaboration with Technical Committee ISO/TC 121, *Anaesthetic and respiratory equipment*, Subcommittee SC 6, *Medical gas systems*, in accordance with the Agreement on technical cooperation between ISO and CEN (Vienna Agreement).

This second edition cancels and replaces the first edition (ISO 7396-2:2000), which has been technically revised.

ISO 7396 consists of the following parts, under the general title *Medical gas pipeline systems*:

- *Part 1: Pipeline systems for compressed medical gases and vacuum*
- *Part 2: Anaesthetic gas scavenging disposal systems*

Introduction

Anaesthetic gas scavenging systems (AGSS) are used to reduce occupational exposure to anaesthetic gases and vapours.

The anaesthetic gas scavenging system comprises three main parts:

- a transfer system,
- a receiving system, and
- a disposal system.

A schematic diagram of typical anaesthetic gas scavenging systems is shown in Figure 1. Requirements for receiving systems and transfer systems are specified in ISO 8835-3. Type-specific connections for terminal units are specified in ISO 9170-2. In this part of ISO 7396, specifications and test procedures are given to ensure compatibility between the components of the system.

This part of ISO 7396 specifies requirements for pipelines for anaesthetic gas scavenging systems for anaesthetic gases and vapours. It is intended for use by those persons involved in the design, construction, inspection and operation of healthcare facilities treating human beings. It is advisable that those persons involved in the design, manufacture and testing of equipment intended to be connected to pipeline systems also be aware of the contents of this part of ISO 7396.

Specific components are used for scavenging terminal units and for other connectors which are intended to be used by the operator. In addition, the system is tested and certified to operate at safe flows and without leakage. It is also intended to address issues of patient safety.

The objectives of this part of ISO 7396 are to ensure the following:

- a) avoidance of cross connections between different pipeline systems;
- b) continuity of function of the system;
- c) use of suitable materials;
- d) cleanliness of components;
- e) correct installation;
- f) provision of indicating system(s);
- g) correct marking of the pipeline system and components;
- h) testing, commissioning and certification;
- i) correct operational management.

Annex E contains rationale statements for some of the requirements of this part of ISO 7396. It is included to provide additional insight into the reasoning that led to the requirements and recommendations that have been incorporated in this part of ISO 7396. The clauses and subclauses marked with (*) after their number have corresponding rationale contained in Annex E.

STANDARDSISO.COM : Click to view the full PDF of ISO 7396-2:2007

Medical gas pipeline systems —

Part 2: Anaesthetic gas scavenging disposal systems

1 Scope

This part of ISO 7396 specifies requirements for the design, installation, function, performance, documentation, testing and commissioning of anaesthetic gas scavenging disposal systems to ensure patient safety and to minimize exposure of the operator and other persons to anaesthetic gases and vapours. It includes requirements for the power device, pipeline system, performance, non-interchangeability between key components and avoidance of cross connections between anaesthetic gas scavenging (AGS) disposal systems and medical gas and vacuum pipeline systems.

NOTE In this part of ISO 7396, the term “pipeline” refers exclusively to pipelines that are part of a dedicated anaesthetic gas scavenging system (AGSS).

This part of ISO 7396 is applicable only to those disposal systems intended to be connected via AGSS terminal units conforming to ISO 9170-2 and to AGSS receiving systems conforming to ISO 8835-3.

This part of ISO 7396 also applies to:

- extensions of existing AGSS disposal systems;
- modifications of existing AGSS disposal systems;
- modifications or replacement of power devices.

2 Normative references

The following referenced documents are indispensable for the application of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

ISO 5359, *Low-pressure hose assemblies for use with medical gases*

ISO 7396-1:2007, *Medical gas pipeline systems — Part 1: Pipeline systems for compressed medical gases and vacuum*

ISO 8835-3:—¹⁾, *Inhalational anaesthesia systems — Part 3: Transfer and receiving systems of active anaesthetic gas scavenging systems*

ISO 9170-2, *Terminal units for medical gas pipeline systems — Part 2: Terminal units for anaesthetic gas scavenging systems*

1) To be published. (Revision of ISO 8835-3:1997.)

ISO 14971, *Medical devices — Application of risk management to medical devices*

ISO 15001, *Anaesthetic and respiratory equipment — Compatibility with oxygen*

EN 1041, *Information supplied by the manufacturer with medical devices*

EN 13348, *Copper and copper alloys — Seamless, round copper tubes for medical gases or vacuum*

3 Terms and definitions

For the purposes of this document, the following terms and definitions apply.

3.1

AGSS socket

female part of a terminal unit which is either integral or attached to the base block by a type-specific interface, and which contains the type-specific connection point

3.2

AGSS terminal unit

inlet assembly in an AGSS at which the operator makes connections and disconnections

3.3

AGSS terminal unit base block

part of an AGSS terminal unit which is attached to the pipeline disposal system

3.4

AGSS type 1 terminal unit

connection point between the receiving system and the disposal system at which an operator makes connections and disconnections

See Figure 1.

3.5

AGSS type 1H terminal units

AGSS type 1 terminal unit to be used in high-flow disposal systems

3.6

AGSS type 1L terminal units

AGSS type 1 terminal unit to be used in low-flow disposal systems

3.7

AGSS type 2 terminal unit

connection point between the power device or the disposal hose and the remainder of the disposal system at which an operator makes connections and disconnections

See Figure 1.

3.8

AGSS type-specific

having characteristics which prevent interchangeability and thereby allow assignment to one AGSS type only

3.9

AGSS type-specific connection point

part of the AGSS socket which is the receptor for an AGSS type-specific probe

3.10**air compressor system**

source of supply with compressor(s) designed to provide medical air and/or air for driving surgical tools and/or air for AGSS

NOTE Different names or symbols are used for air for driving surgical tools, such as: instrument air, surgical air, air motor, air - 700 and air - 800.

3.11**anaesthetic gas scavenging system****AGSS**

complete system which is connected to the exhaust port(s) of a breathing system or other equipment for the purpose of conveying expired and/or excess anaesthetic gases and vapours to an appropriate point of discharge

NOTE Functionally, an AGSS comprises three different parts: a transfer system, a receiving system and a disposal system. These three functionally discrete parts can be either separate or sequentially combined in part or in total. In addition, one or more parts of an AGSS can be combined with a breathing system or other equipment (e.g. an anaesthetic ventilator) to include the transfer system, or transfer and receiving systems.

3.12**commissioning**

proof of function to verify that the agreed specification is met and is accepted by the user or his representative

3.13**disposal hose**

part of an AGSS which transfers expired and/or excess anaesthetic gases and vapours from the power device to the probe of an AGSS type 2 terminal unit

3.14**disposal system**

means by which the expired and/or excess anaesthetic gases and vapours are conveyed from the receiving system to an appropriate point of discharge

NOTE A point of discharge can be, for example, the exterior of a building or a non-recirculating extract ventilation system.

3.15**diversity factor**

factor which represents the maximum proportion of terminal units in a defined clinical area which will be used at the same time, at flow rates defined in agreement with the management of the healthcare facility

3.16**high-flow disposal system**

disposal system which is intended to operate with a high-flow transfer and receiving system complying with ISO 8835-3

3.17**high-flow transfer and receiving system**

transfer and receiving system complying with ISO 8835-3 which connects through an AGSS type 1H terminal unit as specified in ISO 9170-2 to a high-flow disposal system complying with this part of ISO 7396

3.18**low-flow disposal system**

disposal system which is intended to operate with a low-flow transfer and receiving system complying with ISO 8835-3

3.19**low-flow transfer and receiving system**

transfer and receiving system complying with ISO 8835-3 which connects through an AGSS type 1L terminal unit as specified in ISO 9170-2 to a low-flow disposal system complying with this part of ISO 7396

3.20

manufacturer

natural or legal person with responsibility for the design, manufacture, packaging and labelling of a device before it is placed on the market under his own name, regardless of whether these operations are carried out by that person himself or on his behalf by a third party

3.21

maximum operating pressure

maximum pressure at which a terminal unit is designed to operate

NOTE Operating pressure for a type 1 terminal unit is negative and for a type 2 terminal unit it is positive.

3.22

maximum test pressure

maximum pressure to which a terminal unit is designed to be subjected during pipeline pressure testing

3.23

non-return valve

valve which permits flow in one direction only

3.24

power device

part of an AGS disposal system that provides flow and pressure for scavenging

3.25

probe

non-interchangeable male component designed for acceptance by, and retention in, a socket

3.26

quick connector

pair of type-specific components which can be easily and rapidly joined together by a single action of one or both hands without the use of tools

3.27

receiving hose

part of an AGSS which transfers expired and/or excess anaesthetic gases and vapours from the receiving system to the disposal system

3.28

receiving system

part of an AGSS which provides an interface between the transfer system and the disposal system

3.29

shut-off valve


valve which prevents flow in both directions when closed

3.30

single fault condition

condition in which a single means for protection against a safety hazard in equipment is defective or a single external abnormal condition is present

NOTE Maintenance of equipment is considered a normal condition.



Key

- | | | | |
|----|--|----|---|
| 1 | apparatus such as anaesthetic breathing system or anaesthetic ventilator and integral transfer/receiving system and power device | 11 | permanent connection |
| 2 | apparatus such as anaesthetic breathing system or anaesthetic ventilator | 12 | point of discharge |
| 3 | transfer/receiving system and power device | 13 | flexible hose or pendant |
| 4 | apparatus such as anaesthetic breathing system and integral transfer/receiving system | 14 | disposal hose |
| 5 | permanent or proprietary connector | 15 | limit of breathing system or anaesthetic ventilator |
| 6 | receiving hose | 16 | limits of transfer system |
| 7 | breathing system or anaesthetic ventilator | 17 | limits of receiving system |
| 8 | transfer tube | 18 | limit of disposal system |
| 9 | receiving system | 19 | proprietary connection (functionally specific) |
| 10 | power device | 20 | 30 mm conical connection |
| | | 21 | type 1 terminal unit probe/socket |
| | | 22 | type 2 terminal unit probe/socket |

NOTE 1 Type 1 terminal unit probe/socket is for negative pressure. Type 2 terminal unit probe/socket is for positive pressure.

NOTE 2 The limit between the receiving system and the disposal system as shown does not necessarily coincide with an actual physical limit such as a wall. In the arrangement shown, a terminal unit on a wall would be located on the inlet to the power device.

Figure 1 — Schematic diagram of typical AGSS connections

3.31

system design flow

flow calculated from the maximum flow requirement of the healthcare facility and corrected by the diversity factor(s)

3.32

transfer system

part of an AGSS which transfers expired and/or excess anaesthetic gases from the exhaust port of the breathing system or other equipment to the receiving system

3.33

transfer tube

part of an AGSS which transfers expired and/or excess anaesthetic gases from the breathing system to the receiving system

4 General requirements

4.1 Safety

AGS disposal systems shall, when installed, extended, modified, commissioned, operated and maintained in accordance with the instructions of the manufacturer, present no risks that are not reduced to an acceptable level using risk management procedures in accordance with ISO 14971 and which are connected with their intended application, in normal condition and in single fault condition.

NOTE 1 A situation in which a fault is not detected is considered a normal condition. Fault conditions/hazardous situations can remain undetected over a period of time and as a consequence can lead to an unacceptable risk. In that case, a subsequent detected fault condition needs to be considered as a single fault condition. Specific risk control measures need to be determined within the risk management process to deal with such situations.

NOTE 2 Typical safety hazards (discontinuity of operation, incorrect pressure and/or flow, etc.) are listed in Annex D.

4.2 Alternative construction

AGS disposal systems and components, or parts thereof, using materials or having forms of construction different from those detailed in this part of ISO 7396, shall be presumed to be in compliance with the safety objectives of this part of ISO 7396 if it can be demonstrated that an equivalent degree of safety is obtained (i.e. compliance with requirements presumes that risks have been mitigated to acceptable levels) unless objective evidence to the contrary becomes available.

NOTE 1 Objective evidence can be obtained by post-market surveillance.

Evidence of an equivalent degree of safety shall be provided by the manufacturer.

NOTE 2 Regional or national regulations can require the provision of evidence to the competent authority or a conformity assessment body, e.g. notified body in the European Economic Area (EEA), upon request.

4.3 Materials

4.3.1 The materials used for pipelines and other components of the disposal system shall be corrosion-resistant and compatible with anaesthetic gases and vapours under the operating conditions specified by the manufacturer.

NOTE 1 Corrosion resistance includes resistance against the influence of moisture and the surrounding materials.

Evidence shall be provided by the manufacturer.

NOTE 2 Regional or national requirements can require the provision of evidence to the competent authority or a conformity assessment body, e.g. notified body in the European Economic Area (EEA), upon request.

4.3.2 If copper pipes are used, they shall comply with the requirements given in EN 13348.

Evidence shall be provided by the manufacturer.

NOTE 1 Regional or national regulations can require the provision of evidence to the competent authority or a conformity assessment body, e.g. notified body in the European Economic Area (EEA), upon request.

NOTE 2 The requirement in 4.3.2 allows the use of the same stock of copper pipes as is used for the installation of pipeline systems for compressed medical gases and vacuum in accordance with ISO 7396-1.

4.3.3 The potential hazards arising from the use of non-metallic pipes and components shall be taken into account, using risk management procedures in accordance with ISO 14971.

NOTE Experience shows that non-metallic pipes and their junctions used in AGS disposal systems need to be carefully evaluated for their durability following exposure to volatile anaesthetic agents.

4.3.4 All components of the system, other than copper pipes, which come in contact with anaesthetic gases and vapours shall be cleaned in accordance with ISO 15001.

Evidence shall be provided by the manufacturer.

NOTE Regional or national regulations can require the provision of evidence to the competent authority or a conformity assessment body, e.g. notified body in the European Economic Area (EEA), upon request.

4.3.5 If lubricants are used, they shall be compatible with anaesthetic gases and vapours at the operating conditions specified by the manufacturer.

Evidence shall be provided by the manufacturer.

NOTE Regional or national regulations can require the provision of evidence to the competent authority or a conformity assessment body, e.g. notified body in the European Economic Area (EEA), upon request.

4.3.6 Precautions shall be taken to maintain the cleanliness of components during transportation, storage and installation.

4.4 Continuity of operation

The AGS disposal system shall be designed so to achieve continuity of operation in normal condition and in single fault condition.

NOTE Loss of mains electrical power is a single fault condition. A fault in control equipment is a single fault condition.

In order to achieve these objectives, the AGS disposal system shall comprise at least two sources of supply of air to drive exhaust ejectors or at least two fans, blowers or dedicated vacuum pumps.

The AGS disposal system shall be such that the system design flow can be supplied with any one source of supply for air or any one fan, blower or dedicated vacuum pump out of service.

Means shall be provided so that each power device can be isolated for maintenance or repair.

5 Power device

5.1 The power device shall be used solely to power the AGS disposal system.

5.2 The power device shall be one of the following:

- a) an exhaust ejector, for one or more AGSS type 1 terminal unit(s), driven by compressed air from a supply system for air and a pipeline distribution system complying with ISO 7396-1, provided with a means of adjusting the flow from the receiving system through the type 1 terminal unit to meet the requirements specified in 8.1.1 and 8.1.2 [see Figure 2 a)];

- b) an exhaust ejector for each AGSS type 2 terminal unit, driven by compressed air from a supply system for air and a pipeline distribution system complying with ISO 7396-1, provided with a means of adjusting the flow from the receiving system to meet the requirements specified in 8.1.3 [see Figure 2 b)];

NOTE 1 Due to the high air flow required by the AGS disposal system, it is advisable to use a supply system with compressor(s) or proportioning units.

- c) at least two fans, blowers or dedicated vacuum pumps.

NOTE 2 National and regional regulations concerning noise within medical environment levels can exist.

NOTE 3 See Annex A for guidelines for power devices consisting of fans, blowers or dedicated vacuum pumps.

If dedicated vacuum pumps are installed as power device(s), they shall be compatible with oxygen and the anaesthetic gases and vapours.

(*) A vacuum supply system in accordance with ISO 7396-1 shall not be used as AGSS power device.

5.3 Means shall be provided to adjust pressure and flow in the disposal system to meet the requirements given in 8.1.1 and 8.1.2 for type 1 terminal units, regardless of the number of terminal units in use [see Figure 2 c)].

NOTE Such means can be located either within the pipeline and/or in combination with the terminal unit(s).

5.4 Means for adjusting the pressure and flow shall be arranged so that they can be maintained without interruption of operation.

Evidence shall be provided by the manufacturer.

NOTE Regional or national regulations can require the provision of evidence to the competent authority or a conformity assessment body, e.g. notified body in the European Economic Area (EEA), upon request.

5.5 Power devices consisting of fans, blowers or dedicated vacuum pumps shall not be located in the same room as gas and non-cryogenic liquid cylinder supply systems.

5.6 The locations of power devices complying with this part of ISO 7396 and supply systems complying with ISO 7396-1 shall be decided by risk management process in accordance with ISO 14971 in order to minimize the risk arising from hazards such as fire, contamination with oil, grease, and increased oxygen and nitrous oxide concentrations.

6 Indicating systems


Means shall be provided to indicate to the operator that the AGS disposal system is operating.

7 Pipelines, connecting assemblies and disposal hoses

7.1 If connecting assemblies or disposal hoses are readily accessible to the operator, their connectors shall be type-specific. The dimensions of the connectors shall be different from those specified in ISO 5359.

7.2 If flexible connecting assemblies or disposal hoses are used between components of the disposal system and they are not readily accessible to the operator without significant disassembly of fixed components or not normally replaced during their lifetime, the connectors of the assembly need not be type-specific. The dimensions of the connectors shall be different from those specified in ISO 5359.

NOTE Examples of such connecting assemblies are those in hinged-arm booms, tracks and ceiling pendants, and those used for isolation of vibration, building movement and relative movement of the pipelines.



Key

- 1 compressed-air-driven power device
- 2 vacuum pump/fan/blower power device
- 3 means to adjust pressure and flow
- 4 type 1 terminal unit
- 5 type 2 terminal unit
- 6 ambient air
- 7 compressed air
- 8 receiving system
- 9 point of discharge

Figure 2 — Typical examples of power devices

8 Disposal system characteristics and test methods for pressure and flow

8.1 Requirements

8.1.1 Requirements for the AGS disposal system with type 1L terminal units

The flowrate through each type 1L terminal unit or, if not provided, at the interface point upstream of the power device (see Figure 1) shall not exceed 50 l/min when the resistance to flow, which is provided to simulate the resistance of the receiving system, is such as to produce a pressure drop of 1 kPa at 50 l/min, and shall not be lower than 25 l/min when the resistance to flow, which is provided to simulate the resistance of the receiving system, is such as to produce a pressure drop of 2 kPa at 25 l/min (see also ISO 8835-3:—, 10.1).

8.1.2 Requirements for the AGS disposal system with type 1H terminal units

The flowrate through each type 1H terminal unit or, if not provided, at the interface point upstream of the power device (see Figure 1) shall not exceed 80 l/min when the resistance to flow, which is provided to simulate the resistance of the receiving system, is such as to produce a pressure drop of 1 kPa at 80 l/min, and shall not be lower than 50 l/min when the resistance to flow, which is provided, is such as to produce a pressure drop of 2 kPa at 50 l/min (see also ISO 8835-3:—, 10.2).

8.1.3 Requirements for the AGS disposal system with type 2 terminal units

With a flowrate of 50 l/min through the socket of each AGSS type 2 terminal unit, the pressure drop shall not exceed 7,5 kPa.

8.2 Test methods for pressure and flow

8.2.1 General

8.2.1.1 All means for adjusting pressure and flow shall be adjusted to control the flow at each terminal unit. Each terminal unit on the system shall be tested as follows:

- a) with only the terminal unit under test in use;
- b) for systems with more than one terminal unit, with all terminal units in use which are required to provide the system design flow at the specified diversity factor.

8.2.1.2 Testing shall be carried out using ambient air.

8.2.1.3 The resolution and accuracy of all measuring devices used for testing shall be appropriate for the values to be measured. All measuring devices used for certification shall be calibrated at appropriate intervals.

8.2.2 Test methods for flow in disposal systems fitted with type 1L terminal units

8.2.2.1 Test devices

In order to simulate the resistance to flow of a receiving system complying with ISO 8835-3, calibrated test devices which are fitted with type 1L probes and which produce a pressure drop of 1 kPa at a flowrate of 50 l/min (test device 1/50) and 2 kPa at a flowrate of 25 l/min (test device 2/25) shall be used.

NOTE A typical test device is shown in Figure 3.


8.2.2.2 Procedure

8.2.2.2.1 Activate the power device on the AGS disposal system to be tested.

8.2.2.2.2 A test device fitted with type 1L probe which produces a pressure drop of 1 kPa at 50 l/min shall be inserted into each type 1L terminal unit in turn with all the other terminal units closed. The flowrate on the test device at each terminal unit shall be recorded.

8.2.2.2.3 A test device fitted with type 1L probe which produces a pressure drop of 2 kPa at 25 l/min shall be inserted into each type 1L terminal unit in turn with all the other terminal units closed. The flowrate on the test device at each terminal unit shall be recorded.

8.2.2.2.4 Type 1L probes which produce a pressure drop of 1 kPa at 50 l/min shall be inserted into each of several type 1L terminal units up to the system design flow of the AGS disposal system with all the other terminal units closed. A test device with type 1L probe which produces a pressure drop of 2 kPa at 25 l/min shall be inserted into each terminal unit in turn. The flowrate at each terminal unit when this test device is connected shall be recorded.

**Key**

- 1 type 1 probe
- 2 flowmeter
- 3 fixed orifice
- 4 pressure measuring device (for calibration only)

Figure 3 — Typical test device for AGS disposal system characteristics (with type 1 terminal units)

8.2.2.2.5 The tests in 8.2.2.2.2, 8.2.2.2.3 and 8.2.2.2.4 shall be carried out at the same setting of the means of pressure and flow adjustment. The results shall be recorded on a form such as Form C.7.1 (see Annex C).

8.2.3 Test methods for flow in disposal systems fitted with type 1H terminal units

8.2.3.1 Test devices

In order to simulate the resistance to flow of a receiving system complying with ISO 8835-3, calibrated test devices which are fitted with type 1H probes and which produce a pressure drop of 1 kPa at a flowrate of 80 l/min (test device 1/80) and 2 kPa at a flowrate of 50 l/min (test device 2/50) shall be used.

NOTE A typical test device is shown in Figure 3.

8.2.3.2 Procedure

8.2.3.2.1 Activate the power device on the AGS disposal system to be tested.

8.2.3.2.2 A test device fitted with type 1H probe, which produces a pressure drop of 1 kPa at 80 l/min, shall be inserted into each type 1H terminal unit in turn with all the other terminal units closed. The flowrate on the test device at each terminal unit shall be recorded.

8.2.3.2.3 A test device fitted with type 1H probe, which produces a pressure drop of 2 kPa at 50 l/min, shall be inserted into each type 1H terminal unit in turn with all the other terminal units closed. The flowrate on the test device at each terminal unit shall be recorded.

8.2.3.2.4 Type 1H probes, which produce a pressure drop of 1 kPa at 80 l/min, shall be inserted into each of several type 1H terminal units up to the system design flow of the AGS disposal system with all the other terminal units closed. A test device with type 1H probe, which produces a pressure drop of 2 kPa at 50 l/min, shall be inserted into each terminal unit in turn. The flowrate at each terminal unit when this test device is connected shall be recorded.

8.2.3.2.5 The tests in 8.2.3.2.2, 8.2.3.2.3 and 8.2.3.2.4 shall be carried out at the same setting of the means of pressure and flow adjustment. The results shall be recorded on a form such as Form C.7.2 (see Annex C).

8.2.4 Test method for pressure in disposal systems fitted with type 2 terminal units

8.2.4.1 Test devices

Test devices fitted with a type 2 probe and providing flowrates up to 50 l/min shall be used.

8.2.4.2 Procedure

8.2.4.2.1 Activate the power device.

8.2.4.2.2 The probe of the test device shall be inserted into each terminal unit in turn with all the other terminal units closed. The flowrate shall be adjusted to (50 ± 5) l/min. The pressure shall be recorded at the inlet to the terminal unit.

8.2.4.2.3 If individual piping to each terminal unit is not provided, test devices shall be inserted into each of several terminal units up to the system design flow of the AGS disposal system with all the other terminal units closed. Each flowrate shall be adjusted to (50 ± 5) l/min. The pressure at the inlet to each terminal unit shall be recorded.

8.2.4.2.4 The results shall be recorded on a form such as Form C.7.3 (see Annex C).

8.3 Means to prevent backflow

For disposal systems with exhaust ejectors driven by compressed air, means shall be provided to prevent backflow of waste anaesthetic gases and vapours through terminal units.

NOTE This can be achieved by, for example, individual piping or non-return valves.

9 Terminal units

Terminal units shall comply with ISO 9170-2.

10 Marking and colour coding

10.1 Marking

10.1.1 Pipelines shall be marked "AGSS" or national equivalent and shall have arrows denoting the direction of flow adjacent to valves (if fitted) at junctions and changes of direction, before and after walls and partitions, etc., at intervals of no more than 10 m and adjacent to terminal units.

10.1.2 Connecting assemblies and disposal hoses shall be marked "AGSS" or national equivalent.

10.1.3 Marking shall be:

- a) durable;
- b) with letters not less than 6 mm high for the pipelines and not less than 2,5 mm high for connecting assemblies and disposal hoses.

10.2 Colour coding

10.2.1 If colour coding is used, it shall be red magenta or in accordance with the national standard.

NOTE An example of red magenta is 3050-R40B, in accordance with SS 01 91 02.

10.2.2 If colour coding is used, it shall be durable.

10.3 Test for durability

The test for durability of markings and colour coding is given in 12.4.10.

11 Pipeline installation

11.1 Pipelines and electrical services shall be either:

- a) run in separate compartments; or
- b) separated by more than 50 mm.

NOTE Regional or national regulations which apply to electrical installations in buildings can exist.

11.2 Metallic pipelines, if applicable, shall be bonded to an earth terminal as near as possible to the point at which the pipeline enters the building. Pipelines shall not be used for earthing the electrical equipment.

NOTE 1 Regional or national regulations which apply to electrical installations in buildings can exist.

NOTE 2 Regional or national regulations, which apply to continuity of earthing across all joints within the same building and to electrical isolation of different buildings from each other, can exist.

11.3 Pipelines shall be protected from physical damage, for example damage which might be sustained from the movement of portable equipment such as trolleys, stretchers and trucks, in corridors and in other locations.

11.4 Unprotected pipelines containing gas under positive pressure shall not be installed in areas of special hazard. If installation of pipelines in such a location is unavoidable, the pipeline shall be protected by an enclosure which will prevent the liberation of gases within the room should leaks occur in the pipeline installed in the area.

NOTE 1 An area where flammable materials are stored is an example of an area of special hazard.

NOTE 2 Regional or national regulations which apply to building requirements and fire prevention can exist.

11.5 If pipelines are placed underground they shall be placed in tunnels or ducts. The tunnel or duct shall be provided with adequate drainage to prevent the accumulation of water. If pipelines are placed in the same tunnel, trench or duct with fuel pipelines, steam lines or other services, they shall be separated by more than 50 mm. Ducts in which pipelines are installed shall be ventilated.

If pipelines for an AGS disposal system are placed in a tunnel or duct along with other services or with pipelines for other fluids or gases, the potential hazard arising from this situation shall be assessed using risk management procedures in accordance with ISO 14971. The risk assessment shall take into account that a leak which is not detected (e.g. by an alarm or other means such as periodic inspection recommended by the

manufacturer) shall be considered a normal condition and not a single fault condition. The route of pipes placed underground should be indicated at the site by appropriate means, e.g. by continuous marking tape above the pipeline at approximately one-half the depth of burial.

11.6 Pipelines shall not be installed in elevator shafts.

11.7 Damage due to contact with corrosive materials shall be minimised, e.g. by the use of impermeable non-metallic materials applied to the outer surface of the pipe in the area where the contact can occur.

11.8 Allowances shall be made for expansion and contraction of pipelines.

11.9 If condensation is likely to occur in the pipelines, means shall be provided to remove condensation from the system.

11.10 Pipelines shall be supported at intervals to prevent sagging or distortion. Recommended intervals for rigid metallic pipes are given in Table 1.

Table 1 — Recommended intervals between supports for rigid metallic pipes

Outside diameter mm	Maximum intervals between supports ^a m
up to 15	1,5
22 to 28	2,0
35 to 54	2,5
greater than 54	3,0
^a Shorter intervals may be required when using rigid non-metallic pipes.	

11.11 The supports shall ensure that the pipeline cannot be displaced accidentally.

The supports shall either be of corrosion-resistant material, or shall be treated to prevent corrosion. Means shall be provided to prevent electrolytic corrosion.

Where pipelines cross electric cables, the pipes shall be supported adjacent to the cables.

Pipelines shall not be used as support for, nor shall they be supported by, other pipelines or conduits.

11.12 Except for mechanical joints used for certain components, all metallic pipeline joints shall be brazed or welded. The methods used for brazing or welding shall permit the joints to maintain their mechanical characteristics up to an ambient temperature of 600 °C. Filler metals for brazing shall be nominally cadmium-free (less than 0,025 % mass fraction cadmium).

NOTE Mechanical joints (e.g. flanged or threaded connections) can be used to connect components such as shut-off valves, terminal units, pressure regulators, controls and monitoring and alarm sensors to the pipeline.

11.13 The exhaust from the disposal system shall be piped to the outside or into the exhaust conduit of a non-recirculating ventilation system and shall be provided with a means to prevent the ingress of insects, debris and precipitation.

The location of the exhaust outlet shall be remote from the air intake for medical air compressor systems, air intakes, doors, windows or other openings in buildings.

Consideration should be given to the potential effects of prevailing winds when considering the location of the exhaust outlet.

If the exhaust outlet is accessible to personnel, a warning against the inhalation of noxious gas shall be affixed at the point of discharge.

12 Testing, commissioning and certification

12.1 General

Tests after completion of installation shall be carried out, documented and certified by the manufacturer.

NOTE Regional or national regulations requiring the manufacturer to have an approved quality system can exist.

An example of a procedure for testing and commissioning is given in Annex B.

12.2 General requirements for tests

12.2.1 Testing shall be carried out with ambient air.

12.2.2 Before any testing is carried out, every terminal unit in a system under test shall be labelled to indicate that the system is under test and shall not be used.

12.2.3 The resolution and accuracy of all measuring devices used for testing shall be appropriate for the values to be measured. All measuring devices used for certification shall be calibrated at appropriate intervals.

12.3 Tests, inspections and checks

The following tests, inspections and checks shall be carried out before use of the system:

- a) inspection and tests for leakage;
- b) inspection for marking and support intervals of the pipeline system;
- c) check of mechanical function and cleanliness of the terminal units;
- d) test for cross connection;
- e) tests for function of power devices;
- f) tests for pressure and flow at the terminal units;
- g) check of the indicating system;
- h) check of the AGS disposal system exhaust;
- i) check of identification and labelling of the terminal units.

12.4 Requirements for tests, inspections and checks listed in 12.3

12.4.1 Inspection and leakage

12.4.1.1 Pipelines downstream of the power device shall be visually inspected for the integrity of all connections.

12.4.1.2 Pipelines between a type 1 terminal unit and a power device shall be tested at a pressure of $70 \text{ kPa} \pm 10 \%$. The pressure drop in these sections, after a test period of 15 min with the terminal units blanked off, shall be less than 10 kPa.

12.4.2 Marking and support intervals of the pipeline system

The marking of the pipeline system shall meet the requirements of 10.1. The colour coding of the pipeline system, if used, shall meet the requirements of 10.2. The support intervals shall meet the requirements of 11.10.

12.4.3 Mechanical function and cleanliness of the terminal units

It shall be demonstrated for each terminal unit that the appropriate probe can be inserted, captured and released. All terminal units shall be inspected for the absence of visible particulate matter.

12.4.4 Cross connection

There shall be no cross connection to any other pipeline system.

12.4.5 Function of power devices

All power devices shall operate in accordance with the manufacturer's manuals and specifications.

12.4.6 Pressure and flow at the terminal units

It shall be demonstrated that the flow at each AGSS type 1L terminal unit is in accordance with 8.1.1.

It shall be demonstrated that the flow at each AGSS type 1H terminal unit is in accordance with 8.1.2.

It shall be demonstrated that the pressure drop at each AGSS type 2 terminal unit is in accordance with 8.1.3.

12.4.7 Indicating system

The indicating system shall comply with Clause 6.

12.4.8 AGS disposal system exhaust

The exhaust from the disposal system shall comply with 11.13.

12.4.9 Identification and labelling of the terminal units

On satisfactory completion of the tests, inspections and checks described in 12.4.1 to 12.4.8, the construction labels indicating that the system is under test shall be removed. At the same time, the correct identification and labelling (marking and, if used, colour coding) of each terminal unit shall be checked.

12.4.10 Test for durability of markings and colour coding

Rub markings and colour coding by hand, without undue pressure, first for 15 s with a cloth rag soaked with distilled water, then for 15 s with a cloth rag soaked with ethanol and then for 15 s with a cloth rag soaked with isopropanol. Carry out this test at ambient temperature. The markings shall remain legible.

12.5 Certification of the system

Before an AGS disposal system is used, it shall be certified in writing to the healthcare facility that all tests, inspections and checks given in 12.3 have been satisfactorily carried out and all the requirements of 12.4 have been met. The results of tests showing details of the areas tested should be part of the permanent record of the healthcare facility.

NOTE Typical forms for this purpose are given in Annex C.

The system manufacturer shall certify that all drawings and manuals, as required in Clause 13, have been supplied to the owner or client.

12.6 Extensions or modifications

When extensions or modifications are made to the system, the appropriate tests, inspections and checks in 12.3 shall be carried out before the system is returned to service.

13 Information to be supplied by the manufacturer

13.1 General

The information to be provided by the manufacturer shall be in accordance with EN 1041 or equivalent national standards.

13.2 Instructions for use

13.2.1 The manufacturer of the complete system or the manufacturer(s) of each component of the AGS disposal system (i.e. power device, terminal units and pipeline system) shall provide the healthcare facility with instructions for use.

NOTE 1 The power device, terminal units and pipeline system can be supplied by one or several different manufacturers.

NOTE 2 Regional or national regulations which apply to manufacturers of medical devices can exist.

13.2.2 The instructions for use shall contain the following:

- the name or trade name and address of the manufacturer;
- year of manufacture and, where appropriate, the lifetime of the system and its components, any special storage and/or handling conditions;
- any special operating instructions;
- any warnings and/or precautions to be taken, in particular the danger of fire or explosion due to the use of oil and grease in oxygen-enriched atmospheres or the use of flammable anaesthetic agents;
- batch or serial number;
- a technical specification including the performance of the system, and how to connect and disconnect detachable parts and accessories;
- a description of the indicating system;
- the position in normal condition (i.e. open or closed) of all shut-off valves, if fitted;
- instructions for recommended periodic checks of function of the system;
- instructions for recommended maintenance tasks and their frequency, and a list of recommended spare parts, if applicable;
- adequate information regarding which anaesthetic gases and vapours the system is designed to be used with;

- instructions for the disposal of components or consumables (e.g. oil used in compressors and vacuum pumps).

13.2.3 The instruction for use given in 13.2.2 shall take into account the possibility that several different organisations are involved in operation, use and maintenance.

13.3 Operational management information

13.3.1 The manufacturer(s) of each component of the AGS disposal system (i.e. power device, terminal units and pipeline system) shall provide operational management information to the healthcare facility to enable it to draft its Operational management document.

13.3.2 The system manufacturer(s) shall provide instructions to the healthcare facility for recommended maintenance tasks and their frequency, and a list of recommended spare parts.

NOTE Informative guidelines for the preparation of the Operational management document are given in Annex G of ISO 7396-1:2007. Informative guidelines for carrying out a risk management procedure are given in Annex D.

13.4 “As-installed” drawings

13.4.1 A separate set of “as-installed” mechanical drawings which show the actual locations of the pipelines, the diameters of the pipelines, shut-off valves and all other components shall be maintained during construction, and shall be brought up to date as changes are made. These drawings shall include details which will enable buried or concealed pipelines to be located.

13.4.2 A complete set of “as-installed” drawings of the pipeline system as specified in 13.4.1 shall be presented to the healthcare facility of the pipeline system, for inclusion as part of the permanent record of the pipeline system.

13.5 Electrical diagrams

Electrical diagrams for the components supplied shall be provided by the system manufacturer to the healthcare facility.

Annex A

(informative)

Guidelines for power devices consisting of fans, blowers or dedicated vacuum pumps

A.1 Services containing combustible gases or liquids should not be permitted within the power device area.

A.2 All electrical fittings in power device rooms should be located in fixed positions to minimize the risk of physical damage.

A.3 Fire fighting equipment should be provided within the power device area.

NOTE Regional or national regulations which apply to fire protection can exist.

A.4 The power device area should be well ventilated to the open air. Ducting for such ventilation should not be connected to ducting servicing any other building.

A.5 The doors or gate should be capable of being locked. An emergency exit should be provided which should be free from obstructions at all times. It should be possible to open any door from the inside without a key at all times. All doors should open outwards.

A.6 Power device rooms should:

- a) comply with local building codes;
- b) have a warning notice "NO SMOKING", or similar, clearly displayed on both sides of each door or gate.

A.7 Clauses A.1 to A.6 apply to power devices which are centrally located. Power devices that are not centrally located and may or may not be connected to a pipeline system should be installed and serviced in accordance with the instructions supplied by the manufacturer.

Annex B (informative)

Example of procedure for testing and commissioning

B.1 General

This test procedure is given as an example of how the specifications of Clause 12 can be verified so that the system may be commissioned and certified. Other procedures may be devised which validly test these specifications. In this procedure the given sequence of tests is important and should be followed. The general requirements of 12.3 should be followed.

When the results of a test do not meet the pass criteria, remedial work shall be carried out and previous tests repeated as necessary.

Typical forms for certification of the system are given in Annex C. A summary of typical tests required which lists the specification, procedure and form for each test is given in Form C.1.

B.2 Inspection and tests for leakage

B.2.1 Inspection

Visually inspect the exhaust pipeline system for the integrity of all connections.

B.2.2 Tests for leakage

B.2.2.1 General conditions

Isolate the power device from the pipeline. Open all shut-off valves (if fitted) and blank off all type 1 terminal units. If necessary, remove all means of adjusting the flow and blank their connection points.

B.2.2.2 Example of procedure

Connect a suitable pressure-measuring device to the system under test. Fill the system with clean, oil-free, dry compressed gas at a pressure of $70 \text{ kPa} \pm 10 \%$. Record the pressure and, after a period of 15 min, record the pressure again. The pressure drop shall not exceed 10 kPa.

NOTE There is no allowance for temperature variation in this test.

B.2.2.3 Test results

Record the results on a form such as Form C.2.

B.3 Inspection for marking and support intervals of the pipeline system

B.3.1 Example of procedure

Visually inspect that marking has been correctly placed on the pipeline system, especially adjacent to T-connections and where the pipeline system passes through walls or partitions. Check that marking complies with 10.1 and colour coding, if used, complies with 10.2. Check that the support intervals comply with 11.10.

B.3.2 Test results

Record the results on a form such as Form C.3.

B.4 Check of mechanical function and inspection for cleanliness of the terminal units

B.4.1 Example of procedure

B.4.1.1 Inspect the test probes to ensure that they conform to ISO 9170-2. Insert a test probe into each terminal unit in turn. Check that the probe can be inserted, captured and released.

B.4.1.2 Check each terminal unit for the absence of visible particulate matter.

B.4.2 Test results

Record the results on a form such as Form C.4.

B.5 Test for cross connection

B.5.1 Example of procedure

Test the pipeline system of the AGS disposal system for cross connection to any other medical gas or vacuum pipeline system. With all power devices switched off and with pressure in all other medical gas or vacuum pipeline systems, check at all AGSS terminal units that there is no positive or negative pressure.

B.5.2 Test results

Record the results on a form such as Form C.5.

B.6 Tests for function of power devices

B.6.1 Example of procedure

Test all power devices for operation in accordance with the manufacturer's manuals and specifications.

B.6.2 Test results

Record the results on a form such as Form C.6.

B.7 Test for pressure and flow at the terminal units

B.7.1 Example of procedures

Procedures for testing for flow at the type 1L terminal units are given in 8.2.2.

Procedures for testing for flow at the type 1H terminal units are given in 8.2.3.

Procedures for testing for pressure at the type 2 terminal units are given in 8.2.4.

B.7.2 Test results

Record the results on forms such as Forms C.7.1, C.7.2 and C.7.3.

B.8 Check of the indicating system

B.8.1 Example of procedure

Check functioning of the means provided to indicate to the operator that the power device is operating.

B.8.2 Test results

Record the results on a form such as Form C.8.

B.9 Check of the AGS disposal system exhaust

B.9.1 Example of procedure

Verify that the exhaust from the AGS disposal system:

- is piped either to the outside or into the exhaust conduit of a non-recirculating ventilation system;
- is provided with a means to prevent the ingress of insects;
- that the exhaust is in a position where the risk of contamination of occupied buildings is minimized; and
- that the exhaust warning label (if fitted) is legible

B.9.2 Test results

Record the results on a form such as Form C.9.

B.10 Check of identification and labelling of the terminal units

B.10.1 Example of procedure

Check that the tests in B.2 to B.9 have been completed satisfactorily.

Remove the construction label on each terminal unit which indicates that the system is not to be used. Do not remove these labels unless all preceding tests have been completed satisfactorily. At the same time, check for the correct identification and labelling (marking and, if used, colour coding) of each terminal unit.

B.10.2 Test results

Record the results on a form such as Form C.10.

Annex C
(informative)

Typical forms for certification of AGS disposal systems

The forms given in this annex are to be completed during testing and commissioning of AGS disposal systems in accordance with Annex B.

STANDARDSISO.COM : Click to view the full PDF of ISO 7396-2:2007

Form C.1 — Summary of tests

Healthcare facility _____ Area identification _____

This is to certify that the following tests and procedures have been carried out satisfactorily on the anaesthetic gas scavenging disposal system at _____ healthcare facility.

(Sheet of sheets)

Form	Description of tests and procedures	Test required Yes/No	Procedure	Specification	Date of completion of tests and procedures
C.1	Summary of tests				
C.2	Leakage		B.2	12.4.1	
C.3	Marking and support intervals of the pipeline system		B.3	12.4.2	
C.4	Mechanical function and cleanliness of the terminal units		B.4	12.4.3	
C.5	Cross connection		B.5	12.4.4	
C.6	Function of power devices		B.6	12.4.5	
C.7	Pressure and flow at the terminal units		B.7		
C.7.1	— for type 1L terminal units		8.2.2	12.4.6	
C.7.2	— for type 1H terminal units		8.2.3		
C.7.3	— for type 2 terminal units		8.2.4		
C.8	Indicating system		B.8	12.4.7	
C.9	AGS disposal system exhaust		B.9	12.4.8	
C.10	Identification and labelling of the terminal units		B.10	12.4.9	

Manufacturer's Representative

Position _____ Signature _____

Date _____ Name _____

Authorized Person

Position _____ Signature _____

Date _____ Name _____

Form C.2 — Inspections and tests for leakage

Healthcare facility _____ Area identification _____

(Sheet of sheets)

This is to certify that the pipeline system was inspected and tested for leakage. At a test pressure of 70 kPa the pressure drop after 15 min was kPa (maximum permitted is 10 kPa).

Measuring instrument(s) used _____

Manufacturer's Representative

Position _____ Signature _____

Date _____ Name _____

Authorized Person

Position _____ Signature _____

Date _____ Name _____

STANDARDSISO.COM : Click to view the full PDF of ISO 7396-2:2007

Form C.3 — Inspection for marking and support intervals of the pipeline system

Healthcare facility _____ Area identification _____

(Sheet of sheets)

This is to certify that the pipeline system was inspected for marking and support intervals. The marking and, if used, colour coding have been tested for durability.

Manufacturer's Representative

Position _____ Signature _____

Date _____ Name _____

Authorized Person

Position _____ Signature _____

Date _____ Name _____

STANDARDSISO.COM : Click to view the full PDF of ISO 7396-2:2007

Form C.4 — Check of mechanical function and cleanliness of the terminal units

Healthcare facility _____ Area identification _____

(Sheet of sheets)

This is certify that all terminal units were checked for mechanical function and inspected for cleanliness.

Manufacturer's Representative

Position _____ Signature _____

Date _____ Name _____

Authorized Person

Position _____ Signature _____

Date _____ Name _____

STANDARDSISO.COM : Click to view the full PDF of ISO 7396-2:2007

Form C.5 — Test for cross connection

Healthcare facility _____ Area identification _____

(Sheet of sheets)

This is to certify that the pipeline system was tested for cross connection to any other pipeline system.

Measuring instrument(s) used _____

Manufacturer's Representative

Position _____ Signature _____

Date _____ Name _____

Authorized Person

Position _____ Signature _____

Date _____ Name _____

STANDARDSISO.COM : Click to view the full PDF of ISO 7396-2:2007

Form C.6 — Tests for function of power devices

Healthcare facility _____ Area identification _____

(Sheet of sheets)

This is to certify that all power devices have been tested in accordance with the manufacturer's manuals and specifications.

Measuring instrument(s) used _____

Manufacturer's Representative

Position _____ Signature _____

Date _____ Name _____

Authorized Person

Position _____ Signature _____

Date _____ Name _____

Form C.7.1 — Tests for flow for AGSS type 1L terminal units

Healthcare facility _____ Area identification _____

(Sheet of sheets)

This is to certify that the AGSS type 1L terminal units were tested in accordance with 8.2.2 with test device 1/50, (pressure drop 1 kPa, maximum flowrate 50 l/min) and with test device 2/25 (pressure drop 2 kPa, minimum flowrate 25 l/min).

One terminal unit in use				... terminal units in use ^a			
Terminal unit number	Room number	Flowrate measured		Terminal unit number	Room number	Flowrate measured	
		Test device 1/50	Test device 2/25			Test device 1/50	Test device 2/25

^a Number to correspond to system design flow of the AGS system.

Measuring instrument(s) used _____

Manufacturer's Representative

Position _____ Signature _____

Date _____ Name _____

Authorized Person

Position _____ Signature _____

Date _____ Name _____

Form C.7.2 — Tests for flow for AGSS type 1H terminal units

Healthcare facility _____ Area identification _____

(Sheet of sheets)

This is to certify that the AGSS type 1H terminal units were tested in accordance with 8.2.3 with test device 1/80, (pressure drop 1 kPa, maximum flowrate 80 l/min) and with test device 2/50 (pressure drop 2 kPa, minimum flowrate 50 l/min).

One terminal unit in use				... terminal units in use ^a			
Terminal unit number	Room number	Flowrate measured		Terminal unit number	Room number	Flowrate measured	
		Test device 1/80	Test device 2/50			Test device 1/80	Test device 2/50

^a Number to correspond to system design flow of the AGS system.

Measuring instrument(s) used _____

Manufacturer's Representative

Position _____ Signature _____

Date _____ Name _____

Authorized Person

Position _____ Signature _____

Date _____ Name _____

Form C.7.3 — Tests for pressure for AGSS type 2 terminal units

Healthcare facility _____ Area identification _____

(Sheet of sheets)

This is to certify that the type 2 terminal units were tested in accordance with 8.2.4 (test flowrate 50 l/min, maximum pressure drop 7,5 kPa).

One terminal unit in use			... terminal units in use ^a		
Terminal unit number	Room number	Pressure measured	Terminal unit number	Room number	Pressure measured

^a Number to correspond to system design flow of the AGS system.

Measuring instrument(s) used _____

Manufacturer's Representative

Position _____ Signature _____

Date _____ Name _____

Authorized Person

Position _____ Signature _____

Date _____ Name _____

Form C.8 — Check of the indicating system

Healthcare facility _____ Area identification _____

(Sheet of sheets)

This is to certify that the indicating system has been checked for proper operation.

Manufacturer's Representative

Position _____ Signature _____

Date _____ Name _____

Authorized Person

Position _____ Signature _____

Date _____ Name _____

STANDARDSISO.COM : Click to view the full PDF of ISO 7396-2:2007

Form C.9 — Check of the AGS disposal system exhaust

Healthcare facility _____ Area identification _____

(Sheet of sheets)

This is to certify that the AGS disposal system exhaust has been checked.

Manufacturer's Representative

Position _____ Signature _____

Date _____ Name _____

Authorized Person

Position _____ Signature _____

Date _____ Name _____

STANDARDSISO.COM : Click to view the full PDF of ISO 7396-2:2007

Form C.10 — Check of identification and labelling of the terminal units

Healthcare facility _____ Area identification _____

(Sheet of sheets)

This is to certify that all terminal units have been checked for identification and labelling (marking and, if used, colour coding), and labels indicating that the system is not to be used have been removed.

Manufacturer's Representative

Position _____ Signature _____

Date _____ Name _____

Authorized Person

Position _____ Signature _____

Date _____ Name _____