

INTERNATIONAL
STANDARD

ISO/IEEE
11073-
10201

Second edition
2020-04

**Health informatics — Device
interoperability —**

**Part 10201:
Point-of-care medical device
communication — Domain
information model**

Informatique de santé — Interopérabilité des dispositifs —

*Partie 10201: Communication entre dispositifs médicaux sur le site
des soins — Modèle d'informations du domaine*



IEEE

Reference number
ISO/IEEE 11073-10201:2020(E)

© IEEE 2019



COPYRIGHT PROTECTED DOCUMENT

© IEEE 2019

All rights reserved. Unless otherwise specified, or required in the context of its implementation, no part of this publication may be reproduced or utilized otherwise in any form or by any means, electronic or mechanical, including photocopying, or posting on the internet or an intranet, without prior written permission. Permission can be requested from IEEE at the address below.

Institute of Electrical and Electronics Engineers, Inc
3 Park Avenue, New York
NY 10016-5997, USA

Email: stds.ipr@ieee.org
Website: www.ieee.org

Published in Switzerland

Foreword

ISO (the International Organization for Standardization) is a worldwide federation of national standards bodies (ISO member bodies). The work of preparing International Standards is normally carried out through ISO technical committees. Each member body interested in a subject for which a technical committee has been established has the right to be represented on that committee. International organizations, governmental and non-governmental, in liaison with ISO, also take part in the work. ISO collaborates closely with the International Electrotechnical Commission (IEC) on all matters of electrotechnical standardization.

The procedures used to develop this document and those intended for its further maintenance are described in the ISO/IEC Directives, Part 1. In particular, the different approval criteria needed for the different types of ISO documents should be noted (see www.iso.org/directives).

IEEE Standards documents are developed within the IEEE Societies and the Standards Coordinating Committees of the IEEE Standards Association (IEEE-SA) Standards Board. The IEEE develops its standards through a consensus development process, approved by the American National Standards Institute, which brings together volunteers representing varied viewpoints and interests to achieve the final product. Volunteers are not necessarily members of the Institute and serve without compensation. While the IEEE administers the process and establishes rules to promote fairness in the consensus development process, the IEEE does not independently evaluate, test, or verify the accuracy of any of the information contained in its standards.

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. ISO shall not be held responsible for identifying any or all such patent rights. Details of any patent rights identified during the development of the document will be in the Introduction and/or on the ISO list of patent declarations received (see www.iso.org/patents).

Any trade name used in this document is information given for the convenience of users and does not constitute an endorsement.

For an explanation of the voluntary nature of standards, the meaning of ISO specific terms and expressions related to conformity assessment, as well as information about ISO's adherence to the World Trade Organization (WTO) principles in the Technical Barriers to Trade (TBT), see www.iso.org/iso/foreword.html.

ISO/IEEE 11073-10201 was prepared by the IEEE 11073 Standards Committee of the IEEE Engineering in Medicine and Biology Society (as IEEE Std 11073-10201-2018) and drafted in accordance with its editorial rules. It was adopted, under the “fast-track procedure” defined in the Partner Standards Development Organization cooperation agreement between ISO and IEEE, by Technical Committee ISO/TC 215, *Health informatics*.

This second edition cancels and replaces the first edition (ISO/IEEE 11073-10201:2004), which has been technically revised.

A list of all parts in the ISO/IEEE 11073 series can be found on the ISO website.

Any feedback or questions on this document should be directed to the user's national standards body. A complete listing of these bodies can be found at www.iso.org/members.html.

STANDARDSISO.COM : Click to view the full PDF of ISO/IEEE 11073-10201:2020

Health informatics—Point-of-care medical device communication

Part 10201: Domain Information Model

Sponsor

IEEE 11073™ Standards Committee
of the
IEEE Engineering in Medicine and Biology Society

Approved 5 December 2018

IEEE-SA Standards Board

STANDARDSISO.COM : Click to view the full PDF of ISO/IEEE 11073-10201:2020

Abstract: Within the context of the ISO/IEEE 11073 family of standards for point-of-care medical device communication, an abstract, object-oriented domain information model that specifies the structure of exchanged information, as well as the events and services that are supported by each type of object, is provided in this standard. All data structure elements are specified using abstract syntax (ASN.1) and may be applied to many different implementation technologies, transfer syntaxes, and application service models. Core subjects include medical, alert, system, patient, control, archival, communication, and extended services. Model extensibility is supported, and a conformance model and statement template is provided.

Keywords: abstract syntax, alarm, alert, ASN.1, DIM, domain information model, IEEE 11073-10201™, information model, medical device communications, medical information bus, MIB, object-oriented, patient, POC, point-of-care, remote control

The Institute of Electrical and Electronics Engineers, Inc.
3 Park Avenue, New York, NY 10016-5997, USA

Copyright © 2019 by The Institute of Electrical and Electronics Engineers, Inc.
All rights reserved. Published 10 June 2019. Printed in the United States of America.

IEEE is a registered trademark in the U.S. Patent & Trademark Office, owned by The Institute of Electrical and Electronics Engineers, Incorporated.

OMG and UML are registered trademarks of Object Management Group, Inc. in the United States and/or other countries.

PDF: ISBN 978-1-5044-5433-9 STD23484
Print: ISBN 978-1-5044-5434-6 STDPD23484

IEEE prohibits discrimination, harassment, and bullying.

For more information, visit <http://www.ieee.org/web/aboutus/whatis/policies/p9-26.html>.

No part of this publication may be reproduced in any form, in an electronic retrieval system or otherwise, without the prior written permission of the publisher.

Important Notices and Disclaimers Concerning IEEE Standards Documents

IEEE documents are made available for use subject to important notices and legal disclaimers. These notices and disclaimers, or a reference to this page, appear in all standards and may be found under the heading “Important Notices and Disclaimers Concerning IEEE Standards Documents.” They can also be obtained on request from IEEE or viewed at <http://standards.ieee.org/ipr/disclaimers.html>.

Notice and Disclaimer of Liability Concerning the Use of IEEE Standards Documents

IEEE Standards documents (standards, recommended practices, and guides), both full-use and trial-use, are developed within IEEE Societies and the Standards Coordinating Committees of the IEEE Standards Association (“IEEE-SA”) Standards Board. IEEE (“the Institute”) develops its standards through a consensus development process, approved by the American National Standards Institute (“ANSI”), which brings together volunteers representing varied viewpoints and interests to achieve the final product. IEEE Standards are documents developed through scientific, academic, and industry-based technical working groups. Volunteers in IEEE working groups are not necessarily members of the Institute and participate without compensation from IEEE. While IEEE administers the process and establishes rules to promote fairness in the consensus development process, IEEE does not independently evaluate, test, or verify the accuracy of any of the information or the soundness of any judgments contained in its standards.

IEEE Standards do not guarantee or ensure safety, security, health, or environmental protection, or ensure against interference with or from other devices or networks. Implementers and users of IEEE Standards documents are responsible for determining and complying with all appropriate safety, security, environmental, health, and interference protection practices and all applicable laws and regulations.

IEEE does not warrant or represent the accuracy or content of the material contained in its standards, and expressly disclaims all warranties (express, implied and statutory) not included in this or any other document relating to the standard, including, but not limited to, the warranties of: merchantability; fitness for a particular purpose; non-infringement; and quality, accuracy, effectiveness, currency, or completeness of material. In addition, IEEE disclaims any and all conditions relating to: results; and workmanlike effort. IEEE standards documents are supplied “AS IS” and “WITH ALL FAULTS.”

Use of an IEEE standard is wholly voluntary. The existence of an IEEE standard does not imply that there are no other ways to produce, test, measure, purchase, market, or provide other goods and services related to the scope of the IEEE standard. Furthermore, the viewpoint expressed at the time a standard is approved and issued is subject to change brought about through developments in the state of the art and comments received from users of the standard.

In publishing and making its standards available, IEEE is not suggesting or rendering professional or other services for, or on behalf of, any person or entity nor is IEEE undertaking to perform any duty owed by any other person or entity to another. Any person utilizing any IEEE Standards document, should rely upon his or her own independent judgment in the exercise of reasonable care in any given circumstances or, as appropriate, seek the advice of a competent professional in determining the appropriateness of a given IEEE standard.

IN NO EVENT SHALL IEEE BE LIABLE FOR ANY DIRECT, INDIRECT, INCIDENTAL, SPECIAL, EXEMPLARY, OR CONSEQUENTIAL DAMAGES (INCLUDING, BUT NOT LIMITED TO: PROCUREMENT OF SUBSTITUTE GOODS OR SERVICES; LOSS OF USE, DATA, OR PROFITS; OR BUSINESS INTERRUPTION) HOWEVER CAUSED AND ON ANY THEORY OF LIABILITY, WHETHER IN CONTRACT, STRICT LIABILITY, OR TORT (INCLUDING NEGLIGENCE OR OTHERWISE) ARISING IN ANY WAY OUT OF THE PUBLICATION, USE OF, OR RELIANCE UPON ANY STANDARD, EVEN IF ADVISED OF THE POSSIBILITY OF SUCH DAMAGE AND REGARDLESS OF WHETHER SUCH DAMAGE WAS FORESEEABLE.

Translations

The IEEE consensus development process involves the review of documents in English only. In the event that an IEEE standard is translated, only the English version published by IEEE should be considered the approved IEEE standard.

Official statements

A statement, written or oral, that is not processed in accordance with the IEEE-SA Standards Board Operations Manual shall not be considered or inferred to be the official position of IEEE or any of its committees and shall not be considered to be, or be relied upon as, a formal position of IEEE. At lectures, symposia, seminars, or educational courses, an individual presenting information on IEEE standards shall make it clear that his or her views should be considered the personal views of that individual rather than the formal position of IEEE.

Comments on standards

Comments for revision of IEEE Standards documents are welcome from any interested party, regardless of membership affiliation with IEEE. However, IEEE does not provide consulting information or advice pertaining to IEEE Standards documents. Suggestions for changes in documents should be in the form of a proposed change of text, together with appropriate supporting comments. Since IEEE standards represent a consensus of concerned interests, it is important that any responses to comments and questions also receive the concurrence of a balance of interests. For this reason, IEEE and the members of its societies and Standards Coordinating Committees are not able to provide an instant response to comments or questions except in those cases where the matter has previously been addressed. For the same reason, IEEE does not respond to interpretation requests. Any person who would like to participate in revisions to an IEEE standard is welcome to join the relevant IEEE working group.

Comments on standards should be submitted to the following address:

Secretary, IEEE-SA Standards Board
445 Hoes Lane
Piscataway, NJ 08854 USA

Laws and regulations

Users of IEEE Standards documents should consult all applicable laws and regulations. Compliance with the provisions of any IEEE Standards document does not imply compliance to any applicable regulatory requirements. Implementers of the standard are responsible for observing or referring to the applicable regulatory requirements. IEEE does not, by the publication of its standards, intend to urge action that is not in compliance with applicable laws, and these documents may not be construed as doing so.

Copyrights

IEEE draft and approved standards are copyrighted by IEEE under U.S. and international copyright laws. They are made available by IEEE and are adopted for a wide variety of both public and private uses. These include both use, by reference, in laws and regulations, and use in private self-regulation, standardization, and the promotion of engineering practices and methods. By making these documents available for use and adoption by public authorities and private users, IEEE does not waive any rights in copyright to the documents.

Photocopies

Subject to payment of the appropriate fee, IEEE will grant users a limited, non-exclusive license to photocopy portions of any individual standard for company or organizational internal use or individual, non-commercial use only. To arrange for payment of licensing fees, please contact Copyright Clearance Center, Customer Service, 222 Rosewood Drive, Danvers, MA 01923 USA; +1 978 750 8400. Permission to photocopy portions of any individual standard for educational classroom use can also be obtained through the Copyright Clearance Center.

Updating of IEEE Standards documents

Users of IEEE Standards documents should be aware that these documents may be superseded at any time by the issuance of new editions or may be amended from time to time through the issuance of amendments, corrigenda, or errata. A current IEEE document at any point in time consists of the current edition of the document together with any amendments, corrigenda, or errata then in effect.

Every IEEE standard is subjected to review at least every ten years. When a document is more than ten years old and has not undergone a revision process, it is reasonable to conclude that its contents, although still of some value, do not wholly reflect the present state of the art. Users are cautioned to check to determine that they have the latest edition of any IEEE standard.

In order to determine whether a given document is the current edition and whether it has been amended through the issuance of amendments, corrigenda, or errata, visit IEEE Xplore at <http://ieeexplore.ieee.org/> or contact IEEE at the address listed previously. For more information about the IEEE-SA or IEEE's standards development process, visit the IEEE-SA Website at <http://standards.ieee.org>.

Errata

Errata, if any, for all IEEE standards can be accessed on the IEEE-SA Website at the following URL: <http://standards.ieee.org/findstds/errata/index.html>. Users are encouraged to check this URL for errata periodically.

Patents

Attention is called to the possibility that implementation of this standard may require use of subject matter covered by patent rights. By publication of this standard, no position is taken by the IEEE with respect to the existence or validity of any patent rights in connection therewith. If a patent holder or patent applicant has filed a statement of assurance via an Accepted Letter of Assurance, then the statement is listed on the IEEE-SA Website at <http://standards.ieee.org/about/sasb/patcom/patents.html>. Letters of Assurance may indicate whether the Submitter is willing or unwilling to grant licenses under patent rights without compensation or under reasonable rates, with reasonable terms and conditions that are demonstrably free of any unfair discrimination to applicants desiring to obtain such licenses.

Essential Patent Claims may exist for which a Letter of Assurance has not been received. The IEEE is not responsible for identifying Essential Patent Claims for which a license may be required, for conducting inquiries into the legal validity or scope of Patents Claims, or determining whether any licensing terms or conditions provided in connection with submission of a Letter of Assurance, if any, or in any licensing agreements are reasonable or non-discriminatory. Users of this standard are expressly advised that determination of the validity of any patent rights, and the risk of infringement of such rights, is entirely their own responsibility. Further information may be obtained from the IEEE Standards Association.

Participants

At the time this IEEE standard was completed, the Point-of-Care Devices Working Group had the following membership:

John Rhoads, Chair
Michael Faughn, Subgroup Chair

Bjoern Anderson
 Malcolm Clarke
 Todd Cooper
 Chris Courville
 Kenneth Fuchs
 John Garguilo
 Frank Golatowski

David Gregorczyk
 Kai Hassing
 John Hatcliff
 Stefan Karl
 Martin Kasparick
 Koichiro Matsumoto
 Joerg-Uwe Meyer
 Stephan Poehlsen

Tracy Rausch
 Stefan Schlichting
 Paul Schluter
 Masato Tanaka
 Eugene Vasserman
 Stan Wiley
 Jan Wittenber

The following members of the individual balloting committee voted on this standard. Balloters may have voted for approval, disapproval, or abstention.

Bjoern Andersen
 Michael Bayer
 Keith Chow
 Malcolm Clarke
 Michael Faughn
 David Fuschi
 David Gregorczyk
 Randall Groves

Kai Hassing
 Werner Hoelzl
 Noriyuki Ikeuchi
 Atsushi Ito
 Stefan Karl
 Piotr Karocki
 Martin Kasparick
 H. Moll
 John Rhoads

Stefan Schlichting
 Paul Schluter
 Walter Struppler
 Ganesh Subramanian
 Thomas Tullia
 Jan Wittenber
 Oren Yuen
 Daidi Zhong

When the IEEE-SA Standards Board approved this standard on 5 December 2018, it had the following membership:

Jean-Philippe Faure, Chair
Gary Hoffman, Vice Chair
John D. Kulick, Past Chair
Konstantinos Karachalios, Secretary

Ted Burse
 Guido R. Hiertz
 Christel Hunter
 Joseph L. Koepfinger*
 Thomas Koshy
 Hung Ling
 Dong Liu

Xiaohui Liu
 Kevin Lu
 Daleep Mohla
 Andrew Myles
 Paul Nikolich
 Ronald C. Petersen
 Annette D. Reilly

Robby Robson
 Dorothy Stanley
 Mehmet Ulema
 Phil Wennblom
 Philip Winston
 Howard Wolfman
 Jingyi Zhou

*Member Emeritus

Introduction

This introduction is not part of IEEE Std 11073-10201-2018, Health informatics—Point-of-care medical device communication—Part 10201: Domain Information Model.

ISO/IEEE 11073 standards enable communication between different medical devices and between medical devices and other IT systems for information and for command and control. The primary goals are to:

- Provide real-time plug-and-play interoperability for patient-connected medical devices
- Facilitate the efficient exchange of patient related data and medical device related data, acquired at the point-of-care (POC), in all health care environments

“Real-time” means that data from multiple devices can be retrieved, time correlated, and displayed or processed in fractions of a second.

“Plug-and-play” means that when a device or system is connected to another device or system, detection, configuration, and the initiation of communication all occur automatically and without any other human interaction.

“Efficient exchange of medical device data” means that information that is captured at the POC (e.g., patient vital signs data) can be archived, retrieved, and processed by many different types of applications without extensive software and equipment support, and without needless loss of information. This standard is especially targeted at acute and continuing care devices, such as patient monitors, ventilators, infusion pumps, ECG devices, etc. It is a member of a family of standards that can be layered together to provide connectivity optimized for the specific devices being interfaced.

Contents

1. Scope	9
2. Normative references.....	9
3. Definitions, acronyms, and abbreviations	10
3.1 Definitions	10
3.2 Abbreviations and acronyms	13
4. General requirements.....	14
5. Domain information model (DIM)	15
5.1 General	15
5.2 Package diagram—Overview	18
5.3 Model for the Medical Package	19
5.4 Model for the Alert Package	23
5.5 Model for the System Package	25
5.6 Model for the Control Package	27
5.7 Model for the ExtendedServices Package	30
5.8 Model for the Communication Package	33
5.9 Model for the Archival Package	35
5.10 Model for the Patient Package	37
5.11 DIM—Dynamic model	37
6. DIM class definitions	42
6.1 Overview	42
6.2 Top class	51
6.3 Medical package	52
6.4 Alert package	89
6.5 System package	95
6.6 Control package	115
6.7 ExtendedServices package	129
6.8 Communication package	142
6.9 Archival package	149
6.10 Patient package	156
7. Service model for communicating systems	159
7.1 General	159
7.2 Communicating systems	159
7.3 General service model overview	160
7.4 General object management services definition	162
8. MDIB nomenclature	167
9. Conformance model	168
9.1 Applicability	168
9.2 Conformance specification	168
9.3 ICSs	169
Annex A (informative) Bibliography	175

Health informatics—Point-of-care medical device communication

Part 10201: Domain Information Model

1. Scope

The scope of this project is to define a general object-oriented information model that may be used to structure information and identify services used in point-of-care (POC) medical device communications. The scope is primarily focused on acute care medical devices and the communication of patient vital signs information.

2. Normative references

The following referenced documents are indispensable for the application of this document (i.e., they must be understood and used, so each referenced document is cited in text and its relationship to this document is explained). For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments or corrigenda) applies.

ISO/IEC 8824-1, Information technology — Abstract Syntax Notation One (ASN.1) — Part 1: Specification of basic notation.¹

ISO/IEEE 11073-10101, Health informatics — Point-of-care medical device communication — Part 10101: Nomenclature.²

ISO/IEEE 11073-20101, Health informatics — Point-of-care medical device communication — Part 20101: Application profiles – Base standard.

OMG® Unified Modeling Language® (OMG UML®) 2.5.1.³

¹ ISO/IEC documents are available from the International Organization for Standardization (<http://www.iso.org/>), the International Electrotechnical Commission (<http://www.iec.ch>), and the American National Standards Institute (<http://www.ansi.org/>).

² ISO/IEEE documents are available from the International Organization for Standardization (<http://www.iso.org/>) and the Institute of Electrical and Electronics Engineers (<http://standards.ieee.org/>).

³ The OMG UML standard can be freely downloaded at <https://www.omg.org/spec/UML/>

3. Definitions, acronyms, and abbreviations

3.1 Definitions

For the purposes of this document, the following terms and definitions apply. The *IEEE Standards Dictionary Online* should be referenced for terms not defined in this clause.⁴

agent: Device that provides data in a manager-agent communicating system.

alarm: Signal that indicates abnormal events occurring to the patient or the device system.

alert: Synonym for the combination of patient-related physiological alarms, technical alarms, and equipment-user advisory signals.

alert condition: The active (true) state of a physiologic alarm (primarily related to the patient), technical alarm (primarily related to a device), or an advisory that is typically reported to clinicians, physicians, or other healthcare staff, for responding to patient needs or related workflows.

alert monitor: Object representing the output of an alert system that considers multiple alert conditions in a scope defined by objects that are contained by a single medical device system object. An alert monitor is able to report individual, concurrent alert conditions as well as the overall system alert condition.

alert status: Object representing the output of an alert system that considers multiple alert conditions in a scope defined by objects that are contained by either a single virtual medical device object or a single medical device system object. An alert status is able to report concurrent alert conditions.

archival: Relating to the storage of data over a prolonged period.

association control service element (ACSE): Method used to establish logical connections between medical device systems.

attribute: The definition of a property of an object.

channel: An object that groups together physiological measurement data and any derived data that have a contextual relationship with each other.

class: A model which describes the properties and behaviors of a type of entity found within a problem domain.

class diagram: Diagram showing connections between classes in a system.

communication controller: Part of a medical device system responsible for communications.

communication party: Actor of the problem domain that participates in the communication in that domain.

communication role: Role of a party in a communication situation defining the party's behavior in the communication. Associated with a communication role is a set of services that the party provides to other parties.

data agent: As a medical device, a patient data acquisition system that provides the acquired data for other devices.

⁴ The *IEEE Standards Dictionary Online* is available at <http://dictionary.ieee.org/>. An IEEE Account is required for access to the dictionary, and one can be created at no charge on the dictionary sign-in page.

data format: Arrangement of data in a file or stream.

data logger: A device that is functioning in its capacity as a data storage and archival system.

NOTE—There may be several different types of data loggers; clinical, technical, forensic, alarm condition, user logs.⁵

data structure: A data organization format that is implemented by an application.

dictionary: Description of the contents of the medical data information base (MDIB) containing vital signs information, device information, demographics, and other elements of the MDIB.

discrete parameter: Measured, calculated, or manually entered value that can be expressed as a single numeric or textual value.

Example: A non-invasive systolic blood pressure (measured), cardiac index (calculated), gender male or female.

domain information model (DIM): The model describing common concepts and relationships for a problem domain.

event: A change in device status that is communicated by a notification reporting service.

event report: Service (provided by the common medical device information service element) to report an event relating to a managed object instance.

framework: A structure of processes and specifications designed to support the accomplishment of a specific task.

graphic parameter: Parameter that requires multiple regularly sampled data points in order to be expressed properly.

Example: A single ECG waveform snippet.

host system: Term used as an abstraction of a medical system to which measurement devices are attached.

information service element: Instances in the medical data information base.

instance: The realization of an abstract concept or specification, e.g., class instance, application instance, information service element instance, virtual medical device instance, operating instance.

instance method: A procedure or process that defines a behavior exhibited by the instances of a class (i.e., objects). Instance methods provide the interface by which the properties of an object may be accessed or modified.

intensive care unit (ICU): The unit within a medical facility in which patients are managed using multiple modes of monitoring and therapy.

interchange format: The representation of the data elements and the structure of the message containing those data elements while in transfer between systems. The interchange format consists of a data set of construction elements and a syntax. The representation is technology specific.

interoperability: The ability of two or more devices or systems to exchange information in a format that is usable by the receivers of the information.

⁵ Notes in text, tables, and figures of a standard are given for information only and do not contain requirements needed to implement this standard.

latency: In a communications scenario, the time delay between sending a signal from one device and receiving it by another device.

lower layers: Layer 1 to Layer 4 of the International Organization for Standardization (ISO)/open systems interconnection (OSI) reference model. These layers cover mechanical, electrical, and general communication protocol specifications.

manager: Device that receives data in a manager-agent communicating system.

manager-agent model: Communication model where one device (i.e., agent) provides data and another device (i.e., manager) receives data.

medical data information base (MDIB): The concept of an object-oriented database storing (at least) vital signs information.

medical device: A device, apparatus, or system used for patient monitoring, treatment, or therapy, which does not normally enter metabolic pathways. For the purposes of this standard, the scope of medical devices is further limited to patient-connected medical devices that provide support for electronic communications.

medical device system (MDS): Abstraction for system comprising one or more medical functions. In the context of this standard, the term is specifically used as an object-oriented abstraction of a device that provides medical information in the form of instances of the classes that are defined in this standard.

monitor: A medical device designed to acquire, display, record, and/or analyze patient data and to alert caregivers of events needing their attention.

object: A particular instance of a class. An object represents a physical or logical occurrence of an actual medical device or medical device component. *Syn:* object instance.

object instance: *See:* object.

object-oriented analysis: Method of analysis where the problem domain is modelled in the form of classes and the relationships between those classes.

open system: A set of protocols allowing computers of different origins to be linked together.

operation: A function or transformation that may be applied to or by objects (sometimes also called service).

problem domain: The field of health care under consideration in a modeling process.

protocol: A standard set of rules describing the transfer of data between devices. It specifies the format of the data and specifies the signals to start, control, and end the transfer.

real time: At the time when an event or process occurs.

scanner: An observer and “summarizer” of attribute values.

scenario: A formal description of a class of business activities including the semantics of business agreements, conventions, and information content.

service: A specific behavior that a communication party in a specific role is responsible for exhibiting.

syntax (i.e., of an interchange format): The rules for combining the construction elements of the interchange format.

system: The demarcated part of the perceivable universe, existing in time and space, that may be regarded as a set of elements and relationships between these elements.

timestamp: An attribute or field in data that denotes the time of data generation.

top class: The ultimate base class for most of the classes belonging to the domain information model defined in this standard.

upper layers: Layer 5 to Layer 7 of the International Organization for Standardization (ISO)/open systems interconnection (OSI) reference model. These layers cover application, presentation, and session specifications and functionalities.

virtual medical device (VMD): An abstract representation of a medical-related subsystem of a medical device system.

virtual medical object (VMO): An abstract representation of an object in the Medical Package of the domain information model.

vital sign: Clinical information, relating to one or more patients, that is measured by or derived from apparatus connected to the patient or otherwise gathered from the patient.

waveform: Graphic data, typically vital signs data values varying with respect to time, usually presented to the clinician in a graphical form.

3.2 Abbreviations and acronyms

ACSE	association control service element
ASN.1	Abstract Syntax Notation One
BCC	bedside communication controller
BER	basic encoding rules
BMP	basic multilingual plane
CMDIP	Common Medical Device Information Protocol
CMDISE	common medical device information service element
CMIP	Common Management Information Protocol
CMISE	common management information service element
DCC	device communication controller
DICOM	digital imaging and communications in medicine
DIM	domain information model
EBWW	eyeball and wristwatch
ECG	electrocardiogram
EEG	electroencephalogram
FSM	finite state machine
GMDN	Global Medical Device Nomenclature
GMT	Greenwich mean time
IANA	Internet Assigned Numbers Authority
ICS	implementation conformance statement
ICU	intensive care unit
ID	identifier or identification
LAN	local area network
LSB	least significant bit
MDC	medical device communication

MDIB	medical data information base
MDS	medical device system
MEDICOM	medical imaging communication
MIB or Mib	management information base
MOC	managed object class
OID	object identifier
OR	operating room
OSI	open systems interconnection
PC	personal computer
PDU	protocol data unit
PM	persistent metric
POC	point of care
SCADA	supervisory control and data acquisition
SCP ECG	Standard Communications Protocol [for computer-assisted] Electrocardiography
SNMP	Simple Network Management Protocol
SNTP	Simple Network Time Protocol
UDI	Unique Device Identification
UML	unified modeling language
UTC	coordinated universal time
VMD	virtual medical device
VMO	virtual medical object
VMS	virtual medical system

4. General requirements

The ISO/IEEE 11073 family of standards is intended to enable medical devices to interconnect and inter-operate with other medical devices and with computerized healthcare information systems in a manner suitable for the clinical environment.

The ISO/IEEE 11073 family is based on an object-oriented systems management paradigm. Data (e.g., measurement, state) is modeled in the form of classes, instances of which can be accessed and manipulated using an object access service protocol.

The domain information model (DIM) defines the overall set of classes and their attributes, methods, and access functions needed for medical device communication (MDC).

The top-level user requirements are defined in ISO/IEEE 11073-20101,⁶ which also defines the user scenarios covered by the ISO/IEEE 11073 family of standards.

As a part of the ISO/IEEE 11073 family of standards, the primary requirements for the DIM are as follows:

- Define an object-oriented model representing the relevant information (i.e., data) and functions (e.g., device controls) encountered in the problem domain of MDC, including measurement information, contextual data, device control methods, and other relevant aspects.
- Provide detailed specification of the classes defined in the object-oriented model, including their attributes and methods.
- Define a service model for communicating medical devices that provides access to the object instances, their attributes, and their methods.

⁶ Information on references can be found in Clause 2.

- Use the nomenclature defined in ISO/IEEE 11073-10101 to identify all data elements in the model.
- Be usable for the definition of data communication protocols as well as for the definition of file storage formats.
- Define conformance requirements.
- Be extensible and expandable to incorporate future needs in the defined modeling framework.

5. Domain information model (DIM)

5.1 General

5.1.1 Modeling concept

The DIM is an object-oriented model that consists of classifiers, their attributes, and their methods, which are abstractions of real-world entities in the domain of (vital signs information communicating) medical devices.

The information model and the service model for communicating systems defined and used in this standard are conceptually based on the International Organization for Standardization (ISO)/open systems interconnection (OSI) system management model (ISO/IEC 7498-1 [B16], ISO/IEC 7498-2 [B17], ISO/IEC 7498-3 [B18], ISO/IEC 7498-4 [B19]).⁷ Classes defined in the information model are considered to model managed (here, medical) objects. For the most part, the objects are directly available to management (i.e., access) services provided by the common medical device information service element (CMDISE) as defined in this standard.

For communicating systems, the set of object instances available on any medical device that complies with the definitions of this standard forms the medical data information base (MDIB). The MDIB is a structured collection of managed medical objects representing the vital signs information provided by a particular medical device. Attribute data types, hierarchies, and behavior of objects in the MDIB are defined in this standard.

The majority of classes defined here represent generalized vital signs data and support information. Specialization of these classes is achieved by defining appropriate attributes. Class hierarchies and associations between classes are used to express device configuration and device capabilities.

Example: A generalized object is instantiated to represent vital signs in the form of a real-time waveform. A set of attributes is used to specify a particular waveform as an invasive arterial blood pressure. The position in the hierarchy of all objects defines the subsystem that derives the waveform.

Figure 1 shows the relation between managed medical objects, MDIB, CMDISE, application processes, and communication systems.

In the case of communicating systems, managed medical objects are accessible only through services provided by CMDISE. The way that these objects are stored in the MDIB in any specific system and the way applications and the CMDISE access these objects are implementation issues and as such not normative.

In the case of a vital signs archived data format that complies with the definitions in this standard, object instances are stored, together with their dynamic attribute value changes, over a certain time period on archival media. Attribute data types and hierarchies of objects in the archival data format are again defined in this standard.

⁷ The numbers in brackets correspond to those of the bibliography in Annex A.




Figure 1—MDIB in communicating systems

Figure 2 shows the relationship between managed medical objects, the data archive, and archive access services.

In the case of the archived data format, the way managed medical objects are stored on a medium is the subject of standardization. The access services are a local implementation issue and as such are not intended to be governed by this standard.




Figure 2—Managed medical objects in a vital signs archive

5.1.2 Scope of the DIM

5.1.2.1 General

Vital signs information classes that are defined in this standard encompass digitized biosignals that are derived by medical measurement devices used, for example, in anaesthesia, surgery, infusion therapy, intensive care, and obstetrical care.

Biosignal data within the scope of this standard include direct and derived, quantitative and qualitative measurements, technical and medical alarms, and control settings. Patient information relevant for the interpretation of these signals is also defined in the DIM.

5.1.2.2 Communicating systems

Communicating systems within the scope of this standard include physiological meters and analysers, especially systems providing real-time or continuous monitoring. Data processing capabilities are required for these systems.

Information management objects that provide capabilities and concepts for cost-effective communication (specifically data summarization objects) and objects necessary to enable real-time communication are also within the scope of the information model in this standard.

Interoperability issues, specifically lower communication layers, temporal synchronization between multiple devices, etc., are outside the scope of this standard.

5.1.2.3 Archived vital signs

Context information classes that describe the data acquisition process and organize a vital signs archive are within the scope of this standard.

5.1.3 Approach

For the object-oriented modeling, the Unified Modeling Language (UML) is used. The domain is first subdivided into different packages, and this subdivision permits the organization of the model into smaller packages. Each package is then defined in the form of UML class diagrams. Classes are briefly introduced, and their relations and hierarchies are defined in the class diagrams. No single diagram shows all of the classes and relationships defined in the DIM. The diagrams must be considered as a set that, together, define the structure of the DIM.

For the class definitions, a textual approach is followed. Attributes are defined in attribute definition tables. Attribute data types are defined using Abstract Syntax Notation One (ASN.1) as defined by ISO/IEC 8824-1 and ISO/IEC 8824-2 [B23]. The behavior of and notifications generated by objects are also defined in definition tables. These definitions directly relate to the service model specified in Clause 7.

5.1.4 Extension of the model

It is expected that over time extensions of the model may be needed to account for new developments in the area of medical devices. Also, in special implementations, there may be a requirement to model data that are specific for a particular device or a particular application (and that are, therefore, not covered by the general model).

In some cases, it may be possible to use the concept of external object relations. Most classes defined in this standard provide an attribute group (e.g., the Relationship Attribute Group) that can be used to supply information about related objects that are not defined in the DIM. Supplying such information can be done by specifying a relation to an external object and assigning attributes to this relation (see 6.1.3.20).

In other cases, it may be necessary to define completely new classes or to add new attributes, new methods, or new events to already defined classes. These extensions are considered private or manufacturer-specific extensions. Dealing with these extensions is primarily a matter of an interoperability standard that is based on this standard on vital signs representation.

In general, in an interoperability format, classes, attributes, and methods are identified by nomenclature codes. ISO/IEEE 11073-10101 defines nomenclature that should be preferred when implementing an 11073-compliant device. The nomenclature code space (i.e., code values) leaves room for private extensions. As a general rule, an interoperability standard that is based on this DIM should be able to deal with private or manufacturer-specific extensions by ignoring classes, attributes, etc., with unknown identifiers (i.e., nomenclature codes).

5.2 Package diagram—Overview

The package diagram organizes the problem domain into separate groups. It shows key classes inside each package and the relationships between them.

The package diagram depicted in Figure 3 contains only a small subset of all classifiers defined in the DIM. Not all relations are shown between the shown classes. Refer to the detailed UML class diagrams for each package for more information.




Figure 3—Packages of the DIM

The Top class is an abstract class and at the same time the ultimate base for the majority of classes defined in the model. The only classes for which the Top class does not serve as a base class are the DeviceInterface class and the MibElement classes. Figure 4 shows the Top class and all of the class that are immediate subclasses of class Top. Many of the subclasses shown are themselves subclassed. This secondary subclassing is not shown in Figure 4.




Figure 4—Top class inheritance

The more detailed UML class diagrams for these packages are contained in 5.3 through 5.10. These diagrams show relationships between classes defined in the package as well as key relationships between classes defined in the package and classes defined in other packages. Some relationships appear in one diagram and are absent in other diagrams where the two associated classes are shown. The inclusion of a relationship in any UML class diagram indicates that it is part of the complete UML model.


The numbers in the packages refer to the corresponding subclauses in this clause about models and in Clause 6 about the class definitions.

5.3 Model for the Medical Package

5.3.1 General

The Medical Package deals with the derivation and representation of biosignals and contextual information that is important for the interpretation of measurements.

Figure 5 shows the UML class diagram for the Medical Package.

**Figure 5—Medical Package model**

NOTE—Instances of any class that are modeled with a containment association may be contained by exactly one instance of a container class.

The Medical Package model contains the classes described in 5.3.2 through 5.3.14.

5.3.2 VMO (virtual medical object) class

VMO is the abstract base class for all medical-related classes in the model. It provides consistent naming and identification across the Medical Package model.

The VMO class is abstract and cannot be instantiated.

5.3.3 VMD (virtual medical device) class

The VMD class models medical-related subsystems (e.g., hardware or even pure software) of medical devices. The characteristics of a subsystem (e.g., modes, versions) are captured by instances of this class. At the same time, a VMD object is a container for objects representing measurement and status information.

Example: A modular patient monitor provides measurement modalities in the form of plug-in modules. Each module is represented by a VMD object.

5.3.4 Channel class

Channel objects are used for grouping Metric objects that have a contextual relationship with each other.

Example: A blood pressure VMD may define a Channel object to group together all metrics that deal with the blood pressure (e.g., pressure value, pressure waveform). A second Channel object can be used to group together metrics that deal with heart rate.

The Channel object is mandatory for representation of Metric objects in a VMD. In some cases a VMD may contain a single Channel and that Channel may be functionally superfluous. This may be likely if the attribution of the Channel object consists only of the mandatory *type* and *handle* attributes. In this case it is recommended that the value for the *type* attribute be initialized using the values corresponding to the term having the reference ID *MDC_DEV_CHAN*, which is defined in IEEE11073:10101. Usage of this term in this context may provide an indication that the Channel object in question may not require representation in other messaging formats (e.g. IHE PCD-01).

5.3.5 Metric class

The Metric class is the abstract base class for all classes representing direct and derived, quantitative and qualitative biosignal measurement, status, and context data.

Specializations of the Metric class are provided to deal with common representations (e.g., single values, array data, status indications) and presentations (e.g., on a display) of measurement data.

The Metric class is abstract and cannot be instantiated.

5.3.6 Numeric class

The Numeric class models numerical measurements and status information, e.g., amplitude measures, counters.

Example: A heart rate measurement is represented by a Numeric object.

NOTE—A compound Numeric object is defined as an efficient model, for example, for arterial blood pressure, which usually has three associated values (i.e., systolic, diastolic, mean). The availability of multiple values in a single Numeric (or other Metric) object can be indicated in a special structure attribute of the Metric class.

5.3.7 SampleArray class

The SampleArray class is the abstract base class for metrics that have a graphical, curve type presentation and, therefore, have their observation values reported as arrays of data points by communicating systems.

The SampleArray class is abstract and cannot be instantiated.

5.3.8 RealTimeSampleArray class

The RealTimeSampleArray class models a real-time continuous waveform. As such, it has special requirements in communicating systems, e.g., processing power, low latency, high bandwidth.

Example: An electrocardiogram (ECG) real-time wave is represented as a RealTimeSampleArray object.

5.3.9 TimeSampleArray class

The TimeSampleArray class models noncontinuous waveforms (i.e., a wave snippet). Within a single observation (i.e., a single array of sample values), samples are equidistant in time.

Example: Software for ST segment analysis may use the TimeSampleArray class to represent snippets of ECG real-time waves that contain only a single QRS complex. Within this wave snippet, the software can locate the ST measurement points. It generates a new snippet, for example, every 15 s.

5.3.10 DistributionSampleArray class

The DistributionSampleArray class models linear value distributions in the form of arrays containing scaled sample values. Each value within an observation array represents a measured value from a different point in the parameter space. The DistributionSampleArray shall not be used for measurements distributed in time.

Example: An electroencephalogram (EEG) application may use a Fourier transformation to derive a frequency distribution (i.e., a spectrum) from the EEG signal. It then uses a DistributionSampleArray object to represent that spectrum in the MDIB.

5.3.11 Enumeration class

The Enumeration class models status information and/or annotation information. Observation values may be presented in the form of normative codes (that are included in the nomenclature defined in IEEE 11073 part 10101 or in some other nomenclature scheme), bit string, or in the form of free text.

Example: An ECG rhythm qualification may be represented as an Enumeration object. A ventilator may provide information about its current ventilation mode as an Enumeration object.

5.3.12 ComplexMetric class

In special cases, a ComplexMetric object can be used to group a larger number of strongly related Metric objects in one single container object for performance or for modeling convenience. A ComplexMetric object is a composition of Metric objects, possibly recursive.

Example: A ventilator device may provide extensive breath analysis capabilities. For each breath, it calculates various numerical values (e.g., volumes, I:E ratio, timing information) as well as enumerated information (e.g., breath type classification, annotation data). For efficiency, all this information is grouped together in one ComplexMetric object instance, which is updated upon each breath.

5.3.13 PM-Store (i.e., persistent metric) class

The PM-Store class provides long-term storage capabilities for metric data. A PM-Store contains a variable number of PM-Segment objects that can be accessed only through the PM-Store object. A PM-Store object is intended to store data of a single Metric object only.

Example: A device stores the numerical value of an invasive blood pressure on a disk. It uses the PM-Store object to represent this persistent information. The attributes of the PM-Store object describe the sampling period, the sampling algorithm, and the storage format. When the label of the pressure measurement is changed (e.g., during a wedge procedure), the storage process opens a new PM-Segment to store the updated context data (here: the label).

5.3.14 PM-Segment class

The PM-Segment class models a continuous time period in which a metric is stored without any changes of relevant metric context attributes (e.g., scales, labels).

PM-Segment objects are accessible only through the PM-Store object that contains them (e.g., for retrieving stored data, the PM-Store object has to be accessed).

5.4 Model for the Alert Package

5.4.1 General

The Alert Package deals with classes that represent status information about patient condition and/or technical conditions influencing the measurement or device functioning. Alert-related information is often subject to normative regulations to which a device may be required to comply and, therefore, requires special consideration that is outside the scope of this standard.

In the model, all alarm-related object-oriented items are identified by the term alert. The term alert is used in this standard as a synonym for the combination of patient-related physiological alarms, technical alarms, and equipment user-advisory signals.

An alarm is a signal that indicates abnormal events occurring to the patient or the device system. A physiological alarm is a signal that either indicates that a monitored physiological parameter is out of specified limits or indicates an abnormal patient condition. A technical alarm is a signal that indicates a device system is either not capable of accurately monitoring the patient's condition or no longer monitoring the patient's condition.

The model defines three different levels of alarming. These levels represent different sets of alarm processing steps, ranging from a simple context-free alarm event detection to an intelligent device system alarm process. This process facilitates the prioritization of all device alarms, the latching of alarms if needed (a latched alarm does not stop when the alert condition goes away), and the production of audible and visual alarm indications for the user.

For consistent system-wide alarming, a particular medical device may provide either no alarming capability or exactly one level of alarming, which is dependent on the capabilities of the device. Each level is represented by one specific object class. In other words, either zero or one alarm object class (e.g., only Alert or only AlertStatus or only AlertMonitor; no combinations) is instantiated in the device containment tree. Multiple instances of a class are allowed.

NOTE—Medical device alarming is subject to various national and international safety standards (e.g., IEC 60601 series, ISO 9703 series). Considering requirements of current safety standards, objects in this standard define information contents only. Any implementation shall, therefore, follow appropriate standards for dynamic alarming behavior.

Figure 6 shows the UML class diagram for the Alert Package.

Instances of classes in the Alert Package area shall be contained in exactly one superior object.

The Alert Package model contains the classes described in 5.4.2 through 5.4.4.




Figure 6—Alert Package model

5.4.2 Alert class

The Alert class models the status of a simple alert condition check. As such, an instance represents a single alarm only. The alarm can be either a physiological alarm or a technical alarm condition of a related object [e.g., MDS, VMD, Metric]. In the case that neither an AlertStatus nor AlertMonitor object is used, a single Alert object is needed for each alert condition that the device is able to detect.

Each Alert object has a reference to an object defined in the Medical Package to which the alert condition relates.

NOTE—An Alert object is not dynamically created or deleted in cases where alert conditions start or stop. Rather, an existing Alert object's attribute values change (are updated) in these cases.

Example: An Alert object may represent the status of a process that checks for a limit violation physiological alarm of the heart rate signal. In the case of a violation of the limit, the object generates an event (i.e., attribute update) that represents this alert condition in the form of attribute value changes.

5.4.3 AlertStatus class

The AlertStatus class models the output of a process that considers all alert conditions in a scope that spans one or more objects. In contrast to an Alert object, an AlertStatus object collects all alert conditions related to a VMD object hierarchy or related to an MDS object and provides this information in list-structured attributes. Collecting all alarms together allows the implementation of first-level alarm processing where knowledge about the VMD or MDS can be used to prioritize alert conditions and to suppress known false alarm indications.

For larger scale devices without complete alarm processing, use of an AlertStatus object greatly reduces the overhead of a large number of Alert object instances.

If a device contains an AlertStatus object, it shall not contain any Alert or the AlertMonitor objects. Each VMD or MDS in the MDIB is able to contain at most one instance of the AlertStatus class.

Example: An ECG VMD derives a heart rate value. As the VMD is able to detect that the ECG leads are disconnected from the patient, its AlertStatus object reports only a technical alarm and suppresses a heart rate limit violation alarm in this case.

5.4.4 AlertMonitor class

The AlertMonitor class models the output of a medical device system alert processor. As such, it represents the overall device or system alert condition and provides a list of all alert conditions of the system in its scope. This list includes global state information and individual alarm state information that allows the implementation of a safety-standard-compliant alarm display on a remote system.

If a device contains an AlertMonitor object, it shall not contain any Alert or AlertStatus objects. An MDS shall not contain more than one AlertMonitor object.

Example: A patient-monitoring system provides alert information in the form of an AlertMonitor object to a central station. Alert information includes the current global maximum severity of audible and visual alert conditions on the monitor display as well as a list of active technical and physiological alarm conditions. The alert processor operates in a latching mode where physiological alarm conditions are buffered until they are explicitly acknowledged by a user.

5.5 Model for the System Package

5.5.1 General

The System Package deals with the representation of devices that derive or process vital signs information and comply with the definitions in this standard.

Figure 7 shows the UML class diagram for the System Package.

The System Package model contains the classes described in 5.5.2 through 5.5.13.




Figure 7—System Package model

5.5.2 VMS (virtual medical system) class

The VMS class is the abstract base class for all System Package classes in this model. It provides consistent naming and identification of system-related objects.

The VMS class is abstract and cannot be instantiated.

5.5.3 MDS class

The MDS class is an abstraction of a device that provides medical information in the form of instances of classes that are defined in the Medical Package of the DIM.

An instance of the MDS class is the top-level object in the device's MDIB and represents the instrument itself. Composite devices may contain additional MDS objects in the MDIB.

Further specializations of this class are used to represent differences in complexity and scope.

The MDS class is abstract and cannot be instantiated.

5.5.4 CompositeMultipleBedMDS class

The CompositeMultipleBedMDS class models a device that contains multiple MDS objects at multiple locations (i.e., multiple beds).

5.5.5 SinglePatientMDS class

The SinglePatientMDS is an abstract class that models a medical device that is associated with a single patient.

The SinglePatientMDS class is abstract and cannot be instantiated.

5.5.6 CompositeSingleBedMDS class

The CompositeSingleBedMDS class models a device that contains one or more SimpleMDS or HydraMDS objects at one location (i.e., a bed).

5.5.7 SingleSystemMDS class

The SingleSystemMDS class models a medical device that contains VMD objects and that may be contained by a CompositeMDS object.

The SingleSystemMDS class is abstract and cannot be instantiated.

5.5.8 SimpleMDS class

The SimpleMDS class models a medical device that contains a single VMD instance only (i.e., a single-purpose device).

5.5.9 HydraMDS class

The HydraMDS class models a device that contains multiple VMD instances (i.e., a multipurpose device).

5.5.10 Log class

The Log class is an abstract base class that models a storage container for important local system notifications and events. It is possible to define specialized classes for specific event types.

The Log class is abstract and cannot be instantiated.

5.5.11 EventLog class

The EventLog class models a general Log object that stores system events in a free-text representation.

Example: An infusion device may want to keep track of mode and rate changes by remote systems. When a remote operation is invoked, it creates an entry in its event log.

5.5.12 Battery class

For battery-powered devices, some battery information is contained in an MDS object in the form of attributes. If the battery subsystem is either capable of providing more information (i.e., a smart battery) or manageable, then a special Battery object is provided.

5.5.13 Clock class

The Clock class provides additional capabilities for handling date-related and time-related information beyond the basic capabilities of an MDS object. It models the real-time clock capabilities of an MDS object.

The Clock class is used in applications where precise time synchronization of medical devices is needed. This class provides resolution and accuracy information so that applications can synchronize real-time data streams between devices.

5.6 Model for the Control Package

5.6.1 General

The Control Package contains classes that allow remote measurement control and device control.

The model for remote control defined in this standard provides the following benefits:

- A system that allows remote control is able to explicitly register which attributes or features can be accessed or modified by a remote system.
- For attributes that can be remotely modified, a list of possible legal attribute values is provided to the controlling system.
- It is not mandatory that a remote-controllable item correspond to an attribute of a medical object.
- Dependence of a controllable item on internal system states is modeled.
- A simple locking transaction scheme allows the handling of transient states during remote control.

At least two different uses of remote control are considered:

- Automatic control may be done by some processes running on the controlling device. Such a process has to be able to discover automatically how it can modify or access the controllable items to provide its function.
- It is also possible to use remote control to present some form of control interface to a human operator. For this use, descriptions of functions, and possibly help information, need to be provided.

The basic concept presented here is based on Operation objects. An Operation object allows modification of a virtual attribute. This virtual attribute may, for example, be a measurement label, a filter state (on/off), or a gain factor. The attribute is called virtual because it need not correspond to any attribute in other objects instantiated in the system. A virtual attribute may correspond to multiple attributes and may be responsible for a series of actions.

Different specializations of the Operation class define how the virtual attribute is modified. A SelectItemOperation, for example, allows the selection of an item from a given list of possible item values for the attribute. A SetValueOperation allows the setting of the attribute to a value from a defined range with a specific step width (i.e., resolution).

The idea is that the Operation object provides all necessary information about legal attribute values. Furthermore, the Operation object defines various forms of text string to support a human user of the operation. It also contains grouping information that allows logical grouping of multiple Operation objects together when they are presented as part of a human interface.

Operation objects cannot directly be accessed by services defined in the service model in Clause 7. Instead, all controls shall be routed through the SCO (i.e., service and control object). Operation objects support a simple locking mechanism to prevent side effects caused by simultaneous calls.

The SCO groups together all Operation objects that belong to a specific entity (i.e., MDS, VMD). The SCO also allows feedback to a controlled device, for example, for a visual indication that the device is currently remote-controlled.

Figure 8 shows the UML class diagram for the Control Package:

The Control Package model contains the classes described in 5.6.2 through 5.6.10.




Figure 8—Control Package model

5.6.2 SCO class

An instance of the SCO (service and control object) class is responsible for managing all remote-control capabilities that are supported by a medical device.

Remote control in MDC is sensitive to safety and security issues. The SCO provides means for the following:

- Simple transaction processing, which prevents inconsistencies when a device is controlled from multiple access points (e.g., local and remote) and during the processing of control commands.
- State indications, which allows local and remote indication of ongoing controls.

5.6.3 Operation class

The Operation class is the abstract base class for classes that model remote-controllable items. Each Operation object allows the system to modify some specific item (i.e., a virtual attribute) in a specific way

defined by the Operation object. Operation objects are not directly accessible by services defined in the service model in Clause 7. All controls shall be routed through the SCO object (i.e., the parent) to allow a simple form of transaction processing.

The set of Operation objects instantiated by a particular medical device defines the complete remote control interface of the device. In this way a host system is able to discover the remote control capabilities of a device in the configuration phase.

The Operation class is abstract and cannot be instantiated.

5.6.4 SelectItemOperation class

An instance of the SelectItemOperation class facilitates the selection of one item out of a given list.

Example: The invasive pressure VMD may allow modification of its label. It uses a SelectItemOperation object for this function. The list of legal values supplied by the operation may be, for example, {ABP, PAP, CVP, LAP}. By invoking the operation, a user is able to select one value out of this list.

5.6.5 SetValueOperation class

An instance of the SetValueOperation class facilitates the adjustment of a value within a given range with a given resolution.

Example: A measurement VMD may allow adjustment of a signal gain factor. It uses a SetValueOperation object for this function. The SetValueOperation object provides the supported value range and step width within this range.

5.6.6 SetStringOperation class

An instance of the SetStringOperation class allows the system to set the contents of an opaque string variable of a given maximum length and format.

Example: An infusion device may allow a remote system to set the name of the infused drug in free-text form to show it on a local display. It defines an instance of the SetStringOperation class for this function. The SetStringOperation object specifies the maximum string length and the character format so that the device is able to show the drug name on a small display.

5.6.7 ToggleFlagOperation class

An instance of the ToggleFlagOperation class allows operation of a toggle switch (with two states, e.g., on/off).

Example: An ECG VMD may support a line frequency filter. It uses a ToggleFlagOperation object for switching the filter on or off.

5.6.8 ActivateOperation class

An instance of the ActivateOperation class allows a defined activity to be started (e.g., a zero pressure).

Example: The zero procedure of an invasive pressure VMD may be started with an ActivateOperation object.

5.6.9 LimitAlertOperation class

An instance of the LimitAlertOperation class allows adjustment of the limits of a limit alarm detector and the switching of the limit alarm to on or off.

5.6.10 SetRangeOperation class

An instance of the SetRangeOperation class allows the selection of a value range by the simultaneous adjustment of a low and high value within defined boundaries.

Example: A measurement VMD may provide an analog signal input for which the signal input range can be adjusted with a SetRangeOperation object.

5.7 Model for the ExtendedServices Package

5.7.1 General

The ExtendedServices Package contains classes that provide extended medical object management services that allow efficient access to medical information in communicating systems. Such access is achieved by a set of objects that package attribute data from multiple objects in a single event message.

The classes providing extended services are conceptually derived from ISO/OSI system management services defined in the ISO/IEC 10164 family of standards (specifically Part 5 and Part 13). The definitions have been adapted to and optimized for specific needs in the area of vital signs communication between medical devices.

Figure 9 shows the UML class diagram for the ExtendedServices Package.

The ExtendedServices Package model contains the classes described in 5.7.2 through 5.7.10.




Figure 9—ExtendedServices Package model

5.7.2 Scanner class

The Scanner class is an abstract base class that models an observer and “summarizer” of attribute values. A Scanner object observes attributes of managed medical objects and generates summaries in the form of notification event reports. These event reports contain data from multiple objects, which provide a better communication performance compared to separate polling commands (e.g., GET service) or multiple individual event reports from all object instances.

Subclasses of the Scanner class may be instantiated either by the agent system itself or by the manager system (e.g., dynamic scanner creation by using the CREATE service).

The Scanner class is abstract and cannot be instantiated.

5.7.3 CfgScanner (configurable scanner) class

The CfgScanner class is an abstract base class that defines a special attribute (i.e., the Scan-List attribute) that allows the system to configure attributes of an object are scanned. The Scan-List attribute may be modified either by the agent system (i.e., auto-configuration or pre-configuration) or by the manager system (i.e., full dynamic configuration by using the SET service).

A CfgScanner object may support different granularity for scanning:

- a) Attribute group (i.e., a defined set of attributes): The Scan-List attribute contains the identifiers (IDs) of attribute groups, and all attributes in the group are scanned.
- b) Individual attribute: The Scan-List attribute contains the IDs of all attributes that are scanned.

In order to deal efficiently with optional attributes, the attribute group scan granularity is recommended for CfgScanner objects.

The CfgScanner class is abstract and cannot be instantiated.

5.7.4 EpiCfgScanner (episodic configurable scanner) class

An instance of the EpiCfgScanner class is responsible for observing attributes of managed medical objects and for reporting attribute changes in the form of unbuffered event reports.

The unbuffered event report is triggered only by attribute value changes. If an EpiCfgScanner object uses attribute group scan granularity, the event report contains all attributes of the scanned object that belong to this attribute group if one or more of these attributes changed their value.

Example: A medical device provides heart beat detect events in the form of an Enumeration object. A display application creates an instance of the EpiCfgScanner object and adds the observed value of the Enumeration object to the Scan-List attribute. The scanner instance afterwards sends a notification when the Enumeration object reports a heart beat.

5.7.5 PeriCfgScanner (periodic configurable scanner) class

An instance of the PeriCfgScanner class is responsible for observing attributes of managed medical objects and for periodically reporting attribute values in the form of buffered event reports. A buffered event report contains the attribute values of all available attributes that are specified in the scan list, independent of attribute value changes.

If the scanner operates in a special superpositive mode, the buffered event report contains all value changes of attributes that occurred in the reporting period; otherwise, the report contains only the most recent attribute values.

Example: A data logger creates an instance of the PeriCfgScanner class and configures the scanner so that it sends an update of the observed value attributes of all Numeric objects in the MDIB every 15 s.

5.7.6 FastPeriCfgScanner (fast periodic configurable scanner) class

The FastPeriCfgScanner class is specialized for scanning the observed value attribute of RealTimeSampleArray objects. This special scanner class is further optimized for low-latency reporting and efficient communication bandwidth utilization, which is required to access real-time waveform data.

Example: A real-time display application (e.g., manager system) wants to display ECG waveforms. It instantiates a FastPeriCfgScanner object on the agent system (e.g., server device) and requests periodic updates of all ECG leads.

5.7.7 UcfgScanner (unconfigurable scanner) class

The UcfgScanner class is an abstract base class. An UcfgScanner object scans a predefined set of managed medical objects that cannot be modified. In other words, an UcfgScanner object typically is a reporting object that is specialized for one specific purpose.

The UcfgScanner class is abstract and cannot be instantiated.

5.7.8 ContextScanner class

An instance of the ContextScanner class is responsible for observing device configuration changes. After instantiation, a ContextScanner object is responsible for announcing the object instances in the device's MDIB. A ContextScanner object provides the object instance containment hierarchy and static attribute values.

In case of dynamic configuration changes, a ContextScanner object sends notifications about new object instances or deleted object instances.

Example: A data logger creates a ContextScanner instance in an agent MDIB to receive notifications about MDS configuration changes when new measurement modules are plugged in (i.e., new VMD instance) or when such a module is unplugged (i.e., VMD instance deleted).

5.7.9 AlertScanner class

An instance of the AlertScanner class is responsible for observing the alert-related attribute groups of objects modeled in the Alert Package. As alarming in general is security-sensitive, AlertScanner objects are not configurable (i.e., all or no Alert objects are scanned).

An AlertScanner object sends event reports periodically so that timeout conditions can be checked.

5.7.10 OperatingScanner class

An instance of the OperatingScanner class is responsible for providing all information about the operating and control system of a medical device.

In other words, an OperatingScanner instance maintains the configuration of Operation objects contained in SCOs (by sending CREATE notifications for Operation objects), it scans transaction-handling-related SCO attributes, and it scans Operation attributes. Because SCOs and Operation objects may have dependencies, the OperatingScanner is not configurable.

5.8 Model for the Communication Package

5.8.1 General

The Communication Package deals with objects that enable and support basic communication.

Figure 10 shows the UML class diagram for the Communication Package.

The Communication Package model contains the classes described in 5.8.2 through 5.8.7.




Figure 10—Communication Package model

5.8.2 CommunicationController class

The CommunicationController class models the upper layer and lower layer communication profile of a medical device.

CommunicationController objects are the access points for retrieving DeviceInterface attributes and management information base element (MibElement) attributes for obtaining management information related to data communications.

The CommunicationController class is abstract and cannot be instantiated. Two instantiable subclasses are defined: BCC and DCC. A medical device MDIB contains either no CommunicationController object or one BCC object or one DCC object (depending on its role).

5.8.3 DCC (device communication controller) class

The DCC class is the CommunicationController subclass used by medical devices operating as agent systems (i.e., association responders).

DCC objects shall contain one or more DeviceInterface objects.

5.8.4 BCC (bedside communication controller) class

The BCC class is the CommunicationController subclass used by medical devices operating as manager systems (i.e., association requestors).

BCC objects shall contain one or more DeviceInterface objects.

5.8.5 DeviceInterface class

The DeviceInterface class models a particular interface, i.e., port. The port is either a logical or a physical end point of an association for which (e.g., statistical) data captured in the MibElement objects can be independently collected.

Both an agent system and a manager system can have multiple logical or physical ports, depending on the selected implementation of the lower layer communication system.

DeviceInterface objects are not accessible by CMDISE services. DeviceInterface objects contain at least one Mib-Element object (i.e., the DeviceInterfaceMibElement object, which represents device interface properties), which can be accessed by a special method defined by the CommunicationController object.

5.8.6 MibElement class

An instance of the MibElement class contains statistics and performance data for one DeviceInterface object.

The MibElement class is abstract and cannot be instantiated

Management information for a communication link is dependent on the lower layers of the communication stack (i.e., lower layers profile). Various MibElement subclasses are defined to group management information in defined packages, which can be generic or dependent on specific transport profiles. This standard defines two concrete subclasses of MibElement. Additional MibElement specializations may be defined in the future by other standards.

MibElement objects are not directly accessible. Their attributes can be accessed only through a CommunicationController object. MibElement objects are not part of the device's MDIB.

5.8.7 DeviceInterfaceMibElement class

An instance of the DeviceInterfaceMibElement class describes the properties of the device interface. If a Medical Device System (MDS) implements a CommunicationController then a DeviceInterfaceMibElement must be implemented as well.

5.8.8 SpecializedMibElement class

The SpecializedMibElement class is the abstract base class for all classes defined for managing information beyond that which is handled by the DeviceInterfaceMibElement. Only one subclass of SpecializedMibElement is defined in this standard. More specializations may be defined in the future by other standards.

5.8.9 GeneralCommunicationStatisticsMibElement class

The GeneralCommunicationStatisticsMibElement class is a subclass of SpecializedMibElement. The GeneralCommunicationStatistics class models typical communication statistics that are generally applicable.

5.9 Model for the Archival Package

5.9.1 General

The Archival Package deals with storage and representation of biosignals, status, and context information in an on-line or an off-line archive.

Figure 11 shows the UML class diagram for the Archival Package.

The Archival Package model contains the classes described in 5.9.2 through 5.9.8.




Figure 11—Archival Package model

5.9.2 MultipatientArchive class

Instances of the MultipatientArchive class group together multiple PatientArchive objects referring to different patients.

Example: A drug study may be documented in the form of a MultipatientArchive object containing multiple PatientArchive objects that show how the drug affected the monitored vital signs.

5.9.3 PatientArchive class

Instances of the PatientArchive class group patient-related information (e.g., vital signs data, treatment data, and patient demographics) together in a single archive object. This object relates to static (i.e., invariant) data in a PatientDemographics object only.

Example: A hospital may store data about multiple visits of a single patient in a PatientArchive object that contains a number of SessionArchive objects, each documenting vital signs information recorded during a specific visit in a hospital department.

5.9.4 SessionArchive class

The SessionArchive class models a patient visit or a continuous stay in a hospital or hospital department. Diagnostic treatments performed during this time period are represented by SessionTest objects contained in a SessionArchive object. A SessionArchive object refers to dynamic (i.e., variant) data in a PatientDemographics object.

5.9.5 PhysicianArchive class

The Physician class models the physician responsible for the set of diagnostic and therapeutic activities during the time period represented by a SessionArchive object.

5.9.6 SessionTest class

The SessionTest class models vital signs information of a single patient that is recorded during a single examination or diagnostic treatment. Instances of the SessionTest class contain vital signs metrics in form of PM-Store objects. It also may contain information about equipment that was used for recording (in the form of relations to MDS and Ancillary objects).

Example: Vital signs information recorded during a ECG stress test examination is organized in a SessionTest object.

5.9.7 SessionNotes class

The SessionNotes class models a container for diagnostic data, patient care details, and treatment-related information in the form of textual data.

5.9.8 Ancillary class

The Ancillary class is not further defined in this standard. This class is present in the model to indicate that information from sources other than devices within the scope of this standard are permitted to be included in (or referenced by) the SessionTest object.

Example: Image data that complies with the DICOM (ISO 12052) standard are permitted to be included in the SessionTest object as ancillary data.

5.10 Model for the Patient Package

5.10.1 General

The Patient Package deals with all patient-related information that is relevant in the scope of this standard, but is not vital signs information modeled in the Medical Package.

Figure 12 shows the UML class diagram for the Patient Package:

The Patient Package model contains one class (see 5.10.2).




Figure 12—Patient Package model

5.10.2 PatientDemographics class

Instances of the PatientDemographics class store patient census data.

This standard provides minimal patient information as typically required by medical devices. A complete patient record is outside the scope of this standard.

5.11 DIM—Dynamic model

5.11.1 General

Subclause 5.11 defines global dynamic system behavior.

Note that dynamic object behavior resulting from invocation of object management services is part of the class definitions in Clause 6.

5.11.2 MDS communication finite state machine (FSM)

Figure 13 shows the MDS FSM for a communicating medical device that complies with the definitions in this standard. The FSM is used to synchronize the operational behavior of manager (i.e., client) systems and agent (i.e., server) systems.




Figure 13—MDS FSM

After power-up, the device performs all necessary local initializations (i.e., boot phase) and ends up in the disconnected state, where it waits for connection events.

When a connection event is detected, the device tries to establish a logical connection (i.e., an association) with the other device. A manager (i.e., client) system is the association requester, and an agent (i.e., server) system is the association responder. Basic compatibility checks are performed in the associating state.

After successful association, configuration data (i.e., the MDIB structure) is exchanged by the use of services and extended services (in particular, the ContextScanner object) as defined in this standard. Additional information (e.g., MDS attributes) is supplied that allows further compatibility and state checks.

After configuration, medical data are exchanged by using services and extended services as defined in this standard. Dynamic reconfiguration is allowed in the operating state. If the device or the type of reconfiguration does not allow dynamic handling in the operating state, a special “reconfiguring” state is provided.

If an event indicates an intention to disconnect, the disassociating state is entered.

The diagram does not show error events. Fatal error events take the state machine out of the operating state.

NOTE—This state machine describes the behavior of the MDS communication system only. Usually the device must perform its medical function independent of the communication system.

The FSM is considered a part of the MDS class. The MDS-Status attribute reflects the state of the machine. The MDS may announce state changes in the form of attribute change event reports.

Specific application profiles shall use this state machine as a general guideline, but they may define specific deviations to fulfill specific profile-dependent requirements or assumptions.

5.11.3 Communicating systems—Startup object interaction diagram

Figure 14 presents the UML sequence diagram that visualizes the startup phase after connecting two devices.




Figure 14—Startup after connection

It is assumed here that, conceptually, messages are exchanged between the CommunicationController objects (using the device interface).

Some form of connection indication is necessary to make the manager system aware of a new agent on the network. This mechanism is dependent on the specific lower layer implementation; therefore, it is not further defined in this standard.

Specific application profiles shall use this interaction diagram as a general guideline, but they may define specific deviations to fulfill specific profile-dependent requirements or assumptions.

5.11.4 Communication Package—MibElement data access

Figure 15 presents the UML sequence diagram that shows how a manager system accesses the MibElement data using the objects defined in the Communication Package (see 5.8).




Figure 15—MibElement data access

The diagram assumes the following:

- An association is established between the agent and the manager.
- The configuration phase is finished, and the manager has an image of the agent's MDIB.
- The DCC object is part of the agent's MDIB.

The manager first uses the GET service to retrieve all DCC attributes and their values. The attributes specify how many DeviceInterface objects exist.

The manager uses the ACTION service with the CommunicationController's Get-Mib-Data method to retrieve the attributes of the mandatory DeviceInterfaceMibElement object. The MibElement attribute variables specify if any additional MibElement objects are available for the interface. If so, the manager can use the same ACTION command to retrieve the additional management information represented in the MibElement objects.

5.11.5 Dynamic object relations

5.11.5.1 General

This subclause deals with relations between managed medical objects (i.e., instances of classes that are defined as managed objects in this standard).

Generally, the relationships between objects that are defined in the package models are dynamic.

Example: A modular patient monitor is modeled as an MDS. Measurement modules are modeled as VMDs. If a new module is connected to the monitor, there is also a new relationship between the MDS and the new VMD instance.

Communicating agent systems (i.e., agents) use services defined in this standard to announce configuration change events to other connected systems. These manager systems (i.e., managers) modify their view of the agent MDIB.

Not only does a vital signs information archive have to update its configuration, but it also has to permanently store these connection and disconnection events.

Example: An instance of the SessionArchive class represents the stay of a patient in the intensive care unit (ICU). During that period, new devices are connected to the patient to increase the number of recorded vital signs. They are removed again as soon as the patient's condition stabilizes. The SessionArchive object shall not delete recorded data when the recording device is disconnected.

Thus, in certain applications (e.g., archival applications), object relationships have associated information that must be captured.

When required, the relationships themselves can be considered to be special managed objects as shown in Figure 16.




Figure 16—Example of a relationship represented by an object

The example in Figure 16 shows a relation between a SessionArchive object and an MDS object. The relation is represented as an object. This object has attributes that provide information, for example, about time of connection and disconnection.

Modeling the relations as objects has the advantage that information can be defined in the form of attributes. It is not necessary to assign the attributes to one or both objects that are related.

How dynamic object relations are handled by systems that comply with the definitions in this standard is defined in 5.11.5.2 and 5.11.5.3.

5.11.5.2 Dynamic object relations in communicating systems

Relations between objects that are defined in the package models are considered configuration information. The ContextScanner class provides configuration information in the form of object create notifications and object delete notifications. No means for persistent storage of past (i.e., old) configuration information is defined for communicating systems.

Other relations between objects (e.g., to reference a source signal in derived data) are specified in the form of attributes of the corresponding objects (e.g., the Vmo-Source-List attribute of the Metric object). Dynamic changes of these attributes are announced by attribute change notification events.

5.11.5.3 Dynamic object relations in archival systems

An archival system may need to provide persistent storage for configuration information. In this case, the corresponding relations are considered to be represented by objects, as shown in 5.11.5.

An archival system that uses a data format in compliance with the definitions in this standard has to provide means to store (i.e., archive) the attributes of dynamic relationship objects.

6. DIM class definitions

6.1 Overview

6.1.1 General

Clause 6 contains the definitions for all classes in the DIM. The packages defined in the model are used to categorize classes. Attributes, behavior, and notifications are defined for each class.

6.1.2 Notation

Each class is defined in a separate subclause (see 6.2 through 6.10). Further subclauses define attributes, behavior, and notifications for the classes.

The class is defined in a subclause as follows:

Class:	Defines the name of the class.
Description:	Gives a short, informative textual description of the class.
Superclass:	Defines the class from which this class inherits attributes, attribute groups, behavior, and notifications.
Subclasses:	Defines classes that inherit attributes, attribute groups, behavior, and notifications from this class.
Name Binding:	Defines the attribute that uniquely identifies an object instance in a given context. For manageable objects, this definition is the Handle attribute and the context is the device system (i.e., single MDS context). See also 6.1.3.5.
Registered As:	Defines a term that is defined in the nomenclature to allow unique identification [e.g., OID, code] of the class.

The attributes of each class are defined in an attribute subclause. Tables define attribute names, unique attribute IDs, attribute data types, and certain qualifiers. The qualifiers have the following meaning:

M	attribute is mandatory
O	attribute is optional
C	attribute is conditional; availability of attribute depends on a predefined condition

Unless otherwise noted, the attribute definition tables do not show inherited attributes again. In other words, the attribute lists of all superclasses have to be checked for a complete list of attributes.

Attributes are assigned to, or grouped together in, attribute groups so attributes can be classified according to their use (e.g., static context information, dynamic context information, value observations). The grouping also makes it possible to effectively deal with optional attributes: A GET service facilitates the retrieval of all members of the group so an application is able to determine which attributes are actually present in a particular object instance.

Attribute groups may be extensible. In other words, a derived class is able to add additional members to an inherited attribute group.

Attribute groups are also defined in tables that specify group identification and the list of group members. Inherited attribute groups are not shown in the attribute group tables again unless these groups are extensible.

Special instance methods or functions that may be called on an object are defined in a behavior subclause. These methods can be invoked by the CMDISE ACTION service.

Events generated by an object (other than a generic attribute change notification) are defined in a notifications subclause. An object reports these events by using the CMDISE EVENT REPORT service.

6.1.3 Common data types

This subclause defines a set of ASN.1 data types that are used in the class definitions.

The external nomenclature reference data type is a special data type that is defined for this function as follows:

6.1.3.1 Integer and bit string data types

For representing integer numbers, the class definitions use fixed-size data types only. The bit string data type represents a bit field where each single bit has a defined meaning (i.e., flag fields). The following integer data types and bit string data types are used:

```
--
-- 8-bit unsigned integer
--
INT-U8 ::= INTEGER (0..255)

--
-- 8-bit signed integer
--
INT-I8 ::= INTEGER (-128..127)

--
-- 16-bit unsigned integer
--
INT-U16 ::= INTEGER (0..65535)

--
-- 16-bit signed integer
```

```

--
INT-I16 ::= INTEGER (-32768..32767)

--
-- 32-bit unsigned integer
--
INT-U32 ::= INTEGER (0..4294967295)

--
-- 32-bit signed integer
--
INT-I32 ::= INTEGER (-2147483648..2147483647)

--
-- 8-bit bit string
--
BITS-8 ::= BIT STRING (SIZE(8))

--
-- 16-bit bit string
--
BITS-16 ::= BIT STRING (SIZE(16))

--
-- 32-bit bit string
--
BITS-32 ::= BIT STRING (SIZE(32))

--
-- 8-bit octet string
--
OCTET STRING-8 ::= OCTET STRING (SIZE(8))

```

NOTE 1—When interpreting integer numbers, the representation (e.g., little endian versus big endian) has to be considered. Communicating systems negotiate this representation at association (i.e., transfer syntax). Archival data formats have to provide a mechanism to uniquely identify integer representation (e.g., a field in a specification header).

NOTE 2—In the class definitions, data types with named constants or named bits also use the above notation for simplicity. The above notation is illegal ASN.1 syntax, but it can be easily transformed to the correct syntax.

6.1.3.2 Identification data type

All elements (e.g., classes, objects, measurement types) that need unique identification are assigned an OID. The set of valid OIDs for this standard is defined in ISO/IEEE 11073-10101. The nomenclature is split into a set of partitions, and each partition has its own range of 16-bit codes. In other words, the 16-bit code is context-sensitive.

The 16-bit identification data type is defined as follows:

```

--
-- OID type as defined in nomenclature (do not confuse with ASN.1 OID)
-- 16-bit integer type
--
OID-Type ::= INT-U16

```

For IDs that are not part of the standard nomenclature (i.e., private or manufacturer-specific codes), a special type is defined as follows:

```

--
-- Private OID

```

```
--
PrivateOid ::= INT-U16
```

6.1.3.3 Handle data type

The handle data type is used for efficient, locally unique identification of all managed medical object instances. (*Locally unique* means unique within one MDS context.) This data type is defined as follows:

```
--
-- handle
--
HANDLE ::= INT-U16
```

6.1.3.4 Instance number data type

The instance number data type is used to distinguish object instances of the same type or object instances that are not directly manageable (i.e., used, e.g., as the Name Binding attribute for Operation objects). This data type is defined as follows:

```
--
-- Instance Number
--
InstNumber ::= INT-U16
```

6.1.3.5 Global object identification

Handle and instance number data types must be unique inside one specific naming context (e.g., handles are unique within at least one MDS context). This uniqueness allows the identification of an object instance within its naming context by one single, small identifier.

To address larger scale systems, a context ID field at the MDS level within an MDIB is added to the handle data type so that multiple device systems can be distinguished. This global handle data type is defined as follows:

```
--
-- MDS Context ID
--
MdsContext ::= INT-U16

--
-- Global handle allows identification of an object in a larger scale system
--
GLB-HANDLE ::= SEQUENCE {
    context-id MdsContext,
    handle     HANDLE
}

--
-- Managed OID as a type for complete global object identification
--
ManagedObjectId ::= SEQUENCE {
    m-obj-class OID-Type,
    m-obj-inst  GLB-HANDLE
}
```

Example: A medical device may interface with further medical devices (i.e., sub-devices). In the MDIB, this device may model these sub-devices as individual MDS objects with their own naming context. In this way, name space collisions (e.g., duplicate handle values, duplicate nomenclature codes) can be avoided without reassigning handle values. A manager system needs to interpret the

MDS context IDs together with handle values to uniquely identify object instances within this composite MDIB. The context IDs are assigned when the MDIB is created by ContextScanner object create notifications.

Assumptions and possible restrictions about different naming contexts within an MDIB are profile dependent.

6.1.3.6 Type ID data type

The type ID data type is used in the VMOs and VMS objects to provide specific static information about the type of an object instance (e.g., blood pressure could be the type of a Numeric object). Codes defined in the nomenclature are used. The nomenclature contains a number of partitions, and code values are unique only within one partition. As the type ID data type should be context-free, the partition of the nomenclature code is also provided. This data type is defined as follows:

```
--
-- Type ID
--
TYPE ::= SEQUENCE {
    partition    NomPartition,
    code         OID-Type
}

--
-- The following nomenclature partitions exist
--
NomPartition ::= INT-U16 {
    nom-part-unspec(0),
    nom-part-obj(1),           -- object-oriented partition
    nom-part-metric(2),       -- metric [supervisory control and data acquisition (SCADA)] partition
    nom-part-alert(3),        -- alerts/events partition
    nom-part-dim(4),          -- dimensions partition
    nom-part-vattr(5),        -- virtual attribute partition for Operation objects
    nom-part-pgrp(6),         -- parameter group ID partition
    nom-part-sites(7),        -- measurement and body site locations
    nom-part-infrastruct(8),   -- infrastructure elements partition
    nom-part-feff(9),         -- file exchange format partition
    nom-part-ecg-extn(10),     -- ECG extensions partition
    nom-part-icdo(11),        -- IDCO partiion
    nom-part-phddm(128),      -- phd disease management partition
    nom-part-hf(129),         -- health and fitness partition
    nom-part-ageind(130),     -- aging independently partition
    nom-part-returncodes(255), -- return codes patition
    nom-part-ext-nom(256),     -- IDs of other nomenclatures and dictionaries
    nom-part-settings(258),   -- settings partition
    nom-part-priv(1024)       -- private partition
}
```

6.1.3.7 Attribute value assertion data type

A number of services defined in the service model in Clause 7 provide access to the attributes of an object (e.g., GET, SET). Typically, the attribute has to be identified by means of an attribute ID. The attribute data type itself is dependent on this ID. The attribute value assertion data type represents this ID-value pair and is defined as follows:

```
AVA-Type ::= SEQUENCE {
    attribute-id      OID-Type,
    attribute-value    ANY DEFINED BY attribute-id
}
```

6.1.3.8 Attribute list data type

Frequently, a list of attribute ID–attribute value pairs is needed. The attribute list data type is a special data type that is provided for this situation and is defined as follows:

AttributeList ::= SEQUENCE OF AVA-Type

6.1.3.9 Attribute ID list data type

Frequently, a list of attribute IDs is used. The attribute ID list data type is a special type that is provided for convenience and is defined as follows:

AttributeIdList ::= SEQUENCE OF OID-Type

6.1.3.10 Floating point type data type

For performance and efficiency, the class definitions use the floating point type data type, which is a special data type for representing floating point numbers. It is assumed that this data type is 32 bits. This data type is defined as follows:

```
--
-- 32-bit float type; the integer type is a placeholder only
--
FLOAT-Type ::= INT-U32
```

The specific floating point number format is either explicitly negotiated at association or implicitly defined by the association application context.

6.1.3.11 Relative time data type

The relative time data type is a high-resolution time definition relative to some event (e.g., a synchronization event at startup). This data type is used to position events relative to each other. It is defined as follows:

```
--
-- Relative time has a resolution of 125 μs [least significant bit (LSB)], which is sufficient for sampling rates up to
-- 8 kHz and spans time periods up to 6.2 days
--
RelativeTime ::= INT-U32
```

Note that the time accuracy is defined by the system itself.

6.1.3.12 High-resolution relative time data type

If either the resolution or the time span of the previously defined relative time data type is not sufficient, a high-resolution relative time data type is defined. The data type is 64 bits long. However, as there is no 64-bit integer data type defined, an opaque (i.e., string) data structure is used. The type is defined as follows:

```
--
-- 64-bit (8 byte) high-resolution time, the LSB represents 1 μs
--
HighResRelativeTime ::= OCTET STRING-8
```

Note that the time accuracy is defined by the system itself.

6.1.3.13 Absolute time data type

Absolute time data type specifies the time of day with at least a resolution of 1 s. For efficiency, the values in the structure are BCD-encoded (i.e., 4-bit nibbles). The year 1996, for example, is represented by the hexa- decimal value 0x19 in the century field and the hexadecimal value 0x96 in the year field. This format can easily be converted to character-based or integer-based representations. The absolute time data type is defined as follows:

```
AbsoluteTime ::= SEQUENCE {
    century      INT-U8,
    year         INT-U8,
    month        INT-U8,
    day          INT-U8,
    hour         INT-U8,
    minute       INT-U8,
    second       INT-U8,
    sec-fractions INT-U8      -- hundredths of second if available
}
```

6.1.3.14 Date data type

The date data type is used to specify a certain calendar date. For ease of transformation, the data type has the same encoding (i.e., BCD) as the absolute time data type. The date data type is defined as follows:

```
Date ::= SEQUENCE {
    century INT-U8,
    year    INT-U8,
    month   INT-U8,
    day     INT-U8
}
```

6.1.3.15 Data Type: OperationalState

The operational state data type defines if a certain object or other property is enabled or disabled. The definitions are derived from ISO/IEC 10164-2 and are as follows:

```
OperationalState ::= INT-U16 {
    disabled(0),
    enabled(1),
    notAvailable(2)
}
```

6.1.3.16 Administrative state data type

The administrative state data type defines if a certain object is locked or unlocked. The definitions are derived from ISO/IEC 10164-2 and are as follows:

```
AdministrativeState ::= INT-U16 {
    locked(0),
    unlocked(1),
    shuttingDown(2)
}
```

6.1.3.17 Color data type

The color data type represents the basic RGB colors and is defined as follows:

--

```
-- 3 bits representing RGB, respectively
--
SimpleColour ::= INT-U16 {
    col-black(0),          -- 000
    col-red(1),             -- 100
    col-green(2),           -- 010
    col-yellow(3),          -- 110
    col-blue(4),            -- 001
    col-magenta(5),         -- 101
    col-cyan(6),            -- 011
    col-white(7),           -- 111
}
```

6.1.3.18 Locale data type

The locale data type shall be used to specify language and encoding information for data types that represent human-readable text strings. This data type is defined as follows:

```
Locale ::= SEQUENCE {
    language  INT-U32,          -- from ISO 639-1 or ISO 629-2, see below for encoding
    country   INT-U32,          -- from ISO 3166-1, ISO 3166-2, or ISO 3166-3, see below for encoding
    charset    CharSet,         -- format of character encoding
    str-spec   StringSpec
}

--
-- Charset names correspond to Internet Assigned Numbers Authority (IANA), the numeral constants are the
-- IANA MIBenum values for registered charsets
--
CharSet ::= INT-U16 {
    charset-unspec(0),
    charset-iso-10646-ucs-2(1000), -- ISO 10646 two-octet character encoding scheme, big endian
    charset-iso-10646-ucs-4(1001), -- ISO 10646 four-octet character encoding scheme, big endian
    charset-iso-8859-1(4),          -- encoding according to ISO/IEC 8859 Part 1
    charset-iso-8859-2(5),          -- encoding according to ISO/IEC 8859 Part 2
    charset-iso-8859-3(6),          -- encoding according to ISO/IEC 8859 Part 3
    charset-iso-8859-4(7),          -- encoding according to ISO/IEC 8859 Part 4
    charset-iso-8859-5(8),          -- encoding according to ISO/IEC 8859 Part 5
    charset-iso-8859-6(9),          -- encoding according to ISO/IEC 8859 Part 6
    charset-iso-8859-7(10),         -- encoding according to ISO/IEC 8859 Part 7
    charset-iso-8859-8(11),         -- encoding according to ISO/IEC 8859 Part 8
    charset-iso-8859-9(12),         -- encoding according to ISO/IEC 8859 Part 9
    charset-iso-8859-10(13),        -- encoding according to ISO/IEC 8859 Part 10
    charset-iso-8859-13(109),       -- encoding according to ISO/IEC 8859 Part 13
    charset-iso-8859-14(110),       -- encoding according to ISO/IEC 8859 Part 14
    charset-iso-8859-15(111),       -- encoding according to ISO/IEC 8859 Part 15
    charset-iso-2022-kr(37),        -- encoding according to RFC 1557 (Korean Character Encoding)
    charset-ks-c-5601(36),          -- encoding according to Korean Industrial Standard, KSC 5601-1987
    charset-iso-2022-jp(39),        -- encoding according to RFC 1468 (Japanese Character Encoding)
    charset-iso-2022-jp-2(40),      -- encoding according to RFC 1554 (Japanese Character Encoding)
    charset-jis-x0208(63),          -- encoding according to JIS X0208:1983,1990
    charset-iso-2022-cn(104),       -- encoding according to RFC 1922 (Chinese Character Encoding)
    charset-gb-2312(2025),         -- encoding according to Chinese Graphic Character Set, GB 2312:1980
}

StringSpec ::= SEQUENCE {
    str-max-len INT-U16,          -- maximum string length
    str-flags    StringFlags      -- specific flags for string representation and coding
}

StringFlags ::= BITS-16 {
```

```

    str-flag-nt(0)          -- strings are null terminated
}

```

The field `Locale::language` shall represent the lowercase ISO/IEC 646 representation of a two-character language ID code from ISO 639-1 or ISO 639-2. For processing convenience, the language ID is stored in a 32-bit integer field. The first octet of the code is stored in the most significant byte of this field. Unused octets in the field are filled with NULL bytes.

Example:

```

Language:      "English"
Language identifier: "en"
Encoding:      65 6E 00 00h

```

The field `Locale::country` shall represent the uppercase ISO/IEC 646 representation of a two-character country ID code from ISO 3166-1, ISO 3166-2, or ISO 3166-3. For processing convenience, the country ID is stored in a 32-bit integer field. The first octet of the code is stored in the most significant byte of this field. Unused octets of the field are filled with NULL bytes.

The country code can be used to distinguish between certain aspects of the same language used in different countries, e.g., English in the United States versus English in the United Kingdom.

If no specific country is defined, this field shall be set to 0.

Example:

```

Country:      "United States"
Country identifier: "US"
Encoding:      55 53 00 00h

```

The field `Locale::charset` denotes the encoding scheme of the characters used in string data types representing readable text.

For interoperability, the character encoding scheme `iso-10646-ucs-2` is recommended. This encoding scheme corresponds to ISO/IEC 10646 with a 2-octet (i.e., 16-bit per character) big-endian encoding, representing the basic multilingual plane (BMP). The character codes within ISO/IEC 10646 do not correspond directly with glyphs, i.e., the graphical representation of a character. Also the ISO/IEC 10646 is language independent. Other `Locale::charset` values may be more language dependent because they also specify a certain character repertoire.

6.1.3.19 External nomenclature reference data type

In certain cases, it is required to refer to standard coding systems (i.e., nomenclatures) that are outside the scope of this standard.

Example: The nomenclature defined in this standard does not define diagnostic codes or procedure codes. However, it is possible to reference a different coding system and provide the information in the form of an external code.

The external nomenclature reference data type is a special data type that is defined for this function as follows:

```

ExtNomenRef ::= SEQUENCE {
    nomenclature-id      OID-Type,          -- external nomenclature ID from external
                                         -- nomenclature partition
    nomenclature-code    ANY DEFINED BY nomenclature-id
}

```

6.1.3.20 External object relation list data type

In certain cases, managed medical objects defined in the DIM may have relations to other objects that are not defined in this standard (i.e., they are external to the definitions).

The external object relation list data type can be used to provide information about these objects and the particular relation. This data type is defined as follows:

```

--
-- ExtObjRelationList
--
ExtObjRelationList ::= SEQUENCE OF ExtObjRelationEntry

ExtObjRelationEntry ::= SEQUENCE {
    relation-type          OID-Type,
    related-object         OID-Type,
    relation-attributes    AttributeList
}

```

Example 1: In certain situations, it is necessary to record specific production information (e.g., serial number) of a transducer that is used to derive a measurement. The transducer in this standard is not defined as a managed medical object. Therefore, the VMD object instances use a relation entry to supply the information, e.g., {relation-type = is-connected; related-object = Transducer; relation-attributes = {model, “A-Model,” serial-number = “12345”}}.

Example 2: A certain numerical measurement value is manually validated by a nurse. A charting system keeps information about manual validations. The nurse is not modeled as an object in this standard. Therefore, the charting system uses a relation entry as an additional attribute of the Numeric object, e.g., {relation-type = validated-by; related-object = Nurse; relation-attributes = {name, “C. Smith,” date, “041295”}}

The external object relation list data type is a very powerful concept to extend the information model without really defining additional classes of objects.

6.2 Top class

Class:	Top
Description:	The Top class is the common inheritance base for most of the classes in the DIM.
Superclass:	--
Subclasses:	PM-Segment, VMO, Battery, Clock, Log, VMS, Operation, Scanner, CommunicationController, MultiPatientArchive, PatientArchive, Physician, SessionArchive, SessionNotes, SessionTest, PatientDemographics
Name Binding:	-
Registered As:	MDC_MOC_TOP

6.2.1 Attributes

The Top class defines the attributes in Table 1.

Table 1—Top class attributes

Attribute name	Attribute ID	Attribute type	Remark	Qualifier
Class	MDC_ATTR_CLASS	OID-Type	Defines the ID of the class; IDs come from the object-oriented nomenclature partition.	M
Name-Binding	MDC_ATTR_NAME_BINDING	OID-Type	Defines ID of Name Binding attribute, e.g., HANDLE; IDs come from the object-oriented nomenclature partition.	M

The Top class does not define any attribute groups.

6.2.2 Behavior

The Top class does not define any special methods.

6.2.3 Notifications

The Top class defines the events in Table 2.

Table 2—Top events

Event	Mode	Event ID	Event parameter	Event result
Attribute-Update	Confirmed/Unconfirmed	MDC_NOTIF_ATTR_UPDATE	AttributeList	—

The attribute update notification allows all objects to communicate their attribute values with a generic event report. However, the use of this notification for systems with multiple object instances is not recommended. Instead, Scanner objects should be used.

6.3 Medical package

6.3.1 VMO class

Class: VMO

Description: The VMO is the base class for all medical-related classes in the model. It provides consistent naming and identification across the Medical Package model. As a base class, the VMO cannot be instantiated.

Superclass: Top

Subclasses: Alert, AlertStatus, AlertMonitor, Channel, Metric, PM-Store, VMD, SCO

Name Binding: Handle (the value of the Handle attribute is sufficient for unique identification of an instance of a VMO-derived class in a device system)

Registered As: MDC_MOC_VMO

6.3.1.1 Attributes

The VMO class defines the attributes in Table 3.

Table 3—VMO class attributes

Attribute name	Attribute ID	Attribute type	Remark	Qualifier
Type	MDC_ATTR_ID_TYPE	TYPE	Defines a specific static type of this object, as defined in the object-oriented or metric nomenclature partition.	M
Handle	MDC_ATTR_ID_HANDLE	HANDLE	Locally unique short-hand identification.	M
Label-String	MDC_ATTR_ID_LABEL_STRING	OCTET STRING	Textual representation of type ID.	O
Ext-Obj-Relations	MDC_ATTR_EXT_OBJ_RELATION	ExtObjRelationList	Relations to objects that are not defined in the DIM.	O

The VMO class defines in Table 4 the attribute groups or extensions to inherited attribute groups.

Table 4—VMO class attribute groups

Attribute group	Attribute group ID	Group elements
VMO Static Context Group (extensible attribute group)	MDC_ATTR_GRP_VMO_STATIC	from VMO: Type, Handle
VMO Dynamic Context Group (extensible attribute group)	MDC_ATTR_GRP_VMO_DYN	from VMO: Label-String
Relationship Attribute Group	MDC_ATTR_GRP_RELATION	from VMO: Ext-Obj-Relations

6.3.1.2 Behavior

The VMO class does not define any special methods.

6.3.1.3 Notifications

The VMO class does not generate any special notifications.

6.3.2 VMD class

Class: VMD
Description: The VMD class is an abstraction of a medical-related subsystem (e.g., hardware or even pure software) of a medical device.
Superclass: VMO
Subclasses: --
Name Binding: Handle (VMO inherited)
Registered As: MDC_MOC_VMO_VMD

6.3.2.1 Attributes

The VMD class defines the attributes in Table 5.

Table 5—VMD class attributes

Attribute name	Attribute ID	Attribute type	Remark	Qualifier
Vmd-Status	MDC_ATTR_VMD_STAT	VMDStatus	Example: on.	M
Vmd-Model	MDC_ATTR_ID_MODEL	SystemModel	Manufacturer and model number.	O
Instance-Number	MDC_ATTR_ID_INSTNO	InstNumber	If multiple instances of the same VMD exist, this attribute helps to order the sequence.	O
Production-Specification	MDC_ATTR_ID_PROD_SPECN	ProductionSpec	Serial numbers and revisions; only present if VMD represents an independent subsystem.	O
Udi	MDC_ATTR_ID_UDI	UdiSpec	This attribute defines the UDI(s) under which this product is listed with an authority such as the US FDA.	O
Compatibility-Id	MDC_ATTR_ID_COMPAT	INT-U32	Static for manufacturer use.	O
Parameter-Group	MDC_ATTR_ID_PARAM_GRP	OID-Type	Example: cardiovascular.	O
Parameter-Group	MDC_ATTR_ID_PARAM_GRP	OID-Type	Example: cardiovascular.	O
Position	MDC_ATTR_ID_POSN	INT-U16	Example: slot number 0xffff marks an invalid or unknown position.	O
Operating-Hours	MDC_ATTR_TIME_PD_OP_HRS	INT-U32		O
Operation-Cycles	MDC_ATTR_CYC_OP	INT-U32	Example: number of measurements taken.	O
Measurement-Principle	MDC_ATTR_MSMT_PRINCIPLE	MsmtPrinciple	Describes the physical principle of the measurement.	O
Locale	MDC_ATTR_LOCALE	Locale	Defines charset and language of printable string attributes in this VMD and contained objects.	O

Identification and revision attributes are not needed if the VMD does not represent a hardware component.

The VMD class defines in Table 6 the attribute groups or extensions to inherited attribute groups.

Table 6—VMD class attribute groups

Attribute group	Attribute group ID	Group elements
VMO Static Context Group (extensible attribute group)	MDC_ATTR_GRP_VMO_STATIC	from VMO: Type, Handle from VMD: Instance-Number, Compatibility-Id, Parameter-Group, Measurement-Principle, Locale
VMO Dynamic Context Group (extensible attribute group)	MDC_ATTR_GRP_VMO_DYN	from VMO: Label-String from VMD: Vmd-Status
VMD Production Attribute Group	MDC_ATTR_GRP_VMD_PROD	from VMD: Vmd-Model, Production-Specification, Udi
VMD Application Attribute Group	MDC_ATTR_GRP_VMD_APPL	from VMD: Position, Operating-Hours, Operation- Cycles
NOTE—A separate attribute group is defined for VMD static attributes that are needed only in special applications.		

The following ASN.1 data type definitions apply:

```
--
-- VMD status indication bits; all bits 0 indicate that VMD is operational
--
VMDStatus ::= BITS-16 {
    vmd-off(0),
    vmd-not-ready(1),           -- e.g. for an infusion pump that is not ready
    vmd-standby(2),             -- e.g. for device powered but not active
    vmd-transduc-discon(8),     -- transducer disconnected
    vmd-hw-discon(9)            -- measurement hardware disconnected
}

--
-- Physical principle of the measurement (multiple bits may be set)
--
MsmntPrinciple ::= BITS-16 {
    msp-other(0),
    msp-chemical(1),
    msp-electrical(2),
    msp-impedance(3),
    msp-nuclear(4),
    msp-optical(5),
    msp-thermal(6),
    msp-biological(7),
    msp-mechanical(8),
    msp-acoustical(9),
    msp-manual(15)
}
```

6.3.2.2 Behavior

The VMD class does not define any special methods.

6.3.2.3 Notifications

The VMD class does not generate any special notifications.

6.3.3 Channel class

Class: Channel
Description: Channel objects are used for grouping Metric objects that have a contextual relationship with each other.
Superclass: VMO
Subclasses: --
Name Binding: Handle (VMO inherited)
Registered As: MDC_MOC_VMO_CHAN

6.3.3.1 Attributes

The Channel class defines the attributes in Table 7.

Table 7—Channel class attributes

Attribute name	Attribute ID	Attribute type	Remark	Qualifier
Channel-Id	MDC_ATTR_CHAN_ID	OID-Type	Dynamic identification.	O
Channel-Status	MDC_ATTR_CHAN_STAT	ChannelStatus	Example: Transducer Disconnected.	O
Physical-Channel-No	MDC_ATTR_CHAN_NUM_PHYS	INT-U16	Provides a reference to a particular hardware channel, e.g., A/D.	O
Logical-Channel-No	MDC_ATTR_CHAN_NUM_LOGICAL	INT-U16	Dynamic channel numbering.	O
Parameter-Group	MDC_ATTR_ID_PARAM_GRP	OID-Type	Static group of metrics, e.g., cardiovascular.	O
Measurement-Principle	MDC_ATTR_MSMT_PRINCIPLE	MsmtPrinciple	Describes the physical principle of the measurement.	O
Color	MDC_ATTR_COLOR	SimpleColour	Useful to assign a common color to objects in one channel.	O

The Channel class defines in Table 8 the attribute groups or extensions to inherited attribute groups.

Table 8—Channel class attribute groups

Attribute group	Attribute group ID	Group elements
VMO Static Context Group (extensible attribute group)	MDC_ATTR_GRP_VMO_STATIC	from VMO: Type, Handle from Channel: Physical-Channel-No, Parameter-Group, Measurement-Principle
VMO Dynamic Context Group (extensible attribute group)	MDC_ATTR_GRP_VMO_DYN	from VMO: Label-String from Channel: Channel-Id, Channel-Status, Logical-Channel-No, Color

The following ASN.1 data type definitions apply:

```
--
-- Channel Status indication bits
--
ChannelStatus ::= BITS-16 {
    chan-off(0),
```

```

chan-not-ready(1),
chan-standby(2),
chan-transduc-discon(8),
chan-hw-discon(9)
}

```

6.3.3.2 Behavior

The Channel class does not define any special methods.

6.3.3.3 Notifications

The Channel class does not generate any special notifications.

6.3.4 Metric class

Class: Metric
Description: The Metric class is the base class for all classes representing direct and derived, quantitative and qualitative biosignal measurement, status, and context data. It is a base class that is used for inheritance only.
Superclass: VMO
Subclasses: ComplexMetric, Enumeration, Numeric, SampleArray
Name Binding: Handle (VMO inherited)
Registered As: MDC_MOC_VMO_METRIC

6.3.4.1 Attributes

The Metric class defines the attributes in Table 9.

Table 9—Metric class attributes

Attribute name	Attribute ID	Attribute type	Remark	Qualifier
Metric-Specification	MDC_ATTR_METRIC_SPECN	MetricSpec	Static; mandatory basic properties.	M
Max-Delay-Time	MDC_ATTR_DELAY_TIME_MAX	RelativeTime	Static; maximum delay to real time.	O
Metric-Status	MDC_ATTR_METRIC_STAT	MetricStatus		O
Measurement-Status	MDC_ATTR_MSMT_STAT	MeasurementStatus	Usually part of an observed value.	O
Metric-Id-Partition	MDC_ATTR_METRIC_ID_PART	NomPartition	Identifies the nomenclature partition associated with the MetricId if it is different from the partition specified in the object's VMO::Type attribute.	O
Metric-Id	MDC_ATTR_ID_PHYSIO	OID-Type	Contains dynamic identification (e.g., a specific blood pressure label) compared to the static, generic ID in the MetricSpecification. OID is from VMO::Type or Metric-Id-Partition partition. Usually this attribute is part of an observed value, not an individual attribute.	O

Table continues

Table 9—Metric class attributes (continued)

Attribute name	Attribute ID	Attribute type	Remark	Qualifier
Metric-Id-Ext	MDC_ATTR_ID_MSMT_EXT	ExtNomenRef	Dynamic identification of the metric in a different nomenclature or dictionary. Use of this attribute severely limits interoperability of applications.	O
Unit-Code	MDC_ATTR_UNIT_CODE	OID-Type	Example: mmHG; usually part of observed value.	O
Unit-Labelstring	MDC_ATTR_UNIT_LABEL_STRING	OCTET STRING	Textual representation of dimension.	O
Vmo-Source-List	MDC_ATTR_VMO_LIST_SRC	VmoSourceList	Indicates sources of this metric in the form of references to other metrics.	O
Metric-Source-List	MDC_ATTR_METRIC_LIST_SRC	MetricSourceList	Indicates sources of this metric in the form of a list of metric IDs.	O
Msmt-Site-List	MDC_ATTR_SITE_LIST_MSMT	SiteList	Measurement sites, specified in internal nomenclature.	O
Msmt-Site-List-Ext	MDC_ATTR_SITE_LIST_MSMT_EXT	SiteListExt	Measurement sites, specified in external nomenclature.	O
Body-Site-List	MDC_ATTR_SITE_LIST_BODY	SiteList	Body sites, specified in internal nomenclature.	O
Body-Site-List-Ext	MDC_ATTR_SITE_LIST_BODY_EXT	SiteListExt	Body sites, specified in external nomenclature.	O
Metric-Calibration	MDC_ATTR_METRIC_CALIB	MetricCalibration	Indicates type and last time of calibration.	O
Color	MDC_ATTR_COLOR	SimpleColour	Color for representation.	O
Measure-Mode	MDC_ATTR_MODE_MSMT	PrivateOid	Manufacturer-specific measurement information.	O
Measure-Period	MDC_ATTR_TIME_PD_MSMT	MetricMeasure	Measurement repetition time; not necessarily the same as update period.	O
Averaging-Period	MDC_ATTR_TIME_PD_AVG	MetricMeasure	Time period used to average values, e.g., a metric for the average flow of last hour.	O
Start-Time	MDC_ATTR_TIME_START	AbsoluteTime	Time when measurement activity was started, e.g., when infusion was started.	O
Stop-Time	MDC_ATTR_TIME_STOP	AbsoluteTime	Time when measurement activity was stopped.	O
Metric-Info-Labelstring	MDC_ATTR_METRIC_INFO_LABEL_STRING	OCTET STRING	Textual attribute, e.g., to specify electrode displacements or other specific information about the measurement.	O
Substance	MDC_ATTR_ID_SUBSTANCE	ExtNomenRef	Substance to which a metric pertains; expressed in nomenclature that is defined outside of this standard.	O
Substance-Labelstring	MDC_ATTR_ID_SUBSTANCE_LABEL_STRING	OCTET STRING	Textual attribute that identifies the substance.	O

The Metric class defines in Table 10 the attribute groups or extensions to inherited attribute groups.

Table 10—Metric class attribute groups

Attribute group	Attribute group ID	Group elements
VMO Static Context Group (extensible attribute group)	MDC_ATTR_GRP_VMO_STATIC	from VMO: Type, Handle from Metric: Metric-Specification, Max-Delay-Time
VMO Dynamic Context Group (extensible attribute group)	MDC_ATTR_GRP_VMO_DYN	from VMO: Label-String from Metric: Metric-Status, Measurement-Status, Metric-Id, Metric-Id-Ext, Unit-Code, Unit- Labelstring, Vmo-Source-List, Metric- Source-List, Msmt-Site-List, Body-Site- List, Metric-Calibration, Color, Measure- Mode, Measure-Period, Averaging-Period, Start-Time, Stop-Time, Metric-Info- Labelstring, Substance, Substance- Labelstring, Body-Site-List-Ext, Msmt-Site- List-Ext
Metric Observed Value Group (extensible attribute group)	MDC_ATTR_GRP_METRIC_VAL_OBS	from Metric: Metric-Id-Partition

The following ASN.1 data type definitions apply:

```
--
-- Metric-Status attribute
--
MetricStatus ::= BITS-16 {
    metric-off(0),
    metric-not-ready(1),
    metric-standby(2),
    metric-transduc-discon(8),
    metric-hw-discon(9)
}

--
-- The Metric-Specification attribute defines all mandatory static properties of a Metric object
--
MetricSpec ::= SEQUENCE {
    update-period          RelativeTime,      -- minimum time between changes of observed value
    category               MetricCategory,
    access                 MetricAccess,
    structure              MetricStructure,
    relevance              MetricRelevance
}

--
-- Structure describes if the object represents a single value or multiple related values (e.g., an invasive blood
-- pressure could be compound when it represents a pulsatile pressure and derives systolic, diastolic, and mean
-- values)
--
MetricStructure ::= SEQUENCE {
    ms-struct              MetricComplexity,
    ms-comp-no             INT-U8            -- maximum number of components in
                                           -- compound/complex
}

```

```

--
-- The MetricComplexity value facilitates differentiation between simple, compound, and complex metric structures
--
MetricComplexity ::= INT-U8 {
    simple(0),
    compound(1),           -- multiple observed values, same dynamic context
    complex(2)             -- multiple observed values, multiple dynamic contexts
}

--
-- The MetricAccess bit field provides information on how it is possible to access the metric value and when a new
-- value is available
--
-- NOTES
-- 1--The avail-intermittent flag shall be set if the observed value is not always available
-- 2--Exactly one update mode bit (upd-) shall be set
-- 3--At least one access mode bit (acc-) shall be set
-- 4--It is possible to set scan option bits (sc-) only if the acc-scan bit is set
-- 5--If the acc-scan bit is set, at least one sc-opt bit shall be set
--
MetricAccess ::= BITS-16 {
    avail-intermittent(0),   -- value is intermittently available
    upd-periodic(1),        -- value is periodically (fixed period) updated
    upd-episodic(2),        -- value is episodically updated
    msmt-noncontinuous(3),  -- measurement is not continuous (e.g. NBP)
    acc-evrep(4),           -- metric sends event report for observed value
    acc-get(5),             -- metric supports explicit GET service
    acc-scan(6),            -- metric observed value is able to be accessed via Scanner object
    gen-opt-sync(8),        -- observed value shall be processed synchronously
    sc-opt-normal(10),       -- scan option: value can be scanned with update period
    sc-opt-extensive(11),    -- scan option: in update period multiple values may occur
    sc-opt-long-pd-avail(12), -- scan option: value may be scanned slow (superpositive-avg scan bit)
    sc-opt-confirm(13),     -- scan option: scanner should operate in confirmed mode
    sc-opt-refresh(14)      -- scan option: a scan refresh operation is allowed
}

--
-- The metric category makes it possible to distinguish between measurements, settings, and calculations
--
MetricCategory ::= INT-U16 {
    mcat-unspec(0),
    auto-measurement(1),
    manual-measurement(2),
    auto-setting(3),
    manual-setting(4),
    auto-calculation(5),
    manual-calculation(6)
}

--
-- Metric relevance defines in what way the metric should be used (i.e., a value of 0 means normal)
--
MetricRelevance ::= BITS-16 {
    rv-unspec(0),           -- relevance not specified; should normally not be used
    rv-internal(1),         -- an internally used value only
    rv-store-only(2),       -- only relevant for storage
    rv-no-recording(3),     -- not relevant for recording
    rv-phys-ev-ind(4),      -- metric represents a physiological trigger (not a value)
    rv-btb-metric(5),       -- metric is calculated for each beat or breath, not time-averaged
    rv-app-specific(8),     -- dedicated application required to interpret the metric
    rv-service(9)           -- metric is intended for service or diagnostic purposes
}

```

IEEE Std 11073-10201-2018
IEEE Standard for Part 10201: Domain Information Model

```

--
-- The Metric-Calibration attribute defines calibration methods and times
-- NOTE--Multiple entries allowed
--
MetricCalibration ::= SEQUENCE OF MetricCalEntry

MetricCalEntry ::= SEQUENCE {
    cal-type      MetricCalType,
    cal-state     MetricCalState,
    cal-time      AbsoluteTime
}

MetricCalType ::= INT-U16 {
    cal-unspec(0),
    cal-offset(1),           -- offset calibration
    cal-gain(2),             -- gain calibration
    cal-two-point(3)         -- two-point calibration
}

MetricCalState ::= INT-U16 {
    not-calibrated(0),
    cal-required(1),
    calibrated(2)
}

--
-- Ordered list of measurement sites, e.g., EEG electrode positions
-- Entries are from body site nomenclature partition
--
SiteList ::= SEQUENCE OF OID-Type

--
-- Site list may also refer to external nomenclatures to specify measurement sites
--
SiteListExt ::= SEQUENCE OF ExtNomenRef

--
-- Metric-Source-List attribute is an ordered list of metric OIDs
-- OIDs from VMO::Type or Metric-Id-Partition partition
--
MetricSourceList ::= SEQUENCE OF OID-Type

--
-- Vmo-Source-List attribute defines references to other VMO-derived objects that are used as sources of this
-- metric (this is an ordered list)
--
VmoSourceList ::= SEQUENCE OF VmoSourceEntry

VmoSourceEntry ::= SEQUENCE {
    vmo-type      OID-Type,           -- from object-oriented nomenclature partition
    glb-handle     GLB-HANDLE
}

--
-- Measurement-Status attribute defines the state of the measurement; used by derived classes
--
MeasurementStatus ::= BITS-16 {
    invalid(0),
    questionable(1),
    not-available(2),
    calibration-ongoing(3),
    test-data(4),

```

```

demo-data(5),
validated-data(8),           -- relevant e.g. in an archive
early-indication(9),         -- early estimate of value
msmt-ongoing(10),            -- indicates that a new measurement is just being taken (episodic)
msmt-state-in-alarm(14),     -- indicates that the metric has an active alert condition
msmt-state-al-inhibited(15)  -- metric supports alarming, and alarms are turned off (optional)
}

--
-- In a number of derived metrics, specification of ranges is necessary
-- A type for this is defined here in the base class
--
AbsoluteRange ::= SEQUENCE {
    lower-value FLOAT-Type,
    upper-value FLOAT-Type
}

--
-- Metric measure is used for attributes that have a value and a dimension
--
MetricMeasure ::= SEQUENCE {
    value      FLOAT-Type,
    unit-code  OID-Type      -- from dimensions nomenclature partition
}

```

6.3.4.2 Behavior

The Metric class does not define any special methods.

6.3.4.3 Notifications

The Metric class does not generate any special notifications.

6.3.5 Numeric class

Class:	Numeric
Description:	The Numeric class represents numerical measurements and status information, e.g., amplitude measures, counters.
Superclass:	Metric
Subclasses:	—
Name Binding:	Handle (VMO inherited)
Registered As:	MDC_MOC_VMO_METRIC_NU

6.3.5.1 Attributes

The Numeric class defines the attributes in Table 11.

Table 11—Numeric class attributes

Attribute name	Attribute ID	Attribute type	Remark	Qualifier
Nu-Observed-Value	MDC_ATTR_NU_VAL_OBS	NuObsValue	Example: measurement value; should also contain validity information to be useful.	C ^a
Compound-Nu-Observed-Value	MDC_ATTR_NU_CMPD_VAL_OBS	NuObsValueCmp	Used when multiple values are represented in a single Numeric object. (Structure is compound.)	C
Absolute-Time-Stamp	MDC_ATTR_TIME_STAMP_ABS	AbsoluteTime	Time of observation (timestamp).	O
Relative-Time-Stamp	MDC_ATTR_TIME_STAMP_REL	RelativeTime		O
Hires-Time-Stamp	MDC_ATTR_TIME_STAMP_REL_HI_RES	HighResRelativeTime	High-resolution timestamp.	O
Nu-Measure-Range	MDC_ATTR_NU_RANGE_MSMT	AbsoluteRange	Potential measurement range.	O
Nu-Physiological-Range	MDC_ATTR_NU_RANGE_PHYSIO	AbsoluteRange	Physiological reasonable range (note that this is not an alarming range).	O
Nu-Measure-Resolution	MDC_ATTR_NU_MSMT_RES	FLOAT-Type	Resolution of measurement; minimum difference between two observed values.	O
Display-Resolution	MDC_ATTR_DISP_RES	DispResolution	Used when different resolution is needed when value is displayed.	O
Accuracy	MDC_ATTR_NU_ACCUR_MSMT	FLOAT-Type	Maximum deviation of actual value from reported observed value (if it can be specified).	O

^aExactly one observed value type shall be present as defined by the Metric-Specification attribute.

The Numeric class defines in Table 12 the attribute groups or extensions to inherited attribute groups.

Table 12—Numeric class attribute groups

Attribute group	Attribute group ID	Group elements
VMO Static Context Group (extensible attribute group)	MDC_ATTR_GRP_VMO_STATIC	from VMO: Type, Handle from Metric: Metric-Specification, Max-Delay-Time
VMO Dynamic Context Group (extensible attribute group)	MDC_ATTR_GRP_VMO_DYN	from VMO: Label-String from Metric: Metric-Status, Measurement-Status, Metric-Id, Metric-Id-Ext, Unit-Code, Unit- Labelstring, Vmo-Source-List, Metric- Source-List, Msmt-Site-List, Body-Site- List, Metric-Calibration, Color, Measure- Mode, Measure-Period, Averaging-Period, Start-Time, Stop-Time, Metric-Info- Labelstring, Substance, Substance- Labelstring, Body-Site-List-Ext, Msmt-Site- List-Ext from Numeric: Nu-Measure-Range, Nu-Physiological- Range, Nu-Measure-Resolution, Display- Resolution, Accuracy
Metric Observed Value Group (extensible attribute group)	MDC_ATTR_GRP_METRIC_VAL_OBS	from Metric: Metric-Id-Partition from Numeric: Nu-Observed-Value, Absolute-Time- Stamp, Relative-Time-Stamp, Hires-Time- Stamp, Compound-Nu-Observed-Value

The following ASN.1 data type definitions apply:

```
--
-- Nu-Observed-Value attribute always includes identification, state, and dimension to ensure consistency with
-- minimal overhead
--
NuObsValue ::= SEQUENCE {
    metric-id    OID-Type,                -- from VMO::Type or Metric-Id-Partition partition
    state        MeasurementStatus,        -- defined in Metric base
    unit-code    OID-Type,                -- from dimensions nomenclature partition
    value        FLOAT-Type
}

--
-- Observed value for compound numerics
--
NuObsValueCmp ::= SEQUENCE OF NuObsValue

--
-- Display-Resolution attribute is the value representation on a display (may be lower resolution)
--
DispResolution ::= SEQUENCE {
    pre-point    INT-U8,                -- digits before decimal point
    post-point    INT-U8                -- digits after decimal point
}
```

6.3.5.2 Behavior

The Numeric class does not define any special methods.

6.3.5.3 Notifications

The Numeric class does not generate any special notifications.

6.3.6 SampleArray class

Class:	SampleArray
Description:	The SampleArray class is the base class for metrics that have a graphical, curve type presentation and, therefore, have their observation values reported as arrays of data points by communicating systems.
Superclass:	Metric
Subclasses:	DistributionSampleArray, RealTimeSampleArray, TimeSampleArray
Name Binding:	Handle (VMO inherited)
Registered As:	MDC_MOC_VMO_METRIC_SA

6.3.6.1 Attributes

The SampleArray class defines the attributes in Table 13.

Table 13—SampleArray class attributes

Attribute name	Attribute ID	Attribute type	Remark	Qualifier
Sa-Observed-Value	MDC_ATTR_SA_VAL_OBS	SaObsValue	Example: array of measurement values.	C ^a
Compound-Sa-Observed-Value	MDC_ATTR_SA_CMPD_VAL_OBS	SaObsValueCmp		C
Sa-Specification	MDC_ATTR_SA_SPECN	SaSpec	Static description of sample array and sample types.	M
Compression	MDC_ATTR_COMPRES	PrivateOid	Defines potential compression algorithm.	O
Scale-And-Range-Specification-8	MDC_ATTR_SCALE_SPECN_I8	ScaleRangeSpec8	Defines mapping between samples and actual values as well as measurement range; type depends on sample size. Exactly one of the following attributes shall be implemented for any SampleArray object: Scale-And-Range-Specification-8, Scale-And-Range-Specification-16, Scale-And-Range-Specification-32.	C
Scale-And-Range-Specification-16	MDC_ATTR_SCALE_SPECN_I16	ScaleRangeSpec16	Defines mapping between samples and actual values as well as measurement range; type depends on sample size. Exactly one of the following attributes shall be implemented for any SampleArray object: Scale-And-Range-Specification-8, Scale-And-Range-Specification-16, Scale-And-Range-Specification-32.	C

Table continues

Table 13—SampleArray class attributes (*continued*)

Attribute name	Attribute ID	Attribute type	Remark	Qualifier
Scale-And-Range-Specification-32	MDC_ATTR_SCALE_SPECN_I32	ScaleRangeSpec32	Defines mapping between samples and actual values as well as measurement range; type depends on sample size. Exactly one of the following attributes shall be implemented for any SampleArray object: Scale-And-Range-Specification-8, Scale-And-Range-Specification-16, Scale-And-Range-Specification-32.	C
Sa-Physiological-Range-8	MDC_ATTR_SA_RANGE_PHYS_I8	ScaledRange8	For optimum display scaling, the physiologically meaningful range is specified.	O
Sa-Physiological-Range-16	MDC_ATTR_SA_RANGE_PHYS_I16	ScaledRange16	For optimum display scaling, the physiologically meaningful range is specified.	O
Sa-Physiological-Range-32	MDC_ATTR_SA_RANGE_PHYS_I32	ScaledRange32	For optimum display scaling, the physiologically meaningful range is specified.	O
Visual-Grid-8	MDC_ATTR_GRID_VIS_I8	SaVisualGrid8	Defines gridline positions on displays and recorders; type depends on sample size.	O
Visual-Grid-16	MDC_ATTR_GRID_VIS_I16	SaVisualGrid16	Defines gridline positions on displays and recorders; type depends on sample size.	O
Visual-Grid-32	MDC_ATTR_GRID_VIS_I32	SaVisualGrid32	Defines gridline positions on displays and recorders; type depends on sample size.	O
Sa-Calibration-Data-8	MDC_ATTR_SA_CALIB_I8	SaCalData8	Defines positions of calibration markers on display and recorders; type depends on sample size.	O
Sa-Calibration-Data-16	MDC_ATTR_SA_CALIB_I16	SaCalData16	Defines positions of calibration markers on display and recorders; type depends on sample size.	O
Sa-Calibration-Data-32	MDC_ATTR_SA_CALIB_I32	SaCalData32	Defines positions of calibration markers on display and recorders; type depends on sample size.	O
Filter-Specification	MDC_ATTR_FILTER_SPECN	SaFilterSpec		O
Filter-Label-String	MDC_ATTR_FILTER_LABEL_STRING	OCTET STRING	Text label of an active filter, e.g., 'Butterworth' or 'LinearPhase.'	O
Sa-Signal-Frequency	MDC_ATTR_SA_FREQ_SIG	SaSignalFrequency	Maximum signal frequency.	O
Sa-Measure-Resolution	MDC_ATTR_SA_MSMT_RES	FLOAT-Type		O
Sa-Marker-List-8	MDC_ATTR_SA_MARKER_LIST_I8	MarkerListSaVal8		O
Sa-Marker-List-16	MDC_ATTR_SA_MARKER_LIST_I16	MarkerListSaVal16		O
Sa-Marker-List-32	MDC_ATTR_SA_MARKER_LIST_I32	MarkerListSaVal32		O

^aExactly one observed value type shall be present as defined by the Metric-Specification attribute.

The SampleArray class defines in Table 14 the attribute groups or extensions to inherited attribute groups.

Table 14—SampleArray class attribute groups

Attribute group	Attribute group ID	Group elements
VMO Static Context Group (extensible attribute group)	MDC_ATTR_GRP_VMO_STATIC	from VMO: Type, Handle from Metric: Metric-Specification, Max-Delay-Time from SampleArray: Sa-Specification, Compression, Sa-Marker-List-8, Sa-Marker-List-16, Sa-Marker-List-32
VMO Dynamic Context Group (extensible attribute group)	MDC_ATTR_GRP_VMO_DYN	from VMO: Label-String from Metric: Metric-Status, Measurement-Status, Metric-Id, Metric-Id-Ext, Unit-Code, Unit-Labelstring, Vmo-Source-List, Metric-Source-List, Msmt-Site-List, Body-Site-List, Metric-Calibration, Color, Measure-Mode, Measure-Period, Averaging-Period, Start-Time, Stop-Time, Metric-Info-Labelstring, Substance, Substance-Labelstring, Body-Site-List-Ext, Msmt-Site-List-Ext from SampleArray: Scale-And-Range-Specification-8, Sa-Physiological-Range-8, Visual-Grid-8, Sa-Calibration-Data-8, Filter-Specification, Filter-Label-String, Sa-Signal-Frequency, Sa-Measure-Resolution, Scale-And-Range-Specification-16, Scale-And-Range-Specification-32, Sa-Physiological-Range-16, Sa-Physiological-Range-32, Visual-Grid-16, Visual-Grid-32, Sa-Calibration-Data-16, Sa-Calibration-Data-32
Metric Observed Value Group (extensible attribute group)	MDC_ATTR_GRP_METRIC_VAL_OBS	from Metric: Metric-Id-Partition from SampleArray: Sa-Observed-Value, Compound-Sa-Observed-Value

The following ASN.1 data type definitions apply:

```
--
-- Sa-Observed-Value attribute
--
SaObsValue ::= SEQUENCE {
    metric-id    OID-Type,           -- from VMO::Type or Metric-Id-Partition partition
    state        MeasurementStatus, -- defined in Metric base class
    array        OCTET STRING
}

--
-- Compound-Sa-Observed-Value attribute is the compound observed value
--
SaObsValueCmp ::= SEQUENCE OF SaObsValue

--
-- Sa-Specification attribute
```

```

--
SaSpec ::= SEQUENCE {
    array-size          INT-U16,          -- number of samples per metric update period
    sample-type         SampleType,
    flags               SaFlags
}

-- Sample type describes one sample in the observed value array
--
SampleType ::= SEQUENCE {
    sample-size         INT-U8,          -- e.g. 8 for 8bit samples, 16 for 16bit samples, shall be
                                         -- divisible by 8
    significant-bits     SignificantBits  -- defines significant bits in one sample; if value is 255,
                                         -- the samples are signed; all bits are significant;
                                         -- samples are interpreted in twos complement
}

SignificantBits ::= INT-U8 {
    signed-samples(255)
}

--
-- SaFlags data type defines additional wave form properties
--
SaFlags ::= BITS-16 {
    smooth-curve(0),          -- for optimum display, use a smoothing algorithm
    delayed-curve(1),        -- curve is delayed (not real time)
    static-scale(2),         -- ScaleRangeSpec does not change
    sa-ext-val-range(3)      -- the nonsignificant bits in a sample are not 0, e.g., when they are used for
                              -- annotations or markers, the receiver must apply a bit mask to extract the
                              -- significant bits from the sample
}

--
-- Specification of an applied signal filter
--
SaFilterSpec ::= SEQUENCE OF SaFilterEntry

SaFilterEntry ::= SEQUENCE {
    filter-type          FilterType,
    filter-frequency     FLOAT-Type,
    filter-order         INT-I16        -- e.g. -1: 6 dB/oct
}

FilterType ::= INT-U16 {
    other(0),
    low-pass(1),
    high-pass(2),
    notch(3)
}

--
-- Scale-and-Range-Specification attribute describes a relation between scaled values and absolute values;
-- depending on the sample size, multiple attribute types exist
--
-- NOTE--If a wave does not represent absolute values, the absolute value fields should contain a special value; if
-- the Sa-Specification attribute indicates signed samples, the scaled values have to be interpreted as signed values
--
ScaleRangeSpec8 ::= SEQUENCE {
    lower-absolute-value  FLOAT-Type,

```

```

    upper-absolute-value    FLOAT-Type,
    lower-scaled-value      INT-U8,
    upper-scaled-value      INT-U8
}

```

```

ScaleRangeSpec16 ::= SEQUENCE {
    lower-absolute-value    FLOAT-Type,
    upper-absolute-value    FLOAT-Type,
    lower-scaled-value      INT-U16,
    upper-scaled-value      INT-U16
}

```

```

ScaleRangeSpec32 ::= SEQUENCE {
    lower-absolute-value    FLOAT-Type,
    upper-absolute-value    FLOAT-Type,
    lower-scaled-value      INT-U32,
    upper-scaled-value      INT-U32
}

```

```

--
-- Visual-Grid attribute defines grid lines at different levels of grid lines; if the Sa-Specification attribute indicates
-- signed samples, the scaled values have to be interpreted as signed values
--

```

```

SaVisualGrid8 ::= SEQUENCE OF SaGridEntry8

```

```

SaGridEntry8 ::= SEQUENCE {
    absolute-value          FLOAT-Type,
    scaled-value            INT-U8,
    level                   INT-U8
}

```

```

SaVisualGrid16 ::= SEQUENCE OF SaGridEntry16

```

```

SaGridEntry16 ::= SEQUENCE {
    absolute-value          FLOAT-Type,
    scaled-value            INT-U16,
    level                   INT-U16
}

```

```

SaVisualGrid32 ::= SEQUENCE OF SaGridEntry32

```

```

SaGridEntry32 ::= SEQUENCE {
    absolute-value          FLOAT-Type,
    scaled-value            INT-U32,
    level                   INT-U16
}

```

```

--
-- Sa-Calibration-Data attribute defines calibration markers on a display or on a recording strip; if the Sa-
-- Specification attribute indicates signed samples, the scaled values have to be interpreted as signed values
--

```

```

SaCalData8 ::= SEQUENCE {
    lower-absolute-value    FLOAT-Type,
    upper-absolute-value    FLOAT-Type,
    lower-scaled-value      INT-U8,
    upper-scaled-value      INT-U8,
    increment               INT-U16,      -- scaled value for each step of the stair
    cal-type                SaCalDataType
}

```

```

SaCalData16 ::= SEQUENCE {
    lower-absolute-value    FLOAT-Type,
    upper-absolute-value    FLOAT-Type,
    lower-scaled-value      INT-U16,
    upper-scaled-value      INT-U16,
    increment               INT-U16,      -- scaled value for each step of the stair
    cal-type                SaCalDataType
}

SaCalData32 ::= SEQUENCE {
    lower-absolute-value    FLOAT-Type,
    upper-absolute-value    FLOAT-Type,
    lower-scaled-value      INT-U32,
    upper-scaled-value      INT-U32,
    increment               INT-U32,      -- scaled value for each step of the stair
    cal-type                SaCalDataType
}

SaCalDataType ::= INT-U16 {
    bar(0),      -- display a calibration bar
    stair(1)     -- display a calibration stair
}

--
-- Sa-Signal-Frequency attribute specifies the signal frequency
--
SaSignalFrequency ::= SEQUENCE {
    low-edge-freq          FLOAT-Type,
    high-edge-freq         FLOAT-Type    -- both in Hz
}

--
-- Sa-Physiological-Range attribute data types
-- If the Sa-Specification attribute indicates signed samples, the scaled values have to be interpreted as signed
-- values
--
ScaledRange8 ::= SEQUENCE {
    lower-scaled-value     INT-U8,
    upper-scaled-value     INT-U8
}

ScaledRange16 ::= SEQUENCE {
    lower-scaled-value     INT-U16,
    upper-scaled-value     INT-U16
}

ScaledRange32 ::= SEQUENCE {
    lower-scaled-value     INT-U32,
    upper-scaled-value     INT-U32
}

--
-- Sa-Marker-List attribute allows the definition of special sample values to mark or annotate certain conditions
-- directly in the sample value; the special sample value may be a full value or a bit mask, depending on the marker
-- ID; in any case, the sample value may use bits outside the normal range (as defined by the SampleType::
-- significant-bits) only if the SaFlags::sa-ext-val-range flag is set
--
MarkerListSaVal8 ::= SEQUENCE OF MarkerEntrySaVal8

```

```

MarkerEntrySaVal8 ::= SEQUENCE {
    marker-id    OID-Type,      -- from VMO::Type or Metric-Id-Partition partition
    marker-val   INT-U8,        -- a value or bit mask depending on marker-id
    unused      INT-U8          -- for alignment
}

```

```

MarkerListSaVal16 ::= SEQUENCE OF MarkerEntrySaVal16

```

```

MarkerEntrySaVal16 ::= SEQUENCE {
    marker-id    OID-Type,      -- from VMO::Type or Metric-Id-Partition partition
    marker-val   INT-U16        -- a value or bit mask depending on marker-id
}

```

```

MarkerListSaVal32 ::= SEQUENCE OF MarkerEntrySaVal32

```

```

MarkerEntrySaVal32 ::= SEQUENCE {
    marker-id    OID-Type,      -- from VMO::Type or Metric-Id-Partition partition
    marker-val   INT-U32        -- a value or bit mask depending on marker-id
}

```

6.3.6.2 Behavior

The SampleArray class does not define any special methods.

6.3.6.3 Notifications

The SampleArray class does not generate any special notifications.

6.3.7 RealTimeSampleArray class

Class:	RealTimeSampleArray
Description:	The RealTimeSampleArray class describes a sample array that represents a real-time continuous waveform.
Superclass:	SampleArray
Subclasses:	--
Name Binding:	Handle (VMO inherited)
Registered As:	MDC_MOC_VMO_METRIC_SA_RT

6.3.7.1 Attributes

The RealTimeSampleArray class defines the attributes in Table 15.

Table 15—RealTimeSampleArray class attributes

Attribute name	Attribute ID	Attribute type	Remark	Qualifier
Sample-Period	MDC_ATTR_TIME_PD_SAMP	RelativeTime	Example: in (parts of) milliseconds.	M
Sweep-Speed	MDC_ATTR_SPD_SWEEP_DEFAULT	MetricMeasure	Example: millimeters per second.	O
Average-Reporting-Delay	MDC_ATTR_REPORTING_DELAY_AVG	RelativeTime	Indicates the average time between when the first element in an array update was sampled and when the FastPeriCfgScanner event report was generated (i.e., the event report timestamp).	O
Sample-Time-Sync	MDC_ATTR_SAMPLE_TIME_SYNC	RelativeTime	Indicates the precise sample time of the first element in an array update. Optional if the Average-Reporting-Delay attribute is present; out of the scope of this standard otherwise.	C
Hires-Sample-Time-Sync	MDC_ATTR_SAMPLE_TIME_SYNC_HIRES	HighResRelativeTime	Indicates the precise sample time of the first element in an array update. Optional if the Average-Reporting-Delay attribute is present; out of the scope of this standard otherwise.	C

NOTE 1—Together with the Average-Reporting-Delay attribute, the Sample-Time-Sync or HiRes-Sample-Time-Sync attribute can be used to accurately specify specific sample times. The Sample-Time-Sync and HiRes-Sample-Time-Sync attributes should be reported by an episodic scanner

- When reporting is first started and
- Periodically after that start at a frequency that ensures that time drift/clock skew will not compromise precise time correlation with a single waveform sample.

NOTE 2—See also 6.7.5 for the definition of the FastPeriCfgScanner class.

The RealTimeSampleArray class defines in Table 16 the attribute groups or extensions to inherited attribute groups.

Table 16—RealTimeSampleArray class attribute groups

Attribute group	Attribute group ID	Group elements
VMO Static Context Group (extensible attribute group)	MDC_ATTR_GRP_VMO_STATIC	from VMO: Type, Handle from Metric: Metric-Specification, Max-Delay-Time from SampleArray: Sa-Specification, Compression, Sa-Marker-List-8, Sa-Marker-List-16, Sa-Marker-List-32 from RealTimeSampleArray: Sample-Period, Sweep-Speed, Average-Reporting-Delay
VMO Dynamic Context Group (extensible attribute group)	MDC_ATTR_GRP_VMO_DYN	from VMO: Label-String from Metric: Metric-Status, Measurement-Status, Metric-Id, Metric-Id-Ext, Unit-Code, Unit-Labelstring, Vmo-Source-List, Metric-Source-List, Msmt-Site-List, Body-Site-List, Metric-Calibration, Color, Measure-Mode, Measure-Period, Averaging-Period, Start-Time, Stop-Time, Metric-Info-Labelstring, Substance, Substance-Labelstring, Body-Site-List-Ext, Msmt-Site-List-Ext from SampleArray: Scale-And-Range-Specification-8, Sa-Physiological-Range-8, Visual-Grid-8, Sa-Calibration-Data-8, Filter-Specification, Filter-Label-String, Sa-Signal-Frequency, Sa-Measure-Resolution, Scale-And-Range-Specification-16, Scale-And-Range-Specification-32, Sa-Physiological-Range-16, Sa-Physiological-Range-32, Visual-Grid-16, Visual-Grid-32, Sa-Calibration-Data-16, Sa-Calibration-Data-32 from RealTimeSampleArray: Sample-Time-Sync, Hires-Sample-Time-Sync
Metric Observed Value Group (extensible attribute group)	MDC_ATTR_GRP_METRIC_VAL_OBS	from Metric: Metric-Id-Partition from SampleArray: Sa-Observed-Value, Compound-Sa-Observed-Value

6.3.7.2 Behavior

The RealTimeSampleArray class does not define any special methods.

6.3.7.3 Notifications

The RealTimeSampleArray class does not generate any special notifications.

6.3.8 TimeSampleArray class

Class: TimeSampleArray
Description: The TimeSampleArray class describes a sample array that represents noncontinuous waveforms (i.e., a wave snippet).
Superclass: SampleArray
Subclasses: --
Name Binding: Handle (VMO inherited)
Registered As: MDC_MOC_VMO_METRIC_SA_T

6.3.8.1 Attributes

The TimeSampleArray class defines the attributes in Table 17.

Table 17—TimeSampleArray class attributes

Attribute name	Attribute ID	Attribute type	Remark	Qualifier
Absolute-Time-Stamp	MDC_ATTR_TIME_STAMP_ABS	AbsoluteTime	Time of observation (timestamp).	O
Relative-Time-Stamp	MDC_ATTR_TIME_STAMP_REL	RelativeTime		O
Hires-Time-Stamp	MDC_ATTR_TIME_STAMP_REL_HI_RES	HighResRelativeTime	High-resolution timestamp.	O
Sample-Period	MDC_ATTR_TIME_PD_SAMP	RelativeTime	Example: in (parts of) milliseconds.	M
Sweep-Speed	MDC_ATTR_SPD_SWEEP_DEFAULT	MetricMeasure	Example: millimeters per second.	O
Tsa-Marker-List	MDC_ATTR_TSA_MARKER_LIST	MarkerListRelTim	Marks positions in wave snippets.	O

The TimeSampleArray class defines in Table 18 the attribute groups or extensions to inherited attribute groups.

Table 18—TimeSampleArray class attribute groups

Attribute group	Attribute group ID	Group elements
VMO Static Context Group (extensible attribute group)	MDC_ATTR_GRP_VMO_STATIC	from VMO: Type, Handle from Metric: Metric-Specification, Max-Delay-Time from SampleArray: Sa-Specification, Compression, Sa-Marker-List-8, Sa-Marker-List-16, Sa-Marker-List-32 from TimeSampleArray: Sample-Period, Sweep-Speed
VMO Dynamic Context Group (extensible attribute group)	MDC_ATTR_GRP_VMO_DYN	from VMO: Label-String from Metric: Metric-Status, Measurement-Status, Metric-Id, Metric-Id-Ext, Unit-Code, Unit-Labelstring, Vmo-Source-List, Metric-Source-List, Msmt-Site-List, Body-Site-List, Metric-Calibration, Color, Measure-Mode, Measure-Period, Averaging-Period, Start-Time, Stop-Time, Metric-Info-Labelstring, Substance, Substance-Labelstring, Body-Site-List-Ext, Msmt-Site-List-Ext from SampleArray: Scale-And-Range-Specification-8, Sa-Physiological-Range-8, Visual-Grid-8, Sa-Calibration-Data-8, Filter-Specification, Filter-Label-String, Sa-Signal-Frequency, Sa-Measure-Resolution, Scale-And-Range-Specification-16, Scale-And-Range-Specification-32, Sa-Physiological-Range-16, Sa-Physiological-Range-32, Visual-Grid-16, Visual-Grid-32, Sa-Calibration-Data-16, Sa-Calibration-Data-32
Metric Observed Value Group (extensible attribute group)	MDC_ATTR_GRP_METRIC_VAL_OBS	from Metric: Metric-Id-Partition from SampleArray: Sa-Observed-Value, Compound-Sa-Observed-Value from TimeSampleArray: Absolute-Time-Stamp, Relative-Time-Stamp, Hires-Time-Stamp, Tsa-Marker-List

The following ASN.1 data type definitions apply:

```
--
-- Tsa-Marker-List attribute can be used to mark certain time points in the wave snippet; the first sample is at
-- relative time 0
--
MarkerListRelTim ::= SEQUENCE OF MarkerEntryRelTim

MarkerEntryRelTim ::= SEQUENCE {
    marker-id          OID-Type,          -- from VMO::Type or Metric-Id-Partition partition
    marker-time        RelativeTime
}
```

6.3.8.2 Behavior

The TimeSampleArray class does not define any special methods.

6.3.8.3 Notifications

The TimeSampleArray class does not generate any special notifications.

6.3.9 DistributionSampleArray class

Class:	DistributionSampleArray
Description:	The DistributionSampleArray class describes a sample array that represents linear value distributions in the form of arrays containing scaled sample values. Each value within an observation array represents a measured value from a different point in the parameter space. Thus, the observed value array can be considered an x-y coordinate system where the y axis is specified by the attributes inherited from the Metric class and the x axis is specified by attributes defined in the DistributionSampleArray class.
Superclass:	SampleArray
Subclasses:	--
Name Binding:	Handle (VMO inherited)
Registered As:	MDC_MOC_VMO_METRIC_SA_D

6.3.9.1 Attributes

The DistributionSampleArray class defines the attributes in Table 19.

Table 19 —DistributionSampleArray class attributes

Attribute name	Attribute ID	Attribute type	Remark	Qualifier
Absolute-Time-Stamp	MDC_ATTR_TIME_STAMP_ABS	AbsoluteTime	Time of observation (timestamp).	O
Relative-Time-Stamp	MDC_ATTR_TIME_STAMP_REL	RelativeTime		O
Hires-Time-Stamp	MDC_ATTR_TIME_STAMP_REL_HI_RES	HighResRelativeTime	High-resolution timestamp.	O
Distribution-Range-Specification	MDC_ATTR_RANGE_DISTRIB	DsaRangeSpec	Maps array index to absolute value.	M
x-Unit-Code	MDC_ATTR_UNIT_CODE_X	OID-Type	Applies to x axis.	O
x-Unit-Label-String	MDC_ATTR_UNIT_LABEL_STRING_X	OCTET STRING	Applies to x axis.	O
Dsa-Marker-List	MDC_ATTR_DSA_MARKER_LIST	MarkerListIndex	User to mark positions in DistributionSampleArray object samples	O

The DistributionSampleArray class defines in Table 20 the attribute groups or extensions to inherited attribute groups.

Table 20—DistributionSampleArray class attribute groups

Attribute group	Attribute group ID	Group elements
VMO Static Context Group (extensible attribute group)	MDC_ATTR_GRP_VMO_STATIC	from VMO: Type, Handle from Metric: Metric-Specification, Max-Delay-Time from SampleArray: Sa-Specification, Compression, Sa-Marker-List-8, Sa-Marker-List-16, Sa-Marker-List-32
VMO Dynamic Context Group (extensible attribute group)	MDC_ATTR_GRP_VMO_DYN	from VMO: Label-String from Metric: Metric-Status, Measurement-Status, Metric-Id, Metric-Id-Ext, Unit-Code, Unit-Labelstring, Vmo-Source-List, Metric-Source-List, Msmt-Site-List, Body-Site-List, Metric-Calibration, Color, Measure-Mode, Measure-Period, Averaging-Period, Start-Time, Stop-Time, Metric-Info-Labelstring, Substance, Substance-Labelstring, Body-Site-List-Ext, Msmt-Site-List-Ext from SampleArray: Scale-And-Range-Specification-8, Sa-Physiological-Range-8, Visual-Grid-8, Sa-Calibration-Data-8, Filter-Specification, Filter-Label-String, Sa-Signal-Frequency, Sa-Measure-Resolution, Scale-And-Range-Specification-16, Scale-And-Range-Specification-32, Sa-Physiological-Range-16, Sa-Physiological-Range-32, Visual-Grid-16, Visual-Grid-32, Sa-Calibration-Data-16, Sa-Calibration-Data-32 from DistributionSampleArray: Distribution-Range-Specification, x-Unit-Code, x-Unit-Label-String
Metric Observed Value Group (extensible attribute group)	MDC_ATTR_GRP_METRIC_VAL_OBS	from Metric: Metric-Id-Partition from SampleArray: Sa-Observed-Value, Compound-Sa-Observed-Value from DistributionSampleArray: Absolute-Time-Stamp, Relative-Time-Stamp, Hires-Time-Stamp, Dsa-Marker-List

The following ASN.1 data type definitions apply:

```
--
-- Distribution-Range-Specification attribute defines the absolute value for the first and last array element; a linear
-- scale is assumed here unless a specific compression scheme is defined (last-value -first-value)/no.of.array
-- elements == step width
--
DsaRangeSpec ::= SEQUENCE {
```

```

        first-element-value      FLOAT-Type,
        last-element-value      FLOAT-Type
    }

--
-- DSA-Marker-List attribute allows the annotation of samples by referencing the sample with an index
--
MarkerListIndex ::= SEQUENCE OF MarkerEntryIndex

MarkerEntryIndex ::= SEQUENCE {
    marker-id                OID-Type,      -- from VMO::Type or Metric-Id-Partition partition
    marker-index             INT-U16
}

```

6.3.9.2 Behavior

The DistributionSampleArray class does not define any special methods.

6.3.9.3 Notifications

The DistributionSampleArray class does not generate any special notifications.

6.3.10 Enumeration class

Class:	Enumeration
Description:	The Enumeration class represents status information and/or annotation information. Observation values may be presented in the form of normative codes (that are included in the nomenclature defined in this standard or in some other external nomenclature), bit string, or in the form of free text.
Superclass:	Metric
Subclasses:	--
Name Binding:	Handle (VMO inherited)
Registered As:	MDC_MOC_VMO_METRIC_ENUM

6.3.10.1 Attributes

The Enumeration class defines the attributes in Table 21.

Table 21—Enumeration class attributes

Attribute name	Attribute ID	Attribute type	Remark	Qualifier
Enum-Observed-Value	MDC_ATTR_VAL_ENUM_OBS	EnumObsValue	Either Enum-Observed-Value or Compound-EnumObserved-Value shall be supported in one object instance.	C
Compound-Enum-Observed-Value	MDC_ATTR_VAL_ENUM_OBS_CMPD	EnumObsValueCmp	Either Enum-Observed-Value or Compound-Enum-Observed-Value shall be supported in one object instance.	C
Absolute-Time-Stamp	MDC_ATTR_TIME_STAMP_ABS	AbsoluteTime		O
Relative-Time-Stamp	MDC_ATTR_TIME_STAMP_REL	RelativeTime		O
Hires-Time-Stamp	MDC_ATTR_TIME_STAMP_REL_HI_RES	HighResRelativeTime	High-resolution timestamp.	O
Enum-Measure-Range	MDC_ATTR_ENUM_RANGE_MSMT	EnumMsmtRange	List of supported observed value OIDs. Optional if the OID type (EnumVal::enumobjid) is used in the observed value; out of the scope of this standard otherwise.	C
Enum-Measure-Range-Bit-String	MDC_ATTR_ENUM_RANGE_MSMT_BIT_STRING	BITS-32	List of supported observed value bits in the bit string data type. Optional if the bit string type (EnumVal::enum-bit-str) is used in the observed value; out of the scope of this standard otherwise.	C
Enum-Measure-Range-Labels	MDC_ATTR_ENUM_RANGE_MSMT_LABELS	EnumMsmtRangeLabels	Associates text strings with specific enumeration values.	O

The Enumeration class defines in Table 22 the attribute groups or extensions to inherited attribute groups.

Table 22—Enumeration class attribute groups

Attribute group	Attribute group ID	Group elements
VMO Static Context Group (extensible attribute group)	MDC_ATTR_GRP_VMO_STATIC	from VMO: Type, Handle from Metric: Metric-Specification, Max-Delay-Time from Enumeration: Enum-Measure-Range-Labels
VMO Dynamic Context Group (extensible attribute group)	MDC_ATTR_GRP_VMO_DYN	from VMO: Label-String from Metric: Metric-Status, Measurement-Status, Metric-Id, Metric-Id-Ext, Unit-Code, Unit- Labelstring, Vmo-Source-List, Metric- Source-List, Msmt-Site-List, Body-Site- List, Metric-Calibration, Color, Measure- Mode, Measure-Period, Averaging-Period, Start-Time, Stop-Time, Metric-Info- Labelstring, Substance, Substance- Labelstring, Body-Site-List-Ext, Msmt-Site- List-Ext from Enumeration: Enum-Measure-Range, Enum-Measure- Range-Bit-String
Metric Observed Value Group (extensible attribute group)	MDC_ATTR_GRP_METRIC_VAL_OBS	from Metric: Metric-Id-Partition from Enumeration: Enum-Observed-Value, Absolute-Time- Stamp, Relative-Time-Stamp, Hires-Time- Stamp

The following ASN.1 data type definitions apply:

```
--
-- Enum-Observed-Value attribute
--
EnumObsValue ::= SEQUENCE {
    metric-id    OID-Type,           -- from VMO::Type or Metric-Id-Partition partition
    state        MeasurementStatus,
    value        EnumVal             -- supports different value data types
}

--
-- The enumeration value data type is used to provide different specific observation data types as follows
-- (Note that the type of measurement is coded in the top level structure EnumObsVal::metric-id)
--
-- enum-obj-id:                used to communicate a metric OID, e.g., as an annotation
--                               or other event defined in the VMO::Type or Metric-Id-
--                               Partition partition
--
-- enum-text-string:           used to communicate a free text string (e.g., a status
--                               message)
--
-- enum-external-code:         used to provide the code of an external nomenclature (e.g.,
--                               could be used for procedure codes not covered in the
--                               standard nomenclature)
--
-- enum-bit-str:               for coding bit string values; the bit string data type must be
--                               defined separately, e.g., in the nomenclature or in a
--                               device-specific standard
--
-- enum-record-metric/oo:      allows the identification of additional data types by a
--                               nomenclature code from the VMO::Type or
```

IEEE Std 11073-10201-2018
IEEE Standard for Part 10201: Domain Information Model

```

--
-- Metric-Id-Partition partition; the appended data type must
-- be defined separately, e.g., in a device-specific standard
enum-numeral:
-- used to provide numeral enumerated values that must be
-- defined separately, e.g., in a device-specific standard;
-- this type is not to be used for numeric measurements
--
EnumVal ::= CHOICE {
    enum-obj-id          [1] OID-Type,          -- from VMO::Type or Metric-Id-
-- Partition partition
    enum-text-string     [2] OCTET STRING,      -- free text
    enum-external-code   [8] ExtNomenRef,       -- code defined in other coding
-- system
    enum-bit-str         [16] BITS-32,          -- bit string
    enum-record-metric   [33] EnumRecordMetric, -- record type defined by ID from
-- VMO::Type or Metric-Id-
-- Partition partition
    enum-record-oo       [34] EnumRecordOo,     -- record type defined by ID from
-- object-oriented nomenclature
-- partition
    enum-numeral         [64] INT-U32           -- enumerated integer value
}

--
-- Record data type with structure and contents defined by a nomenclature ID from the VMO::Type or Metric-Id-
-- Partition partition
--
EnumRecordMetric ::= SEQUENCE {
    record-type-code     OID-Type,          -- from VMO::Type or Metric-Id-Partition partition
    record-data          ANY DEFINED BY record-type-code
}

--
-- Record data type with structure and contents defined by a nomenclature ID from the object-oriented
-- nomenclature partition
--
EnumRecordOo ::= SEQUENCE {
    record-type-code     OID-Type,          -- must be from object-oriented nomenclature partition
    record-data          ANY DEFINED BY record-type-code
}

--
-- Compound-Enum-Observed-Value attribute is the compound observed value
--
EnumObsValueCmp ::= SEQUENCE OF EnumObsValue

--
-- Enum-Measure-Range attribute defines the set of potential (i.e., legal) values of the Enum-Observed-Value
-- attribute (only allowed when EnumVal::enum-obj-id type is used)
-- OID-Types from VMO::Type or Metric-Id-Partition partition
--
EnumMsmRange ::= SEQUENCE OF OID-Type

--
-- Enum-Measure-Range-Labels attribute defines both the set of potential (i.e., legal) values of the Enum-
-- Observed-Value attribute as well as a text label that can be associated with each enumeration value
--
EnumMsmRangeLabels ::= SEQUENCE OF EnumMsmRangeLabel

EnumMsmRangeLabel ::= SEQUENCE {
    value      EnumVal,          -- specific enumeration setting
    label      OCTET STRING      -- textual label associated with value
}

```

6.3.10.2 Behavior

The Enumeration class does not define any special methods.

6.3.10.3 Notifications

The Enumeration class does not generate any special notifications.

6.3.11 ComplexMetric class

Class: ComplexMetric
Description: ComplexMetric objects act as a containers objects for other Metric objects, enabling reporting of the collection as a single semantic entity.
Superclass: Metric
Subclasses: --
Name Binding: Handle (VMO inherited)
Registered As: MDC_MOC_VMO_METRIC_CMPLX

6.3.11.1 Attributes

The ComplexMetric class defines the attributes in Table 23.

Table 23—ComplexMetric class attributes

Attribute name	Attribute ID	Attribute type	Remark	Qualifier
Cmplx-Metric-Info	MDC_ATTR_CMPLX_INFO	CmplxMetricInfo	Static attribute defining the object types used in the container.	M
Cmplx-Observed-Value	MDC_ATTR_CMPLX_VAL_OBS	CmplxObsValue		M
Cmplx-Dyn-Attr	MDC_ATTR_CMPLX_DYN_ATTR	CmplxDynAttr	Dynamic attributes of the individual objects within the ComplexMetric object.	O
Cmplx-Static-Attr	MDC_ATTR_CMPLX_STATIC_ATTR	CmplxStaticAttr	Static attributes of the individual objects within the ComplexMetric object.	O
Cmplx-Recursion-Depth	MDC_ATTR_CMPLX_RECURSION_DEPTH	INT-U16	Mandatory if the ComplexMetric object contains further ComplexMetric objects (e.g., recursion). If so, the attribute defines the maximum recursion depth.	C

ComplexMetric objects shall set the Metric::MetricSpec::structure::ms-struct::complex flag.

The ComplexMetric class defines in Table 24 the attribute groups or extensions to inherited attribute groups.

Table 24—ComplexMetric class attribute groups

Attribute group	Attribute group ID	Group elements
VMO Static Context Group (extensible attribute group)	MDC_ATTR_GRP_VMO_STATIC	from VMO: Type, Handle from Metric: Metric-Specification, Max-Delay-Time from ComplexMetric: Cmplx-Metric-Info, Cmplx-Static-Attr, Cmplx-Recursion-Depth
VMO Dynamic Context Group (extensible attribute group)	MDC_ATTR_GRP_VMO_DYN	from VMO: Label-String from Metric: Metric-Status, Measurement-Status, Metric-Id, Metric-Id-Ext, Unit-Code, Unit- Labelstring, Vmo-Source-List, Metric- Source-List, Msmt-Site-List, Body-Site- List, Metric-Calibration, Color, Measure- Mode, Measure-Period, Averaging-Period, Start-Time, Stop-Time, Metric-Info- Labelstring, Substance, Substance- Labelstring, Body-Site-List-Ext, Msmt-Site- List-Ext from ComplexMetric: Cmplx-Dyn-Attr
Metric Observed Value Group (extensible attribute group)	MDC_ATTR_GRP_METRIC_VAL_OBS	from Metric: Metric-Id-Partition from ComplexMetric: Cmplx-Observed-Value

The following ASN.1 data type definitions apply:

```
--
-- Definitions for Cmplx-Metric-Info attribute
--
CmplxMetricInfo ::= SEQUENCE {
    max-mplex-obs          INT-U8,
    max-mplex-dyn          INT-U8,
    cm-elem-info-list      CmplxElemInfoList
}

CmplxElemInfoList ::= SEQUENCE OF CmplxElemInfo

CmplxElemInfo ::= SEQUENCE {
    class-id               OID-Type,
    max-inst               INT-U8,
    max-inst-comp          INT-U8,
    max-comp-no            INT-U8,
    max-inst-mplex        INT-U8,
    max-str-size           INT-U16
}
```

-- maximum number of messages
-- until all multiplexed elements are
-- transmitted in the Metric
-- Observed Value Group
-- maximum number of messages
-- until all multiplexed elements are
-- transmitted in the VMO
-- Dynamic Context Group

-- number of objects from type class-id
-- number of compound objects from type class-id
-- maximum number of elements within a compound
-- object
-- number of multiplexed objects within max-inst +
-- max-inst-comp
-- maximum string size

```

--
-- Cmplx-Observed-Value attribute, representing the hierarchy of contained Metric objects
--
CmplxObsValue ::= SEQUENCE {
    cm-obs-cnt          INT-U8,          -- sequence counter begins with 0
                                         -- when a multiplex period begins
    cm-obs-flags        CmplxFlags,
    cm-obs-elem-list     CmplxObsElemList
}

CmplxFlags ::= BITS-8 {
    cmplx-flag-reserved(0)  -- for future extensions
}

CmplxObsElemList ::= SEQUENCE OF CmplxObsElem

CmplxObsElem ::= SEQUENCE {
    cm-elem-idx          INT-U8,
    cm-obs-elem-flgs     CmplxObsElemFlags,
    attributes           AttributeList
}

CmplxObsElemFlags ::= BITS-8 {
    cm-obs-elem-flg-mplex(0),          -- the element will be multiplexed
    cm-obs-elem-flg-is-setting(2),
    cm-obs-elem-flg-updt-episodic(4),
    cm-obs-elem-flg-msmt-noncontinuous(5)
}

--
-- Cmplx-Dyn-Attr with the dynamic context data of the hierarchy of contained Metric objects
--
CmplxDynAttr ::= SEQUENCE {
    cm-dyn-cnt          INT-U8,          -- sequence counter begins with 0
                                         -- when a multiplex period begins
    unused              INT-U8,
    cm-dyn-elem-list     CmplxDynAttrElemList
}

CmplxDynAttrElemList ::= SEQUENCE OF CmplxDynAttrElem

CmplxDynAttrElem ::= SEQUENCE {
    cm-elem-idx-1       INT-U8,          -- allows the definition, with cm-elem-idx-2, of a range
                                         -- of elements where the dynamic attributes apply
    cm-elem-idx-2       INT-U8,
    attributes           AttributeList
}

--
-- Cmplx-Static-Attr with the static context data of the hierarchy of contained Metric objects
--
CmplxStaticAttr ::= SEQUENCE {
    cm-static-elem-list  CmplxStaticAttrElemList
}

CmplxStaticAttrElemList ::= SEQUENCE OF CmplxStaticAttrElem

CmplxStaticAttrElem ::= SEQUENCE {
    cm-elem-idx-1       INT-U8,          -- allows the definition, with cm-elem-idx-2, of a range
                                         -- of elements where the static attributes apply
    cm-elem-idx-2       INT-U8,

```

```

attributes
    AttributeList
    -- only static attributes as defined for metric
    -- specialization are allowed here (i.e., no VMO or
    -- Metric attributes)
}

```

6.3.11.2 Behavior

The ComplexMetric class does not define any special methods.

6.3.11.3 Notifications

The ComplexMetric class does not generate any special notifications.

6.3.12 PM-Store class

Class: PM-Store
Description: PM-Store objects provide long-term storage capabilities for metric data. A PM-Store contains a variable number of PM-Segment objects that can be accessed only through the PM-Store object.
Superclass: VMO
Subclasses: --
Name Binding: Handle
Registered As: MDC_MOC_VMO_PMSTORE

6.3.12.1 Attributes

The PM-Store class defines the attributes in Table 25.

Table 25 —PM-Store class attributes

Attribute name	Attribute ID	Attribute type	Remark	Qualifier
Metric-Class	MDC_ATTR_METRIC_CLASS	OID-Type	Class of stored metric(s).	M
Store-Sample-Algorithm	MDC_ATTR_METRIC_STORE_SAMPLE_ALG	StoSampleAlg	Method used to derive stored values from metric observed values.	O
Storage-Format	MDC_ATTR_METRIC_STORE_FORMAT	StorageFormat	Layout of stored data in PM-Segment objects.	M
Store-Capacity-Count	MDC_ATTR_METRIC_STORE_CAPAC_CNT	INT-U32	Maximum number of stored values.	O
Store-Usage-Count	MDC_ATTR_OP_STAT	OperationalState	Actual number of stored values.	O
Sample-Period	MDC_ATTR_TIME_PD_SAMP	RelativeTime	Used if values are sampled periodically.	C
Number-Of-Segments	MDC_ATTR_NUM_SEG	INT-U16	Currently instantiated PM-Segment objects contained in the PM-Store object.	M

The PM-Store class defines in Table 26 the attribute groups or extensions to inherited attribute groups.

Table 26—PM-Store class attribute groups

Attribute group	Attribute group ID	Group elements
VMO Static Context Group (extensible attribute group)	MDC_ATTR_GRP_VMO_STATIC	from VMO: Type, Handle
VMO Dynamic Context Group (extensible attribute group)	MDC_ATTR_GRP_VMO_DYN	from VMO: Label-String
PM-Store Attribute Group	MDC_ATTR_GRP_PMSTORE	from PM-Store: Metric-Class, Store-Sample-Algorithm, Storage-Format, Store-Capacity-Count, Store-Usage-Count, Sample-Period, Number-Of-Segments

The following ASN.1 data type definitions apply:

```
--
-- The storage format defines the structure of the Segment-Data attribute in all contained PM-Segment objects
-- 1..255: range for normative formats
-- 32768..65535: range for private formats
-- other: reserved
--
StorageFormat ::= INT-U16 {
    sto-t-nos(0),
    sto-t-gen(1),           -- implies general format (i.e., PM-Segment, see 6.3.13)
    sto-t-nu-opt(2),        -- implies optimized Numeric object format
    sto-t-rtsa-opt(3)       -- implies optimized RealTimeSampleArray object format
}

--
-- Store-Sample-Algorithm attribute describes how samples are derived
--
StoSampleAlg ::= INT-U16 {
    st-alg-nos(0),
    st-alg-moving-average(1),
    st-alg-recursive(2),
    st-alg-min-pick(3),
    st-alg-max-pick(4),
    st-alg-median(5)
}
```

6.3.12.2 Behavior

The PM-Store class defines the methods in Table 27.

Table 27—PM-Store instance methods

Action	Mode	Action ID	Action parameter	Action result
Clear-Segments	Confirmed	MDC_ACT_SEG_CLEAR	SegmSelection	—
Get-Segments	Confirmed	MDC_ACT_SEG_GET	SegmSelection	SegmentAttrList
Get-Segment-Info	Confirmed	MDC_ACT_SEG_GET_INFO	SegmSelection	SegmentInfoList

The following ASN.1 data type definitions apply:

```
--
-- SegmSelection selects the PM-Segment objects that are subject to the method
--
SegmSelection ::= CHOICE {
```

IEEE Std 11073-10201-2018
IEEE Standard for Part 10201: Domain Information Model

```

all-segments          [1] INT-U16,      -- if this type is chosen to select all segments, the actual
                                -- contents of the field are "do not care" and should be 0
segm-id-list          [2] SegmIdList,
abs-time-range        [3] AbsTimeRange
}

--
-- SegmIdList selects PM-Segment objects by ID
--
SegmIdList ::= SEQUENCE OF InstNumber

--
-- The time range allows selection of PM-Segment objects by time period
--
AbsTimeRange ::= SEQUENCE {
    from-time  AbsoluteTime,
    to-time    AbsoluteTime
}

--
-- Get-Segments method returns a list of PM-Segment attribute lists that include the Segment-Data attribute; the
-- instance number is used to identify each segment
--
SegmentAttrList ::= SEQUENCE OF SegmentAttr

SegmentAttr ::= SEQUENCE {
    seg-inst-no  InstNumber,
    seg-attr     AttributeList
}

--
-- Segment contents information as a result to the Get-Segment-Info returns all attributes of the PM-Segment
-- objects except the Segment-Data attribute; this is useful to get just information about the contents
--
SegmentInfoList ::= SEQUENCE OF SegmentInfo

SegmentInfo ::= SEQUENCE {
    seg-inst-no  InstNumber,
    seg-info     AttributeList
}

```

6.3.12.3 Notifications

The PM-Store class does not generate any special notifications.

6.3.13 PM-Segment class

Class:	PM-Segment
Description:	A PM-Segment object represents a continuous time period in which a metric is stored without any changes of relevant metric context attributes (e.g., scales, labels). PM-Segment objects are contained in a PM-Store object and are not directly accessible by management services.
Superclass:	Top
Subclasses:	--
Name Binding:	Instance Number (object not directly manageable; instance number unique within a single PM-Store instance)
Registered As:	MDC_MOC_PM_SEGMENT

6.3.13.1 Attributes

The PM-Segment class defines the attributes in Table 28.

Table 28—PM-Segment class attributes

Attribute name	Attribute ID	Attribute type	Remark	Qualifier
Instance-Number	MDC_ATTR_ID_INSTNO	InstNumber		M
Metric-Id	MDC_ATTR_ID_PHYSIO	OID-Type	ID of stored metric (from VMO::Type or Metric-IdPartition partition).	M
Metric-Id-Ext	MDC_ATTR_ID_MSMT_EXT	ExtNomenRef	Dynamic identification of the metric in a different nomenclature or dictionary. Use of this attribute severely limits interoperability of applications.	O
Vmo-Global-Reference	MDC_ATTR_VMO_REF_GLB	GLB-HANDLE	Reference to stored Metric object.	O
Segment-Start-Abs-Time	MDC_ATTR_TIME_START_SEG	AbsoluteTime	Start time of segment.	O
Segment-End-Abs-Time	MDC_ATTR_TIME_END_SEG	AbsoluteTime	End time of segment.	O
Segment-Usage-Count	MDC_ATTR_SEG_USAGE_CNT	INT-U32	Actual (i.e., current) number of stored values.	O
Segment-Data-Gen	MDC_ATTR_SEG_DATA_GEN	SegDataGen	Segment data stored in a format as specified in the PM-Store object. Exactly one of the following attributes shall be implemented for any PM-Segment object: Segment-Data-Gen, Segment-Data-Nu-Opt, Segment-Data-Rtsa-Opt.	C
Segment-Data-Nu-Opt	MDC_ATTR_SEG_DATA_NU_OPT	SegDataNuOpt	Segment data stored in a format as specified in the PM-Store object. Exactly one of the following attributes shall be implemented for any PM-Segment object: Segment-Data-Gen, Segment-Data-Nu-Opt, Segment-Data-Rtsa-Opt.	C
Segment-Data-Rtsa-Opt	MDC_ATTR_SEG_DATA_RTSA_OPT	SegDataRtsaOpt	Segment data stored in a format as specified in the PM-Store object. Exactly one of the following attributes shall be implemented for any PM-Segment object: Segment-Data-Gen, Segment-Data-Nu-Opt, Segment-Data-Rtsa-Opt.	C
Context Attributes	As defined for Metric derived objects	Any attribute from Metric-derived objects that is member of either the VMO Static Context Group or the VMO Dynamic Context Group	Metric context attributes are allowed in this object without container. Attributes are identified by their OID. This reference to attributes is an editorial convenience. There is no need to copy all attributes from the various objects to the PM-Segment object. Copying attributes is not a hidden form of inheritance.	

The PM-Segment class defines no attribute groups.

The following ASN.1 data type definitions apply:

```
--
-- General segment data format; each stored value is one attribute list
-- NOTE--This format may be very storage-intensive
--
SegDataGen ::= SEQUENCE OF AttributeList

--
-- Optimized Numeric object format for periodically acquired numerics; only the actual value is stored
--
SegDataNuOpt ::= SEQUENCE OF FLOAT-Type

--
-- Optimized RealTimeSampleArray object format; a consecutive array of samples
--
SegDataRtsaOpt ::= OCTET STRING
```

6.3.13.2 Behavior

The PM-Segment class does not define any special methods.

6.3.13.3 Notifications

The PM-Segment class does not generate any special notifications.

6.4 Alert package

6.4.1 Alert class

Class: Alert

Description: An Alert object stands for the status of a simple alert condition check. As such, it represents a single alert condition only. The alert condition can be either a physiological alarm or a technical alarm condition of a related object (e.g., MDS, VMD, Metric).

Superclass: VMO

Subclasses: --

Name Binding: Handle

Registered As: MDC_MOC_VMO_AL

6.4.1.1 Attributes

The Alert class defines the attributes in Table 29.

Table 29—Alert class attributes

Attribute name	Attribute ID	Attribute type	Remark	Qualifier
Alert-Condition	MDC_ATTR_AL_COND	AlertCondition		M
Limit-Specification	MDC_ATTR_AL_LIMIT	LimitSpecEntry	Relevant for limit alarms only.	O
Vmo-Reference	MDC_ATTR_VMO_REF	HANDLE		O

NOTE—The VMO inherited type field defines if the Alert represents a technical or physiological alarm.

The Alert class defines in Table 30 the attribute groups or extensions to inherited attribute groups.

Table 30 —Alert class attribute groups

Attribute group	Attribute group ID	Group elements
VMO Static Context Group (extensible attribute group)	MDC_ATTR_GRP_VMO_STATIC	from VMO: Type, Handle from Alert: Vmo-Reference
VMO Dynamic Context Group (extensible attribute group)	MDC_ATTR_GRP_VMO_DYN	from VMO: Label-String from Alert: Limit-Specification
Alert Group	MDC_ATTR_GRP_AL	from Alert: Alert-Condition

The following ASN.1 data type definitions apply:

```
--
-- Alert-Condition attribute is the status output of the process that is detecting the alert
--
AlertCondition ::= SEQUENCE {
    obj-reference      HANDLE,
    controls           AlertControls,
    alert-flags        AlertFlags,      -- supporting flags
    alert-source       OID-Type,        -- from metric or object-oriented nomenclature
                                         -- partition
    alert-code         OID-Type,        -- from events nomenclature partition
    alert-type         AlertType,       -- defines type and severity of condition
    alert-info-id      PrivateOid,     -- specific information can be appended; 0 if not used
    alert-info         ANY DEFINED BY alert-info-id
}
```

NOTE—The alert-code value is a code that comes from the events nomenclature partition. Entries (i.e., codes) in this partition are even. The last bit of the code is used to determine whether the alert-source comes from the metric nomenclature partition or the object-oriented nomenclature partition. If the last bit of the alert-code value is 0, the alert-source comes from the metric nomenclature partition. If the last bit is 1 (1 is added to the base code in the events nomenclature), the alert-source comes from the object-oriented nomenclature partition.

```
--
-- Alert controls define flags to communicate status information relevant for alert processor; this structure is
-- reused in the AlertStatus class
--
AlertControls ::= BITS-16 {
    ac-obj-off(0),      -- the object supervised by the alert is off
    ac-chan-off(1),     -- channel is off
    ac-all-obj-al-off(3), -- all alerts supervising the referenced objects are off
    ac-alert-off(4),    -- this alert supervisor process is off
    ac-alert-muted(5)   -- this alert is temporarily muted by the user (e.g. on ventilators to allow
                        -- physiotherapy or suction)
}

--
-- Alert flags give additional support information on how to process the condition; this structure is used by
-- AlertStatus objects as well
--
AlertFlags ::= BITS-16 {
    local-audible(1),   -- indicates that the condition is audible at the local system
    remote-audible(2),  -- condition can be audible at remote (i.e., not suppressed)
```

IEEE Std 11073-10201-2018
IEEE Standard for Part 10201: Domain Information Model

```

visual-latching(3),          -- visible latching of the condition is allowed
audible-latching(4),        -- audio latching of the condition is allowed
derived(6),                  -- do not start alarm recording
record-inhibit(8)
}

--
-- Alert type is used to distinguish severity of technical and physiological alarms
--
AlertType ::= INT-U16 {
    no-alert(0),
    low-pri-t-al(1),          -- low-priority technical alarm
    med-pri-t-al(2),          -- medium-priority technical alarm
    hi-pri-t-al(4),           -- high-priority technical alarm
    low-pri-p-al(256),         -- awareness condition
    med-pri-p-al(512),         -- prompt response required (i.e., abnormal condition)
    hi-pri-p-al(1024)         -- immediate response required (i.e., emergency condition)
}

--
-- Limit-Specification attribute specifies the supervised limit range
--
LimitSpecEntry ::= SEQUENCE {
    object-handle              HANDLE,
    al-source-id               OID-Type,    -- typically the metric ID of the measurement
    unit-code                  OID-Type,    -- from DIM partition
    lim-al-stat                 CurLimAlStat, -- see 6.6.8.1 for definition
    lim-al-val                  CurLimAlVal, -- see 6.6.8.1 for definition
                                -- for definition
}

```

6.4.1.2 Behavior

The Alert class does not define any special methods.

6.4.1.3 Notifications

The Alert class does not generate any special notifications.

6.4.2 AlertStatus class

Class:	AlertStatus
Description:	An AlertStatus object represents the output of an alarm process that considers all alert conditions in a scope that spans one or more objects. In contrast to an Alert object, an AlertStatus object collects all alert conditions related to a VMD object hierarchy or multiple alert conditions related to an MDS object and provides this information in list-structured attributes.
Superclass:	VMO
Subclasses:	--
Name Binding:	Handle
Registered As:	MDC_MOC_VMO_AL_STAT

6.4.2.1 Attributes

The AlertStatus class defines the attributes in Table 31.

Table 31—AlertStatus class attributes

Attribute name	Attribute ID	Attribute type	Remark	Qualifier
Alert-Capab-List	MDC_ATTR_AL_STAT_AL_C_LIST	AlertCapabList	Capabilities of the AlertStatus object.	M
Tech-Alert-List	MDC_ATTR_ALSTAT_AL_T_LIST	AlertList	List of technical alert information.	O
Physio-Alert-List	MDC_ATTR_ALSTAT_AL_P_LIST	AlertList	List of physiological alert information.	O
Limit-Spec-List	MDC_ATTR_AL_LIMIT_SPEC_LIST	LimitSpecList	List of limit alarm ranges.	O

The AlertStatus class defines in Table 32 the attribute groups or extensions to inherited attribute groups.

Table 32—AlertStatus class attribute groups

Attribute group	Attribute group ID	Group elements
VMO Static Context Group (extensible attribute group)	MDC_ATTR_GRP_VMO_STATIC	from VMO: Type, Handle from AlertStatus: Alert-Capab-List
VMO Dynamic Context Group (extensible attribute group)	MDC_ATTR_GRP_VMO_DYN	from VMO: Label-String from AlertStatus: Limit-Spec-List
AlertStatus Group	MDC_ATTR_GRP_AL_STAT	from AlertStatus: Tech-Alert-List, Physio-Alert-List

The following ASN.1 data type definitions apply:

```
--
-- The alert list is used to communicate alert conditions derived by the AlertStatus object
--
AlertList ::= SEQUENCE OF AlertEntry

AlertEntry ::= SEQUENCE {
    obj-reference      HANDLE,
    instance          InstNumber,      -- to support multiple alarms of one object
    controls          AlertControls,
    alert-source       OID-Type,        -- from metric or object-oriented nomenclature
                                         -- partition
    alert-code         OID-Type,        -- from alerts nomenclature partition
    alert-type         AlertType,
    alert-info-id      PrivateOid,
    alert-info         ANY DEFINED BY alert-info-id
}
```

NOTE—The alert-code value is a code that comes from the events nomenclature partition. Entries (i.e., codes) in this partition are even. The last bit of the code is used to determine whether the alert-source comes from the metric nomenclature partition or the object-oriented nomenclature partition. If the last bit of the alert-code value is 0, the alert-source comes from the metric nomenclature partition. If the last bit is 1 (1 is added to the base code in the events nomenclature), the alert-source comes from the object-oriented nomenclature partition.

```
--
-- AlertStatus object provides a capability list with entries for each supervised object in its scope
--
AlertCapabList ::= SEQUENCE OF AlertCapabEntry
```

```

AlertCapabEntry ::= SEQUENCE {
    obj-reference      HANDLE,
    obj-class          OID-Type,
    alert-group        OID-Type,      -- allows grouping of Alert objects so that a processor
                                     -- can select to display only one from a given group
                                     -- (metric ID)

    al-rep-flags       AlertRepFlags, -- defines how multiple alarms are communicated
    max-t-severity     AlertType,      -- most severe technical alarm
    max-t-obj-al        INT-U16,       -- maximum number of parallel technical alarms for
                                     -- this object

    max-p-severity     AlertType,      -- most severe physiological alarm
    max-p-obj-al        INT-U16       -- maximum number of parallel physiological alarms
                                     -- for this object
}

AlertRepFlags ::= BITS-16 {
    dyn-inst-contents(1),
    rep-all-inst(2)
}

--
-- Limit-Spec-List attributed specifies the supervised limit ranges
--
LimitSpecList ::= SEQUENCE OF LimitSpecEntry

```

6.4.2.2 Behavior

The AlertStatus class does not define any special methods.

6.4.2.3 Notifications

The AlertStatus class does not generate any special notifications.

6.4.3 AlertMonitor class

Class:	AlertMonitor
Description:	An AlertMonitor object represents the output of a medical device system or system alert processor. As such, it represents the overall device or system alert condition and provides a list of all alert conditions of the system in its scope. This list includes global state information and individual alarm state information that allows the implementation of a safety standard-compliant alarm display on a remote system.
Superclass:	VMO
Subclasses:	--
Name Binding:	Handle
Registered As:	MDC_MOC_VMO_AL_MON

6.4.3.1 Attributes

The AlertMonitor class defines the attributes in Table 33.

Table 33—AlertMonitor class attributes

Attribute name	Attribute ID	Attribute type	Remark	Qualifier
Device-Alert-Condition	MDC_ATTR_DEV_AL_COND	DevAlertCondition	Global device alert status.	M
Device-P-Alarm-List	MDC_ATTR_AL_MON_P_AL_LIST	DevAlarmList	Active physiological alarm list.	M
Device-T-Alarm-List	MDC_ATTR_AL_MON_T_AL_LIST	DevAlarmList	Active technical alarm list.	M
Device-Sup-Alarm-List	MDC_ATTR_AL_MON_S_AL_LIST	DevAlarmList	Suppressed physiological alarm list.	O
Limit-Spec-List	MDC_ATTR_AL_LIMIT_SPEC_LIST	LimitSpecList	List of limit alarm ranges.	O
Suspension-Period	MDC_ATTR_TIME_PD_AL_SUSP	RelativeTime	Remaining alarm suspend time.	O

The AlertMonitor class defines in Table 34 the attribute groups or extensions to inherited attribute groups.

Table 34—AlertMonitor class attribute groups

Attribute group	Attribute group ID	Group elements
VMO Static Context Group (extensible attribute group)	MDC_ATTR_GRP_VMO_STATIC	from VMO: Type, Handle
VMO Dynamic Context Group (extensible attribute group)	MDC_ATTR_GRP_VMO_DYN	from VMO: Label-String from AlertMonitor: Limit-Spec-List
AlertMonitor Group	MDC_ATTR_GRP_AL_MON	from AlertMonitor : Device-Alert-Condition, Device-P-Alarm-List, Device-T-Alarm-List, Device-Sup-Alarm-List, Suspension-Period

The following ASN.1 data type definitions apply:

```
--
-- Device-Alert-Condition attribute describes the global MDS alarm status
--
DevAlertCondition ::= SEQUENCE {
    device-alert-state      AlertState,
    al-stat-chg-cnt         AlStatChgCnt,    -- change counter marks state or active alerts change
    max-p-alarm             AlertType,
    max-t-alarm             AlertType,
    max-aud-alarm           AlertType        -- maximum severity of audible alarm
}

AlertState ::= BITS-16 {
    al-inhibited(0),          -- off
    al-suspended(1),         -- alert(ing) inactivated temporarily; alert condition acknowledged
    al-latched(2),           -- specific alert is latched (or AlMon latches alert conditions)
    al-silenced-reset(3),    -- (transition only); alert indication stopped, but alarming re-enabled
    al-dev-in-test-mode(5),   -- device is in test mode; the alarms are not real patient alarms
    al-dev-in-standby-mode(6), -- device is in standby mode
    al-dev-in-demo-mode(7)   -- device is in demonstration mode, the alarms are not real patient alarms
}

AlStatChgCnt ::= SEQUENCE {
```

IEEE Std 11073-10201-2018
IEEE Standard for Part 10201: Domain Information Model

```

    al-new-chg-cnt          INT-U8,          -- Device-Alert-Condition attribute changed
    al-stack-chg-cnt       INT-U8          -- alert stack (active alarm list attributes) changed
}

--
-- Device alarm list
--
DevAlarmList ::= SEQUENCE OF DevAlarmEntry

DevAlarmEntry ::= SEQUENCE {
    al-source              OID-Type,        -- from metric or object-oriented nomenclature
                                         -- partition
    al-code                OID-Type,        -- from events nomenclature partition
    al-type                AlertType,
    al-state               AlertState,
    object                 ManagedObjectId,
    alert-info-id          PrivateOid,
    alert-info             ANY DEFINED BY alert-info-id
}

```

NOTE—The al-code value is a code that comes from the events nomenclature partition. Entries (i.e., codes) in this partition are even. The last bit of the code is used to determine whether the al-source comes from the metric nomenclature partition or the object-oriented nomenclature partition. If the last bit of the al-code value is 0, the al-source comes from the metric nomenclature partition. If the last bit is 1 (1 is added to the base code in the events nomenclature), the al-source comes from the object-oriented nomenclature partition.

6.4.3.2 Behavior

The AlertMonitor class does not define any special methods.

6.4.3.3 Notifications

The AlertMonitor class does not generate any special notifications.

6.5 System package

6.5.1 VMS class

Class:	VMS
Description:	The VMS class is the abstract base class for all System Package classes in this model. It provides consistent naming and identification of system-related objects.
Superclass:	Top
Subclasses:	MDS
Name Binding:	Handle
Registered As:	MDC_MOC_VMS

6.5.1.1 Attributes

The VMS class defines the attributes in Table 35.

Table 35—VMS class attributes

Attribute name	Attribute ID	Attribute type	Remark	Qualifier
Handle	MDC_ATTR_ID_HANDLE	HANDLE	Name binding attribute.	M
System-Type	MDC_ATTR_SYS_TYPE	TYPE	Examples: ventilator, monitor as defined in nomenclature	M
System-Model	MDC_ATTR_ID_MODEL	SystemModel	Model describes manufacturer and model number.	C
System-Id	MDC_ATTR_SYS_ID	OCTET STRING	Unique system ID, e.g., serial number.	C
Compatibility-Id	MDC_ATTR_ID_COMPAT	INT-U32	For manufacturer use.	O
Nomenclature-Version	MDC_ATTR_NOM_VERSION	NomenclatureVersion	Version ISO/IEEE 11073 part 10101 used by the system.	C
System-Capability	MDC_ATTR_SYS_CAPAB	SystemCapability	Set of supported features; system specific.	O
System-Specification	MDC_ATTR_SYS_SPECN	SystemSpec	Defines functional components.	O
Production-Specification	MDC_ATTR_ID_PROD_SPECN	ProductionSpec	Component revisions, serial numbers, etc.	O
Udi	MDC_ATTR_ID_UDI	UdiSpec	This attribute defines the UDI(s) under which this product is listed with an authority such as the US FDA.	O
Ext-Obj-Relations	MDC_ATTR_EXT_OBJ_RELATION	ExtObjRelationList	Relations to objects that are not defined in the DIM.	O

The conditional (C) VMS attributes are mandatory for the top-level VMS object instance (i.e., root object instance of the containment tree); they are optional otherwise.

The VMS class defines in Table 36 the attribute groups or extensions to inherited attribute groups.

Table 36—VMS class attribute groups

Attribute group	Attribute group ID	Group elements
System Identification Attribute Group (extensible attribute group)	MDC_ATTR_GRP_SYS_ID	from VMS: System-Type, System-Model, System-Id, Compatibility-Id, Nomenclature-Version
System Application Attribute Group (extensible attribute group)	MDC_ATTR_GRP_SYS_APPL	from VMS: System-Capability, System-Specification
System Production Attribute Group (extensible attribute group)	MDC_ATTR_GRP_SYS_PROD	from VMS: Production-Specification, Udi

NOTE—The Relationship Attribute Group is not shown again in the definitions of derived classes.

The following ASN.1 data type definitions apply:

```
--
-- System-Model attribute is specified by manufacturer and manufacturer-specific model number
--
SystemModel ::= SEQUENCE {
```

IEEE Std 11073-10201-2018
IEEE Standard for Part 10201: Domain Information Model

```

    manufacturer          OCTET STRING,
    model-number          OCTET STRING
}

--
-- System-Capability attribute is a top-level specification of implemented functions; (the following is an example
-- only)
--
SystemCapability ::= BITS-32 {
    sc-multiple-context(0),      -- indicates that system uses multiple naming contexts
    sc-dyn-configuration(1),    -- containment tree changes dynamically
    sc-dyn-scanner-create(2),   -- system allows host to create Scanner objects dynamically
    sc-auto-init-scan-list(3),  -- CfgScanner object supports automatic scan list initialization
    sc-auto-updt-scan-list(4)   -- CfgScanner object supports automatic scan list update
}

--
-- System-Specification attribute allows specific entries for system functional components
--
SystemSpec ::= SEQUENCE OF SystemSpecEntry

SystemSpecEntry ::= SEQUENCE {
    component-capab-id         PrivateOid,
    component-spec             ANY DEFINED BY component-capab-id
}

--
-- Production-Specification attribute deals with serial numbers, part numbers, revisions, etc.; note that a device
-- may have multiple components so the Production-Specification attribute should be a printable string defining
-- the component and the "number"
--
ProductionSpec ::= SEQUENCE OF ProdSpecEntry

ProdSpecEntry ::= SEQUENCE {
    spec-type                 ProdSpecType,
    component-id              PrivateOid,
    prod-spec                 OCTET STRING
}

ProdSpecType ::= INT-U16 {
    unspecified(0),
    serial-number(1),
    part-number(2),
    hw-revision(3),
    sw-revision(4),
    fw-revision(5),
    protocol-revision(6),
    prod-spec-gmdn(7),        -- Global Medical Device Nomenclature8
    device-identifier(8),    -- component of UDI.
    manufacture-date(9),    -- component of UDI. ISO 8601 formatted date with optional hour.
    expiry-date(10),        -- component of UDI. ISO 8601 formatted date with optional hour.
    lot-number(11)          -- component of UDI.
}

--
-- UdiSpec supports the encoding of a unique device identifier such as the US FDA UDI.
--
UdiSpec ::= SEQUENCE OF UdiSpecification

```

⁸ The Global Medical Device Nomenclature (GMDN) is based on ISO 15225 and was developed under the auspices of CEN TC257 SC1

```

UdiSpecification ::= SEQUENCE {
    udi-authority      UdiAuthority,
    udi-issuer         UdiIssuer,
    udi-label          UdiLabel
}

--

-- Identifies the regulatory agency having jurisdiction over the creation of the UDI, such as the US FDA.
-- The ITU OID for US FDA is 2.16.840.1.113883.3.24
UdiAuthority ::= ITU-OID;

-- Organization that is charged with issuing UDIs for devices.
-- For example, the US FDA issuers include:
-- GS1(2.51), HIBCC(1.0.15961.13.10) and ICCBBA(2.16.840.1.113883.6.18)
-- An ITU OID length of 0 should be used if the issuer is unknown or not recorded in the
-- device.
UdiIssuer ::= ITU-OID;

--
-- An ITU OID can be used as an unique identifier for an organization
-- ITU OID trees are maintained by registration authorities with ITU-T and ISO at the top;
-- HL7 manages an OID tree;
-- see http://oid-info.com/index.htm
--
ITU-OID ::= OCTET STRING

-- Full text label on the human readable string
-- Matches the human readable UDI string that is part of the labeling of the device
UdiLabel ::= OCTET STRING

--
-- Nomenclature-Version attribute contains a part of the major version field (i.e., basic compatibility) and the
-- minor version (used to identified the latest used update); the major version part is coded as a bit field so that
-- systems supporting multiple versions can negotiate the version used within an association
--
NomenclatureVersion ::= SEQUENCE {
    nom-major-version  NomenclatureMajorVersion,      -- major version identifier
    nom-minor-version  INT-U16                        -- counter to identify minor updates
}

NomenclatureMajorVersion ::= BITS-16 {
    majorVersion1(0),
    majorVersion2(1),
    majorVersion3(2),
    majorVersion4(3)
}

```

6.5.1.2 Behavior

The VMS class does not define any special methods.

6.5.1.3 Notifications

The VMS class does not generate any special notifications.

6.5.2 MDS class

Class:	MDS
Description:	The MDS class is an abstraction of a device that provides medical information in the form of instances of classes that are defined in the Medical Package of the DIM. Further specializations of this class are used to represent differences in complexity and scope. As a base class, the MDS object cannot be instantiated.
Superclass:	VMS
Subclasses:	CompositeMultipleBedMDS, SinglePatientMDS
Name Binding:	Handle
Registered As:	MDC_MOC_VMS_MDS

6.5.2.1 Attributes

The MDS class defines the attributes in Table 37.

Table 37—MDS class attributes

Attribute name	Attribute ID ^a	Attribute type	Remark	Qualifier ^b
Mds-Status	MDC_ATTR_VMS_MDS_STAT	MDSStatus	Device state according to MDS FSM.	C
Bed-Label	MDC_ATTR_ID_BED_LABEL	OCTET STRING	Printable string identifying system location.	O
Soft-Id	MDC_ATTR_ID_SOFT	OCTET STRING	Settable, e.g., hospital inventory number.	O
Operating-Mode	MDC_ATTR_MODE_OP	PrivateOid		O
Application-Area	MDC_ATTR_AREA_APPL	ApplicationArea		O
Patient-Type	MDC_ATTR_PT_TYPE	PatientType	May control algorithms, see 7.10.1.1 for definition of type.	O ^c
Date-And-Time	MDC_ATTR_TIME_ABS	AbsoluteTime	MDS maintains device time.	O
Relative-Time	MDC_ATTR_TIME_REL	RelativeTime		O
Hires-Relative-Time	MDC_ATTR_TIME_REL_HI_RES	HighResRelativeTime		O
Power-Status	MDC_ATTR_POWER_STAT	PowerStatus	Either onBattery or onMains.	O ^d
Altitude	MDC_ATTR_ALTITUDE	INT-I16	Meters above or below sea level.	O
Battery-Level	MDC_ATTR_VALBAT_CHARGE	INT-U16	In % of capacity; undefined if value > 100.	O
Remaining-Battery-Time	MDC_ATTR_TIME_BATT_REMAIN	BatMeasure	See 7.5.9.1 for the definition of type; minutes are the recommended measurement unit.	O
Line-Frequency	MDC_ATTR_LINE_FREQ	LineFrequency	Frequency of mains; implicitly in hertz (typically either 50 Hz or 60 Hz)	O

Table continues

Table 37—MDS class attributes (continued)

Attribute name	Attribute ID ^a	Attribute type	Remark	Qualifier ^b
Association-Invoke-Id	MDC_ATTR_ID_ASSOC_NO	INT-U16	Counter for number of associations on a given communications port; Incremented with each association control service element (ACSE) association	O
Locale	MDC_ATTR_LOCALE	Locale	Defines charset and language of printable string attributes in this MDS and contained objects. Contained MDS or VMD objects may define different Locale attributes for their scope. The top-level MDS shall support this attribute.	C

^a Some of the VMS and MDS attributes need to be exchanged during association as user information fields in the ACSE protocol. The ACSE user information fields should contain only VMS or MDS attributes.

^b The conditional (C) MDS attributes are mandatory for the top-level MDS object instance (i.e., root object instance of the containment tree); they are optional otherwise.

^c If MDS supports the PatientDemographics object, the MDS object should not contain this attribute to avoid conflicts

^d If more information for battery-powered devices about the battery is needed (especially if the battery is manageable), a special Battery object should be used.

The MDS class defines in Table 38 the attribute groups or extensions to inherited attribute groups.

Table 38—MDS class attribute groups

Attribute group	Attribute group ID	Group elements
System Identification Attribute Group (extensible attribute group)	MDC_ATTR_GRP_SYS_ID	from VMS: System-Type, System-Model, System-Id, Compatibility-Id, Nomenclature-Version from MDS: Soft-Id, Association-Invoke-Id, Locale
System Application Attribute Group (extensible attribute group)	MDC_ATTR_GRP_SYS_APPL	from VMS: System-Capability, System-Specification from MDS: Mds-Status, Bed-Label, Operating-Mode, Application-Area, Patient-Type, Date-And- Time, Relative-Time, Hires-Relative-Time, Power-Status, Altitude, Battery-Level, Remaining-Battery-Time, Line-Frequency
System Production Attribute Group (extensible attribute group)	MDC_ATTR_GRP_SYS_PROD	from VMS: Production-Specification

The following ASN.1 data type definitions apply:

```
--
-- MDS state of one association/connection according to FSM
--
MDSStatus ::= INT-U16 {
    disconnected(0),
    unassociated(1),
    associating(2),
    associated(3),
```

```

    configuring(4),
    configured(5),
    operating(6),
    re-initializing(7),
    terminating(8),
    disassociating(9),
    disassociated(10),
    re-configuring(11)
}

--
-- Application-Area attribute
--
ApplicationArea ::= INT-U16 {
    area-unspec(0),
    area-operating-room(1),
    area-intensive-care(2)
}

--
-- Power-Status attribute defines whether the device is on battery or on mains; upper bits define the charging state
--
PowerStatus ::= BITS-16 {
    onMains(0),           -- Power source is mains, feed instance agnostic.
    onBattery(1),         -- Power source is battery, battery instance agnostic.
    deviceOff(4),         -- Device is off, condition detected by an external device interface
                        -- or other means.
    standby(5),           -- Device is in standby mode, typically at a lower power consumption
                        -- level and typically after the power on self-test. Device is
                        -- immediately available for use.
    chargingFull(8),      -- Indicates fully charged, battery instance agnostic.
    chargingTrickle(9),   -- Indicates at least one charging in trickle state, battery instance
                        -- agnostic.
    chargingOff(10)       -- Indicates all charging is off, battery instance agnostic.
}

--
-- Line-Frequency attribute
--
LineFrequency ::= INT-U16 {
    line-f-unspec(0),
    line-f-50hz(1),
    line-f-60hz(2)
}

```

6.5.2.2 Behavior

The MDS class defines the methods in Table 39.

Table 39 —MDS instance methods

Action	Mode	Action ID	Action parameter	Action result
Mds-Set-Status	Confirmed	MDC_ACT_SET_MDS_STATE	MdsSetStateInvoke	MdsSetStateResult

The following ASN.1 data type definitions apply:

```

--
-- MDS-Set-State method permits modification of the state of the MDS state machine e.g., to trigger a reset (if
-- supported by a device)

```

-- NOTE--Usage of the authorization type is implementation-specific, especially given the security and operational coordination issues involved

```
--
MdsSetStateInvoke ::= SEQUENCE {
    new-state          MDSSStatus,
    authorization      INT-U32
}
```

```
MdsSetStateResult ::= MDSSStatus
```

6.5.2.3 Notifications

The MDS class defines the events in Table 40.

Table 40—MDS events

Event	Mode	Event ID	Event parameter	Event result
System-Error	Unconfirmed	MDC_NOTI_SYS_ERR	MdsErrorInfo	—
Mds-Create-Notification	Confirmed	MDC_NOTI_MDS_CREAT	MdsCreateInfo	—
Mds-Attribute-Update	Confirmed	MDC_NOTI_MDS_ATTR_UPDT	MdsAttributeChangeInfo	—

The following ASN.1 data type definitions apply:

```
--
-- System-Error notification in case of system errors
--
MdsErrorInfo ::= SEQUENCE {
    error-type PrivateOid,
    error-info ANY DEFINED BY error-type
}

--
-- Mds-Create-Notification event is sent after association is established
--
MdsCreateInfo ::= SEQUENCE {
    class-id          ManagedObjectId,
    attribute-list     AttributeList -- attributes from the System Identification Attribute
                                -- Group and System Application Attribute Group
}

--
-- MDS may report changes of attribute values
--
MdsAttributeChangeInfo ::= AttributeList
```

6.5.3 CompositeMultipleBedMDS class

Class: CompositeMultipleBedMDS
Description: The CompositeMultipleBedMDS class represents a device that contains multiple MDS objects at multiple locations (i.e., multiple beds).
Superclass: MDS
Subclasses: --
Name Binding: Handle
Registered As: MDC_MOC_VMS_MDS_COMPOS_MULTI_BED

The CompositeMultipleBedMDS class does not define any attributes, methods, or notifications.

6.5.4 SinglePatientMDS class

Class:	SinglePatientMDS
Description:	The SinglePatientMDS is an abstract class that models a medical device that is associated with a single patient.
Superclass:	MDS
Subclasses:	CompositeSingleBedMDS, SingleSystemMDS
Name Binding:	Handle
Registered As:	N/A

The SinglePatientMDS class does not define any attributes, methods, or notifications.

6.5.5 CompositeSingleBedMDS class

Class:	CompositeSingleBedMDS
Description:	The CompositeSingleBedMDS class models a device that contains one or more SimpleMDS or HydraMDS objects at one location (i.e., a bed).
Superclass:	SinglePatientMDS
Subclasses:	--
Name Binding:	Handle
Registered As:	MDC_MOC_VMS_MDS_COMPOS_SINGLE_BED

The CompositeSingleBedMDS class does not define any attributes, methods, or notifications.

6.5.6 SingleSystemMDS class

Class:	SingleSystemMDS
Description:	The SingleSystemMDS class models a medical device that contains VMD objects and that may be contained by a CompositeMDS object.
Superclass:	SinglePatientMDS
Subclasses:	SimpleMDS, HydraMDS
Name Binding:	Handle
Registered As:	N/A

The SingleSystemMDS class does not define any attributes, methods, or notifications.

6.5.7 SimpleMDS class

Class:	SimpleMDS
Description:	The SimpleMDS class models a medical device that contains a single VMD instance only (i.e., a single-purpose device).
Superclass:	SingleSystemMDS
Subclasses:	--
Name Binding:	Handle
Registered As:	MDC_MOC_VMS_MDS_SIMP

The SimpleMDS class does not define any attributes, methods, or notifications.

6.5.8 HydraMDS class

Class:	HydraMDS
Description:	The HydraMDS class models a device that contains multiple VMD instances (i.e., a multipurpose device).
Superclass:	SingleSystemMDS
Subclasses:	--
Name Binding:	Handle
Registered As:	MDC_MOC_VMS_MDS_HYD

The HydraMDS class does not define any attributes, methods, or notifications.

6.5.9 Log class

Class: Log
Description: A Log object is a storage container for important local system notifications and events. Further specializations define specific event types that are stored in the Log object. The Log class is an abstract base class and cannot be instantiated.
Superclass: Top
Subclasses: EventLog
Name Binding: Handle
Registered As: MDC_MOC_LOG

6.5.9.1 Attributes

The Log class defines the attributes in Table 41.

Table 41—Log class attributes

Attribute name	Attribute ID	Attribute type	Remark	Qualifier
Handle	MDC_ATTR_ID_HANDLE	HANDLE	Name binding attribute.	M
Max-Log-Entries	MDC_ATTR_LOG_ENTRIES_MAX	INT-U32	Maximum capacity of the Log object; GET service used to retrieve this attribute.	M
Current-Log-Entries	MDC_ATTR_LOG_ENTRIES_CURR	INT-U32	Current used capacity of the Log object; GET service used to retrieve this attribute.	M
Log-Change-Count	MDC_ATTR_LOG_CHANGE_COUNT	INT-U16	Incremented when log contents change.	O

NOTE—It is assumed that Log object entries are indexed from 0 to the Current-Log-Entries attribute value.

The Log class does not define any attribute groups.

6.5.9.2 Behavior

The Log class defines the methods in Table 42.

Table 42—Log instance methods

Action	Mode	Action ID	Action parameter	Action result
Clear-Log	Confirmed	MDC_ACT_CLEAR_LOG	ClearLogRangeInvoke	ClearLogRangeResult (optional)

The following ASN.1 data type definitions apply:

```
--
-- Range of log entries to be deleted; if the parameter is not appended to the Clear-Log method, the complete log
-- shall be cleared unconditionally
--
ClearLogRangeInvoke ::= SEQUENCE {
    clear-log-option      ClearLogOptions,
    log-change-count      INT-U16,
    from-log-entry-index  INT-U32,
    to-log-entry-index    INT-U32
}
-- 0 if unconditional clear
```

```

ClearLogRangeResult ::= SEQUENCE {
    clear-log-result      ClearLogResult,
    log-change-count      INT-U16,          -- current change count after clear
    from-log-entry-index  INT-U32,          -- do not care if not successful
    to-log-entry-index    INT-U32,          -- do not care if not successful
    current-log-entries   INT-U32          -- updated number of entries in the log
}

--
-- Options that control the clear command
--
ClearLogOptions ::= BITS-16 {
    log-clear-if-unchanged(1)  -- only perform this action if the log has not been changed; in other words,
                                -- the evlog-change-count in the request is still current
}

--
-- Result of the clear log function
--
ClearLogResult ::= INT-U16 {
    log-range-cleared(0),          -- successful operation
    log-changed-clear-error(1),    -- the change count was wrong (i.e., log has been
                                    -- modified)
    log-change-counter-not-supported(2) -- log does not support a change counter
}

```

6.5.9.3 Notifications

The Log class does not generate any special notifications.

6.5.10 EventLog class

Class: EventLog
Description: An EventLog object is a general Log object that stores system events in a free-text or in a binary representation.
Superclass: Log
Subclasses: --
Name Binding: Handle
Registered As: MDC_MOC_LOG_EVENT

6.5.10.1 Attributes

The EventLog class defines the attributes in Table 43.

Table 43—EventLog class attributes

Attribute name	Attribute ID	Attribute type	Remark	Qualifier
Type	MDC_ATTR_ID_TYPE	TYPE	Further specification of log entry format.	O
Event-Log-Entry-List	MDC_ATTR_EVENT_LOG_ENTRY_LIST	EventLogEntryList	Event entries; can be retrieved with GET service.	M
Event-Log-Info	MDC_ATTR_EVENT_LOG_INFO	EventLogInfo	Static and dynamic specifications.	O

The EventLog class does not define any attribute groups.

The following ASN.1 data type definitions apply:

```
--
-- Event-Log-Entry-List attribute
--
EventLogEntryList ::= SEQUENCE OF EventLogEntry

EventLogEntry ::= SEQUENCE {
    entry-number          INT-U32,          -- entry counter independent of the
                                           -- index number that is used for
                                           -- access
    abs-time              AbsoluteTime,     -- event time
    event-entry            OCTET STRING     -- free text or binary event
                                           -- information; structure defined by
                                           -- the Type attribute
}

--
-- Event-Log-Info attribute
-- Bits 0 to 15 are reserved for static information; bits 16 to 31 are dynamically updated to reflect log status
-- changes
-- If this attribute is not present, all bits are implicitly assumed 0
--
EventLogInfo ::= BITS-32 {
    ev-log-clear-range-sup(0), -- supports to clear specified ranges (not just the entire log)
    ev-log-get-act-sup(1),     -- supports retrieving individual entries using the Get-Event-Log method
                               -- (not just a simple GET service)
    ev-log-binary-entries(8),  -- log entries are binary, not free text
    ev-log-full(16),          -- log is full; cleared as soon as the log contains at least 1 free entry as a
                               -- result of a clear action
    ev-log-wrap-detect(17)     -- set when the log is full and the first old entry is overwritten; cleared as
                               -- soon as the log contains at least 1 free entry as a result of a clear action
}
```

6.5.10.2 Behavior

The EventLog class defines the methods in Table 44.

Table 44 —EventLog instance methods

Action	Mode	Action ID	Action parameter	Action result
Get-Event-Log-Entries	Confirmed	MDC_ACT_GET_EVENT_LOG_ENTRIES	GetEventLogEntryInvoke	GetEventLogEntryResult

The following ASN.1 data type definitions apply:

```
--
-- Range of log entries to be retrieved
--
GetEventLogEntryInvoke ::= SEQUENCE {
    from-log-entry-index  INT-U32,
    to-log-entry-index    INT-U32
}

--
-- Reply containing the requested entries; depending on agent restrictions, the reply may contain only a part of the
-- requested entries; this situation must be checked by the manager
--
```

```

GetEventLogEntryResult ::= SEQUENCE {
    log-change-count      INT-U16,                -- current log change counter (0 if
                                                    -- not supported)
    from-log-entry-index  INT-U32,
    to-log-entry-index    INT-U32,
    entry-list            EventLogEntryList
}

```

6.5.10.3 Notifications

The EventLog class does not generate any special notifications.

6.5.11 Battery class

Class: Battery

Description: For battery-powered devices, some battery information is contained in the MDS object in the form of attributes. If the battery subsystem is either capable of providing more information (i.e., smart battery) or manageable, then a special Battery object is provided.

Superclass: Top

Subclasses: --

Name Binding: Handle

Registered As: MDC_MOC_BATT

6.5.11.1 Attributes

The Battery class defines the attributes in Table 45.

Table 45—Battery class attributes

Attribute name	Attribute ID	Attribute type	Remark	Qualifier
Handle	MDC_ATTR_ID_HANDLE	HANDLE	Name binding attribute.	M
Battery-Status	MDC_ATTR_BATT_STAT	BatteryStatus		M
Production-Specification	MDC_ATTR_ID_PROD_SPECN	ProductionSpec	A smart battery system may have a serial number or version.	O
Capacity-Remaining	MDC_ATTR_CAPAC_BATT_REMAIN	BatMeasure	Remaining capacity at current load (e.g., in milliAmperehours).	O
Capacity-Full-Charge	MDC_ATTR_CAPAC_BATT_FULL	BatMeasure	Battery capacity after a full charge.	O
Capacity-Specified	MDC_ATTR_CAPAC_BATT_SPECN	BatMeasure	Specified capacity of new battery.	O
Remaining-Battery-Time	MDC_ATTR_TIME_BATT_REMAIN	BatMeasure		O
Voltage	MDC_ATTR_BATT_VOLTAGE	BatMeasure	Present battery voltage	O
Voltage-Specified	MDC_ATTR_BATT_VOLTAGE_SPECN	BatMeasure	Specified battery voltage.	O
Current	MDC_ATTR_BATT_CURR	BatMeasure	Present current delivered by/to battery; negative if battery is charge.	O
Battery-Temperature	MDC_ATTR_TEMP_BATT	BatMeasure		O
Charge-Cycles	MDC_ATTR_BATT_CHARGE_CYCLES	INT-U32	Number of charge/discharge cycles.	O

The Battery class defines in Table 46 the attribute groups or extensions to inherited attribute groups.

Table 46—Battery class attribute groups

Attribute group	Attribute group ID	Group elements
Battery Attribute Group	MDC_ATTR_GRP_BATT	from Battery: Handle, Battery-Status, Production-Specification, Capacity-Remaining, Capacity-Full-Charge, Capacity-Specified, Remaining-Battery-Time, Voltage, Voltage-Specified, Current, Battery-Temperature, Charge-Cycles

The following ASN.1 data type definitions apply:

```
--
-- Battery Status bit field
--
BatteryStatus ::= BITS-16 {
    batt-discharged(0),
    batt-full(1),                -- > 95% of capacity
    batt-discharging(2),
    batt-chargingFull(8),
    batt-chargingTrickle(9),
    batt-malfunction(12),
    batt-needs-conditioning(13)  -- battery needs conditioning
}

--
-- All measures about the battery are values with their dimensions
--
BatMeasure ::= SEQUENCE {
    value      FLOAT-Type,
    unit       OID-Type         -- from dimensions nomenclature partition
}
```

6.5.11.2 Behavior

The Battery class does not define any special methods.

6.5.11.3 Notifications

The Battery class does not generate any special notifications.

6.5.12 Clock class

Class: Clock

Description: The Clock class provides additional date/time capability and status information beyond the information provided by the time-related attributes. The Clock class does not imply any specific hardware or software support.

Superclass: Top

Subclasses: --

Name Binding: Handle

Registered As: MDC_MOC_CLOCK

6.5.12.1 Attributes

The Clock class defines the attributes in Table 47.

Table 47 —Clock class attributes

Attribute name	Attribute ID	Attribute type	Remark	Qualifier
Handle	MDC_ATTR_ID_HANDLE	HANDLE	Name binding attribute.	M
Time-Support	MDC_ATTR_TIME_SUPPORT	TimeSupport	Indicates the time services provided by the device.	M
Date-Time-Status	MDC_ATTR_DATE_TIME_STATUS	DateTimeStatus	General information about the functioning of time-support services. Mandatory if remote sync services are supported by the device [e.g., Simple Network Time Protocol (SNTP)]; optional otherwise.	C
Date-And-Time	MDC_ATTR_TIME_ABS	AbsoluteTime	Current date/time setting.	O
ISO-Date-And-Time	MDC_ATTR_TIME_ABS_ISO	AbsoluteTimeISO	Date and time string formatted in accordance with ISO 8601; provides for international coordinated universal time (UTC) coordination. Attribute is in wide use by computing systems; however, it is ASCIIbased and thus less efficient than absolute time.	O
Relative-Time	MDC_ATTR_TIME_REL	RelativeTime	Relative time (in 8 kHz ticks).	O
Hires-Relative-Time	MDC_ATTR_TIME_REL_HI_RES	HighResRelativeTime	High-resolution relative time (in 1 MHz ticks).	O
Ext-Time-Stamp-List	MDC_ATTR_TIME_STAMP_LIST_EXT	ExtTimeStampList	Extended timestamp (which may be used individually elsewhere in data structures).	O
Absolute-Relative-Sync	MDC_ATTR_TIME_ABS_REL_SYNC	AbsoluteRelativeTimeSync	Provides a means of correlating between absolute time and relative time values. ^a	O
Time-Zone	MDC_ATTR_TIME_ZONE	UTCTimeZone	Identifies the UTC local time zone offset [from Greenwich mean time (GMT)] and label.	O
Daylight-Savings-Transition	MDC_ATTR_TIME_DAYLIGHT_SAVINGS_TRANS	DaylightSavingsTransition	Provides the settings for the next daylight savings time transition.	O

Table continues

Table 47—Clock class attributes (continued)

Attribute name	Attribute ID	Attribute type	Remark	Qualifier
Cumulative-Leap-Seconds	MDC_ATTR_CUM_LEAP_SECONDS	INT-U32	Cumulative leap-seconds relative to January 1, 1900, 00:00:00.00. Format is +nn. For the entire year 2001, this value is +32. ^b	O
Next-Leap-Seconds	MDC_ATTR_NEXT_LEAP_SECOND	LeapSecondsTransition	Specifies the settings for when the next leap-seconds transition shall occur and the next value.	O

^aThis attribute is periodically updated internally (e.g., once per minute) and thus does not reflect the actual time when read (e.g., using a GET service). The error between relative and absolute time should be as small as possible given system limitations (e.g., an atomic operation should be used if possible). The attribute should be updated frequently enough to minimize the error between the reported mapping and should be updated at a minimum of every 6 days, namely when the relative time would roll over to 0.

^bWhen subtracted from SNTP seconds yields UTC seconds.

The Clock class defines in Table 48 the attribute groups or extensions to inherited attribute groups.

Table 48—Clock class attribute groups

Attribute group	Attribute group ID	Group elements
Clock Attribute Group	MDC_ATTR_GRP_CLOCK	from Clock: Handle, Time-Support, Date-Time-Status, Date-And-Time, ISO-Date-And-Time, Relative-Time, Hires-Relative-Time, Ext-Time-Stamp-List, Absolute-Relative-Sync, Time-Zone, Daylight-Savings-Transition, Cumulative-Leap-Seconds, Next-Leap-Seconds

The following ASN.1 data type definitions apply:

```
--
-- Time-Support attribute provides general information about time-related services that are provided by the device
-- Some of this information could be determined by examining the presence/absence of various attributes in a
-- containment tree; however, its presence here simplifies time management for device managers
--
-- NOTES
-- 1-- If remote date/time synchronization is supported (e.g., SNTP), then either the Date-And-Time or ISO-Date-
--    And-Time attribute must also be supported
-- 2-- If the device is also a server of time information (e.g., an SNTP server), this fact should be indicated in the
--    time protocol IDs
--
TimeSupport ::= SEQUENCE {
    time-capability          TimeCapability,          -- Flags indicating general time
                                                         -- support
    relative-resolution      INT-U32,                -- Time between actual ticks in
                                                         -- microseconds; set to
                                                         -- 0xFFFFFFFF if not defined or
                                                         -- specified
    time-protocols           TimeProtocolIdList       -- List of external time protocols
                                                         -- supported (e.g., SNTP)
}
```

```
TimeProtocolIdList ::= SEQUENCE OF TimeProtocolId
```

IEEE Std 11073-10201-2018
IEEE Standard for Part 10201: Domain Information Model

NOTE—The relative-resolution type provides a means of correlating the 8 kHz frequency reported by the relative time value to the device's time sources from which it is being derived. For example, if the device's timer updates at 100 Hz or 18.2 Hz [as is the case in older personal computers (PCs)], then the resolution and accuracy of the relative time would reflect this time source resolution and accuracy.

```
--
-- Time capability
--
TimeCapability ::= BITS-32 {
    time-capab-real-time-clock(0),           -- the device includes hardware support for time
                                              -- (including battery power)
    time-capab-ebww(1),                     -- time can be set locally/manually ("eyeball and
                                              -- wristwatch" or "EBWW")
    time-capab-leap-second-aware(2),        -- supports adjustment of time for leap-seconds (SNTP-
                                              -- related)
    time-capab-time-zone-aware(3),          -- supports time zone-related attributes
    time-capab-internal-only(4),            -- date/time is used only internally to the device; not
                                              -- displayed to operator
    time-capab-time-displayed(5),           -- date/time can be displayed continually on the device
                                              -- versus in a menu
    time-capab-patient-care(6),             -- date/time is used in critical patient care
                                              -- algorithms/protocols
    time-capab-rtsa-time-sync-annotations(7), -- timestamp annotations supported for real-time
                                              -- waveform data (RealTimeSampleArray objects)
    time-capab-rtsa-time-sync-high-precision(8), -- RealTimeSampleArray objects support attributes
                                              -- for high precision sample timestamps
    time-capab-set-time-action-sup(16),      -- Clock object supports the set time action
    time-capab-set-time-zone-action-sup(17), -- Clock object supports the set time zone action
    time-capab-set-leap-sec-action-sup(18),  -- Clock object supports the set leap-seconds action
    time-capab-set-time-iso-sup(19)         -- Clock object supports the set time ISO action
}

--
-- Time protocol ID indicates the time protocols that are supported/used by the device
--
-- OID-Types from the infrastructure nomenclature partition
--
TimeProtocolId ::= OID-Type

--
-- Timestamp ID (e.g., for SNTP timestamps)
--
-- OID-Types from the infrastructure nomenclature partition
--
TimeStampId ::= OID-Type

--
-- Extended timestamp (e.g., SNTP timestamp value)
--
ExtTimeStamp ::= SEQUENCE {
    time-stamp-id          TimeStampId,
    time-stamp             ANY DEFINED BY time-stamp-id
}

ExtTimeStampList ::= SEQUENCE OF ExtTimeStamp

--
-- Date-Time-Status attribute defines the current/active usage status for date and time in the device
--
DateTimeStatus ::= SEQUENCE {
    usage-status          DateTimeUsage, -- flags indicating dynamic time usage
    clock-last-set        AbsoluteTime,  -- time the absolute time was last set
    clock-accuracy        FLOAT-Type,    -- decimal number indicating the accuracy or
                                              -- maximum error of the absolute time relative to a
```

```

        active-sync-protocol      TimeProtocolId    -- primary reference clock source (in seconds)
                                                    -- protocol that is actively being used for time
                                                    -- synchronization
    }

```

NOTE 1—If a time synchronization protocol is used that changes the time and date at a high frequency, the clock-last-set type value should be updated at a lower periodicity (e.g., once every 10 min or once an hour), so that communications bandwidth is not consumed unnecessarily.

NOTE 2—In systems where time synchronization is not used (i.e., EBWW is source), the clock-accuracy type should be initialized to 2 or 3 min when the clock time is set and should be incremented periodically to reflect drift from an absolute external reference source. If NTP is used, clock-accuracy type initialization is equivalent to Root Dispersion + ½ Root Delay.

```

--
-- Date/time usage flags indicate dynamic usage status for date and time in the device; no bits set indicates
-- unknown/indeterminate status
--
DateTimeUsage ::= BITS-16 {
    dt-use-remote-sync(0),    -- date/time is synchronized to an external source
    dt-use-operator-set(1),   -- date/time set by operator (i.e., EBWW)
    dt-use-rtc-synced(2),     -- date/time in the RTC has been synchronized to a remote time source
    dt-use-critical-use(3),   -- date/time is actively being used in care delivery algorithms/protocols
    dt-use-displayed(4)       -- date/time is actively being displayed to the operator
}

--
-- ISO-Date-and-Time attribute is an ASCII string that can provide additional information beyond the basic
-- date/time setting (e.g., UTC offset or device-local time zone indication); this attribute can be set using the SET
-- service (as can the Date-And-Time attribute)
-- Note that if both AbsoluteTime and AbsoluteTimeISO types are concurrently supported, they shall reflect the
-- same time (relative to their accuracy and resolution limitations)
-- Although not mandatory, it is highly recommended that all optional fields be included in the string
-- To simplify processing, the following constraints shall apply:
-- (a) Only complete representations shall be used
-- (b) Only extended formats shall be used
-- (c) "Week date" and "ordinal "day of the year" representations shall not be used; only calendar dates
-- (d) Decimal fractions shall be used only for partial seconds (e.g., not fractional hours)
-- (e) Per ISO 8601:2000(E), the representation of decimal fractions shall be in accordance with Section 5.3.1.3
-- (f) If known, UTC shall be communicated as the offset between local and
-- GMT/UTC time. If the local time zone offset is unknown, i.e. NTP is used, then UTC timeshall be specified
-- by adding a time offset of +0000. +0000 shall be used to indicate GMT.
-- (g) Specification of time intervals and recurring periods is beyond the use of this data type and shall require a
-- definition of a new data type if used (e.g., ISOTimeInterval ::= OCTET STRING); for example: November 24,
-- 2001, 3:45:32.65 P.M. in San Diego, California, USA, shall be represented by the following string: 2001-11-
-- 24T15:45:32.65-08:00
--
-- ASCII text string that adheres to ISO 8601 format
--
AbsoluteTimeISO ::= OCTET STRING

--
-- SNTPTimestamp, a 64-bit timestamp value that is provided by an SNTP time synchronization service
--
SNTPTimestamp ::= SEQUENCE {
    seconds    INT-U32,    -- Seconds since January 1, 1900 00:00
    fraction    INT-U32    -- Binary fraction of a second
}

--
-- Absolute-Relative-Sync attribute provides a means for correlating relative timestamps to the device's date/time
-- setting
-- NOTE--This attribute needs to be updated only periodically to account for drift between the various time

```

IEEE Std 11073-10201-2018
IEEE Standard for Part 10201: Domain Information Model

```

-- sources (e.g., once a minute)
--
AbsoluteRelativeTimeSync ::= SEQUENCE {
    absolute-time-mark      AbsoluteTime,
                                -- use of this data type limits
                                -- resolution to 1/100 second
                                -- resolution limited by 125 µs tick
                                -- and resolution/accuracy settings
                                -- for relative time service
                                -- number of times the relative time
                                -- has "rolled over" from its
                                -- maximum value to 0
                                -- NOTE--The relative time will
                                -- roll over every 6.2 days
                                -- defaults to 0x00000000 if not
                                -- supported
                                -- list is empty if no extended
                                -- timestamps are supported

    relative-time-mark      RelativeTime,

    relative-rollovers      INT-U16,

    hires-time-mark         HighResRelativeTime,

    ext-time-marks          ExtTimeStampList
}

--
-- Time-Zone attribute supports time zone information for UTC
--
UTCTimeZone ::= SEQUENCE {
    time-zone-offset-hours  INT-I8,
                                -- device's local time zone (i.e., at
                                -- the point of care), relative to
                                -- UTC
                                -- format is +hh for time zones east
                                -- of GMT and -hh for locations
                                -- west of GMT
                                -- minutes offset from GMT (if
                                -- specified); format conventions
                                -- are the same as the conventions
                                -- for hours, only they are not
                                -- signed (shall always be a positive
                                -- value); default is NULL
                                -- device's local time zone label,
                                -- e.g., PST or PDT; see device's
                                -- Locale attribute for string
                                -- encoding

    time-zone-offset-minutes INT-U8,

    time-zone-label         OCTET STRING
}

--
-- Daylight-Savings-Transition attribute specifies the settings for the next transition to/from daylight savings time
--
DaylightSavingsTransition ::= SEQUENCE {
    transition-date          AbsoluteTime,
                                -- device's local date/time when the daylight savings
                                -- transition will occur
    next-offset              UTCTimeZone
                                -- next local time zone offset and label after transition
                                -- date
                                -- NOTE--May be same as previous value
}

--
-- Next-Leap-Seconds attribute specifies the settings for the next leap-seconds transition
--
LeapSecondsTransition ::= SEQUENCE {
    transition-date          Date,
                                -- device's local date when the transition will occur;
                                -- adjustment occurs at the end (i.e., 23:59:59Z) of the
                                -- specified date
    next-cum-leap-seconds    INT-U32
                                -- next cumulative leap-seconds value (see Cumulative-
                                -- Leap-Seconds in Clock class attributes table)
                                -- NOTE--May be same as previous value
}

```

6.5.12.2 Behavior

The Clock class defines the methods in Table 49.

Table 49—Clock instance methods

Action	Mode	Action ID	Action parameter	Action result
Set-Time	Confirmed	MDC_ACT_SET_TIME	SetTimeInvoke	—
Set-Time-Zone	Confirmed	MDC_ACT_SET_TIME_ZONE	SetTimeZoneInvoke	—
Set-Leap-Seconds	Confirmed	MDC_ACT_SET_LEAP_SECONDS	SetLeapSecondsInvoke	—
Set-Time-ISO	Confirmed	MDC_ACT_SET_TIME_ISO	AbsoluteTimeISO	—

When setting the time with either Set-Time or Set-Time-ISO methods, all supported absolute timestamp attributes (i.e., Date-and-Time, ISO-Date-and-Time and possibly Ext-Time-Stamp-List) shall be updated consistently.

The following ASN.1 data type definitions apply:

```
--
-- Date/time to be set
--
SetTimeInvoke ::= SEQUENCE {
    date-time    AbsoluteTime,
    accuracy     FLOAT-Type    -- accounts for manually set time (e.g., 2 min error); value is defined in
                                -- seconds
}

--
-- Time zone information to be set
--
SetTimeZoneInvoke ::= SEQUENCE {
    time-zone    UTCTimeZone,    -- current time zone to be used by
                                -- device
    next-time-zone    DaylightSavingsTransition -- information for the next
                                -- transition to/from daylight
                                -- savings time
}

--
-- Cumulative leap-seconds information to be set
--
SetLeapSecondsInvoke ::= SEQUENCE {
    leap-seconds-cum    INT-I32,    -- cumulative leap-seconds, which
                                -- when subtracted from S/NTP
                                -- seconds yields UTC seconds
    next-leap-seconds    LeapSecondsTransition -- date of transition from previous
                                -- to new cumulative leap-second
                                -- value + new value
}
```

6.5.12.3 Notifications

The Clock class defines the events in Table 50.

Table 50—Clock events

Event	Mode	Event ID	Event parameter	Event result
Clock-Date-Time-Status- Changed	Unconfirmed	MDC_NOTI_DATE_ TIME_CHANGED	ClockStatusUpdateInfo	—

The following ASN.1 data type definitions apply:

```
--
-- Clock status update information is sent, for example, when the relative time setting rolls over to 0 or when the
-- time is changed by the device operator
--
ClockStatusUpdateInfo ::= SEQUENCE {
    date-time-status      DateTimeStatus,      -- current clock/time usage status
    time-sync            AbsoluteRelativeTimeSync -- current time synchronization
    -- values
}
```

6.6 Control package

6.6.1 SCO class

Class: SCO

Description: The SCO is responsible for managing all remote control capabilities that are supported by a medical device. The SCO is the primary access point for invoking remote control functions. It contains all Operation objects and provides a means for transaction processing. All Operation object invoke commands shall be done through the SCO.

Superclass: VMO

Subclasses: --

Name Binding: Handle (VMO inherited)

Registered As: MDC_MOC_CNTRL SCO

6.6.1.1 Attributes

The SCO class defines the attributes in Table 51.

Table 51—SCO class attributes

Attribute name	Attribute ID	Attribute type	Remark	Qualifier
Sco-Capability	MDC_ATTR_SCO_ CAPAB	ScoCapability	Static option flag field.	M
Sco-Help-Text-String	MDC_ATTR_SCO_ HELP_TEXT_ STRING	OCTET STRING	Help text.	O
Vmo-Reference	MDC_ATTR_VMO_ REF	HANDLE	Reference to controlled item, if not the VMD.	O
Activity-Indicator	MDC_ATTR_ INDIC_ACTIV	ScoActivityIndicator	Can be set by remote system to give feedback that system is under remote control.	O
Lock-State	MDC_ATTR_STAT_ LOCK	AdministrativeState	If locked, no operation can be invoked.	M
Invoke-Cookie	MDC_ATTR_ID_ INVOK_COOKIE	INT-U32	Transaction ID assigned by invoke command.	M

The SCO class defines in Table 52 the attribute groups or extensions to inherited attribute groups.

Table 52—SCO class attribute groups

Attribute group	Attribute group ID	Group elements
VMO Static Context Group (extensible attribute group)	MDC_ATTR_GRP_VMO_STATIC	from VMO: Type, Handle from SCO: Sco-Capability, Sco-Help-Text-String
VMO Dynamic Context Group (extensible attribute group)	MDC_ATTR_GRP_VMO_DYN	from VMO: Label-String from SCO: Vmo-Reference, Activity-Indicator
SCO Transaction Group	MDC_ATTR_GRP_SCO_TRANSACTION	from SCO: Lock-State, Invoke-Cookie

The following ASN.1 data type definitions apply:

```
--
-- Activity-Indicator attribute can be set by a remote system to indicate that remote control is active
--
ScoActivityIndicator ::= INT-U16 {
    act-ind-off(0),
    act-ind-on(1),
    act-ind-blinking(2)
}

--
-- Sco-Capability bits
--
ScoCapability ::= BITS-16 {
    act-indicator(0),          -- supports activity indicator
    sco-locks(1),             -- at least one operation sets the SCO lock flag
    sco-ctxt-help(8)          -- SCO supports context-dependent dynamic help
}
```

6.6.1.2 Behavior

In addition to the SET service, which can be used to modify the Activity-Indicator attribute, the SCO defines the methods in Table 53.

Table 53—SCO instance methods

Action	Mode	Action ID	Action parameter	Action result
Operation-Invoke	Confirmed	MDC_ACT_SCO_OP_INVOKE	OperationInvoke	OperationInvokeResult
Get-Ctxt-Help	Confirmed	MDC_ACT_GET_CTXT_HELP	CtxtHelpRequest	CtxtHelpResult

The following ASN.1 data type definitions apply:

```
--
-- Operation-Invoke method has an additional security mechanism
--
OperationInvoke ::= SEQUENCE {
    checksum          INT-I16,          -- 16-bit twos complement
}
```

IEEE Std 11073-10201-2018
IEEE Standard for Part 10201: Domain Information Model

```

        invoke-cookie          INT-U32,          -- arbitrary ID mirrored back in resulting updates
        op-elem-list           OpInvokeList
    }

```

NOTE—If check-summing is not used, the checksum field shall be 0. If calculated checksum is 0, the checksum field shall be –1. Checksum calculation is the 16-bit twos-complement sum of 16-bit words in the message starting at the address after the checksum field.

OpInvokeList ::= SEQUENCE OF OpInvokeElement

```

OpInvokeElement ::= SEQUENCE {
    op-class-id          OID-Type,          -- from object-oriented nomenclature partition
    op-instance-no       InstNumber,
    op-mod-type          OpModType,
    attributes           AttributeList
}

```

```

OpModType ::= INT-U16 {
    op-replace(0),          -- normally replace value of virtual attribute
    op-setToDefault(3),     -- set to default value if this is supported
    op-invokeAction(10),    -- needed for singular action type of operations
    op-invokeActionWithArgs(15) -- action with arguments
}

```

```

--
-- Result confirms reception (and execution) of operations
-- Updated attributes are communicated via normal update method (e.g., scanner) to avoid inconsistencies
--

```

```

OperationInvokeResult ::= SEQUENCE {
    invoke-cookie          INT-U32,
    result                 OpInvResult
}

```

```

OpInvResult ::= INT-U16 {
    op-successful(0),
    op-failure(1)
}

```

```

--
-- The following types allow the retrieval of dynamic help information that is SCO or Operation object context-
-- dependent (i.e., state-dependent)
--

```

```

CtxtHelpRequest ::= SEQUENCE {
    type                  OID-Type,          -- either Operation object class ID or SCO class ID
    op-instance-no        InstNumber        -- operation instance number (0 if SCO is addressed)
}

```

```

CtxtHelpResult ::= SEQUENCE {
    type                  OID-Type,          -- either Operation object class ID or SCO class ID
    op-instance-no        InstNumber,
    hold-time             RelativeTime,     -- how long to display help; 0 if not applicable
    help                  CtxtHelp
}

```

```

CtxtHelp ::= CHOICE {
    text-string [1] OCTET STRING,
    oid         [8] OID-Type
}

```

6.6.1.3 Notifications

The SCO class defines the events in Table 54.

Table 54—SCO events

Event	Mode	Event ID	Event parameter	Event result
SCO-Operating-Request	Confirmed/Unconfirmed	MDC_NOTI_SCO_OP_REQ	ScoOperReqSpec	—
SCO-Operation-Invoke-Error	Confirmed/Unconfirmed	MDC_NOTI_SCO_OP_INVOK_ERR	ScoOperInvokeError	—

The following ASN.1 data type definitions apply:

```

--
-- An operating request may append additional information
--
ScoOperReqSpec ::= SEQUENCE {
    op-req-id PrivateOid, -- device-or manufacturer-specific
    op-req-info ANY DEFINED BY op-req-id
}

--
-- SCO-Operation-Invoke-Error notification
--
ScoOperInvokeError ::= SEQUENCE {
    invoke-cookie INT-U32,
    op-error OpErrorType,
    failed-operation-list InstNumberList
}

OpErrorType ::= INT-U16 {
    op-err-unspec(0),
    checksum-error(1),
    sco-lock-violation(2),
    unknown-operation(3),
    invalid-value(4),
    invalid-mod-type(5)
}

InstNumberList ::= SEQUENCE OF InstNumber

```

6.6.2 Operation class

Class: Operation

Description: The Operation class is the abstract base class for classes that represent remote controllable items.

Superclass: Top

Subclasses: ActivateOperation, LimitAlertOperation, SelectItemOperation, SetRangeOperation, SetStringOperation, SetValueOperation, ToggleFlagOperation

Name Binding: Instance-Number (not directly accessible by object management services; unique within a single SCO instance)

Registered As: MDC_MOC_CNTRL_OP

6.6.2.1 Attributes

The Operation class defines the attributes in Table 55.

Table 55—Operation class attributes

Attribute name	Attribute ID	Attribute type	Remark	Qualifier
Instance-Number	MDC_ATTR_ID_INSTNO	InstNumber	Unique within SCO for operation identification.	M
Operation-Spec	MDC_ATTR_OP_SPEC	OperSpec	Structure defining operation types and properties.	M
Operation-Text-Strings	MDC_ATTR_OP_TEXT_STRING	OperTextStrings	Static description of operation.	O
Operation-Text-Strings-Dyn	MDC_ATTR_OP_TEXT_STRING_DYN	OperTextStrings	Dynamic description of operation.	O
Vmo-Reference	MDC_ATTR_VMO_REF	HANDLE	Reference to an object.	O
Operational-State	MDC_ATTR_OP_STAT	OperationalState	Specifies whether operation is accessible.	O

The Operation class defines in Table 56 the attribute groups or extensions to inherited attribute groups.

Table 56—Operation class attribute groups

Attribute group	Attribute group ID	Group elements
Operation Static Context Group (extensible attribute group)	MDC_ATTR_GRP_OP_STATIC_CTXT	from Operation: Operation-Spec, Operation-Text-Strings
Operation Dynamic Context Group (extensible attribute group)	MDC_ATTR_GRP_OP_DYN_CTXT	from Operation: Vmo-Reference, Operational-State

The following ASN.1 data type definitions apply:

```
--
-- Operation-Spec attribute indicates what this operation really does
--
OperSpec ::= SEQUENCE {
    vattr-id    OID-Type,    -- ID of the virtual attribute that is changed by operation
    op-target   OID-Type,    -- from metric or object-oriented nomenclature partition
    options     OpOptions,   -- special options
    level       OpLevel,     -- range of importance
    grouping    OpGrouping   -- to describe relations between operations
}
```

NOTE—The vattr-id code comes from the virtual attribute nomenclature partition. Entries (i.e., codes) in this partition are even. The last bit of the code is used to define from which nomenclature partition the op-target code comes. If the last bit is 0, the op-target code comes from the metric nomenclature partition. If the last bit is 1 (1 is added to the base code in the virtual attribute nomenclature), the op-target code comes from the object-oriented nomenclature partition.

```
--
-- Operation texts
--
OperTextStrings ::= SEQUENCE {
    label       OCTET STRING,    -- the label string indicates the meaning of the
                                -- operation
    help        OCTET STRING,    -- the help string may contain additional help for the
                                -- user
    confirm     OCTET STRING     -- the confirm string is shown by manager to a user to
                                -- reconfirm the operation (e.g., "do you really want to
                                -- shut down?")
}
```

```

--
-- Operation options
--
OpOptions ::= BITS-16 {
    needs-confirmation(0),
    supports-default(1),           -- a default value is supported for the virtual attributes
    sets-sco-lock(2),             -- needs transaction processing to avoid side effects
    is-setting(3),                 -- value preserved over system power fail
    op-dependency(6),             -- operation has dependencies to others (always set if sets-sco-lock bit is set)
    op-auto-repeat(7),            -- supports auto repeat
    op-ctxt-help(8)               -- provides context-dependent help via SCO action
}

--
-- Level
--
OpLevel ::= BITS-16 {
    op-level-basic(0),             -- a normal operation
    op-level-advanced(1),         -- an advanced operation
    op-level-professional(2),
    op-item-normal(8),             -- operation modifies a normal user item
    op-item-config(9),            -- operation modifies a configuration item
    op-item-service(10)           -- operation modifies a service item (not used by regular operator)
}

--
-- Field for grouping operations (i.e., defines logical relations); can be used to organize operations in a useful
-- sequence on an operator interface (i.e., display)
--
OpGrouping ::= SEQUENCE {
    group      INT-U8,
    priority   INT-U8
}

```

6.6.2.2 Behavior

The Operation class does not define any special methods.

6.6.2.3 Notifications

The Operation class does not generate any special notifications.

6.6.3 SelectItemOperation class

Class:	SelectItemOperation
Description:	The SelectItemOperation class allows selection of one item out of a given list. The list can have different types.
Superclass:	Operation
Subclasses:	--
Name Binding:	Instance-Number (not directly accessible by object management services)
Registered As:	MDC_MOC_CNTRL_OP_SEL_IT

6.6.3.1 Attributes

The SelectItemOperation class defines the attributes in Table 57.

Table 57—SelectItemOperation class attributes

Attribute name	Attribute ID	Attribute type	Remark	Qualifier
Selected-Item-Index	MDC_ATTR_INDEX_SEL	INT-U16	Index of current selection.	M
Nom-Partition	MDC_ATTR_ID_NOM_PARTITION	NomPartition	If entries in list are OIDs, specifies the nomenclature partition that is used.	C
Select-List	MDC_ATTR_LIST_SEL	SelectList	List of possible choices.	M

The SelectItemOperation class defines in Table 58 the attribute groups or extensions to inherited attribute groups.

Table 58—SelectItemOperation class attribute groups

Attribute group	Attribute group ID	Group elements
Operation Static Context Group (extensible attribute group)	MDC_ATTR_GRP_OP_STATIC_CTXT	from Operation: Operation-Spec, Operation-Text-Strings from SelectItemOperation: Nom-Partition
Operation Dynamic Context Group (extensible attribute group)	MDC_ATTR_GRP_OP_DYN_CTXT	from Operation: Vmo-Reference, Operational-State from SelectItemOperation: Selected-Item-Index, Select-List

The following ASN.1 data type definitions apply:

```
--
-- Select-List attribute defines valid selections
--
SelectList ::= CHOICE {
    oid-list      [1] OID-TypeList,
    value-list    [3] FLOAT-TypeList,
    value-u-list  [4] SelectUValueEntryList,
    string-list   [5] OCTET-STRING-List
}

OID-TypeList ::= SEQUENCE OF OID-Type

FLOAT-TypeList ::= SEQUENCE OF FLOAT-Type

SelectUValueEntryList ::= SEQUENCE OF SelectUValueEntry

--
-- Value with a unit/dimension code
--
SelectUValueEntry ::= SEQUENCE {
    value        FLOAT-Type,
    m-units      OID-Type      -- from dimensions nomenclature partition
}

OCTET-STRING-List ::= SEQUENCE OF OCTET STRING
```

6.6.3.2 Behavior

The SelectItemOperation class does not define any special methods.

6.6.3.3 Notifications

The SelectItemOperation class does not generate any special notifications.

6.6.4 SetValueOperation class

Class: SetValueOperation

Description: The SetValueOperation class allows the system to adjust a value within a given range with a given resolution.

Superclass: Operation

Subclasses: --

Name Binding: Instance-Number (not directly accessible by object management services)

Registered As: MDC_MOC_CNTRL_OP_SEL_VAL

6.6.4.1 Attributes

The SetValueOperation class defines the attributes in Table 59.

Table 59—SetValueOperation class attributes

Attribute name	Attribute ID	Attribute type	Remark	Qualifier
Current-Value	MDC_ATTR_VAL_CURR	FLOAT-Type	Current value.	M
Set-Value-Range	MDC_ATTR_VAL_RANGE	OpSetValueRange	Range of legal values.	M
Step-Width	MDC_ATTR_VAL_STEP_WIDTH	OpValStepWidth	Allowed step width.	O
Unit-Code	MDC_ATTR_UNIT_CODE	OID-Type	From dimensions nomenclature partition.	O

The SetValueOperation class defines in Table 60 the attribute groups or extensions to inherited attribute groups.

Table 60—SetValueOperation class attribute groups

Attribute group	Attribute group ID	Group elements
Operation Static Context Group (extensible attribute group)	MDC_ATTR_GRP_OP_STATIC_CTXT	from Operation: Operation-Spec, Operation-Text-Strings
Operation Dynamic Context Group (extensible attribute group)	MDC_ATTR_GRP_OP_DYN_CTXT	from Operation: Vmo-Reference, Operational-State from SetValueOperation: Current-Value, Set-Value-Range, Step-Width, Unit-Code

The following ASN.1 data type definitions apply:

```
--
-- Set-Value-Range attribute defines range and minimum resolution
--
```

```
OpSetValueRange ::= SEQUENCE {
    minimum    FLOAT-Type,
    maximum    FLOAT-Type,
    resolution  FLOAT-Type
}
```

```
--
-- Step-Width attribute is an ordered (in ascending order) array of ranges and corresponding minimum step
```

```
-- widths; the lower edge is defined in the minimum value of the range specification
--
OpValStepWidth ::= SEQUENCE OF StepWidthEntry

StepWidthEntry ::= SEQUENCE {
    upper-edge FLOAT-Type,
    step-width  FLOAT-Type
}
```

6.6.4.2 Behavior

The SetValueOperation class does not define any special methods.

6.6.4.3 Notifications

The SetValueOperation class does not generate any special notifications.

6.6.5 SetStringOperation class

Class: SetStringOperation
Description: The SetStringOperation class is used to set the contents of a string type virtual attribute.
Superclass: Operation
Subclasses: --
Name Binding: Instance-Number (not directly accessible by object management services)
Registered As: MDC_MOC_CNTRL_OP_SET_STRING

6.6.5.1 Attributes

The SetStringOperation class defines the attributes in Table 61.

Table 61—SetStringOperation class attributes

Attribute name	Attribute ID	Attribute type	Remark	Qualifier
Current-String	MDC_ATTR_STRING_CURR	OCTET STRING	Current value of the string type virtual attribute.	C ^a
Set-String-Spec	MDC_ATTR_SET_STRING_SPEC	SetStringSpec	Properties of the string type virtual attribute.	M

^aThe Current-String attribute is out of the scope of this standard if the setstr-hidden-val flag is set in the specification attribute; it is mandatory otherwise.

The SetStringOperation class defines in Table 62 the attribute groups or extensions to inherited attribute groups.

Table 62—SetStringOperation class attribute groups

Attribute group	Attribute group ID	Group elements
Operation Static Context Group (extensible attribute group)	MDC_ATTR_GRP_OP_STATIC_CTXT	from Operation: Operation-Spec, Operation-Text-Strings
Operation Dynamic Context Group (extensible attribute group)	MDC_ATTR_GRP_OP_DYN_CTXT	from Operation: Vmo-Reference, Operational-State from SetStringOperation: Current-String, Set-String-Spec

The following ASN.1 data type definitions apply:

```
--
-- Set-String-Spec attribute
--
SetStringSpec ::= SEQUENCE {
    max-str-len INT-U16,      -- maximum supported string length
    char-size   INT-U16,      -- character size in bits, e.g. 7, 8 or 16
    set-str-opt  SetStrOpt     -- special option bits
}

--
-- Options for the string
--
SetStrOpt ::= BITS-16 {
    setstr-null-terminated(0), -- string is terminated with NULL character
    setstr-displayable(1),     -- string is displayable
    setstr-var-length(2),      -- string has variable length (up to maximum)
    setstr-hidden-val(3)       -- actual contents is hidden, e.g., for password entry
}
```

6.6.5.2 Behavior

The SetStringOperation class does not define any special methods.

6.6.5.3 Notifications

The SetStringOperation class does not generate any special notifications.

6.6.6 ToggleFlagOperation class

Class: ToggleFlagOperation
Description: The ToggleFlagOperation class allows a switch to be toggled (with two states, e.g., on/off).
Superclass: Operation
Subclasses: --
Name Binding: Instance-Number (not directly accessible by object management services)
Registered As: MDC_MOC_CNTRL_OP_TOG

6.6.6.1 Attributes

The ToggleFlagOperation class defines the attributes in Table 63.

Table 63—ToggleFlagOperation class attributes

Attribute name	Attribute ID	Attribute type	Remark	Qualifier
Toggle-State	MDC_ATTR_STAT_OP_TOG	ToggleState	Current state of toggle.	M
Toggle-Label-Strings	MDC_ATTR_TOG_LABELS_STRING	ToggleLabelStrings		M

The ToggleFlagOperation class defines in Table 64 the attribute groups or extensions to inherited attribute groups.

Table 64—ToggleFlagOperation class attribute groups

Attribute group	Attribute group ID	Group elements
Operation Static Context Group (extensible attribute group)	MDC_ATTR_GRP_OP_STATIC_CTXT	from Operation: Operation-Spec, Operation-Text-Strings
Operation Dynamic Context Group (extensible attribute group)	MDC_ATTR_GRP_OP_DYN_CTXT	from Operation: Vmo-Reference, Operational-State from ToggleFlagOperation: Toggle-State, Toggle-Label-Strings

The following ASN.1 data type definitions apply:

```
--
-- Toggle-State attribute
--
ToggleState ::= INT-U16 {
    tog-state0(0),
    tog-state1(1)
}

--
-- Each state has a label
--
ToggleLabelStrings ::= SEQUENCE {
    lbl-state0 OCTET STRING,
    lbl-state1 OCTET STRING
}
```

6.6.6.2 Behavior

The ToggleFlagOperation class does not define any special methods.

6.6.6.3 Notifications

The ToggleFlagOperation class does not generate any special notifications.

6.6.7 ActivateOperation class

Class: ActivateOperation
Description: The ActivateOperation class allows a defined activity to be started (e.g., a zero pressure).
Superclass: Operation
Subclasses: --
Name Binding: Instance-Number (not directly accessible by object management services)
Registered As: MDC_MOC_CNTRL_OP_ACTIV

6.6.7.1 Attributes

The ActivateOperation class does not define any additional attributes.

The ActivateOperation class defines in Table 65 the attribute groups or extensions to inherited attribute groups.

Table 65—ActivateOperation class attribute groups

Attribute group	Attribute group ID	Group elements
Operation Static Context Group (extensible attribute group)	MDC_ATTR_GRP_OP_STATIC_CTXT	from Operation: Operation-Spec, Operation-Text-Strings
Operation Dynamic Context Group (extensible attribute group)	MDC_ATTR_GRP_OP_DYN_CTXT	from Operation: Vmo-Reference, Operational-State

6.6.7.2 Behavior

The ActivateOperation class does not define any special methods.

6.6.7.3 Notifications

The ActivateOperation class does not generate any special notifications.

6.6.8 LimitAlertOperation class

Class: LimitAlertOperation
Description: The LimitAlertOperation class allows the limits of a limit alarm detector to be adjusted and the limit alarm to be switched on or off.
Superclass: Operation
Subclasses: --
Name Binding: Instance-Number (not directly accessible by object management services)
Registered As: MDC_MOC_CNTRL_OP_LIM

6.6.8.1 Attributes

The LimitAlertOperation class defines the attributes in Table 66.

Table 66—LimitAlertOperation class attributes

Attribute name	Attribute ID	Attribute type	Remark	Qualifier
Alert-Op-Capability	MDC_ATTR_AL_OP_CAPAB	AlOpCapab	Indicates what can be switched on or off.	M
Alert-Op-State	MDC_ATTR_AL_OP_STAT	CurLimAlStat	Current on/off state; can be set by Operation-Invoke method.	M
Current-Limits	MDC_ATTR_LIMIT_CURR	CurLimAlVal	Current alarm limits; can be set by Operation-Invoke method.	M
Alert-Op-Text-String	MDC_ATTR_AL_OP_TEXT_STRING	AlertOpTextString	Individual text for upper and lower limit.	O
Set-Value-Range	MDC_ATTR_VAL_RANGE	OpSetValueRange	Allowed range for limits.	M
Unit-Code	MDC_ATTR_UNIT_CODE	OID-Type	Dimension of values.	M
Metric-Id	MDC_ATTR_ID_PHYSIO	OID-Type	Measurement (i.e., Numeric object) to which the limit applies, from metric nomenclature partition.	M

The LimitAlertOperation class defines in Table 67 the attribute groups or extensions to inherited attribute groups.

Table 67—LimitAlertOperation class attribute groups

Attribute group	Attribute group ID	Group elements
Operation Static Context Group (extensible attribute group)	MDC_ATTR_GRP_OP_STATIC_CTXT	from Operation: Operation-Spec, Operation-Text-Strings from LimitAlertOperation: Alert-Op-Capability, Alert-Op-Text-String
Operation Dynamic Context Group (extensible attribute group)	MDC_ATTR_GRP_OP_DYN_CTXT	from Operation: Vmo-Reference, Operational-State from LimitAlertOperation: Alert-Op-State, Current-Limits, Set-Value-Range, Unit-Code, Metric-Id

The following ASN.1 data type definitions apply:

```
--
-- Alert operation static flags indicate which on/off flags are supported
--
ALOpCapab ::= BITS-16 {
    low-limit-sup(1),          -- supports low limit
    high-limit-sup(2),         -- supports high limit
    auto-limit-sup(5),         -- supports automatic limits
    low-lim-on-off-sup(8),     -- supports to switch on/off low limit
    high-lim-on-off-sup(9),    -- supports to switch on/off high limit
    lim-on-off-sup(10)         -- supports to switch on/off the complete alarm
}

--
-- Alert-Op-State attribute defines the current limit alert state
-- NOTE--The bits refer to the limit alarm only, not to the global alert state of the metric
--
CurLimAlStat ::= BITS-16 {
    lim-alert-off(0),          -- if this bit is set, all alerts (both high and low) are off
    lim-low-off(1),           -- low-limit violation detection is off
    lim-high-off(2)           -- high-limit violation detection is off
}

--
-- Current-Limits attribute
--
CurLimAlVal ::= SEQUENCE {
    lower    FLOAT-Type,
    upper    FLOAT-Type
}

--
-- Alert-Op-Text-String attribute assigns individual labels to upper and lower alarm limit
--
AlertOpTextString ::= SEQUENCE {
    lower-text OCTET STRING,
    upper-text OCTET STRING
}
```

6.6.8.2 Behavior

The LimitAlertOperation class does not define any special methods.

6.6.8.3 Notifications

The LimitAlertOperation class does not generate any special notifications.

6.6.9 SetRangeOperation class

Class: SetRangeOperation

Description: The SetRangeOperation class allows the system to adjust low and high values (i.e., a value range) within defined boundaries.

Superclass: Operation

Subclasses: --

Name Binding: Instance-Number (not directly accessible by object management services)

Registered As: MDC_MOC_CNTRL_OP_SET_RANGE

6.6.9.1 Attributes

The SetRangeOperation class defines the attributes in Table 68.

Table 68—SetRangeOperation class attributes

Attribute name	Attribute ID	Attribute type	Remark	Qualifier
Current-Range	MDC_ATTR_RANGE_CURR	CurrentRange	Current value.	M
Range-Op-Text	MDC_ATTR_RANGE_OP_TEXT_STRING	RangeOpText	Static attribute to define individual texts for upper and lower boundaries.	O
Set-Value-Range	MDC_ATTR_VAL_RANGE	OpSetValueRange	Range of legal values.	M
Step-Width	MDC_ATTR_VAL_STEP_WIDTH	OpValStepWidth	Allowed step width.	O
Unit-Code	MDC_ATTR_UNIT_CODE	OID-Type	From dimensions nomenclature partition.	O

The SetRangeOperation class defines in Table 69 the attribute groups or extensions to inherited attribute groups.

Table 69—SetRangeOperation class attribute groups

Attribute group	Attribute group ID	Group elements
Operation Static Context Group (extensible attribute group)	MDC_ATTR_GRP_OP_STATIC_CTXT	from Operation: Operation-Spec, Operation-Text-Strings from SetRangeOperation: Range-Op-Text
Operation Dynamic Context Group (extensible attribute group)	MDC_ATTR_GRP_OP_DYN_CTXT	from Operation: Vmo-Reference, Operational-State from SetRangeOperation: Current-Range, Set-Value-Range, Step-Width, Unit-Code

The following ASN.1 data type definitions apply:

```
--
-- Current-Range attribute defines the current upper and lower range values
--
```

```

CurrentRange ::= SEQUENCE {
    lower      FLOAT-Type,
    upper      FLOAT-Type
}

--
-- Range-Op-Text attribute assigns labels to the upper and lower boundaries
--
RangeOpText ::= SEQUENCE {
    low-text   OCTET STRING,          -- printable label text for low value
    high-text  OCTET STRING          -- printable label text for high value
}

```

6.6.9.2 Behavior

The SetRangeOperation class does not define any special methods.

6.6.9.3 Notifications

The SetRangeOperation class does not generate any special notifications.

6.7 ExtendedServices package

6.7.1 Scanner class

Class: Scanner

Description: A Scanner object is an observer and 'summarizer' of attribute values. It observes attributes of managed medical objects and generates summaries in the form of notification event reports. The Scanner object class is an abstract class, it cannot be instantiated.

Superclass: Top

Subclasses: CfgScanner, UcfgScanner

Name Binding: Handle

Registered As: MDC_MOC_SCAN

6.7.1.1 Attributes

The Scanner class defines the attributes in Table 70.

Table 70—Scanner class attributes

Attribute name	Attribute ID	Attribute type	Remark	Qualifier
Handle	MDC_ATTR_ID_HANDLE	HANDLE	Scanners are identified by handles.	M
Instance-Number	MDC_ATTR_ID_INSTNO	InstNumber	Shall be used when dynamic creation of scanner instances is allowed.	C
Operational-State	MDC_ATTR_OP_STAT	OperationalState	Defines if scanner is active; can be set.	M

The Scanner class defines in Table 71 the attribute groups or extensions to inherited attribute groups.

Table 71 —Scanner class attribute groups

Attribute group	Attribute group ID	Group elements
Scanner Attribute Group (extensible attribute group)	MDC_ATTR_GRP_SCAN	from Scanner: Handle, Instance-Number, Operational- State

6.7.1.2 Behavior

The Scanner class does not define any special methods.

Scanner subclasses use the following ASN.1 data type definitions:

```
--
-- List of objects for which scanned attributes are refreshed
-- If list is empty, all objects in the scan list are refreshed
-- If scanned-attribute is 0 (NOS), all attributes of that object that are scanned are refreshed
-- If the object-glb-handle is 0 (in all components), the specified attribute ID is refreshed for all objects in the scan
-- list
--
RefreshObjList ::= SEQUENCE OF RefreshObjEntry

RefreshObjEntry ::= SEQUENCE {
    object-glb-handle      GLB-HANDLE,
    scanned-attribute      OID-Type      -- attribute ID from object-oriented nomenclature
                                   -- partition
}
```

6.7.1.3 Notifications

Events are defined in Scanner subclasses.

Most Scanner subclasses share a common event report data structure that is defined as follows:

```
--
-- A scanner may scan objects from multiple device contexts. For efficiency, scanned data that belongs to a single
-- device context are grouped together
--
ScanReportInfo ::= SEQUENCE {
    scan-report-no      INT-U16,      -- counter for detection of missing
                                   -- events
    glb-scan-info      SingleCtxtScanList
}

SingleCtxtScanList ::= SEQUENCE OF SingleCtxtScan

SingleCtxtScan ::= SEQUENCE {
    context-id      MdsContext,
    scan-info      ObservationScanList
}

ObservationScanList ::= SEQUENCE OF ObservationScan

ObservationScan ::= SEQUENCE {
    obj-handle      HANDLE,
    attributes      AttributeList
}
```

6.7.2 CfgScanner class

Class: CfgScanner

Description: The CfgScanner class defines a special attribute (i.e., the Scan-List attribute) that is used to configure which attributes of an object are scanned. A CfgScanner object has the following properties:

- It scans VMO-derived objects (mostly Metric, Channel, and VMD objects).
- It contains a list of scanned objects/attributes that can be modified. The CfgScanner object is an abstract class; it cannot be instantiated.

Superclass: Scanner

Subclasses: EpiCfgScanner, PeriCfgScanner

Name Binding: Handle

Registered As: MDC_MOC_SCAN_CFG

6.7.2.1 Attributes

The CfgScanner class defines the attributes in Table 72.

Table 72—CfgScanner class attributes

Attribute name	Attribute ID	Attribute type	Remark	Qualifier
Scan-List	MDC_ATTR_SCAN_LIST	ScanList	List of scanned objects and attributes; can be set.	M
Confirm-Mode	MDC_ATTR_CONFIRM_MODE	ConfirmMode	Determines whether confirmed event reports are used.	M
Confirm-Timeout	MDC_ATTR_CONFIRM_TIMEOUT	RelativeTime	Determines when a confirmed event report is resent in case of a missing response.	C
Transmit-Window	MDC_ATTR_TX_WIND	INT-U16	Maximum number of not-yet-acknowledged event reports at one time.	C
Scan-Config-Limit	MDC_ATTR_SCAN_CFG_LIMIT	ScanConfigLimit	Even a configurable scanner may restrict the way it can be configured.	O

The CfgScanner class defines in Table 73 the attribute groups or extensions to inherited attribute groups.

Table 73—CfgScanner class attribute groups

Attribute group	Attribute group ID	Group elements
Scanner Attribute Group (extensible attribute group)	MDC_ATTR_GRP_SCAN	from Scanner: Handle, Instance-Number, Operational-State from CfgScanner: Scan-List, Confirm-Mode, Confirm-Timeout, Transmit-Window, Scan-Config-Limit

The following ASN.1 data type definitions apply:

```
--
-- Scan-List attribute determines which attributes of an object are scanned
-- NOTES
-- 1--If the scan list is empty, an episodic scanner has to send empty event reports
-- 2--The scan list will typically contain attribute group IDs for specific objects
--
```

ScanList ::= SEQUENCE OF ScanEntry

ScanEntry ::= SEQUENCE {
 object-glb-handle GLB-HANDLE, -- works for all objects with name binding handle
 scanned-attribute OID-Type -- could also be attribute group ID
 }

--
 -- Confirm-Mode attribute defines if confirmed event reports or unconfirmed event reports are used
 --

ConfirmMode ::= INT-U16 {
 unconfirmed(0),
 confirmed(1)
 }

--
 -- Even a configurable scanner may restrict the way it can be configured
 -- If Scan-Config-Limit attribute is absent, the scanner is fully configurable
 --

ScanConfigLimit ::= BITS-16 {
 no-scan-delete(0), -- scanner cannot be deleted
 no-scan-list-mod(1), -- scan list cannot be dynamically modified
 auto-init-scan-list(3), -- scan list is automatically initialized after scanner create
 auto-updt-scan-list(4) -- scan list is automatically updated in case of configuration change
 }

6.7.2.2 Behavior

The CfgScanner class does not define any special methods.

6.7.2.3 Notifications

The CfgScanner class does not generate any special notifications.

6.7.3 EpiCfgScanner class

Class: EpiCfgScanner
Description: An EpiCfgScanner object is responsible for scanning attributes or attribute groups of objects and for reporting these attributes in episodic, unbuffered (i.e., on change only) event reports.
Superclass: CfgScanner
Subclasses: --
Name Binding: Handle
Registered As: MDC_MOC_SCAN_CFG_EPI

6.7.3.1 Attributes

The EpiCfgScanner class does not define attributes other than the attributes inherited from the CfgScanner class.

The EpiCfgScanner class uses the Scanner Attribute Group that is inherited from the CfgScanner class.

6.7.3.2 Behavior

The EpiCfgScanner class defines the methods in Table 74.

Table 74—EpiCfgScanner instance methods

Action	Mode	Action ID	Action parameter	Action result
Refresh-Episodic-Data	Confirmed	MDC_ACT_REFR_EPI_DATA	RefreshObjList	—

The Refresh-Episodic-Data method triggers a refresh of all scanned attributes.

6.7.3.3 Notifications

The EpiCfgScanner class defines the events in Table 75.

Table 75—EpiCfgScanner events

Event	Mode	Event ID	Event parameter	Event result
Unbuf-Scan-Report	Confirmed/Unconfirmed	MDC_NOTI_UNBUF_SCAN_RPT	ScanReportInfo	—

NOTE 1—If the EpiCfgScanner scans attribute groups of an object and one or more of the attribute values in the group change, then the scanner reports all values of attributes in the group, even those that did not change their value. This is important so that attributes that are dynamically deleted from an object instance can be detected without a special notification.

NOTE 2—If no attribute of an object changes its value, then no data of this object are included in the scan report (unless an explicit refresh phase was triggered).

NOTE 3—Because an episodic scanner does not buffer any changes and does not have an update period specification attribute (which is not needed because updates are sent on value changes), attribute change notifications should be sent at a rate that ensures no data loss. For example, in order to ensure that no metric value changes more than once between scans of dynamic attribute groups, the episodic scanner should check for changes at a rate at least as fast as the the shortest MetricSpec::update-period of the metric instances in the scanner's scan list.

NOTE 4—After instantiation of the scanner, all attribute values are considered changed so that the first scan report contains all attribute values of all objects.

6.7.4 PeriCfgScanner class

Class: PeriCfgScanner
Description: A PeriCfgScanner object is responsible for scanning attributes and attribute groups of objects and for reporting these attributes in periodic event reports.
Superclass: CfgScanner
Subclasses: FastPeriCfgScanner
Name Binding: Handle
Registered As: MDC_MOC_SCAN_CFG_PERI

6.7.4.1 Attributes

The PeriCfgScanner class defines the attributes in Table 76.

Table 76—PeriCfgrScanner class attributes

Attribute name	Attribute ID	Attribute type	Remark	Qualifier
Scan-Extensibility	MDC_ATTR_SCAN_EXTEND	ScanExtend	Default is extensive.	M
Reporting-Interval	MDC_ATTR_SCAN_REP_PD	RelativeTime	Period of reports.	M

The PeriCfgrScanner class defines in Table 77 the attribute groups or extensions to inherited attribute groups.

Table 77—PeriCfgrScanner class attribute groups

Attribute group	Attribute group ID	Group elements
Scanner Attribute Group (extensible attribute group)	MDC_ATTR_GRP_SCAN	from Scanner: Handle, Instance-Number, Operational-State from CfgScanner: Scan-List, Confirm-Mode, Confirm-Timeout, Transmit-Window, Scan-Config-Limit from PeriCfgrScanner: Scan-Extensibility, Reporting-Interval

The following ASN.1 data type definitions apply:

```
--
-- Scan-Extensibility attribute defines if the scanner includes all observations in the ScanReportInfo event
-- parameter or if it includes just the latest observation (i.e., superpositive)
--
ScanExtend ::= INT-U16 {
    extensive(0),           -- all attribute changes in the scan period are included
    superpositive(1),       -- only the last attribute change is included
    superpositive-avg(2)    -- superpositive, but all values in period are averaged
}
```

6.7.4.2 Behavior

The PeriCfgrScanner class does not define any special methods.

6.7.4.3 Notifications

The PeriCfgrScanner class defines the events in Table 78.

Table 78—PeriCfgrScanner events

Event	Mode	Event ID	Event parameter	Event result
Buf-Scan-Report	Confirmed/Unconfirmed	MDC_NOTI_BUF_SCAN_RPT	ScanReportInfo	—

6.7.5 FastPeriCfgScanner class

Class: FastPeriCfgScanner

Description: The FastPeriCfgScanner class is a specialized class for scanning the observed value attribute of a RealTimeSampleArray object. This special Scanner class is further optimized for low-latency reporting and efficient communication bandwidth utilization, which is required to access real-time waveform data.

Superclass: PeriCfgScanner

Subclasses: --

Name Binding: Handle

Registered As: MDC_MOC_SCAN_CFG_PERI_FAST

6.7.5.1 Attributes

The FastPeriCfgScanner class does not define any additional attributes.

6.7.5.2 Behavior

The FastPeriCfgScanner class does not define any special methods.

6.7.5.3 Notifications

The FastPeriCfgScanner class defines the events in Table 79.

Table 79 —FastPeriCfgScanner events

Event	Mode	Event ID	Event parameter	Event result
Fast-Buf-Scan-Report	Confirmed/Unconfirmed	MDC_NOT_FAST_BUF_SCAN_RPT	FastScanReportInfo	—

The following ASN.1 data type definitions apply:

```
--
-- Event report contains the observed values of scanned RealTimeSampleArray objects
--
FastScanReportInfo ::= SEQUENCE {
    scan-report-no      INT-U16,
    glb-scan-info       SingleCtxtFastScanList
}

SingleCtxtFastScanList ::= SEQUENCE OF SingleCtxtFastScan

SingleCtxtFastScan ::= SEQUENCE {
    context-id  MdsContext,
    scan-info   RtsaObservationScanList
}

RtsaObservationScanList ::= SEQUENCE OF RtsaObservationScan

RtsaObservationScan ::= SEQUENCE {
    handle      HANDLE,
    observation  SaObsValue
}
```

A FastPeriCfgScanner object is a dedicated scanner for RealTimeSampleArray objects. For performance reasons, the sample arrays do not carry a separate timestamp in each observation scan structure. For time synchronization and timestamping of specific samples, two different methods can be supported:

- The default method assumes that the timestamp provided by the EVENT REPORT service is the time of the first sample value in each RtsaObservationScan::SaObsValue data structure
- For higher precision time synchronization, RealTimeSampleArray objects may support the Average-Reporting-Delay and Sample-Time-Sync attributes. The support for this method is signaled by the presence of the Time-Support::time-capability-time-capab-rtsa-time-sync-highprecision flag in the Clock object. If this method is used, the individual sample times are determined by these attributes and they are independent of the timestamp provided by the EVENT REPORT service.

6.7.6 UcfgScanner class

Class:	UcfgScanner
Description:	A UcfgScanner object scans a predefined set of managed medical objects that cannot be modified. In other words, a UcfgScanner object typically is a reporting object that is specialized for one specific purpose. It has the following properties: - Scanner event reports are typically used in confirmed mode because the data they contain are not stateless. - The list of scanned objects/attributes is fixed (i.e., cannot be configured). The UcfgScanner object is an abstract class; it cannot be instantiated.
Superclass:	Scanner
Subclasses:	AlertScanner, ContextScanner, OperatingScanner
Name Binding:	Handle
Registered As:	MDC_MOC_SCAN_UCFG

6.7.6.1 Attributes

The UcfgScanner class defines the attributes in Table 80.

Table 80—UcfgScanner class attributes

Attribute name	Attribute ID	Attribute type	Remark	Qualifier
Confirm-Mode	MDC_ATTR_CONFIRM_MODE	ConfirmMode	Default is confirmed mode.	O
Confirm-Timeout	MDC_ATTR_CONFIRM_TIMEOUT	RelativeTime	Determines when a confirmed event report is resent in case of a missing response.	O
Transmit-Window	MDC_ATTR_TX_WIND	INT-U16	Maximum number of not-yet-acknowledged event reports at one time.	O

The UcfgScanner class defines in Table 81 the attribute groups or extensions to inherited attribute groups.

Table 81—UcfgScanner class attribute groups

Attribute group	Attribute group ID	Group elements
Scanner Attribute Group (extensible attribute group)	MDC_ATTR_GRP_SCAN	from Scanner: Handle, Instance-Number, Operational-State from UcfgScanner: Confirm-Mode, Confirm-Timeout, Transmit-Window

6.7.6.2 Behavior

The UcfgScanner class does not define any special methods.

6.7.6.3 Notifications

The UcfgScanner class does not generate any special notifications.

6.7.7 ContextScanner class

Class: ContextScanner

Description: ContextScanner objects are responsible for observing device configuration changes. After instantiation, a ContextScanner object is responsible for announcing the object instances in the device's MDIB. The scanner provides the object instance containment hierarchy and static attribute values. In case of dynamic configuration changes, the ContextScanner object sends notifications about new object instances or deleted object instances.

Superclass: UcfgScanner

Subclasses: --

Name Binding: Handle

Registered As: MDC_MOC_SCAN_UCFG_CTXT

6.7.7.1 Attributes

The ContextScanner class defines the attributes in Table 82.

Table 82—ContextScanner class attributes

Attribute name	Attribute ID	Attribute type	Remark	Qualifier
Context-Mode	MDC_ATTR_SCAN_CTXT_MODE	ContextMode	Default is dynamic.	M

The ContextScanner class uses the Scanner Attribute Group that is defined by the Scanner class.

The following ASN.1 data type definitions apply:

```
--
-- Context-Mode attribute determines if the context scanner sends create notifications for the maximum set of
-- object instances in the MDIB (and requires no delete notifications) or for active objects only
--
ContextMode ::= INT-U16 {
    static-mode(0),
    dynamic-mode(1)
}
```

6.7.7.2 Behavior

The ContextScanner class defines the methods in Table 83.

Table 83—ContextScanner instance methods

Action	Mode	Action ID	Action parameter	Action result
Refresh-Context	Confirmed	MDC_ACT_REFR_CTXT	RefreshObjList	ObjCreateInfo (scan report no is 0)

The Refresh-Context method returns configuration information for all object instances currently in the MDIB.

6.7.7.3 Notifications

The ContextScanner class defines the events in Table 84.

Table 84—ContextScanner events

Event	Mode	Event ID	Event parameter	Event result
Object-Create-Notification	Confirmed/Unconfirmed	MDC_NOTI_OBJ_CREAT	ObjCreateInfo	—
Object-Delete-Notification	Confirmed	MDC_NOTI_OBJ_DEL	ObjDeleteInfo	—

The following ASN.1 data type definitions apply:

```
--
-- Object-Create-Notification event contains type, ID, and attribute information about new object instances in the
-- MDIB
--
ObjCreateInfo ::= SEQUENCE {
    scan-report-no          INT-U16,
    scan-report-info        CreateEntryList
}

CreateEntryList ::= SEQUENCE OF CreateEntry

--
-- A single new entry for one parent object, necessary to construct hierarchy in MDIB
--
CreateEntry ::= SEQUENCE {
    superior-object          ManagedObjectId,
    created-object            CreatedObjectList
}

CreatedObjectList ::= SEQUENCE OF CreatedObject

--
-- Now finally the new object itself
--
CreatedObject ::= SEQUENCE {
    class-id                ManagedObjectId,
    attributes                AttributeList
}

--
-- Object-Delete-Notification event implicitly deletes all child objects as well
--
ObjDeleteInfo ::= SEQUENCE {
    scan-report-no          INT-U16,
    object-list              ManagedObjectIdList
}

ManagedObjectIdList ::= SEQUENCE OF ManagedObjectId
```

6.7.8 AlertScanner class

Class:	AlertScanner
Description:	An AlertScanner object is responsible for observing the alert-related attribute groups of objects defined in the Alert Package. As alarming in general is security-sensitive, the scanner is not configurable (i.e., all or no Alert objects are scanned). An AlertScanner object sends event reports periodically so that timeout conditions can be checked.
Superclass:	UcfgScanner
Subclasses:	--
Name Binding:	Handle
Registered As:	MDC_MOC_SCAN_UCFG_ALSTAT

6.7.8.1 Attributes

The AlertScanner class defines the attributes in Table 85.

Table 85—AlertScanner class attributes

Attribute name	Attribute ID	Attribute type	Remark	Qualifier
Reporting-Interval	MDC_ATTR_SCAN_REP_PD	RelativeTime	Period of reports.	M

The AlertScanner class uses the Scanner Attribute Group that is defined by the Scanner class.

6.7.8.2 Behavior

The AlertScanner class does not define any special methods.

6.7.8.3 Notifications

The AlertScanner class defines the events in Table 86.

Table 86—AlertScanner events

Event	Mode	Event ID	Event parameter	Event result
Alert-Scan-Report	Confirmed/Unconfirmed	MDC_NOTI_AL_STAT_SCAN_RPT	ScanReportInfo	—

6.7.9 OperatingScanner class

Class:	OperatingScanner
Description:	The OperatingScanner class is responsible for providing all information about the operating and control system of the medical device. This information mainly includes SCO-contained Operation objects, which are considered SCO properties, not separate managed medical objects. The operating scanner — Sends CREATE events for Operation object instances — Scans Operation attributes together with attributes of the SCO Transaction Group (see 6.1.1) — Provides a refresh mechanism for Operation attributes.
Superclass:	UcfgScanner
Subclasses:	--
Name Binding:	Handle
Registered As:	MDC_MOC_SCAN_UCFG_OP

6.7.9.1 Attributes

The OperatingScanner class does not define any additional attributes.

The OperatingScanner class uses the Scanner Attribute Group that is defined by the Scanner class.

6.7.9.2 Behavior

The OperatingScanner class defines the methods in Table 87.

Table 87—OperatingScanner instance methods

Action	Mode	Action ID	Action parameter	Action result
Refresh-Operation-Context	Confirmed	MDC_ACT_REFR_OP_CTXT	RefreshObjList	OpCreateInfo (scan report no is 0)
Refresh-Operation-Attributes	Confirmed	MDC_ACT_REFR_OP_ATTR	RefreshObjList	—

NOTE—The RefreshObjList action parameter for the Refresh-Operation-Attributes method may identify both SCO attributes and Operation attributes.

6.7.9.3 Notifications

The OperatingScanner class defines the events in Table 88.

Table 88—OperatingScanner events

Event	Mode	Event ID	Event parameter	Event result
Oper-Create-Notification	Confirmed/Unconfirmed	MDC_NOTI_OP_CREAT	OpCreateInfo	—
Oper-Delete-Notification	Confirmed	MDC_NOTI_OP_DEL	OpDeleteInfo	—
Oper-Attribute-Update	Confirmed/Unconfirmed	MDC_NOTI_OP_ATTR_UPDT	OpAttributeInfo	—

The following ASN.1 data type definitions apply:

```
--
-- Support data types
--
OpElemAttr ::= SEQUENCE {
    op-class-id          OID-Type,
    op-instance-no      InstNumber,
    attributes           AttributeList
}

OpElemAttrList ::= SEQUENCE OF OpElemAttr

--
-- Create and delete operations
--
OpCreateInfo ::= SEQUENCE {
    scan-report-no      INT-U16,
    scan-info           OpCreateEntryList
}
```

OpCreateEntryList ::= SEQUENCE OF OpCreateEntry

OpCreateEntry ::= SEQUENCE {
 sco-glb-handle GLB-HANDLE,
 created-op-list OpElemAttrList
}

OpDeleteInfo ::= SEQUENCE {
 scan-report-no INT-U16,
 deleted-op-list OpDeleteEntryList
}

OpDeleteEntryList ::= SEQUENCE OF OpDeleteEntry

OpDeleteEntry ::= SEQUENCE {
 sco-glb-handle GLB-HANDLE,
 deleted-op-list OpElemList
}

OpElemList ::= SEQUENCE OF OpElem

OpElem ::= SEQUENCE {
 op-class-id OID-Type,
 op-instance-no InstNumber
}

--
-- Report of Operation attributes (from multiple contexts, if necessary)
--

OpAttributeInfo ::= SEQUENCE {
 scan-report-no INT-U16,
 glb-scan-info SingleCtxtOperScanList
}

SingleCtxtOperScanList ::= SEQUENCE OF SingleCtxtOperScan

SingleCtxtOperScan ::= SEQUENCE {
 context-id MdsContext,
 scan-info OpAttributeScanList
}

OpAttributeScanList ::= SEQUENCE OF OpAttributeScan

--
-- The scanned information contains SCO transaction attributes and Operation attributes
--

OpAttributeScan ::= SEQUENCE {
 sco-handle HANDLE,
 invoke-cookie INT-U32,
 lock-state AdministrativeState,
 op-elem-updt-list OpElemAttrList
}