

Issued 1948-11
Revised 2000-04
Reaffirmed 2008-01

Superseding AS245A

Water Solution Type Hand Fire Extinguisher

FOREWORD

Changes in this revision are format/editorial only.

1. SCOPE:

This specification covers the following types and classes of extinguishers:

Type I Stored pressure type

Category A - Temperature range -40 to +140

Category B - Temperature range +35 to +140

Type II Cartridge operated type

Category A - Temperature range -40 to +140

Category B - Temperature range +35 to +140

1.1 Purpose:

To specify minimum requirements for a water solution type hand fire extinguisher which shall be suitable for use on incipient fires which may occur in an airplane cabin interior. The type of fire for which these units are intended is one involving combustible materials such as paper, textiles and similar materials.

2. REFERENCES:

MIL-C-5499

AN-C-105

SAE Technical Standards Board Rules provide that: "This report is published by SAE to advance the state of technical and engineering sciences. The use of this report is entirely voluntary, and its applicability and suitability for any particular use, including any patent infringement arising therefrom, is the sole responsibility of the user."

SAE reviews each technical report at least every five years at which time it may be reaffirmed, revised, or cancelled. SAE invites your written comments and suggestions.

Copyright © 2008 SAE International

All rights reserved. No part of this publication may be reproduced, stored in a retrieval system or transmitted, in any form or by any means, electronic, mechanical, photocopying, recording, or otherwise, without the prior written permission of SAE.

TO PLACE A DOCUMENT ORDER: Tel: 877-606-7323 (inside USA and Canada)
Tel: 724-776-4970 (outside USA)
Fax: 724-776-0790
Email: CustomerService@sae.org
SAE WEB ADDRESS: <http://www.sae.org>

3. GENERAL REQUIREMENTS:

3.1 Material and Workmanship:

3.1.1 Materials: Materials shall be of a quality which experience or tests have demonstrated to be suitable and dependable for use in aircraft equipment manufacturing practice.

3.1.2 Workmanship: Workmanship shall be consistent with high-grade aircraft equipment manufacturing practice.

3.2 Identification:

The following information shall be legibly and permanently marked on the extinguisher:

- a. Name of extinguisher.
- b. SAE Aeronautical Standard AS245A, Type ____, Category ____.
- c. Capacity.
- d. Test pressure of container.
- e. Manufacturer's Part or Model Number.
- f. Manufacturer's Name and/or Trade Mark.
- g. Operating and Maintenance instructions.
- h. Category "B" units shall be marked "Protect from freezing".

3.3 Environmental Conditions:

The following conditions have been established as design requirements only. Tests shall be conducted as specified in Sections 5 and 6.

3.3.1 Temperature: Category "A" extinguishers shall withstand, without deterioration, temperatures from -40 to +140 °F and shall operate satisfactorily within that temperature range. Category "B" extinguishers shall withstand, without deterioration, temperatures from +35 to +140 °F and shall operate satisfactorily within that temperature range.

3.3.2 Humidity: The extinguisher shall function and shall not be adversely affected when exposed to any relative humidity in the range of from 0 to 95% at a temperature of approximately 90 °F.

3.3.3 Altitude: The extinguisher shall function and not be adversely affected when subjected to a pressure and temperature range equivalent to -1000 feet to +40,000 feet standard altitude, except as limited by the application of 3.3.1.

3.3.4 Vibration: When mounted in accordance with the extinguisher manufacturer's instructions, the unit shall not be adversely affected when subjected to a vibration of 2400 cycles per minute with a total excursion of 3/32 inch, and when subjected to a vibration of 3000 cycles per minute with a total excursion of .015 inches.

4. DETAIL REQUIREMENTS:

4.1 Design:

4.1.1 The extinguisher shall consist of:

Type I - A container having a dischargeable capacity of at least 1-3/8 quarts, a connection for pressurizing the unit and a means of controlling the discharge of the liquid content.

Type II - A container having a dischargeable capacity of at least 1-3/8 quarts, a suitable holder and releasing means for the cartridge, and a means of controlling the discharge of the liquid content.

4.1.2 The container shall be designed for a minimum burst pressure of 500 psi.

4.1.3 The Type I unit shall be fitted with an AN connection in accordance with MIL-C-5499 or equivalent, for pressurizing the unit. A pressure gage to indicate the stored pressure shall also be provided. The gage range shall be at least 100 pounds above the charged pressure of the unit at 70 °F.

4.1.4 Type II units shall use as a pressurizing means a carbon dioxide filled cartridge made in accordance with Specification AN-C-105 or equivalent, but in addition suitably winterized to insure proper operation. A means shall be provided to readily release the carbon dioxide from the cartridge immediately prior to the use of the units. The torque required to release the cartridge shall not exceed 15 inch pounds and the releasing device shall have a minimum diameter of 1 inch. The cartridge holder shall be designed so that it cannot be assembled if the cartridge is in the wrong position. The cartridge holder shall be designed so that a simple visual inspection will indicate whether a cartridge is in the holder.

4.1.5 The extinguisher shall be provided with a valve which will control the liquid discharge. The extinguisher shall be designed so that after the unit has been placed in operation it shall be completely controllable with one hand, including starting, stopping and directing the discharge stream. The force to operate the valve shall not exceed 3 pounds if the lever type is used. If a rotary type is used the torque required shall not exceed 15 inch pounds and the releasing device shall have a minimum diameter of 1 inch. For Type II extinguishers, with the unit mounted in its bracket, it shall not be possible to operate the valve controlling the discharge.

4.1.6 Type I units shall be designed so that the maximum stored pressure at 70 °F when the cartridge is released into a filled unit shall not exceed 200 psig.

4.1.7 The extinguisher shall be designed so that it cannot be overfilled with extinguisher medium.

4.1.8 The extinguisher shall be provided with a satisfactory seal to indicate tampering and/or operation.

4.2 Liquid Charge:

- 4.2.1 The liquid used with either Category "A" or Category "B" extinguishers shall be water base solutions suitable for service over the temperature range for the category intended.
- 4.2.2 The liquid used as the extinguishing medium shall be as free from corrosive effects as practicable and shall not adversely affect the operating mechanism of the extinguisher.
- 4.2.3 The fire extinguishing liquid shall be essentially non-toxic and non-injurious to personnel and shall not form injurious toxic fumes when discharged on a fire.
- 4.2.4 The fire extinguishing liquid shall not deteriorate or lose its efficiency over a one year period.
- 4.2.5 The fire extinguishing liquid shall have extinguishing qualities equal to or better than an equal quantity of water when used at 70 °F.
- 4.2.6 A wetting agent may be used provided the resulting solution complies with all requirements of the specification.

4.3 Discharge Characteristics:

- 4.3.1 At 70 °F the time of effective discharge for a full extinguisher shall be not less than 30 nor more than 45 seconds.
- 4.3.2 At 70 °F, with the extinguisher nozzle approximately 4 feet above the floor, it shall throw a stream a horizontal distance of not less than 12 feet and maintain this range for at least three-quarters of the contents.
- 4.3.3 The extinguisher at 70 °F shall be capable of discharging three-quarters of its contents by directing the stream in any desired direction.
- 4.3.4 The discharge tests shall be conducted using the appropriate liquid charge for the extinguisher.

4.4 Bracket:

- 4.4.1 A bracket shall be furnished from which the extinguisher can be quickly and easily removed. The bracket shall be designed to hold the charged extinguisher against an acceleration force of 10 g applied in any direction.